



Air Hygiene International, Inc.

The Clear Choice

**EMISSION COMPLIANCE TEST
FOR THE
BIOMASS BOILER STACK OUTLET AND
SPRAY DRYER ABSORBER INLET
PREPARED FOR
FIBROMINN, LLC
AT THE
FIBROMINN BIOMASS POWER PLANT
900 INDUSTRY DRIVE
BENSON, MINNESOTA
JULY 2-4, 2007**



Air Hygiene International, Inc.

Corporate Headquarters
5634 S. 122nd E. Ave. Ste. F
Tulsa, Oklahoma 74146

Las Vegas Office
5925 E. Lake Mead Blvd.
Las Vegas, Nevada 89156

Philadelphia Office
8900 State Road
Philadelphia, Pennsylvania 19136

Houston Office
1920 Treble Drive
Humble, Texas 77338

(918) 307-8865 or (888) 461-8778
www.airhygiene.com

**EMISSION COMPLIANCE TEST
FOR THE
BIOMASS BOILER STACK OUTLET AND
SPRAY DRYER ABSORBER INLET
PREPARED FOR
FIBROMINN, LLC
AT THE
FIBROMINN BIOMASS POWER PLANT
900 INDUSTRY DRIVE
BENSON, MINNESOTA
JULY 2-4, 2007**

Prepared and Reviewed by:



Thomas K. Graham, PE, Director of Operations




Quinn A. Bierman, President

Minn R. 7017.2040 Certification Statements

Certification of sampling procedures

I certify under penalty of law that the sampling procedures were performed in accordance with the approved test plan and that the data presented in this test report are, to the best of my knowledge and belief, true, accurate, and complete. All exceptions are listed and explained below.




Thomas K. Graham, PE, Director of Operations

Exceptions: None

Certification of analytical procedures

I certify under penalty of law that the analytical procedures were performed in accordance with the requirements of the test methods and that the data presented for use in the test report were, to the best of my knowledge and belief, true, accurate, and complete. All exceptions are listed and explained below.




Pandu Sattvika, Laboratory Manager

Exceptions: None

Certification of test report by testing company

I certify under penalty of law that this test report and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the test information submitted. Based on my inquiry of the person or persons who performed sampling and analysis relating to the performance test, the information submitted in this test report is, to the best of my knowledge and belief, true, accurate, and complete. All exceptions are listed and explained below.




Quinn A. Bierman, President

Exceptions: None

Certification of test report by owner or operator of emission facility

I certify under penalty of law that the information submitted in this test report accurately reflects the operating conditions at the emission facility during this performance test and describes the date and nature of all operational and maintenance activities that were performed on process and control equipment during the month prior to the performance test. Based on my inquiry of the person or persons who performed the operational and maintenance activities, the information submitted in this test report is, to the best of my knowledge and belief, true, accurate, and complete. All exceptions are listed and explained below.



Exceptions:

Table of Contents

1.0	INTRODUCTION	1
1.1	TEST PURPOSE AND OBJECTIVES	1
1.2	SUMMARY OF TEST PROGRAM	1
1.2.1	Participating Organizations	1
1.2.2	Industry	1
1.2.3	Air Permit	1
1.2.4	Plant Location	1
1.2.5	Equipment Tested	1
1.2.6	Emission Points	1
1.2.7	Pollutants Measured	2
1.2.8	Dates of Emission Test	2
1.3	KEY PERSONNEL	2
2.0	SUMMARY OF TEST RESULTS	2
3.1	PROCESS DESCRIPTION	5
3.2	SAMPLING LOCATION	5
4.0	SAMPLING AND ANALYTICAL PROCEDURES	5
4.1	TEST METHODS	5
4.2	INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS	6

APPENDICES

Appendix A	Test Results and Calculations
Appendix B	Unit Operation Parameters
Appendix C	Calibration Gas Certifications
Appendix D	Quality Assurance and Quality Control Data
Appendix E	Stratification Test Data
Appendix F	Fuel Analysis
Appendix G	Test Protocol
Appendix H	MPCA Approvals and Requested Forms

**Emissions Compliance Test
Biomass Boiler Stack Outlet and Spray Dryer Absorber Inlet
Fibrominn, LLC
Fibrominn Biomass Power Plant
Benson, Minnesota
July 2-4, 2007**

1.0 INTRODUCTION

Air Hygiene International, Inc. (Air Hygiene) has completed the emissions testing study for nitrogen oxides (NO_x), carbon monoxide (CO), sulfur dioxide (SO₂), hydrochloric acid (HCl), particulate matter (PM), opacity, carbon dioxide (CO₂), and oxygen (O₂) from the Biomass Boiler Stack Outlet and Spray Dryer Absorber Inlet for Fibrominn, LLC at the Fibrominn Biomass Power Plant near Benson, Minnesota. This report details the background, results, process description, and the sampling/analysis methodology of the stack sampling survey conducted on July 2-4, 2007.

1.1 TEST PURPOSE AND OBJECTIVES

The purpose of the test was to conduct an initial compliance emission test to document levels of selected pollutants at a maximum test load (greater than 90 percent). The information will be used to confirm compliance with the operating permit issued by the Minnesota Pollution Control Agency (MPCA). The specific objective was to determine the emission concentration of NO_x, CO, SO₂, HCl, PM, opacity, CO₂, and O₂ from Fibrominn, LLC's Biomass Boiler Stack Outlet and Spray Dryer Absorber Inlet.

1.2 SUMMARY OF TEST PROGRAM

The following list details pertinent information related to this specific project:

- 1.2.1 Participating Organizations
 - Minnesota Pollution Control Agency (MPCA)
 - Fibrominn, LLC
 - SNC - Lavalin
 - Air Hygiene
- 1.2.2 Industry
 - Biomass Fired Electric Utility / Electric Services
- 1.2.3 Air Permit
 - Permit Number: 15100038-004
 - AQ Facility ID No: 4065
- 1.2.4 Plant Location
 - Fibrominn Biomass Power Plant near Benson, Minnesota
- 1.2.5 Equipment Tested
 - Biomass Boiler Stack Outlet and Spray Dryer Absorber Inlet
- 1.2.6 Emission Points
 - Biomass Boiler Stack Outlet and Spray Dryer Absorber Inlet
 - For NO_x, CO, SO₂, CO₂, and O₂, 12 sampling points from the Biomass Boiler Stack Outlet and Spray Dryer Absorber Inlet (SO₂ and O₂, only), determined after conducting a stratification test (refer to Appendix E)

- For all HCl testing, one sample point in the Biomass Boiler Stack Outlet and Spray Dryer Absorber Inlet (refer to Appendix B)
- For all PM testing, twelve sample points in the Biomass Boiler Stack Outlet (refer to Appendix B)
- For opacity, one sample visual observation point from the exit of the exhaust duct to the atmosphere from the Biomass Boiler Stack Outlet

1.2.7 Pollutants Measured

- | | |
|-------------------|-------------------|
| • NO _x | • PM |
| • CO | • Opacity |
| • SO ₂ | • CO ₂ |
| • HCl | • O ₂ |

1.2.8 Dates of Emission Test

- July 2-4, 2007

1.3 KEY PERSONNEL

Fibrominn, LLC:	Chuck Wagoner	320-843-9013
MPCA:	Steven Gorg	651-296-8766
CiSCO:	Brad Shibata	303-790-1000
SNC:	Victor Myers	320-843-5170
Air Hygiene:	Thomas Graham	918-307-8865

2.0 SUMMARY OF TEST RESULTS

Results from the sampling conducted on Fibrominn, LLC's Biomass Boiler Stack Outlet and Spray Dryer Absorber Inlet located at the Fibrominn Biomass Power Plant on July 2-4, 2007 are summarized in the following tables.

**TABLE 1.1
BIOMASS BOILER, UNIT #1 SDA INLET DATA SUMMARY**

Parameter	High Load, Run - In-1	High Load, Run - In-2	High Load, Run - In-3	Average	Permit Limits
Date (mm/dd/yy)	07/03/07	07/03/07	07/03/07	07/03/07	--
Start Time (hh:mm:ss)	17:58:14	19:40:14	21:39:14	17:58:14	--
End Time (hh:mm:ss)	18:57:44	20:39:44	22:38:44	22:38:44	--
Run Duration (min)	60	60	60	60	--
Bar. Pressure (in. Hg)	29.43	29.44	29.46	29.44	--
Amb. Temp. (°F)	81	78	77	79	--
Rel. Humidity (%)	71	72	71	71	--
Spec. Humidity (lb water / lb air)	0.016438	0.014868	0.014450	0.015252	--
SO ₂ (ppmvd)	337.80	337.81	334.51	336.71	--
SO ₂ GeoAvg (ppmvd)	335.87	336.02	330.47	334.12	--
HCl (ppm)	60.82	81.46	41.28	61.19	--
O ₂ (%)	5.24	5.22	4.89	5.11	--

**TABLE 1.2
BIOMASS BOILER, UNIT #1 STACK OUTLET DATA SUMMARY**

Parameter	High Load, Run - Out-1	High Load, Run - Out-2	High Load, Run - Out-3	Average	Permit Limits
Date (mm/dd/yy)	07/03/07	07/03/07	07/03/07	07/03/07	--
Start Time (hh:mm:ss)	17:58:14	19:40:14	21:39:14	17:58:14	--
End Time (hh:mm:ss)	18:57:44	20:39:44	22:38:44	22:38:44	--
Run Duration (min)	60	60	60	60	--
Bar. Pressure (in. Hg)	29.43	29.44	29.46	29.44	--
Amb. Temp. (°F)	81	78	77	79	--
Rel. Humidity (%)	71	72	71	71	--
Spec. Humidity (lb water / lb air)	0.016438	0.014868	0.014450	0.015252	--
Stack Flow (M2) (SCFH)	10,257,198	9,847,715	10,305,362	10,136,759	--
Stack Moisture (% Method 4)	25.7	26.0	24.9	25.5	--
Heat Input (MMBtu/hr)	784.4	774.1	777.9	778.8	--
Gross Power Output (gross MW)	61.3	61.8	62.8	62.0	--
Steam Rate (lb/hr)	487,155.4	487,320.0	490,766.8	488,414.1	--
Biomass Flow (TPH)	83.9	83.3	88.5	85.22	--
Urea Injection (gal/hr)	89.3	89.0	94.1	90.82	--
Feedwater Flow (lb/hr)	496,079.1	486,900.6	492,715.3	491,898.33	--
Secondary Air Flow (lb/hr)	354,765.7	339,053.9	354,522.2	349,447.27	--
Primary Air Flow (lb/hr)	249,174.1	244,226.6	258,475.4	250,625.36	--
Dist. Air Flow (lb/hr)	70,974.0	71,209.3	72,455.2	71,546.16	--
SDA Slurry Flow (GPM)	27.1	22.3	30.9	26.76	--
SDA Quench Flow (GPM)	14.4	14.5	8.6	12.50	--
Sootblower Flow (lb/hr)	4,414.2	2,176.5	2,648.5	3,079.75	--
SH Steam Temp (°F)	968.0	970.6	968.9	969.19	--
SH Steam Pres. (psi)	1,499.7	1,503.8	1,498.8	1,500.78	--
NOx (ppmvd)	90.31	77.80	101.11	89.74	--
NOx (ppm@7%O ₂)	80.71	67.52	91.25	79.83	--
NOx (lb/hr)	110.64	91.50	124.45	108.86	--
NOx (ton/year) at 8760 hr/year	484.59	400.78	545.10	476.82	--
NOx (lb/MMBtu)	0.141	0.118	0.160	0.140	0.16
CO (ppmvd)	229.25	260.13	165.12	218.17	--
CO (ppm@7%O ₂)	204.89	225.77	149.01	193.22	--
CO (lb/hr)	170.91	186.20	123.68	160.26	--
CO (ton/year) at 8760 hr/year	748.60	815.54	541.72	701.95	--
CO (lb/MMBtu)	0.218	0.241	0.159	0.206	0.24
SO ₂ (ppmvd)	64.35	65.95	66.90	65.73	--
SO ₂ (ppm@7%O ₂)	57.51	57.24	60.38	58.37	--
SO ₂ (lb/hr)	109.65	107.90	114.55	110.70	--
SO ₂ (ton/year) at 8760 hr/year	480.28	472.59	501.71	484.86	--
SO ₂ (lb/MMBtu)	0.140	0.139	0.147	0.142	--
SO ₂ (% reduction)	80.95	80.48	80.00	80.48	--
SO ₂ GeoAvg (ppmvd)	64.21	63.09	64.56	63.95	--
SO ₂ GeoAvg (ppm@7%O ₂)	56.83	55.88	59.15	57.29	--
SO ₂ GeoAvg (lb/hr)	108.36	105.34	112.23	108.64	--
SO ₂ GeoAvg (ton/year) at 8760 hr/year	480.28	472.59	501.71	484.86	--
SO ₂ GeoAvg (lb/MMBtu)	0.138	0.136	0.145	0.140	0.07
SO ₂ GeoAvg (% reduction)	80.88	81.23	80.47	80.86	80
HCl (ppm)	4.83	14.84	11.02	10.23	--
HCl (ppm@7%O ₂)	4.32	12.88	9.94	9.05	--
HCl (lb/hr)	4.69	13.83	10.75	9.76	--
HCl (ton/year) at 8760 hr/year	20.44	60.24	46.81	42.50	--
HCl (lb/MMBtu)	0.006	0.018	0.014	0.013	0.034
HCl (% reduction)	92.05	81.78	73.30	82.38	95
Maximum Opacity (%)	15	15	5	12	20
CO ₂ (%)	14.46	14.86	14.27	14.53	--
O ₂ (%)	5.35	4.88	5.50	5.24	--

**TABLE 1.3
BIOMASS BOILER, UNIT #1 STACK OUTLET PM DATA SUMMARY**

Parameter	High Load, Run - 3-1	High Load, Run - 3-2	High Load, Run - 3-3	Average	Permit Limits
Date (mm/dd/yy)	07/03/07	07/04/07	07/04/07	07/03/07	--
Start Time (hh:mm:ss)	23:42	02:44	05:27	23:42	--
End Time (hh:mm:ss)	02:38	05:22	07:58	07:58	--
Sample Time (min)	150	150	150	150	--
Bar. Pressure (in. Hg)	29.49	29.49	29.49	29.49	--
Gross Power Output (gross MW)	62.4	62.6	62.8	62.6	--
Steam Rate (lb/hr)	483,806	482,478	483,952	483,412.1	--
Biomass Flow (TPH)	84.2	81.1	81.0	82.12	--
Urea Injection (gal/hr)	95.8	90.1	93.5	93.13	--
Feedwater Flow (lb/hr)	499,002	488,761	495,380	494,380.93	--
Secondary Air Flow (lb/hr)	358,166	350,944	359,827	356,312.66	--
Primary Air Flow (lb/hr)	262,704	254,618	261,366	259,562.48	--
Dist. Air Flow (lb/hr)	72,757	73,188	73,838	73,260.72	--
SDA Slurry Flow (GPM)	34.7	26.1	27.6	29.49	--
SDA Quench Flow (GPM)	7.1	10.1	12.7	9.95	--
Sootblower Flow (lb/hr)	9,746	2,493	9,618	7,285.56	--
SH Steam Temp (°F)	970	970	971	970.15	--
SH Steam Pres. (psi)	1,500	1,502	1,502	1,501.47	--
Total PM/PM10 (mg)	241.84	292.66	276.34	270.28	--
Total PM/PM10 (g/dscf)	2.24E-03	2.63E-03	2.32E-03	2.40E-03	--
Total PM/PM10 (gr/dscf)	3.46E-02	4.05E-02	3.58E-02	3.70E-02	--
Total PM/PM10 (kg/hr)	23.72	26.25	26.20	25.39	--
Total PM/PM10 (lb/hr)	52.30	57.88	57.76	55.98	--
Total PM/PM10 (ton/year) at 8760 hr/year	229.07	253.52	253.00	245.20	--
Total PM/PM10 (lb/MMBtu)	0.061	0.073	0.069	0.068	--
Front Half PM (mg)	21.28	19.23	15.89	18.80	--
Front Half PM (g/dscf)	1.97E-04	1.73E-04	1.34E-04	1.68E-04	--
Front Half PM (gr/dscf)	3.04E-03	2.66E-03	2.06E-03	2.59E-03	--
Front Half PM (kg/hr)	2.09	1.73	1.51	1.77	--
Front Half PM (lb/hr)	4.60	3.80	3.32	3.91	--
Front Half PM (ton/year) at 8760 hr/year	20.16	16.66	14.55	17.12	--
Front Half PM (lb/MMBtu)	0.005	0.005	0.004	0.005	0.02
Back Half PM10 (mg)	220.56	273.43	260.45	251.48	--
Back Half PM10 (g/dscf)	2.04E-03	2.45E-03	2.19E-03	2.23E-03	--
Back Half PM10 (gr/dscf)	3.15E-02	3.79E-02	3.38E-02	3.44E-02	--
Back Half PM10 (kg/hr)	21.64	24.53	24.69	23.62	--
Back Half PM10 (lb/hr)	47.70	54.08	54.44	52.07	--
Back Half PM10 (ton/year) at 8760 hr/year	208.92	236.86	238.45	228.08	--
Back Half PM10 (lb/MMBtu)	0.055	0.068	0.065	0.063	--

All measured pollutant concentrations and calculated rates were below the given permit limits with the exception of SO₂ in units of pounds per million British thermal units (lb/MMBtu). Instead, SO₂ passed under a permit limit based on total percent reduction. Also, due to the testing timeframe, based on periods of proper / maximum operation of the source, the third opacity run was performed on the following day, as the sun had set and no light was available for proper opacity readings. All other measurements and calculations were performed as stated and approved in the attached testing protocol (Appendix G) without any real or apparent errors. Unit loads during testing were at or above 90 percent of maximum.

3.0 SOURCE OPERATION

3.1 PROCESS DESCRIPTION

PowerMinn 9090, LLC (PowerMinn) owns and Fibrominn, LLC (Fibrominn) operates the Fibrominn Biomass Power Plant in Swift County, Benson, Minnesota. The plant consists of one boiler, fueled principally with poultry litter. Vegetative biomass may also be burned. The facility generates a nominal 50 megawatts (MW) of electricity for export and has a peak electrical export capacity of 55 MW with a peak gross electrical generating capacity of 65 MW.

Emissions from the boiler are controlled by a spray dryer absorber followed by a fabric filter baghouse to control particulate matter and particulate matter / particulate matter less than 10 microns in diameter (PM/PM₁₀), SO₂, sulfuric acid mist (H₂SO₄), and HCl. Selective non-catalytic reduction (SNCR) is used to control NO_x. Good combustion practices are used to control CO and volatile organic compounds (VOCs).

3.2 SAMPLING LOCATION

Compliance testing was performed on the unit at the spray dryer absorber (SDA) inlet and the stack outlet. The SDA inlet duct is circular and measures 10.8 feet (ft) (129 inches) in diameter at the test ports which are approximately 120 ft above grade level. The test ports are located approximately 101.8 ft (1,222 inches) downstream and approximately 29.2 ft (350 inches) upstream from the nearest disturbances.

The stack exhaust is circular and measures 9 feet (ft) (108 inches) in diameter at the test ports which are approximately 104 ft above grade level with an exit elevation of approximately 300 ft above grade level. The test ports are located approximately 75.8 ft (910 inches) downstream and approximately 196.5 ft (2,358 inches) upstream from the nearest disturbances.

All samples for NO_x, CO, SO₂, CO₂, and O₂ emissions were continuously drawn from the stack exhaust and SDA Inlet (SO₂ and O₂, only) at 12 sample points determined after conducting an initial stratification test (Appendix E). During the stratification test 12 points were traversed from each location. The probe was allowed to remain at each point for two times the systems response time. For PM testing on the stack exhaust, an initial velocity traverse was performed across the stack from 12 total points. All PM sampling occurred from the same 12 points by leaving the probe at each for an equal amount of time in order to draw at least 100 dry standard cubic feet of gas through the sample train. All HCl testing on the stack exhaust and the SDA inlet occurred from single sampling points near the center of each location, per MPCA proposed variation approval. All opacity observations were made by viewing the point where the exhaust system exited to the atmosphere at the top of the exhaust stack.

4.0 SAMPLING AND ANALYTICAL PROCEDURES

4.1 TEST METHODS

The emission test on the Biomass Boiler Stack Outlet and Spray Dryer Absorber Inlet at the Fibrominn Biomass Power Plant was performed following United States Environmental Protection Agency (EPA) methods described by the Code of Federal Regulations (CFR). Table 4.1 outlines the specific methods performed on July 2-4, 2007.

**TABLE 4.1
SUMMARY OF SAMPLING METHODS**

Pollutant or Parameter	Sampling Method	Analysis Method
Sample Point Location	EPA Method 1	Equal Area Method
Stack Flow Rate	EPA Method 2	S-Type Pitot Tube
Oxygen	EPA Method 3a	Paramagnetic Cell
Carbon Dioxide	EPA Method 3a	Nondispersive Infrared Analyzer
Stack Moisture Content	EPA Method 4	Gravimetric Analysis
Particulate Matter	EPA Method 5	Front Half Filterables
Sulfur Dioxide	EPA Method 6c	Ultraviolet
Nitrogen Oxides	EPA Method 7e	Chemiluminescent Analyzer
Opacity	EPA Method 9	Visual Observation
Carbon Monoxide	EPA Method 10	Nondispersive Infrared Analyzer
Fuel Based F-Factor	EPA Method 19	CO ₂ Based F Factor
Hydrochloric Acid	EPA Method 26a	Chemiluminescent Analyzer
Particulate Matter	EPA Method 202	Back Half Condensables

4.2 INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS

The sampling and analysis procedures used during these tests conform with the methods outlined in the Code of Federal Regulations (CFR), Title 40, Part 60, Appendix A, Methods 1, 2, 3a, 4, 5, 6c, 7e, 9, 10, 19, 26a, and 40 CFR 51, Appendix M, 202.

Figure 4.1 depicts the sample system used for the NO_x, CO, SO₂, CO₂, and O₂ tests. An identical system was used to monitor SO₂ and O₂ at the SDA inlet. A heated stainless steel probe was inserted into the sample ports of the stack exhaust and the SDA inlet to extract gas measurements from the emission stream at twelve points in the stacks determined after conducting an initial stratification test. The gas sample was continuously pulled through the probe and transported via heat-traced Teflon® tubing to a stainless steel minimum-contact condenser designed to dry the sample and through Teflon® tubing via a stainless steel/Teflon® diaphragm pump and into the sample manifold within the mobile laboratory. From the manifold, the sample was partitioned to the NO_x, CO, SO₂, CO₂, and O₂ analyzers through rotameters that controlled the flow rate of the sample.

Figure 4.1 shows that the sample systems were also equipped with a separate path through which a calibration gas could be delivered to the probe and back through the entire sampling systems. This allowed for convenient performance of system bias checks as required by the testing methods.

All instruments were housed in an air-conditioned trailer-mounted mobile laboratory. Gaseous calibration standards were provided in aluminum cylinders with the concentrations certified by the vendor. EPA Protocol No. 1 was used to determine the cylinder concentrations where applicable (i.e. NO_x calibration gases).

Table 4.2 provides a description of the analyzers used for the instrument portion of the tests. All data from the continuous monitoring instruments were recorded on a Logic Beach Portable Data Logging System Hyperlogger which retrieves calibrated electronic data from each instrument every one second and reports an average of the collected data every 30 seconds. Data records can be found in Appendix A and B of this report.

Figure 4.2 represent the sample system used for the PM tests. A heated stainless steel probe with an inconel liner and stainless steel nozzle was inserted into the sample ports of the stack to extract gas measurements from the emission stream through a filter and glass impinger train. Flow rates are monitored with oil filled manometers and total sample volumes are measured with a dry gas meter. An identical system was utilized for the HCl testing, however the nozzle and liner were glass and the impinger contents were changed to reflect the requirements of the reference method.

Three test runs of approximately 60 minutes each were conducted on the Biomass Boiler Stack Outlet and Spray Dryer Absorber Inlet at the maximum test load simultaneously for NO_x, CO, SO₂, HCl, opacity, CO₂, and O₂ on the stack exhaust and SO₂, HCl, and O₂ on the SDA inlet. Three test runs pulling at least 100 dry standard cubic feet of sample were run at at the maximum test load for the PM testing at the stack exhaust.

The stack gas analysis for O₂ and CO₂ concentrations was performed in accordance with procedures set forth in EPA Method 3a. The O₂ analyzer uses a paramagnetic cell detector and the CO₂ analyzer uses a continuous nondispersive infrared analyzer.

EPA Method 6c was used to determine the concentrations of SO₂. An ultraviolet analyzer was used to determine the sulfur dioxide concentrations in the gas stream.

EPA Method 7e was used to determine concentrations of NO_x. A chemiluminescence analyzer was used to determine the nitrogen oxides concentration in the gas stream. A NO₂ in nitrogen certified gas cylinder was used to verify at least a 90 percent NO₂ conversion on the day of the test.

CO emission concentrations were quantified in accordance with procedures set forth in EPA Method 10. A continuous nondispersive infrared (NDIR) analyzer was used for this purpose.

**TABLE 4.2
ANALYTICAL INSTRUMENTATION**

Parameter	Model & Manufacturer	Max. Ranges	Sensitivity	Detection Principle
NO _x	Outlet: THERMO 42C	User may select up to 5,000 ppm	0.1 ppm	Thermal reduction of NO ₂ to NO Chemiluminescence of reaction of NO with O ₃ . Detection by PMT. Inherently linear for listed ranges.
CO	Outlet: THERMO 48C	User may select up to 3,000 ppm	0.1 ppm	Infrared absorption, gas filter correlation detector, microprocessor based linearization.
CO ₂	Outlet: SERV 1440	0-20%	0.1%	Nondispersive infrared
SO ₂	Outlet: THERMO 43C Inlet: Ametek 721M	User may select up to 10,000 ppm	0.1 ppm	Ultraviolet
O ₂	Outlet: SERV 1400 Inlet: M&C PMA 22	0-25%	0.1%	Paramagnetic cell, inherently linear.




Figure 4.1
EMISSIONS TESTING LAB
 5634 S. 122nd East Ave, Suite F
 Tulsa, Oklahoma 74146
 www.airhygiene.com
 (888) 461-8778




Figure 4.2
WET CHEMISTRY ASSEMBLY
5634 S. 122nd East Ave, Suite F
Tulsa, Oklahoma 74146
www.airhygiene.com
(888) 461-8778



APPENDIX A
TEST RESULTS AND CALCULATIONS

**TABLE A.1:
EMISSIONS TESTING SCHEDULE**

Unit	Load	Test Type	Run	Date	Start	Stop	Time Sync
1	High	Stratification Test	1	07/02/07	07:10	07:49	DAHS
1	High	Gases	1	07/03/07	17:58	18:57	DAHS
1	High	Gases	2	07/03/07	19:40	20:39	DAHS
1	High	Gases	3	07/03/07	21:39	22:38	DAHS
1	High	HCl	1	07/03/07	17:58	18:57	DAHS
1	High	HCl	2	07/03/07	19:40	20:39	DAHS
1	High	HCl	3	07/03/07	21:39	22:38	DAHS
1	High	PM	1	07/03/07	23:42	02:38	DAHS
1	High	PM	2	07/04/07	02:44	05:22	DAHS
1	High	PM	3	07/04/07	05:27	07:58	DAHS
1	High	Opacity	1	07/03/07	17:58	18:57	DAHS
1	High	Opacity	2	07/03/07	19:40	20:39	DAHS
1	High	Opacity	3	07/04/07	14:52	15:52	DAHS

Note: DAHS Time (CST)

TEST RESULTS AND CALCULATIONS

NO_x, CO, SO₂, CO₂, and O₂ Emissions Data

Fibrominn, LLC
July 3, 2007
Biomass Boiler, Unit #Outlet
Fibrominn Biomass Power Plant

Fuel Data

Fuel F _c factor	1,890	SCF/MMBtu
Fuel Heating Value (HHV)	4,334	Btu/lb

Weather Data

Barometric Pressure	29.43	in. Hg
Relative Humidity	71	%
Ambient Temperature	81	° F
Specific Humidity	0.016438	lb H ₂ O / lb air

Unit Data

Gross Unit Load	61.3	gross MW
Heat Input	784	MMBtu/hr
Steam Rate	487,155	Steam lb/hr
Meas. Stack Moisture	25.7	%
Stack Exhaust Flow (M2)	10,257,198	SCFH

High Load, Run - Out-1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)	CO ₂ (%)	SO ₂ (ppmvd)
07/03/07 17:58:14	28680	4.58	92.61	205.79	14.75	65.24
07/03/07 17:58:44	28710	4.87	88.71	255.16	14.49	65.96
07/03/07 17:59:14	28740	4.87	92.13	76.87	14.49	64.80
07/03/07 17:59:44	28770	4.08	102.36	63.08	15.23	64.29
07/03/07 18:00:14	28800	5.52	88.46	118.74	13.97	70.87
07/03/07 18:00:44	28830	6.02	103.88	48.80	13.40	69.56
07/03/07 18:01:14	28860	5.15	81.14	52.14	14.18	59.34
07/03/07 18:01:44	28890	4.30	79.17	278.74	15.07	59.66
07/03/07 18:02:14	28920	5.69	98.82	282.02	13.70	71.90
07/03/07 18:02:44	28950	4.41	87.42	135.21	14.91	69.94
07/03/07 18:03:14	28980	6.21	76.24	142.04	13.32	72.68
07/03/07 18:03:44	29010	5.59	81.80	57.13	13.74	70.10
07/03/07 18:04:14	29040	4.98	88.17	36.49	14.40	62.10
07/03/07 18:04:44	29070	5.56	94.39	36.40	13.82	64.19
07/03/07 18:05:14	29100	4.70	95.63	106.69	14.69	65.21
07/03/07 18:05:44	29130	5.90	91.89	102.47	13.53	72.59
07/03/07 18:06:14	29160	6.31	84.32	61.17	13.13	68.94
07/03/07 18:06:44	29190	4.87	79.56	70.55	14.50	61.21
07/03/07 18:07:14	29220	6.02	73.35	175.44	13.45	63.84
07/03/07 18:07:44	29250	5.26	65.53	262.73	14.03	62.67
07/03/07 18:08:14	29280	5.00	47.13	1,181.94	14.36	60.77
07/03/07 18:08:44	29310	5.21	42.26	879.03	14.19	60.05
07/03/07 18:09:14	29340	5.49	61.61	271.01	13.89	51.04
07/03/07 18:09:44	29370	4.89	67.04	86.86	14.50	45.71
07/03/07 18:10:14	29400	5.67	72.42	74.01	13.79	49.03
07/03/07 18:10:44	29430	5.05	67.45	336.03	14.26	50.62
07/03/07 18:11:14	29460	4.97	48.01	831.42	14.39	55.93
07/03/07 18:11:44	29490	4.87	58.59	553.05	14.47	59.71
07/03/07 18:12:14	29520	5.84	80.98	237.93	13.69	56.38
07/03/07 18:12:44	29550	5.29	79.69	176.39	14.02	55.91
07/03/07 18:13:14	29580	5.35	76.18	336.45	14.04	57.92
07/03/07 18:13:44	29610	4.20	82.39	312.30	15.08	64.74
07/03/07 18:14:14	29640	4.51	84.36	243.55	14.90	70.50
07/03/07 18:14:44	29670	4.94	114.44	88.85	14.43	76.66
07/03/07 18:15:14	29700	5.19	85.96	324.21	14.24	73.67
07/03/07 18:15:44	29730	6.25	87.21	287.09	13.32	71.79
07/03/07 18:16:14	29760	6.60	71.16	128.43	12.74	69.43
07/03/07 18:16:44	29790	4.03	68.25	339.42	15.27	61.26
07/03/07 18:17:14	29820	5.12	68.53	312.61	14.27	65.28
07/03/07 18:17:44	29850	3.78	78.03	428.77	15.39	65.60
07/03/07 18:18:14	29880	3.93	64.11	1,300.34	15.40	71.05
07/03/07 18:18:44	29910	4.66	78.55	381.91	14.71	78.71
07/03/07 18:19:14	29940	4.76	92.24	111.30	14.68	70.00
07/03/07 18:19:44	29970	5.16	84.47	82.99	14.21	69.51
07/03/07 18:20:14	30000	4.63	94.82	59.70	14.69	67.46
07/03/07 18:20:44	30030	3.94	101.13	318.27	15.35	69.89
07/03/07 18:21:14	30060	4.91	71.27	582.20	14.59	82.61
07/03/07 18:21:44	30090	5.66	87.91	196.03	13.68	85.13
07/03/07 18:22:14	30120	4.40	81.92	153.30	14.90	74.15
07/03/07 18:22:44	30150	4.81	85.16	315.09	14.63	77.37
07/03/07 18:23:14	30180	5.04	106.29	204.62	14.32	80.40

Fibrominn, LLC
July 3, 2007
Biomass Boiler, Unit #Outlet
Fibrominn Biomass Power Plant

Fuel Data

Fuel F _c factor	1,890	SCF/MMBtu
Fuel Heating Value (HHV)	4,334	Btu/lb

Weather Data

Barometric Pressure	29.43	in. Hg
Relative Humidity	71	%
Ambient Temperature	81	° F
Specific Humidity	0.016438	lb H ₂ O / lb air

Unit Data

Gross Unit Load	61.3	gross MW
Heat Input	784	MMBtu/hr
Steam Rate	487,155	Steam lb/hr
Meas. Stack Moisture	25.7	%
Stack Exhaust Flow (M2)	10,257,198	SCFH

High Load, Run - Out-1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)	CO ₂ (%)	SO ₂ (ppmvd)
07/03/07 18:23:44	30210	5.82	92.67	274.79	13.65	74.24
07/03/07 18:24:14	30240	6.01	97.99	79.43	13.45	69.63
07/03/07 18:24:44	30270	4.76	113.87	73.97	14.58	63.28
07/03/07 18:25:14	30300	4.23	96.02	213.36	15.10	66.91
07/03/07 18:25:44	30330	6.29	86.91	415.19	13.30	78.06
07/03/07 18:26:14	30360	5.95	79.90	156.03	13.44	79.74
07/03/07 18:26:44	30390	4.80	97.55	93.23	14.57	73.03
07/03/07 18:27:14	30420	6.04	99.25	79.34	13.44	73.31
07/03/07 18:27:44	30450	5.28	93.87	46.20	14.09	69.26
07/03/07 18:28:14	30480	5.74	97.56	36.96	13.73	68.12
07/03/07 18:28:44	30510	5.29	102.77	48.72	14.05	68.46
07/03/07 18:29:14	30540	4.07	86.36	192.50	15.25	70.82
07/03/07 18:29:44	30570	5.08	85.30	334.31	14.41	84.92
07/03/07 18:30:14	30600	5.81	82.07	280.06	13.58	91.82
07/03/07 18:30:44	30630	5.37	107.81	52.77	14.04	78.59
07/03/07 18:31:14	30660	4.78	90.99	96.50	14.55	73.05
07/03/07 18:31:44	30690	4.34	84.61	170.41	15.07	74.21
07/03/07 18:32:14	30720	5.49	76.09	186.49	13.83	80.62
07/03/07 18:32:44	30750	4.24	58.06	1,546.44	15.06	79.96
07/03/07 18:33:14	30780	3.75	77.85	1,815.28	15.46	86.54
07/03/07 18:33:44	30810	5.40	80.34	1,381.59	14.06	87.16
07/03/07 18:34:14	30840	5.94	106.21	178.73	13.47	77.56
07/03/07 18:34:44	30870	4.39	99.65	392.62	14.97	63.81
07/03/07 18:35:14	30900	5.12	92.04	452.28	14.25	71.23
07/03/07 18:35:44	30930	5.95	112.34	77.01	13.57	70.46
07/03/07 18:36:14	30960	6.38	96.93	50.07	13.07	67.56
07/03/07 18:36:44	30990	5.45	86.84	55.91	13.97	61.81
07/03/07 18:37:14	31020	6.78	92.41	70.28	12.71	62.60
07/03/07 18:37:44	31050	5.38	90.27	56.07	14.01	62.51
07/03/07 18:38:14	31080	5.76	99.46	47.62	13.67	61.75
07/03/07 18:38:44	31110	5.57	109.37	30.71	13.82	59.50
07/03/07 18:39:14	31140	4.45	109.87	36.00	14.89	58.05
07/03/07 18:39:44	31170	6.64	112.83	44.58	12.99	62.57
07/03/07 18:40:14	31200	7.03	82.87	42.01	12.31	62.75
07/03/07 18:40:44	31230	4.88	88.80	39.45	14.49	53.14
07/03/07 18:41:14	31260	5.76	112.33	34.27	13.68	53.50
07/03/07 18:41:44	31290	5.24	104.09	37.75	14.14	55.10
07/03/07 18:42:14	31320	5.96	110.45	38.24	13.46	56.55
07/03/07 18:42:44	31350	5.85	103.63	31.09	13.57	56.35
07/03/07 18:43:14	31380	4.61	110.70	82.18	14.73	56.91
07/03/07 18:43:44	31410	5.14	94.05	159.70	14.28	65.34
07/03/07 18:44:14	31440	7.75	92.53	75.55	11.78	69.13
07/03/07 18:44:44	31470	4.69	72.19	209.61	14.52	62.23
07/03/07 18:45:14	31500	4.13	71.62	434.55	15.18	61.70
07/03/07 18:45:44	31530	5.22	96.04	141.57	14.22	72.19
07/03/07 18:46:14	31560	5.93	114.63	41.80	13.52	69.38
07/03/07 18:46:44	31590	5.46	93.16	37.23	13.90	61.12
07/03/07 18:47:14	31620	5.21	98.35	53.36	14.17	58.22
07/03/07 18:47:44	31650	5.99	107.77	41.14	13.51	58.76
07/03/07 18:48:14	31680	5.28	98.42	59.46	14.10	56.09
07/03/07 18:48:44	31710	6.39	94.87	83.17	13.10	55.36

Fibrominn, LLC
July 3, 2007
Biomass Boiler, Unit #Outlet
Fibrominn Biomass Power Plant

Fuel Data

Fuel F _c factor	1,890	SCF/MMBtu
Fuel Heating Value (HHV)	4,334	Btu/lb

Weather Data

Barometric Pressure	29.43	in. Hg
Relative Humidity	71	%
Ambient Temperature	81	° F
Specific Humidity	0.016438	lb H ₂ O / lb air

Unit Data

Gross Unit Load	61.3	gross MW
Heat Input	784	MMBtu/hr
Steam Rate	487,155	Steam lb/hr
Meas. Stack Moisture	25.7	%
Stack Exhaust Flow (M2)	10,257,198	SCFH

High Load, Run - Out-1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)	CO ₂ (%)	SO ₂ (ppmvd)
07/03/07 18:49:14	31740	4.98	77.14	65.23	14.29	52.84
07/03/07 18:49:44	31770	5.52	64.14	347.58	13.99	55.93
07/03/07 18:50:14	31800	5.58	73.32	246.25	13.74	65.95
07/03/07 18:50:44	31830	4.90	67.54	302.20	14.48	63.76
07/03/07 18:51:14	31860	6.82	69.33	159.39	12.75	65.82
07/03/07 18:51:44	31890	5.82	59.45	127.17	13.55	58.06
07/03/07 18:52:14	31920	5.59	77.93	105.13	13.84	46.35
07/03/07 18:52:44	31950	6.67	89.71	40.92	12.84	43.31
07/03/07 18:53:14	31980	5.04	76.19	55.95	14.30	40.91
07/03/07 18:53:44	32010	5.08	76.80	106.17	14.32	44.34
07/03/07 18:54:14	32040	5.64	73.49	113.17	13.75	53.85
07/03/07 18:54:44	32070	5.48	85.45	297.76	14.03	53.82
07/03/07 18:55:14	32100	5.70	83.59	253.07	13.64	56.00
07/03/07 18:55:44	32130	5.77	83.11	325.61	13.70	54.04
07/03/07 18:56:14	32160	5.23	82.17	143.53	14.13	53.01
07/03/07 18:56:44	32190	5.61	76.76	97.44	13.86	53.00
07/03/07 18:57:14	32220	5.38	83.84	75.20	13.92	53.39
07/03/07 18:57:44	32250	5.32	67.88	420.84	14.14	53.00

RAW AVERAGE

5.30 86.21 230.77 14.09 64.96

	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)	CO ₂ (%)	SO ₂ (ppmvd)
Serial Number:	INST-22-0002	INST-NX-0012	INST-CO-0001	INST-22-0002	INST-S2-0002
Initial Zero	0.02	-0.49	0.59	0.08	0.91
Final Zero	-0.02	0.53	1.51	0.05	0.83
Avg. Zero	0.00	0.02	1.05	0.07	0.87
Initial UpScale	11.94	106.88	221.78	8.75	47.44
Final UpScale	11.85	105.04	221.23	8.79	45.74
Avg. UpScale	11.90	105.96	221.51	8.77	46.59

Bias

**Calcs by
Geo Mean
SO₂ avg
64.21
CO₂ avg
14.44**

Upscale Cal Gas

12.00 111.00 220.00 8.97 45.90

EMISSIONS DATA	O ₂	NOx	CO	CO ₂	SO ₂	SO ₂ GEO
Corrected Raw Average (ppm/% dry basis)	5.35	90.31	229.25	14.46	64.35	63.59
Concentration (ppm@ 7%O ₂)	N/A	80.71	204.89	N/A	57.51	56.83
Emission Rate (lb/hr)	N/A	110.64	170.91	N/A	109.65	108.36
Emission Rate (tons/year) at 8760 hr/yr	N/A	484.59	748.60	N/A	480.28	480.28
Emission Rate (lb/MMBtu)	N/A	0.141	0.218	N/A	0.140	0.138

Fibrominn, LLC
July 3, 2007
Biomass Boiler, Unit #Outlet
Fibrominn Biomass Power Plant

Fuel Data

Fuel F _c factor	1,890	SCF/MMBtu
Fuel Heating Value (HHV)	4,334	Btu/lb

Weather Data

Barometric Pressure	29.44	in. Hg
Relative Humidity	72	%
Ambient Temperature	78	° F
Specific Humidity	0.014868	lb H ₂ O / lb air

Unit Data

Gross Unit Load	61.8	gross MW
Heat Input	774	MMBtu/hr
Steam Rate	487,320	Steam lb/hr
Meas. Stack Moisture	26.0	%
Stack Exhaust Flow (M2)	9,847,715	SCFH

High Load, Run - Out-2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)	CO ₂ (%)	SO ₂ (ppmvd)
07/03/07 19:40:14	34800	4.44	36.34	1,444.56	14.94	45.94
07/03/07 19:40:44	34830	4.90	63.77	602.17	14.38	42.23
07/03/07 19:41:14	34860	4.86	64.13	262.76	14.49	27.19
07/03/07 19:41:44	34890	5.17	73.41	123.90	14.26	29.81
07/03/07 19:42:14	34920	5.60	63.37	110.87	13.73	32.52
07/03/07 19:42:44	34950	3.90	39.34	716.02	15.31	36.93
07/03/07 19:43:14	34980	6.15	49.73	797.63	13.34	48.99
07/03/07 19:43:44	35010	5.45	78.06	100.32	13.85	49.08
07/03/07 19:44:14	35040	4.50	76.85	79.46	14.84	37.92
07/03/07 19:44:44	35070	4.32	68.22	177.32	14.88	41.50
07/03/07 19:45:14	35100	4.47	74.70	372.95	14.88	50.96
07/03/07 19:45:44	35130	5.11	80.94	106.96	14.26	66.57
07/03/07 19:46:14	35160	4.56	72.99	95.00	14.75	63.13
07/03/07 19:46:44	35190	5.44	62.17	173.84	13.96	61.38
07/03/07 19:47:14	35220	5.85	75.66	3.66	13.52	56.63
07/03/07 19:47:44	35250	4.37	76.10	146.99	14.89	52.35
07/03/07 19:48:14	35280	4.48	65.08	183.72	14.80	59.32
07/03/07 19:48:44	35310	4.55	66.00	66.68	14.75	63.45
07/03/07 19:49:14	35340	3.90	74.47	253.22	15.34	64.62
07/03/07 19:49:44	35370	4.99	70.04	436.84	14.41	74.51
07/03/07 19:50:14	35400	6.29	73.93	103.78	13.16	71.23
07/03/07 19:50:44	35430	5.13	61.23	28.34	14.11	59.88
07/03/07 19:51:14	35460	4.77	52.93	199.95	14.55	51.16
07/03/07 19:51:44	35490	3.91	62.07	162.07	15.26	56.78
07/03/07 19:52:14	35520	4.07	61.63	255.09	15.24	63.13
07/03/07 19:52:44	35550	4.81	67.11	117.68	14.48	77.80
07/03/07 19:53:14	35580	4.28	66.79	235.09	14.97	71.08
07/03/07 19:53:44	35610	4.16	50.54	914.36	15.13	75.30
07/03/07 19:54:14	35640	5.38	71.99	389.08	14.00	78.94
07/03/07 19:54:44	35670	5.34	86.06	16.17	14.00	66.91
07/03/07 19:55:14	35700	4.03	67.91	117.64	15.19	57.23
07/03/07 19:55:44	35730	5.02	56.37	404.65	14.32	61.73
07/03/07 19:56:14	35760	4.30	70.75	286.37	14.94	66.23
07/03/07 19:56:44	35790	4.65	71.10	285.50	14.69	68.36
07/03/07 19:57:14	35820	5.48	81.26	124.06	13.85	66.48
07/03/07 19:57:44	35850	4.29	66.35	372.68	15.04	58.85
07/03/07 19:58:14	35880	5.37	72.01	351.17	13.99	60.65
07/03/07 19:58:44	35910	4.25	93.27	32.29	14.98	53.71
07/03/07 19:59:14	35940	4.06	79.13	267.41	15.19	56.57
07/03/07 19:59:44	35970	3.69	57.67	556.59	15.55	71.97
07/03/07 20:00:14	36000	5.14	70.52	534.02	14.25	79.05
07/03/07 20:00:44	36030	5.97	87.36	91.14	13.39	71.53
07/03/07 20:01:14	36060	3.64	77.31	1,258.25	15.48	61.90
07/03/07 20:01:44	36090	4.13	56.91	1,684.63	15.14	75.25
07/03/07 20:02:14	36120	4.90	55.10	592.73	14.49	67.33
07/03/07 20:02:44	36150	5.75	86.27	64.18	13.63	54.27
07/03/07 20:03:14	36180	4.56	90.74	51.58	14.72	39.86
07/03/07 20:03:44	36210	5.53	77.06	119.37	13.87	40.59
07/03/07 20:04:14	36240	5.47	67.20	3.06	13.84	42.37
07/03/07 20:04:44	36270	5.41	71.32	4.53	13.96	41.50
07/03/07 20:05:14	36300	4.30	76.44	71.70	14.96	47.33

Fibrominn, LLC
July 3, 2007
Biomass Boiler, Unit #Outlet
Fibrominn Biomass Power Plant

Fuel Data

Fuel F _c factor	1,890	SCF/MMBtu
Fuel Heating Value (HHV)	4,334	Btu/lb

Weather Data

Barometric Pressure	29.44	in. Hg
Relative Humidity	72	%
Ambient Temperature	78	° F
Specific Humidity	0.014868	lb H ₂ O / lb air

Unit Data

Gross Unit Load	61.8	gross MW
Heat Input	774	MMBtu/hr
Steam Rate	487,320	Steam lb/hr
Meas. Stack Moisture	26.0	%
Stack Exhaust Flow (M2)	9,847,715	SCFH

High Load, Run - Out-2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)	CO ₂ (%)	SO ₂ (ppmvd)
07/03/07 20:05:44	36330	5.09	84.91	82.24	14.34	56.69
07/03/07 20:06:14	36360	6.02	80.89	12.17	13.33	63.53
07/03/07 20:06:44	36390	4.45	61.38	133.80	14.87	59.16
07/03/07 20:07:14	36420	4.75	70.37	241.78	14.60	66.53
07/03/07 20:07:44	36450	5.83	85.62	171.66	13.56	69.71
07/03/07 20:08:14	36480	5.68	83.24	55.44	13.75	65.22
07/03/07 20:08:44	36510	4.56	63.99	204.80	14.69	60.50
07/03/07 20:09:14	36540	5.16	67.98	285.71	14.23	63.25
07/03/07 20:09:44	36570	5.07	79.94	43.15	14.24	66.37
07/03/07 20:10:14	36600	4.55	75.00	98.61	14.82	66.18
07/03/07 20:10:44	36630	5.37	72.55	65.81	14.00	72.46
07/03/07 20:11:14	36660	5.84	82.32	8.83	13.59	67.04
07/03/07 20:11:44	36690	5.39	94.03	29.68	13.94	60.94
07/03/07 20:12:14	36720	4.71	92.09	31.37	14.63	59.57
07/03/07 20:12:44	36750	4.80	91.15	23.40	14.53	65.74
07/03/07 20:13:14	36780	4.80	74.80	52.24	14.57	69.38
07/03/07 20:13:44	36810	5.24	70.44	66.83	14.18	72.21
07/03/07 20:14:14	36840	6.55	80.81	8.41	12.99	70.23
07/03/07 20:14:44	36870	5.61	76.26	5.91	13.64	63.37
07/03/07 20:15:14	36900	4.53	67.67	336.42	14.79	56.09
07/03/07 20:15:44	36930	3.19	64.83	1,006.78	15.90	64.63
07/03/07 20:16:14	36960	3.67	55.38	1,559.50	15.56	80.84
07/03/07 20:16:44	36990	3.73	66.64	780.48	15.57	85.52
07/03/07 20:17:14	37020	5.76	62.86	341.79	13.70	80.94
07/03/07 20:17:44	37050	4.78	55.59	105.06	14.52	67.86
07/03/07 20:18:14	37080	5.03	52.20	109.58	14.37	51.15
07/03/07 20:18:44	37110	3.79	61.41	275.34	15.47	49.81
07/03/07 20:19:14	37140	4.22	59.84	541.30	15.12	56.77
07/03/07 20:19:44	37170	5.26	70.68	383.20	14.14	62.41
07/03/07 20:20:14	37200	4.75	62.82	86.68	14.58	55.02
07/03/07 20:20:44	37230	3.84	60.08	183.36	15.41	53.28
07/03/07 20:21:14	37260	4.85	64.36	415.39	14.57	63.59
07/03/07 20:21:44	37290	4.66	86.07	202.34	14.64	66.16
07/03/07 20:22:14	37320	4.28	67.01	220.54	15.03	62.50
07/03/07 20:22:44	37350	4.42	79.27	82.98	14.98	65.00
07/03/07 20:23:14	37380	4.49	80.48	67.53	14.81	71.56
07/03/07 20:23:44	37410	3.80	77.07	221.23	15.50	75.87
07/03/07 20:24:14	37440	3.91	64.18	231.45	15.37	84.28
07/03/07 20:24:44	37470	4.22	61.46	275.86	15.19	85.72
07/03/07 20:25:14	37500	5.41	88.61	112.61	13.96	86.55
07/03/07 20:25:44	37530	5.04	87.65	27.47	14.39	71.89
07/03/07 20:26:14	37560	5.38	88.43	12.72	13.99	64.48
07/03/07 20:26:44	37590	4.43	75.09	120.81	14.86	58.03
07/03/07 20:27:14	37620	3.49	67.73	394.98	15.72	62.24
07/03/07 20:27:44	37650	3.96	57.90	979.00	15.36	80.53
07/03/07 20:28:14	37680	5.30	78.88	515.14	14.04	90.99
07/03/07 20:28:44	37710	5.52	81.52	52.93	13.93	69.96
07/03/07 20:29:14	37740	4.58	66.44	4.85	14.73	57.90
07/03/07 20:29:44	37770	4.28	79.91	10.29	15.07	58.72
07/03/07 20:30:14	37800	4.08	85.00	47.73	15.19	67.28
07/03/07 20:30:44	37830	4.53	74.04	492.11	14.89	72.81

Fibrominn, LLC
July 3, 2007
Biomass Boiler, Unit #Outlet
Fibrominn Biomass Power Plant

Fuel Data

Fuel F _c factor	1,890	SCF/MMBtu
Fuel Heating Value (HHV)	4,334	Btu/lb

Weather Data

Barometric Pressure	29.44	in. Hg
Relative Humidity	72	%
Ambient Temperature	78	° F
Specific Humidity	0.014868	lb H ₂ O / lb air

Unit Data

Gross Unit Load	61.8	gross MW
Heat Input	774	MMBtu/hr
Steam Rate	487,320	Steam lb/hr
Meas. Stack Moisture	26.0	%
Stack Exhaust Flow (M2)	9,847,715	SCFH

High Load, Run - Out-2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)	CO ₂ (%)	SO ₂ (ppmvd)
07/03/07 20:31:14	37860	4.61	78.81	312.31	14.67	78.41
07/03/07 20:31:44	37890	5.47	84.55	222.89	14.00	71.54
07/03/07 20:32:14	37920	4.68	95.44	89.78	14.62	69.02
07/03/07 20:32:44	37950	4.59	84.62	172.68	14.76	73.00
07/03/07 20:33:14	37980	4.36	84.37	211.03	14.99	83.41
07/03/07 20:33:44	38010	6.78	91.02	286.81	12.73	89.53
07/03/07 20:34:14	38040	5.01	88.32	31.18	14.31	79.91
07/03/07 20:34:44	38070	4.26	86.95	107.41	15.10	71.62
07/03/07 20:35:14	38100	5.52	98.11	92.59	13.86	78.33
07/03/07 20:35:44	38130	4.32	91.29	170.86	14.96	76.44
07/03/07 20:36:14	38160	5.11	83.74	334.21	14.38	81.66
07/03/07 20:36:44	38190	5.27	83.88	209.66	14.01	87.07
07/03/07 20:37:14	38220	4.46	79.01	304.28	14.92	79.44
07/03/07 20:37:44	38250	5.07	77.42	144.44	14.37	86.09
07/03/07 20:38:14	38280	4.85	102.96	110.50	14.48	80.53
07/03/07 20:38:44	38310	4.91	96.96	515.77	14.46	77.79
07/03/07 20:39:14	38340	5.35	108.60	171.14	14.14	76.26
07/03/07 20:39:44	38370	5.20	98.18	149.01	14.16	73.87

RAW AVERAGE

4.81 73.92 261.72 14.52 64.60

	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)	CO ₂ (%)	SO ₂ (ppmvd)
Serial Number:	INST-22-0002	INST-NX-0012	INST-CO-0001	INST-22-0002	INST-S2-0002
Initial Zero	-0.02	0.53	1.51	0.05	0.83
Final Zero	-0.02	1.00	0.91	0.12	0.24
Avg. Zero	-0.02	0.77	1.21	0.09	0.54
Initial UpScale	11.85	105.04	221.23	8.79	45.74
Final UpScale	11.86	105.25	221.82	8.81	44.51
Avg. UpScale	11.86	105.15	221.53	8.80	45.13

Bias

**Calcs by
Geo Mean
SO₂ avg
63.09
CO₂ avg
14.85**

Upscale Cal Gas

12.00 111.00 220.00 8.97 45.90

EMISSIONS DATA	O ₂	NOx	CO	CO ₂	SO ₂	SO ₂ GEO
Corrected Raw Average (ppm/% dry basis)	4.88	77.80	260.13	14.86	65.95	64.39
Concentration (ppm@ 7%O ₂)	N/A	67.52	225.77	N/A	57.24	55.88
Emission Rate (lb/hr)	N/A	91.50	186.20	N/A	107.90	105.34
Emission Rate (tons/year) at 8760 hr/yr	N/A	400.78	815.54	N/A	472.59	472.59
Emission Rate (lb/MMBtu)	N/A	0.118	0.241	N/A	0.139	0.136

Fibrominn, LLC
July 3, 2007
Biomass Boiler, Unit #Outlet
Fibrominn Biomass Power Plant

Fuel Data

Fuel F _c factor	1,890	SCF/MMBtu
Fuel Heating Value (HHV)	4,334	Btu/lb

Weather Data

Barometric Pressure	29.46	in. Hg
Relative Humidity	71	%
Ambient Temperature	77	° F
Specific Humidity	0.014450	lb H ₂ O / lb air

Unit Data

Gross Unit Load	62.8	gross MW
Heat Input	778	MMBtu/hr
Steam Rate	490,767	Steam lb/hr
Meas. Stack Moisture	24.9	%
Stack Exhaust Flow (M2)	10,305,362	SCFH

High Load, Run - Out-3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)	CO ₂ (%)	SO ₂ (ppmvd)
07/03/07 21:39:14	41940	4.58	95.19	203.69	14.75	68.20
07/03/07 21:39:44	41970	4.42	88.33	268.93	14.95	73.93
07/03/07 21:40:14	42000	6.12	97.53	136.44	13.37	76.13
07/03/07 21:40:44	42030	5.68	108.21	36.88	13.64	68.15
07/03/07 21:41:14	42060	3.55	94.72	306.41	15.64	59.44
07/03/07 21:41:44	42090	3.55	80.50	454.95	15.68	73.84
07/03/07 21:42:14	42120	4.56	80.77	635.48	14.77	88.54
07/03/07 21:42:44	42150	2.97	93.81	1,331.19	16.01	88.52
07/03/07 21:43:14	42180	5.54	63.31	1,999.47	13.87	88.53
07/03/07 21:43:44	42210	4.36	93.83	622.77	14.83	88.48
07/03/07 21:44:14	42240	4.55	73.02	601.19	14.78	87.88
07/03/07 21:44:44	42270	4.05	90.05	268.82	15.17	76.68
07/03/07 21:45:14	42300	3.79	91.85	415.95	15.48	70.67
07/03/07 21:45:44	42330	4.30	89.59	598.08	14.92	80.28
07/03/07 21:46:14	42360	4.98	85.66	468.30	14.49	81.65
07/03/07 21:46:44	42390	5.42	103.04	142.11	13.89	82.56
07/03/07 21:47:14	42420	3.79	94.82	87.64	15.45	70.73
07/03/07 21:47:44	42450	4.98	98.44	123.95	14.46	77.33
07/03/07 21:48:14	42480	5.36	112.29	67.10	13.92	79.60
07/03/07 21:48:44	42510	4.03	91.67	356.45	15.26	73.31
07/03/07 21:49:14	42540	5.13	83.00	239.25	14.28	83.26
07/03/07 21:49:44	42570	5.72	107.19	44.98	13.70	80.58
07/03/07 21:50:14	42600	5.42	114.52	26.09	13.95	71.97
07/03/07 21:50:44	42630	4.84	96.37	47.37	14.46	69.58
07/03/07 21:51:14	42660	3.99	103.87	209.57	15.26	75.47
07/03/07 21:51:44	42690	4.67	82.32	774.44	14.73	87.54
07/03/07 21:52:14	42720	5.19	112.05	334.76	14.15	88.60
07/03/07 21:52:44	42750	5.11	113.75	55.07	14.28	88.60
07/03/07 21:53:14	42780	3.71	108.45	161.21	15.46	88.59
07/03/07 21:53:44	42810	3.09	76.18	904.41	16.10	88.48
07/03/07 21:54:14	42840	4.50	80.14	629.52	14.86	88.49
07/03/07 21:54:44	42870	4.19	97.78	250.23	15.10	88.60
07/03/07 21:55:14	42900	4.45	65.67	497.05	14.88	88.65
07/03/07 21:55:44	42930	4.90	80.51	226.91	14.47	82.97
07/03/07 21:56:14	42960	4.48	99.88	74.19	14.86	71.02
07/03/07 21:56:44	42990	4.89	89.04	91.51	14.44	67.95
07/03/07 21:57:14	43020	3.57	84.30	201.48	15.63	67.13
07/03/07 21:57:44	43050	3.85	74.21	403.16	15.45	78.28
07/03/07 21:58:14	43080	4.52	97.78	195.86	14.87	88.54
07/03/07 21:58:44	43110	6.54	117.39	67.29	12.97	88.14
07/03/07 21:59:14	43140	6.29	104.90	29.66	13.08	78.77
07/03/07 21:59:44	43170	5.82	105.20	27.23	13.62	61.15
07/03/07 22:00:14	43200	5.25	112.83	34.64	14.10	57.73
07/03/07 22:00:44	43230	6.54	105.83	36.34	12.93	58.52
07/03/07 22:01:14	43260	5.71	104.10	27.95	13.65	55.54
07/03/07 22:01:44	43290	5.96	104.16	28.46	13.46	53.61
07/03/07 22:02:14	43320	4.95	118.05	29.37	14.31	54.67
07/03/07 22:02:44	43350	4.09	108.29	248.59	15.23	59.35
07/03/07 22:03:14	43380	5.50	118.38	141.75	13.90	80.00
07/03/07 22:03:44	43410	5.69	135.06	28.48	13.71	79.55
07/03/07 22:04:14	43440	5.35	120.47	25.62	13.98	71.26

Fibrominn, LLC
July 3, 2007
Biomass Boiler, Unit #Outlet
Fibrominn Biomass Power Plant

Fuel Data

Fuel F _c factor	1,890	SCF/MMBtu
Fuel Heating Value (HHV)	4,334	Btu/lb

Weather Data

Barometric Pressure	29.46	in. Hg
Relative Humidity	71	%
Ambient Temperature	77	° F
Specific Humidity	0.014450	lb H ₂ O / lb air

Unit Data

Gross Unit Load	62.8	gross MW
Heat Input	778	MMBtu/hr
Steam Rate	490,767	Steam lb/hr
Meas. Stack Moisture	24.9	%
Stack Exhaust Flow (M2)	10,305,362	SCFH

High Load, Run - Out-3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)	CO ₂ (%)	SO ₂ (ppmvd)
07/03/07 22:04:44	43470	5.74	110.26	32.84	13.79	68.92
07/03/07 22:05:14	43500	7.20	97.98	30.91	12.24	68.82
07/03/07 22:05:44	43530	6.14	94.29	27.91	13.21	57.36
07/03/07 22:06:14	43560	5.41	102.14	32.87	14.00	51.85
07/03/07 22:06:44	43590	4.92	100.12	56.27	14.34	57.66
07/03/07 22:07:14	43620	5.52	101.46	261.44	13.95	64.65
07/03/07 22:07:44	43650	5.48	105.84	101.96	13.87	75.21
07/03/07 22:08:14	43680	5.70	116.44	44.42	13.68	71.73
07/03/07 22:08:44	43710	5.39	124.46	23.39	13.96	68.18
07/03/07 22:09:14	43740	5.79	113.98	24.90	13.68	67.80
07/03/07 22:09:44	43770	6.88	95.66	28.56	12.49	67.44
07/03/07 22:10:14	43800	4.22	85.00	245.90	15.02	59.37
07/03/07 22:10:44	43830	5.31	82.10	426.08	14.07	68.77
07/03/07 22:11:14	43860	7.10	122.13	76.61	12.49	72.27
07/03/07 22:11:44	43890	7.32	84.42	35.98	12.03	65.12
07/03/07 22:12:14	43920	5.30	87.38	28.83	14.06	47.77
07/03/07 22:12:44	43950	5.79	105.57	25.30	13.61	47.13
07/03/07 22:13:14	43980	5.23	114.47	25.28	14.14	51.18
07/03/07 22:13:44	44010	6.78	113.74	26.28	12.71	55.84
07/03/07 22:14:14	44040	5.99	93.55	27.23	13.43	52.21
07/03/07 22:14:44	44070	5.59	107.15	23.72	13.76	49.99
07/03/07 22:15:14	44100	6.13	101.96	26.46	13.34	54.27
07/03/07 22:15:44	44130	7.04	93.66	27.67	12.45	53.61
07/03/07 22:16:14	44160	6.70	85.00	28.48	12.66	46.70
07/03/07 22:16:44	44190	4.41	87.46	73.99	14.88	44.26
07/03/07 22:17:14	44220	5.49	103.02	59.28	13.95	56.47
07/03/07 22:17:44	44250	6.19	118.76	27.66	13.16	65.70
07/03/07 22:18:14	44280	5.82	107.20	34.22	13.63	61.00
07/03/07 22:18:44	44310	6.74	99.47	30.30	12.69	61.09
07/03/07 22:19:14	44340	6.45	87.42	26.92	13.00	55.35
07/03/07 22:19:44	44370	6.01	93.55	25.07	13.38	50.89
07/03/07 22:20:14	44400	6.51	86.26	28.50	12.95	51.24
07/03/07 22:20:44	44430	6.33	87.54	27.27	13.08	49.83
07/03/07 22:21:14	44460	5.75	98.28	25.20	13.58	47.48
07/03/07 22:21:44	44490	5.18	96.10	39.83	14.21	50.51
07/03/07 22:22:14	44520	5.88	104.35	29.11	13.53	61.78
07/03/07 22:22:44	44550	5.68	110.10	24.48	13.68	61.31
07/03/07 22:23:14	44580	5.39	112.21	25.12	14.01	61.72
07/03/07 22:23:44	44610	6.98	114.92	23.81	12.54	63.73
07/03/07 22:24:14	44640	6.13	84.93	25.84	13.23	58.72
07/03/07 22:24:44	44670	5.64	96.67	22.40	13.76	53.31
07/03/07 22:25:14	44700	5.91	99.50	23.04	13.42	55.95
07/03/07 22:25:44	44730	4.74	96.99	78.13	14.64	57.49
07/03/07 22:26:14	44760	5.75	85.92	74.07	13.59	71.31
07/03/07 22:26:44	44790	6.28	85.97	66.44	13.28	72.76
07/03/07 22:27:14	44820	6.88	81.19	47.31	12.47	71.45
07/03/07 22:27:44	44850	4.63	86.84	31.70	14.67	59.21
07/03/07 22:28:14	44880	6.68	97.22	34.71	12.87	61.85
07/03/07 22:28:44	44910	6.68	73.24	32.21	12.66	62.15
07/03/07 22:29:14	44940	5.81	85.23	27.20	13.55	51.68
07/03/07 22:29:44	44970	5.44	101.58	27.95	14.00	51.80

Fibrominn, LLC
July 3, 2007
Biomass Boiler, Unit #Outlet
Fibrominn Biomass Power Plant

Fuel Data

Fuel F _c factor	1,890	SCF/MMBtu
Fuel Heating Value (HHV)	4,334	Btu/lb

Weather Data

Barometric Pressure	29.46	in. Hg
Relative Humidity	71	%
Ambient Temperature	77	° F
Specific Humidity	0.014450	lb H ₂ O / lb air

Unit Data

Gross Unit Load	62.8	gross MW
Heat Input	778	MMBtu/hr
Steam Rate	490,767	Steam lb/hr
Meas. Stack Moisture	24.9	%
Stack Exhaust Flow (M2)	10,305,362	SCFH

High Load, Run - Out-3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)	CO ₂ (%)	SO ₂ (ppmvd)
07/03/07 22:30:14	45000	6.28	92.26	35.37	13.06	56.39
07/03/07 22:30:44	45030	5.59	83.86	151.11	13.88	55.09
07/03/07 22:31:14	45060	6.82	97.01	70.90	12.66	58.25
07/03/07 22:31:44	45090	5.97	94.09	27.16	13.34	51.09
07/03/07 22:32:14	45120	5.56	98.03	46.88	13.89	49.48
07/03/07 22:32:44	45150	5.85	88.13	41.91	13.51	57.39
07/03/07 22:33:14	45180	6.80	99.73	23.82	12.73	54.97
07/03/07 22:33:44	45210	6.14	78.07	31.26	13.21	51.32
07/03/07 22:34:14	45240	4.79	86.34	36.46	14.55	48.79
07/03/07 22:34:44	45270	6.85	90.37	36.62	12.63	56.34
07/03/07 22:35:14	45300	5.60	89.69	27.27	13.75	56.29
07/03/07 22:35:44	45330	6.43	96.46	23.61	13.05	54.23
07/03/07 22:36:14	45360	7.04	74.71	28.37	12.40	50.29
07/03/07 22:36:44	45390	5.72	63.78	30.87	13.60	40.25
07/03/07 22:37:14	45420	4.24	74.76	99.07	15.02	40.10
07/03/07 22:37:44	45450	4.57	68.71	519.48	14.66	55.62
07/03/07 22:38:14	45480	3.94	71.97	503.01	15.38	71.21
07/03/07 22:38:44	45510	6.55	71.72	377.41	12.92	87.29

RAW AVERAGE

5.43 95.74 166.75 13.94 65.88

Serial Number:	O ₂	NOx	CO	CO ₂	SO ₂
	(%)	(ppmvd)	(ppmvd)	(%)	(ppmvd)
INST-22-0002	INST-NX-0012	INST-CO-0001	INST-22-0002	INST-S2-0002	
Initial Zero	-0.02	1.00	0.91	0.12	0.24
Final Zero	-0.01	0.67	1.52	0.13	0.87
Avg. Zero	-0.02	0.84	1.22	0.13	0.56
Initial UpScale	11.86	105.25	221.82	8.81	44.51
Final UpScale	11.87	104.79	221.71	8.81	46.23
Avg. UpScale	11.87	105.02	221.77	8.81	45.37

Bias

**Calcs by
Geo Mean
SO₂ avg
64.56
CO₂ avg
14.24**

Upscale Cal Gas

12.00 111.00 220.00 8.97 45.90

EMISSIONS DATA	O ₂	NOx	CO	CO ₂	SO ₂	SO ₂ GEO
Corrected Raw Average (ppm/% dry basis)	5.50	101.11	165.12	14.27	66.90	65.55
Concentration (ppm@ 7%O ₂)	N/A	91.25	149.01	N/A	60.38	59.15
Emission Rate (lb/hr)	N/A	124.45	123.68	N/A	114.55	112.23
Emission Rate (tons/year) at 8760 hr/yr	N/A	545.10	541.72	N/A	501.71	501.71
Emission Rate (lb/MMBtu)	N/A	0.160	0.159	N/A	0.147	0.145

EXAMPLE CALCULATIONS (INFORMATION)**Specific Humidity (RH_{sp})**

Note: RH_{sp} (gr/lb) calculated using temperature, relative humidity, and barometric pressure with psychrometric chart, psychrometric calculator, or built in psychrometric algorithm.

$$RH_{sp} \text{ (lb / lb)} = \left[\left(\frac{gr}{lb} \right) \times \frac{lb}{7000 \text{ gr}} \right] \quad RH_{sp} = \frac{115.06 \text{ gr}}{lb} \times \frac{1 \text{ lb}}{7000 \text{ gr}} = 0.016438 \frac{\text{lb H}_2\text{O}}{\text{lb Air}}$$

EXAMPLE CALCULATIONS (CALIBRATION)**Analyzer Calibration Error**

RM 7E, (08-15-06), 12.2 Analyzer Calibration Error. For non-dilution systems, use Equation 7E-1 to calculate the analyzer calibration error for the low-, mid-, and high-level calibration gases. (calc for NOx analyzer mid gas, if applicable)

$$ACE = \left(\frac{C_{Dir} - C_V}{CS} \right) \times 100 \quad \text{Eq. 7E-1} \quad ACE = \frac{109.64 \text{ ppm} - 111.00 \text{ ppm}}{254.00 \text{ ppm}} \times 100 = -0.54 \%$$

EXAMPLE CALCULATIONS (BIAS, DRIFT, AND CORRECTED RAW AVERAGE)**System Bias**

RM 7E, (08-15-06), 12.3 System Bias. For non-dilution systems, use Equation 7E-2 to calculate the system bias separately for the low-level and upscale calibration gases. (calc for NOx analyzer upscale gas, Run 1 initial bias, if applicable)

$$SB = \left(\frac{C_S - C_{Dir}}{CS} \right) \times 100 \quad \text{Eq. 7E-2} \quad SB = \frac{106.88 \text{ ppm} - 111.00 \text{ ppm}}{254.00 \text{ ppm}} \times 100 = -1.62 \%$$

Drift Assessment

RM 7E, (08-15-06), 12.5 Drift Assessment. Use Equation 7E-4 to separately calculate the low-level and upscale drift over each test run. (calc for NOx analyzer upscale drift, Run 1, if applicable)

$$D = |SB_{final} - SB_i| \quad \text{Eq. 7E-4} \quad D = | -1.81 \% - -1.09 \% | = 0.72 \%$$

Alternative Drift and Bias

RM 7E, (08-15-06), 13.2 / 13.3 System Bias and Drift. Alternatively, the results are acceptable if |Cs - Cdir| is ≤ 0.5 ppmv or if |Cs - Cv| is ≤ 0.5 ppmv (as applicable). (calc for NOx analyzer initial upscale, Run 1, if applicable)

$$SB / D_{Alt} = |C_S - C_{Dir}| \quad \text{Eq. Section 13.2 and 13.3} \quad SB / D_{Alt} = | 106.88 \text{ ppm} - 111.00 \text{ ppm} | = 4.12 \text{ ppm}$$

Bias Adjusted Average

RM 7E, (08-15-06), 12.6 Effluent Gas Concentration. For each test run, calculate C_{avg}, the arithmetic average of all valid NOx concentration values (e.g., 1-minute averages). Then adjust the value of C_{avg} for bias, using Equation 7E-5. (calc for NOx analyzer, Run 1, if applicable)

$$C_{Gas} = (C_{Avg} - C_O) \times \left(\frac{C_{MA}}{C_M - C_O} \right) \quad \text{Eq. 7E-5} \quad C_{Gas} = \left(86.21 \text{ ppm} - 0.02 \text{ ppm} \right) \times \left(\frac{111.00 \text{ ppm}}{105.96 \text{ ppm} - 0.02 \text{ ppm}} \right) = 90.31 \text{ ppm}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (RUNS)

Moisture Correction

RM 7E, (08-15-06), RM7E, (08-15-06), 12.10 Moisture Correction. Use Equation 7E-10 if your measurements need to be corrected to a dry basis. (calc for NOx analyzer, Run 1, if applicable) Note: Calculations may not match as Run 1 results are typically also bias adjusted

$$C_D = \frac{C_W}{1 - B_{WS}} \quad \text{Eq. 7E-10} \quad C_D = \frac{67.10 \text{ ppmvw}}{1 - 0.26} = 90.31 \text{ ppmvd} \quad \text{or inversely,} \quad C_W = 90.31 \text{ ppmvd} \times (1 - 0.26) = 67.10 \text{ ppmvw}$$

Diluent-Corrected Pollutant Concentration, O₂ Based

RM 20, (11-26-02), 7.3.1 Correction of Pollutant Concentration Using O₂ Concentration. Calculate the O₂ corrected pollutant concentration, as follows: (calc for NOx gas, Run 1, if applicable)

$$C_{adj} = C_{Gas(Target)} \times \left(\frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O_2)}} \right) \quad \text{Eq. 20-4} \quad C_{adj} = 90.31 \text{ ppm} \times \left(\frac{20.9\% - 7.00\%}{20.9\% - 5.35\%} \right) = 80.71 \text{ ppm@7\%O}_2$$

EXAMPLE CALCULATIONS (RUNS)

Emissions Rate (lb/hr)

Calculation for pound per hour emission rate. Calculate, as follows: (calc for NOx gas Run 1, if applicable)

$$E_{lb/hr} = \frac{C_{Gas}}{10^6} \times \frac{Q_S \times MW}{G} \quad E_{lb/hr} = \frac{90.31 \text{ ppm}}{10^6 \text{ ppm/part}} \times \frac{10,257,198 \text{ SCFH} \times 46.01 \text{ lb/lb-mol}}{385.23 \text{ SCF/lb-mol}} = \frac{110.64 \text{ lb}}{\text{hr}}$$

Emissions Rate (ton/year)

Calculation for tons per year emission rate based on 8760 hours per year. Calculate, as follows: (calc for NOx gas Run 1, if applicable)

$$E_{ton/yr} = \frac{E_{lb/hr} \times hr_{year}}{2000} \quad E_{ton/yr} = \frac{110.64 \text{ lb}}{\text{hr}} \times \frac{8,760 \text{ hr}}{\text{year}} \times \frac{\text{ton}}{2000 \text{ lb}} = \frac{484.59 \text{ ton}}{\text{year}}$$

Emissions Rate (lb/MMBtu)

RM 19, (07-19-06), 12.2 Emission Rates of PM, SO₂, and NOx. Select from the following sections the applicable procedure to compute the PM, SO₂, or NOx emission rate (E) in ng/J (lb/million Btu). (calc for NOx gas Run 1, if applicable)

Carbon Dioxide Based

12.2.4 Carbon Dioxide-Based F Factor, Dry Basis. When measurements are on a dry basis for both CO₂ (%CO₂d) and pollutant (Cd) concentrations, use the following equation:

$$E_{lb/MMBtu} = \frac{C_{Gas} \times F_c Factor \times Conv_c \times 100\%}{C_{Gas(CO_2)}} \quad \text{Eq. 19-6}$$

$$E_{lb/MMBtu} = \frac{90.31 \text{ ppm} \times 1,890.34 \text{ SCF/MMBtu} \times 0.0000001194 \text{ lb/ppm} \cdot \text{ft}^3 \times 100\%}{14.46\%} = \frac{0.141 \text{ lb}}{\text{MMBtu}}$$

Conversion Constant

Conv_c for NOx

$$Conv_c (lb / ppm \cdot ft^3) = \frac{MW}{10^6} \quad Conv_c = \frac{46.01 \text{ lb}}{\text{lb} \cdot \text{mole}} \times \frac{\text{lb} \cdot \text{mole}}{385.23 \text{ SCF}} = \frac{0.0000001194 \text{ lb}}{\text{ppm} \cdot \text{ft}^3}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

RM 7E, (08-15-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

ACE = Analyzer calibration error, percent of calibration span.
B_{WS} = Moisture content of sample gas as measured by Method 4 or other approved method, percent/100.
C_{Avg} = Average unadjusted gas concentration indicated by data recorder for the test run.
C_D = Pollutant concentration adjusted to dry conditions.
C_{Dir} = Measured concentration of a calibration gas (low, mid, or high) when introduced in direct calibration mode.
C_{Gas} = Average effluent gas concentration adjusted for bias.
C_M = Average of initial and final system calibration bias (or 2-point system calibration error) check responses for the upscale calibration gas.
C_{MA} = Actual concentration of the upscale calibration gas, ppmv.
C_O = Average of the initial and final system calibration bias (or 2-point system calibration error) check responses from the low-level (or zero) calibration gas.
C_S = Measured concentration of a calibration gas (low, mid, or high) when introduced in system calibration mode.
C_{SS} = Concentration of NO_x measured in the spiked sample.
C_{Spike} = Concentration of NO_x in the undiluted spike gas.
C_{Calc} = Calculated concentration of NO_x in the spike gas diluted in the sample.
C_V = Manufacturer certified concentration of a calibration gas (low, mid, or high).
C_W = Pollutant concentration measured under moist sample conditions, wet basis.
CS = Calibration span.
D = Drift assessment, percent of calibration span.
E_p = The predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level response.
Eff_{NO₂} = NO₂ to NO converter efficiency, percent.
H = High calibration gas, designator.
L = Low calibration gas, designator.
M = Mid calibration gas, designator.
NO_{Final} = The average NO concentration observed with the analyzer in the NO mode during the converter efficiency test in Section 16.2.2.
NO_xCorr = The NO_x concentration corrected for the converter efficiency.
NO_xFinal = The final NO_x concentration observed during the converter efficiency test in Section 16.2.2.
NO_xPeak = The highest NO_x concentration observed during the converter efficiency test in Section 16.2.2.
Q_{Spike} = Flow rate of spike gas introduced in system calibration mode, L/min.
Q_{Total} = Total sample flow rate during the spike test, L/min.
R = Spike recovery, percent.
SB = System bias, percent of calibration span.
SB_i = Pre-run system bias, percent of calibration span.
SB_r = Post-run system bias, percent of calibration span.
SB / D_{Alt} = Alternative absolute difference criteria to pass bias and/or drift checks.
SCE = System calibration error, percent of calibration span.
SCE_i = Pre-run system calibration error, percent of calibration span.
SCE_{Final} = Post-run system calibration error, percent of calibration span.
Z = Zero calibration gas, designator.

RM 19, (07-29-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

AdjFactor = percent oxygen or carbon dioxide adjustment applied to a target pollutant
 B_{wa} = Moisture fraction of ambient air, percent.
 Btu = British thermal unit
 $\%_C$ = Concentration of carbon from an ultimate analysis of fuel, weight percent.
 $\%_{CO2d}, \%_{CO2w}$ = Concentration of carbon dioxide on a dry and wet basis, respectively, percent.
 CIP / CDP = Combustor inlet pressure / compressor discharge pressure (mm Hg); note, some manufactures reference as PCD.
 E = Pollutant emission rate, ng/J (lb/million Btu).
 E_a = Average pollutant rate for the specified performance test period, ng/J (lb/million Btu).
 E_{a0}, E_{a1} = Average pollutant rate of the control device, outlet and inlet, respectively, for the performance test period, ng/J (lb/million Btu).
 E_{bi} = Pollutant rate from the steam generating unit, ng/J (lb/million Btu).
 E_{bo} = Pollutant emission rate from the steam generating unit, ng/J (lb/million Btu).
 E_{ci} = Pollutant rate in combined effluent, ng/J (lb/million Btu).
 E_{co} = Pollutant emission rate in combined effluent, ng/J (lb/million Btu).
 E_d = Average pollutant rate for each sampling period (e.g., 24-hr Method 6B sample or 24-hr fuel sample) or for each fuel lot (e.g., amount of fuel bunkered), ng/J (lb/million Btu).
 E_{di} = Average inlet SO₂ rate for each sampling period d, ng/J (lb/million Btu).
 E_g = Pollutant rate from gas turbine, ng/J (lb/million Btu).
 E_{ga} = Daily geometric average pollutant rate, ng/J (lbs/million Btu) or ppm corrected to 7 percent O₂.
 E_{oi}, E_{ji} = Matched pair hourly arithmetic average pollutant rate, outlet and inlet, respectively, ng/J (lb/million Btu) or ppm corrected to 7 percent O₂.
 E_o = Hourly average pollutant, ng/J (lb/million Btu).
 E_{hj} = Hourly arithmetic average pollutant rate for hour "j," ng/J (lb/million Btu) or ppm corrected to 7 percent O₂.
 EXP = Natural logarithmic base (2.718) raised to the value enclosed by brackets.
 F_c = Ratio of the volume of carbon dioxide produced to the gross calorific value of the fuel from Method 19
 F_d, F_w, F_c = Volumes of combustion components per unit of heat content, scm/J (scf/million Btu).
 ft^3 = cubic feet
 G = ideal gas conversion factor
 (385.23 SCF/lb-mol at 68 deg F & 14.696 psia)
 GCM = gross Btu per SCF (constant, compound based)
 GCV = Gross calorific value of the fuel consistent with the ultimate analysis, kJ/kg (Btu/lb).
 GCV_p, GCV_r = Gross calorific value for the product and raw fuel lots, respectively, dry basis, kJ/kg (Btu/lb).
 $\%_H$ = Concentration of hydrogen from an ultimate analysis of fuel, weight percent.
 H_b = Heat input rate to the steam generating unit from fuels fired in the steam generating unit, J/hr (million Btu/hr).
 H_g = Heat input rate to gas turbine from all fuels fired in the gas turbine, J/hr (million Btu/hr).
 $\%_{H2O}$ = Concentration of water from an ultimate analysis of fuel, weight percent.
 H_t = Total numbers of hours in the performance test period (e.g., 720 hours for 30-day performance test period).
 K = volume of combustion component per pound of component (constant)
 K = Conversion factor, 10^{-5} (kJ/J)/(%) [10^6 Btu/million Btu].
 $K_c = (9.57 \text{ scm/kg})/\% [(1.53 \text{ scf/lb})/\%]$.
 $K_{cc} = (2.0 \text{ scm/kg})/\% [(0.321 \text{ scf/lb})/\%]$.
 $K_{hd} = (22.7 \text{ scm/kg})/\% [(3.64 \text{ scf/lb})/\%]$.
 $K_{hw} = (34.74 \text{ scm/kg})/\% [(5.57 \text{ scf/lb})/\%]$.
 $K_n = (0.86 \text{ scm/kg})/\% [(0.14 \text{ scf/lb})/\%]$.
 $K_o = (2.85 \text{ scm/kg})/\% [(0.46 \text{ scf/lb})/\%]$.
 $K_s = (3.54 \text{ scm/kg})/\% [(0.57 \text{ scf/lb})/\%]$.
 $K_{sulfur} = 2 \times 10^4 \text{ Btu/wt}\% \text{-MMBtu}$
 $K_w = (1.30 \text{ scm/kg})/\% [(0.21 \text{ scf/lb})/\%]$.
 lb = pound
 \ln = Natural log of indicated value.
 L_p, L_r = Weight of the product and raw fuel lots, respectively, metric ton (ton).
 $\%_N$ = Concentration of nitrogen from an ultimate analysis of fuel, weight percent.
 $M\%$ = mole percent
 mol = mole
 MW = molecular weight (lb/lb-mol)
 MW_{AIR} = molecular weight of air (28.9625 lb/lb-mole)¹
 NCM = net Btu per SCF (constant based on compound)
 $\%_O$ = Concentration of oxygen from an ultimate analysis of fuel, weight percent.
 $\%_{O2d}, \%_{O2w}$ = Concentration of oxygen on a dry and wet basis, respectively, percent.
 P_B = barometric pressure, in Hg
 P_s = Potential SO₂ emissions, percent.
 $\%_S$ = Sulfur content of as-fired fuel lot, dry basis, weight percent.
 S_e = Standard deviation of the hourly average pollutant rates for each performance test period, ng/J (lb/million Btu).
 $\%_{SF}$ = Concentration of sulfur from an ultimate analysis of fuel, weight percent.
 $S(wt\%)$ = weight percent of sulfur, per lab analysis by appropriate ASTM standard
 S_d = Standard deviation of the hourly average inlet pollutant rates for each performance test period, ng/J (lb/million Btu).
 S_o = Standard deviation of the hourly average emission rates for each performance test period, ng/J (lb/million Btu).
 $\%S_p, \%S_r$ = Sulfur content of the product and raw fuel lots respectively, dry basis, weight percent.
 SCF = standard cubic feet
 SH = specific humidity, pounds of water per pound of air
 $t_{0.95}$ = Values shown in Table 19-3 for the indicated number of data points n.
 T_{amb} = ambient temperature, °F
 $W/D \text{ Factor} = 1.0236 = \text{conv. at } 14.696 \text{ psia and } 68 \text{ deg F (ref. Civil Eng. Ref. Manual, 7th Ed.)}$
 X_{CO2} = CO₂ Correction factor, percent.
 X_k = Fraction of total heat input from each type of fuel k.

Calculations, Formulas, and Constants

The following information supports the spreadsheets for this testing project.

Given Data:

Ideal Gas Conversion Factor = 385.23 SCF/lb-mol at 68 deg F & 14.696 psia

Fuel Heating Value is based upon Air Hygiene's fuel gas calculation sheet. All calculations are based upon a correction to 68 deg F & 14.696 psia

High Heating Values (HHV) are used for the Fuel Heating Value, F-Factor, and Fuel Flow Data per EPA requirements.

ASTM D 3588

Molecular Weight of NOx (lb/lb-mole) =	46.01
Molecular Weight of CO (lb/lb-mole) =	28.00
Molecular Weight of SO2 (lb/lb-mole) =	64.00
Molecular Weight of THC (propane) (lb/lb-mole) =	44.00
Molecular Weight of VOC (methane) (lb/lb-mole) =	16.00
Molecular Weight of NH3 (lb/lb-mole) =	17.03
Molecular Weight of HCHO (lb/lb-mole) =	30.03

40CFR60, App. A., RM 19, Table 19-1

Conversion Constant for NOx =	0.0000001194351
Conversion Constant for CO =	0.0000000726839
Conversion Constant for SO2 =	0.0000001661345
Conversion Constant for THC =	0.0000001142175
Conversion Constant for VOC (methane) =	0.0000000415336
Conversion Constant for NH ₃ =	0.0000000442074
Conversion Constant for HCHO =	0.0000000779534

NOTE: units are lb/ppm*ft³

Formulas:

1. Corrected Raw Average (C_{Gas}), 40CFR60, App. A, RM 7E, Eq. 7E-5 (08/15/06)

$$C_{Gas} = (C_{Avg} - C_O) \times \left(\frac{C_{MA}}{C_M - C_O} \right)$$

2. Correction to % O₂, 40CFR60, App. A, RM 20, Eq. 20-5 (11/26/02)

$$C_{adj} = C_{Gas(Target)} \times \left(\frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O_2)}} \right)$$

3. Emission Rate in lb/hr

$$E_{lb/hr} = \frac{C_{Gas}}{10^6} \times \frac{Q_S \times MW}{G}$$

4. Emission Concentration in lb/MMBtu (O₂ based)

$$E_{lb/MMBtu} = \frac{C_{Gas} \times F_d \times Factor \times Conv_C \times 20.9\%}{20.9\% - C_{Gas(O_2)}}$$

5. Emission Concentration in lb/MMBtu (CO₂ based)

$$E_{lb/MMBtu} = \frac{C_{Gas} \times F_c \times Factor \times Conv_C \times 100\%}{C_{Gas(CO_2)}}$$

Fibrominn, LLC
July 3, 2007
Biomass Boiler, Unit #Inlet
Fibrominn Biomass Power Plant

Fuel Data

Fuel F _c factor	1,890	SCF/MMBtu
Fuel Heating Value (HHV)	4,334	Btu/lb

Weather Data

Barometric Pressure	29.43	in. Hg
Relative Humidity	71	%
Ambient Temperature	81	° F
Specific Humidity	0.016438	lb H ₂ O / lb air

Unit Data

Gross Unit Load	61.3	gross MW
Heat Input	784	MMBtu/hr
Steam Rate	487,155	Steam lb/hr
Meas. Stack Moisture	18.5	%
Stack Exhaust Flow (M2)	8,106,276	SCFH

High Load, Run - In-1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	SO ₂ (ppmvd)	
07/03/07 17:58:14	28680	4.22	322.95	10.0
07/03/07 17:58:44	28710	4.83	329.00	
07/03/07 17:59:14	28740	4.75	322.83	
07/03/07 17:59:44	28770	4.00	331.78	
07/03/07 18:00:14	28800	5.28	348.50	
07/03/07 18:00:44	28830	5.91	293.31	
07/03/07 18:01:14	28860	5.17	294.52	
07/03/07 18:01:44	28890	3.74	335.30	
07/03/07 18:02:14	28920	5.91	328.43	
07/03/07 18:02:44	28950	4.27	311.55	
07/03/07 18:03:14	28980	5.92	334.07	
07/03/07 18:03:44	29010	5.60	278.88	
07/03/07 18:04:14	29040	5.02	300.43	
07/03/07 18:04:44	29070	5.48	307.97	
07/03/07 18:05:14	29100	4.19	322.32	
07/03/07 18:05:44	29130	6.06	316.55	
07/03/07 18:06:14	29160	6.30	287.00	
07/03/07 18:06:44	29190	4.51	287.62	
07/03/07 18:07:14	29220	5.87	314.81	
07/03/07 18:07:44	29250	5.46	288.67	
07/03/07 18:08:14	29280	4.77	331.95	
07/03/07 18:08:44	29310	4.97	325.51	
07/03/07 18:09:14	29340	5.56	307.35	
07/03/07 18:09:44	29370	4.75	309.81	
07/03/07 18:10:14	29400	5.53	318.32	
07/03/07 18:10:44	29430	4.80	301.40	
07/03/07 18:11:14	29460	4.97	333.97	
07/03/07 18:11:44	29490	4.79	330.59	
07/03/07 18:12:14	29520	5.43	338.35	
07/03/07 18:12:44	29550	5.23	293.69	
07/03/07 18:13:14	29580	5.40	336.12	
07/03/07 18:13:44	29610	3.87	332.09	
07/03/07 18:14:14	29640	4.49	363.05	
07/03/07 18:14:44	29670	5.01	328.10	
07/03/07 18:15:14	29700	5.01	343.08	
07/03/07 18:15:44	29730	5.75	319.25	
07/03/07 18:16:14	29760	7.00	267.94	
07/03/07 18:16:44	29790	3.68	324.38	
07/03/07 18:17:14	29820	4.96	351.88	
07/03/07 18:17:44	29850	4.90	317.52	
07/03/07 18:18:14	29880	4.81	314.14	
07/03/07 18:18:44	29910	4.87	313.50	
07/03/07 18:19:14	29940	4.90	312.65	
07/03/07 18:19:44	29970	4.89	311.13	
07/03/07 18:20:14	30000	4.91	310.46	
07/03/07 18:20:44	30030	4.98	308.95	
07/03/07 18:21:14	30060	5.01	306.85	
07/03/07 18:21:44	30090	4.99	304.46	
07/03/07 18:22:14	30120	5.01	301.66	
07/03/07 18:22:44	30150	5.10	298.18	
07/03/07 18:23:14	30180	5.77	294.66	

Fibrominn, LLC
July 3, 2007
Biomass Boiler, Unit #Inlet
Fibrominn Biomass Power Plant

Fuel Data

Fuel F _c factor	1,890	SCF/MMBtu
Fuel Heating Value (HHV)	4,334	Btu/lb

Weather Data

Barometric Pressure	29.43	in. Hg
Relative Humidity	71	%
Ambient Temperature	81	° F
Specific Humidity	0.016438	lb H ₂ O / lb air

Unit Data

Gross Unit Load	61.3	gross MW
Heat Input	784	MMBtu/hr
Steam Rate	487,155	Steam lb/hr
Meas. Stack Moisture	18.5	%
Stack Exhaust Flow (M2)	8,106,276	SCFH

High Load, Run - In-1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	SO ₂ (ppmvd)
07/03/07 18:23:44	30210	7.74	290.64
07/03/07 18:24:14	30240	5.91	326.02
07/03/07 18:24:44	30270	4.68	329.93
07/03/07 18:25:14	30300	4.54	272.92
07/03/07 18:25:44	30330	5.94	326.91
07/03/07 18:26:14	30360	5.71	295.93
07/03/07 18:26:44	30390	4.39	323.82
07/03/07 18:27:14	30420	6.00	335.20
07/03/07 18:27:44	30450	5.09	310.22
07/03/07 18:28:14	30480	5.53	327.89
07/03/07 18:28:44	30510	5.23	308.75
07/03/07 18:29:14	30540	3.94	360.55
07/03/07 18:29:44	30570	4.66	380.12
07/03/07 18:30:14	30600	5.78	327.27
07/03/07 18:30:44	30630	5.26	330.88
07/03/07 18:31:14	30660	4.56	334.65
07/03/07 18:31:44	30690	3.80	369.96
07/03/07 18:32:14	30720	5.67	338.72
07/03/07 18:32:44	30750	3.90	411.86
07/03/07 18:33:14	30780	5.93	406.72
07/03/07 18:33:44	30810	5.95	405.92
07/03/07 18:34:14	30840	5.97	405.88
07/03/07 18:34:44	30870	5.96	405.39
07/03/07 18:35:14	30900	5.94	404.61
07/03/07 18:35:44	30930	5.92	403.58
07/03/07 18:36:14	30960	5.89	402.87
07/03/07 18:36:44	30990	5.90	402.17
07/03/07 18:37:14	31020	5.87	401.62
07/03/07 18:37:44	31050	4.19	389.58
07/03/07 18:38:14	31080	5.79	341.06
07/03/07 18:38:44	31110	5.88	258.70
07/03/07 18:39:14	31140	4.36	307.95
07/03/07 18:39:44	31170	6.41	335.22
07/03/07 18:40:14	31200	6.89	262.66
07/03/07 18:40:44	31230	4.59	307.47
07/03/07 18:41:14	31260	5.67	317.61
07/03/07 18:41:44	31290	4.72	307.69
07/03/07 18:42:14	31320	6.07	309.01
07/03/07 18:42:44	31350	5.70	299.92
07/03/07 18:43:14	31380	4.18	321.70
07/03/07 18:43:44	31410	5.01	346.16
07/03/07 18:44:14	31440	7.96	305.12
07/03/07 18:44:44	31470	4.05	306.65
07/03/07 18:45:14	31500	3.99	381.63
07/03/07 18:45:44	31530	4.46	374.84
07/03/07 18:46:14	31560	4.69	372.97
07/03/07 18:46:44	31590	4.70	371.67
07/03/07 18:47:14	31620	4.68	370.61
07/03/07 18:47:44	31650	4.67	369.47
07/03/07 18:48:14	31680	4.64	368.02
07/03/07 18:48:44	31710	4.63	366.09

Fibrominn, LLC
July 3, 2007
Biomass Boiler, Unit #Inlet
Fibrominn Biomass Power Plant

Fuel Data

Fuel F _c factor	1,890	SCF/MMBtu
Fuel Heating Value (HHV)	4,334	Btu/lb

Weather Data

Barometric Pressure	29.43	in. Hg
Relative Humidity	71	%
Ambient Temperature	81	° F
Specific Humidity	0.016438	lb H ₂ O / lb air

Unit Data

Gross Unit Load	61.3	gross MW
Heat Input	784	MMBtu/hr
Steam Rate	487,155	Steam lb/hr
Meas. Stack Moisture	18.5	%
Stack Exhaust Flow (M2)	8,106,276	SCFH

High Load, Run - In-1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	SO ₂ (ppmvd)	
07/03/07 18:49:14	31740	4.59	363.77	
07/03/07 18:49:44	31770	4.52	360.96	
07/03/07 18:50:14	31800	4.48	357.30	
07/03/07 18:50:44	31830	4.45	353.30	
07/03/07 18:51:14	31860	4.43	349.16	
07/03/07 18:51:44	31890	4.40	345.12	
07/03/07 18:52:14	31920	5.67	317.04	
07/03/07 18:52:44	31950	6.07	258.91	
07/03/07 18:53:14	31980	4.92	240.33	
07/03/07 18:53:44	32010	4.85	315.52	
07/03/07 18:54:14	32040	5.49	314.64	
07/03/07 18:54:44	32070	4.99	337.32	
07/03/07 18:55:14	32100	5.42	299.36	
07/03/07 18:55:44	32130	5.80	334.11	
07/03/07 18:56:14	32160	4.92	309.52	
07/03/07 18:56:44	32190	5.36	329.71	
07/03/07 18:57:14	32220	5.37	298.96	
07/03/07 18:57:44	32250	4.92	353.35	
RAW AVERAGE		5.16	329.82	327.96
		O₂	SO₂	SO₂
	Serial Number:	INST-O2-0008	205246	
		(%)	(ppmvd)	
	Initial Zero	-0.09	3.08	
	Final Zero	-0.01	4.87	
	Avg. Zero	-0.05	3.98	
Bias	Initial UpScale	11.94	249.73	
	Final UpScale	11.82	244.39	
	Avg. UpScale	11.88	247.06	
Upscale Cal Gas		12.00	252.00	

EMISSIONS DATA	O ₂	SO ₂	SO _{2 GEO}
Corrected Raw Average (ppm/% dry basis)	5.24	337.80	335.87

Fibrominn, LLC
July 3, 2007
Biomass Boiler, Unit #Inlet
Fibrominn Biomass Power Plant

Fuel Data

Fuel F _c factor	1,890	SCF/MMBtu
Fuel Heating Value (HHV)	4,334	Btu/lb

Weather Data

Barometric Pressure	29.44	in. Hg
Relative Humidity	72	%
Ambient Temperature	78	° F
Specific Humidity	0.014868	lb H ₂ O / lb air

Unit Data

Gross Unit Load	61.8	gross MW
Heat Input	774	MMBtu/hr
Steam Rate	487,320	Steam lb/hr
Meas. Stack Moisture	23.0	%
Stack Exhaust Flow (M2)	8,438,795	SCFH

High Load, Run - In-2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	SO ₂ (ppmvd)
07/03/07 19:40:14	34800	4.28	412.07
07/03/07 19:40:44	34830	4.39	343.07
07/03/07 19:41:14	34860	4.74	362.91
07/03/07 19:41:44	34890	4.79	349.73
07/03/07 19:42:14	34920	5.20	316.86
07/03/07 19:42:44	34950	3.11	381.51
07/03/07 19:43:14	34980	6.43	363.20
07/03/07 19:43:44	35010	4.81	299.96
07/03/07 19:44:14	35040	4.00	344.81
07/03/07 19:44:44	35070	3.96	345.32
07/03/07 19:45:14	35100	4.26	386.80
07/03/07 19:45:44	35130	4.88	351.88
07/03/07 19:46:14	35160	3.94	340.14
07/03/07 19:46:44	35190	5.34	342.57
07/03/07 19:47:14	35220	5.77	306.91
07/03/07 19:47:44	35250	3.72	334.76
07/03/07 19:48:14	35280	4.27	357.73
07/03/07 19:48:44	35310	4.31	356.21
07/03/07 19:49:14	35340	3.39	369.91
07/03/07 19:49:44	35370	4.85	376.44
07/03/07 19:50:14	35400	6.08	318.27
07/03/07 19:50:44	35430	4.63	294.95
07/03/07 19:51:14	35460	4.52	340.47
07/03/07 19:51:44	35490	3.43	342.49
07/03/07 19:52:14	35520	3.74	395.34
07/03/07 19:52:44	35550	4.61	354.13
07/03/07 19:53:14	35580	3.95	354.33
07/03/07 19:53:44	35610	3.69	381.58
07/03/07 19:54:14	35640	5.16	349.95
07/03/07 19:54:44	35670	5.11	318.80
07/03/07 19:55:14	35700	3.46	339.06
07/03/07 19:55:44	35730	4.94	375.80
07/03/07 19:56:14	35760	3.77	352.41
07/03/07 19:56:44	35790	4.35	362.51
07/03/07 19:57:14	35820	5.39	327.48
07/03/07 19:57:44	35850	3.56	358.81
07/03/07 19:58:14	35880	5.25	333.90
07/03/07 19:58:44	35910	4.88	320.47
07/03/07 19:59:14	35940	4.90	320.25
07/03/07 19:59:44	35970	4.92	319.43
07/03/07 20:00:14	36000	4.91	317.95
07/03/07 20:00:44	36030	4.91	317.57
07/03/07 20:01:14	36060	4.91	316.49
07/03/07 20:01:44	36090	4.93	315.63
07/03/07 20:02:14	36120	4.93	314.21
07/03/07 20:02:44	36150	4.95	313.82
07/03/07 20:03:14	36180	4.95	313.01
07/03/07 20:03:44	36210	4.92	312.24
07/03/07 20:04:14	36240	4.93	311.23
07/03/07 20:04:44	36270	4.95	310.21
07/03/07 20:05:14	36300	4.95	308.86

Fibrominn, LLC
July 3, 2007
Biomass Boiler, Unit #Inlet
Fibrominn Biomass Power Plant

Fuel Data

Fuel F _c factor	1,890	SCF/MMBtu
Fuel Heating Value (HHV)	4,334	Btu/lb

Weather Data

Barometric Pressure	29.44	in. Hg
Relative Humidity	72	%
Ambient Temperature	78	° F
Specific Humidity	0.014868	lb H ₂ O / lb air

Unit Data

Gross Unit Load	61.8	gross MW
Heat Input	774	MMBtu/hr
Steam Rate	487,320	Steam lb/hr
Meas. Stack Moisture	23.0	%
Stack Exhaust Flow (M2)	8,438,795	SCFH

High Load, Run - In-2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	SO ₂ (ppmvd)
07/03/07 20:05:44	36330	4.93	307.69
07/03/07 20:06:14	36360	4.93	306.25
07/03/07 20:06:44	36390	4.94	304.46
07/03/07 20:07:14	36420	4.93	302.43
07/03/07 20:07:44	36450	4.91	300.71
07/03/07 20:08:14	36480	4.89	298.53
07/03/07 20:08:44	36510	4.90	296.58
07/03/07 20:09:14	36540	4.96	293.96
07/03/07 20:09:44	36570	5.34	291.35
07/03/07 20:10:14	36600	6.32	288.32
07/03/07 20:10:44	36630	7.95	285.92
07/03/07 20:11:14	36660	9.80	283.20
07/03/07 20:11:44	36690	11.57	279.80
07/03/07 20:12:14	36720	13.17	276.49
07/03/07 20:12:44	36750	14.57	273.17
07/03/07 20:13:14	36780	15.68	269.51
07/03/07 20:13:44	36810	16.54	265.45
07/03/07 20:14:14	36840	17.23	261.91
07/03/07 20:14:44	36870	14.95	267.44
07/03/07 20:15:14	36900	4.53	329.73
07/03/07 20:15:44	36930	4.25	284.89
07/03/07 20:16:14	36960	3.57	318.39
07/03/07 20:16:44	36990	3.39	386.78
07/03/07 20:17:14	37020	5.92	322.03
07/03/07 20:17:44	37050	3.88	308.23
07/03/07 20:18:14	37080	4.88	322.68
07/03/07 20:18:44	37110	2.98	352.17
07/03/07 20:19:14	37140	2.64	377.30
07/03/07 20:19:44	37170	2.64	375.07
07/03/07 20:20:14	37200	2.64	372.42
07/03/07 20:20:44	37230	2.63	370.85
07/03/07 20:21:14	37260	2.64	369.24
07/03/07 20:21:44	37290	2.60	367.59
07/03/07 20:22:14	37320	2.61	366.12
07/03/07 20:22:44	37350	2.66	364.99
07/03/07 20:23:14	37380	2.67	363.59
07/03/07 20:23:44	37410	2.68	362.16
07/03/07 20:24:14	37440	2.80	363.03
07/03/07 20:24:44	37470	4.72	334.19
07/03/07 20:25:14	37500	5.24	264.25
07/03/07 20:25:44	37530	4.95	267.59
07/03/07 20:26:14	37560	4.90	281.87
07/03/07 20:26:44	37590	3.97	313.82
07/03/07 20:27:14	37620	3.00	378.39
07/03/07 20:27:44	37650	3.79	410.45
07/03/07 20:28:14	37680	4.95	321.24
07/03/07 20:28:44	37710	5.45	318.39
07/03/07 20:29:14	37740	3.79	317.52
07/03/07 20:29:44	37770	4.02	348.67
07/03/07 20:30:14	37800	3.57	348.64
07/03/07 20:30:44	37830	4.51	394.31

Fibrominn, LLC
July 3, 2007
Biomass Boiler, Unit #Inlet
Fibrominn Biomass Power Plant

Fuel Data

Fuel F _c factor	1,890	SCF/MMBtu
Fuel Heating Value (HHV)	4,334	Btu/lb

Weather Data

Barometric Pressure	29.44	in. Hg
Relative Humidity	72	%
Ambient Temperature	78	° F
Specific Humidity	0.014868	lb H ₂ O / lb air

Unit Data

Gross Unit Load	61.8	gross MW
Heat Input	774	MMBtu/hr
Steam Rate	487,320	Steam lb/hr
Meas. Stack Moisture	23.0	%
Stack Exhaust Flow (M2)	8,438,795	SCFH

High Load, Run - In-2

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	SO ₂ (ppmvd)	
07/03/07 20:31:14	37860	3.87	335.11	
07/03/07 20:31:44	37890	5.57	346.11	
07/03/07 20:32:14	37920	4.02	318.41	
07/03/07 20:32:44	37950	4.42	352.90	
07/03/07 20:33:14	37980	3.78	358.05	
07/03/07 20:33:44	38010	6.95	317.25	
07/03/07 20:34:14	38040	4.30	293.00	
07/03/07 20:34:44	38070	3.82	350.14	
07/03/07 20:35:14	38100	5.34	318.18	
07/03/07 20:35:44	38130	3.93	331.18	
07/03/07 20:36:14	38160	4.96	369.53	
07/03/07 20:36:44	38190	4.89	306.52	
07/03/07 20:37:14	38220	4.25	369.27	
07/03/07 20:37:44	38250	4.78	345.68	
07/03/07 20:38:14	38280	5.97	319.39	
07/03/07 20:38:44	38310	6.00	318.22	
07/03/07 20:39:14	38340	6.01	317.96	
07/03/07 20:39:44	38370	6.01	317.55	
RAW AVERAGE		5.13	331.41	329.68
		O₂	SO₂	SO₂
	Serial Number:	INST-O2-0008	205246	
		(%)	(ppmvd)	
	Initial Zero	-0.01	4.87	
	Final Zero	-0.01	5.26	
	Avg. Zero	-0.01	5.07	
Bias	Initial UpScale	11.82	244.39	
	Final UpScale	11.82	252.63	
	Avg. UpScale	11.82	248.51	
Upscale Cal Gas		12.00	252.00	

EMISSIONS DATA	O ₂	SO ₂	SO _{2 GEO}
Corrected Raw Average (ppm/% dry basis)	5.22	337.81	336.02

Fibrominn, LLC
July 3, 2007
Biomass Boiler, Unit #Inlet
Fibrominn Biomass Power Plant

Fuel Data

Fuel F _c factor	1,890	SCF/MMBtu
Fuel Heating Value (HHV)	4,334	Btu/lb

Weather Data

Barometric Pressure	29.46	in. Hg
Relative Humidity	71	%
Ambient Temperature	77	° F
Specific Humidity	0.014450	lb H ₂ O / lb air

Unit Data

Gross Unit Load	62.8	gross MW
Heat Input	778	MMBtu/hr
Steam Rate	490,767	Steam lb/hr
Meas. Stack Moisture	9.5	%
Stack Exhaust Flow (M2)	10,329,857	SCFH

High Load, Run - In-3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	SO ₂ (ppmvd)
07/03/07 21:39:14	41940	4.41	373.46
07/03/07 21:39:44	41970	4.05	385.89
07/03/07 21:40:14	42000	6.09	327.38
07/03/07 21:40:44	42030	5.11	299.25
07/03/07 21:41:14	42060	2.87	412.30
07/03/07 21:41:44	42090	3.18	442.25
07/03/07 21:42:14	42120	4.47	423.52
07/03/07 21:42:44	42150	2.14	517.68
07/03/07 21:43:14	42180	5.76	482.30
07/03/07 21:43:44	42210	3.62	378.29
07/03/07 21:44:14	42240	4.43	425.48
07/03/07 21:44:44	42270	3.52	378.98
07/03/07 21:45:14	42300	3.37	437.57
07/03/07 21:45:44	42330	4.03	395.30
07/03/07 21:46:14	42360	4.57	425.28
07/03/07 21:46:44	42390	5.94	399.11
07/03/07 21:47:14	42420	6.00	399.28
07/03/07 21:47:44	42450	6.01	399.75
07/03/07 21:48:14	42480	5.99	399.46
07/03/07 21:48:44	42510	6.00	398.39
07/03/07 21:49:14	42540	5.97	397.65
07/03/07 21:49:44	42570	5.91	396.87
07/03/07 21:50:14	42600	6.07	375.63
07/03/07 21:50:44	42630	4.16	309.75
07/03/07 21:51:14	42660	3.81	307.43
07/03/07 21:51:44	42690	4.45	361.92
07/03/07 21:52:14	42720	4.75	329.31
07/03/07 21:52:44	42750	4.88	344.55
07/03/07 21:53:14	42780	3.09	375.48
07/03/07 21:53:44	42810	2.65	497.55
07/03/07 21:54:14	42840	4.39	417.23
07/03/07 21:54:44	42870	3.75	390.23
07/03/07 21:55:14	42900	4.11	389.46
07/03/07 21:55:44	42930	4.68	356.07
07/03/07 21:56:14	42960	4.31	360.03
07/03/07 21:56:44	42990	4.38	359.94
07/03/07 21:57:14	43020	4.38	358.20
07/03/07 21:57:44	43050	4.41	357.37
07/03/07 21:58:14	43080	4.42	356.45
07/03/07 21:58:44	43110	4.45	355.29
07/03/07 21:59:14	43140	4.47	354.30
07/03/07 21:59:44	43170	4.47	353.05
07/03/07 22:00:14	43200	4.49	351.54
07/03/07 22:00:44	43230	4.49	349.68
07/03/07 22:01:14	43260	4.50	347.21
07/03/07 22:01:44	43290	4.26	351.58
07/03/07 22:02:14	43320	4.72	312.16
07/03/07 22:02:44	43350	3.74	299.00
07/03/07 22:03:14	43380	5.25	316.04
07/03/07 22:03:44	43410	5.37	306.68
07/03/07 22:04:14	43440	4.92	310.70

Fibrominn, LLC
July 3, 2007
Biomass Boiler, Unit #Inlet
Fibrominn Biomass Power Plant

Fuel Data

Fuel F _c factor	1,890	SCF/MMBtu
Fuel Heating Value (HHV)	4,334	Btu/lb

Weather Data

Barometric Pressure	29.46	in. Hg
Relative Humidity	71	%
Ambient Temperature	77	° F
Specific Humidity	0.014450	lb H ₂ O / lb air

Unit Data

Gross Unit Load	62.8	gross MW
Heat Input	778	MMBtu/hr
Steam Rate	490,767	Steam lb/hr
Meas. Stack Moisture	9.5	%
Stack Exhaust Flow (M2)	10,329,857	SCFH

High Load, Run - In-3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	SO ₂ (ppmvd)
07/03/07 22:04:44	43470	5.71	332.46
07/03/07 22:05:14	43500	6.71	263.43
07/03/07 22:05:44	43530	5.54	272.32
07/03/07 22:06:14	43560	5.13	325.74
07/03/07 22:06:44	43590	4.30	318.49
07/03/07 22:07:14	43620	5.53	360.41
07/03/07 22:07:44	43650	4.90	316.95
07/03/07 22:08:14	43680	5.45	320.06
07/03/07 22:08:44	43710	5.01	322.07
07/03/07 22:09:14	43740	5.48	331.36
07/03/07 22:09:44	43770	6.67	275.79
07/03/07 22:10:14	43800	3.36	363.47
07/03/07 22:10:44	43830	5.20	360.95
07/03/07 22:11:14	43860	7.08	306.84
07/03/07 22:11:44	43890	6.74	242.61
07/03/07 22:12:14	43920	4.70	295.82
07/03/07 22:12:44	43950	5.63	308.33
07/03/07 22:13:14	43980	4.70	310.82
07/03/07 22:13:44	44010	6.72	299.24
07/03/07 22:14:14	44040	5.48	277.71
07/03/07 22:14:44	44070	4.86	294.20
07/03/07 22:15:14	44100	4.42	303.93
07/03/07 22:15:44	44130	4.47	301.84
07/03/07 22:16:14	44160	4.47	300.20
07/03/07 22:16:44	44190	4.44	298.79
07/03/07 22:17:14	44220	4.43	297.61
07/03/07 22:17:44	44250	4.42	296.73
07/03/07 22:18:14	44280	4.41	295.70
07/03/07 22:18:44	44310	4.41	294.23
07/03/07 22:19:14	44340	4.40	293.29
07/03/07 22:19:44	44370	4.42	292.23
07/03/07 22:20:14	44400	4.41	291.23
07/03/07 22:20:44	44430	5.61	289.80
07/03/07 22:21:14	44460	6.99	233.98
07/03/07 22:21:44	44490	5.55	234.88
07/03/07 22:22:14	44520	5.59	286.85
07/03/07 22:22:44	44550	5.23	298.93
07/03/07 22:23:14	44580	4.99	321.50
07/03/07 22:23:44	44610	7.04	292.93
07/03/07 22:24:14	44640	5.44	285.00
07/03/07 22:24:44	44670	5.28	321.59
07/03/07 22:25:14	44700	5.58	306.73
07/03/07 22:25:44	44730	4.25	373.84
07/03/07 22:26:14	44760	5.45	331.92
07/03/07 22:26:44	44790	6.21	348.41
07/03/07 22:27:14	44820	6.34	273.59
07/03/07 22:27:44	44850	3.83	332.36
07/03/07 22:28:14	44880	3.69	340.51
07/03/07 22:28:44	44910	3.68	336.47
07/03/07 22:29:14	44940	3.68	334.11
07/03/07 22:29:44	44970	3.74	332.52

Fibrominn, LLC
July 3, 2007
Biomass Boiler, Unit #Inlet
Fibrominn Biomass Power Plant

Fuel Data

Fuel F _c factor	1,890	SCF/MMBtu
Fuel Heating Value (HHV)	4,334	Btu/lb

Weather Data

Barometric Pressure	29.46	in. Hg
Relative Humidity	71	%
Ambient Temperature	77	° F
Specific Humidity	0.014450	lb H ₂ O / lb air

Unit Data

Gross Unit Load	62.8	gross MW
Heat Input	778	MMBtu/hr
Steam Rate	490,767	Steam lb/hr
Meas. Stack Moisture	9.5	%
Stack Exhaust Flow (M2)	10,329,857	SCFH

High Load, Run - In-3

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	SO ₂ (ppmvd)	
07/03/07 22:30:14	45000	3.75	330.59	
07/03/07 22:30:44	45030	3.76	328.55	
07/03/07 22:31:14	45060	3.77	326.56	
07/03/07 22:31:44	45090	3.75	324.62	
07/03/07 22:32:14	45120	3.76	322.93	
07/03/07 22:32:44	45150	3.77	321.17	
07/03/07 22:33:14	45180	3.78	319.27	
07/03/07 22:33:44	45210	3.82	317.43	
07/03/07 22:34:14	45240	3.83	316.30	
07/03/07 22:34:44	45270	5.94	325.87	
07/03/07 22:35:14	45300	6.71	236.50	
07/03/07 22:35:44	45330	6.64	235.88	
07/03/07 22:36:14	45360	6.63	248.23	
07/03/07 22:36:44	45390	4.91	281.76	
07/03/07 22:37:14	45420	3.78	370.23	
07/03/07 22:37:44	45450	4.34	384.65	
07/03/07 22:38:14	45480	3.73	460.66	
07/03/07 22:38:44	45510	6.53	333.77	
RAW AVERAGE		4.80	338.12	334.11

**Calcs by
Geo Mean**

	O ₂ (%)	SO ₂ (ppmvd)	SO ₂
Serial Number: INST-O2-0008		205246	
Initial Zero	-0.01	5.26	
Final Zero	-0.03	5.83	
Avg. Zero	-0.02	5.55	
Initial UpScale	11.82	252.63	
Final UpScale	11.82	259.55	
Avg. UpScale	11.82	256.09	
Upscale Cal Gas	12.00	252.00	

EMISSIONS DATA	O ₂	SO ₂	SO _{2 GEO}
Corrected Raw Average (ppm/% dry basis)	4.89	334.51	330.47

TEST RESULTS AND CALCULATIONS

HCl Emissions Data



Air Hygiene International, Inc.
5634 S. 122nd East Ave, Suite F
Tulsa, Oklahoma 74146
(888) 461-8778
www.airhygiene.com

HCl ANALYSIS

PARAMETER	UNITS	RUN			
		1	2	3	BLANK
Sample Number		IN-HCl-1	IN-HCl-2	IN-HCl-3	Blank
Lab Log Number		070307-OUT-HCl1	070307-OUT-HCl2	070307-OUT-HCl3	070307-OUT-HCl4
Concentration of Sample (S_x or B_x)	(mg Cl ⁻ /L)	16	46.5	38.2	0.521
Sample Volume (V_{HCl})	(ml)	725	725	715	N/A
DGM Volume (V_m) _{dscf}	(dscf)	51.775	50.100	54.524	N/A
DGM Volume (V_m) _{dstdL}	(L _{dstd})	1466.09	1418.66	1543.95	N/A
Sum of HCl Ion (N)	(mg/L)	15.912	47.266	38.734	N/A
Volume of HCl (V_a)	(L)	0.00709	0.02105	0.01701	N/A
HCl Concentration (C_{HCl})	(ppmvd)	4.834	14.840	11.020	N/A

Equations & Constants:

Example Using Data from the 1st run

DGM Volume (L_{dstd})

$$(V_m)_{dstdL} (L_{dstd}) = (V_m)_{dscf} \times 28.31685$$

$$(V_m)_{dstdL} (L_{dstd}) = 51.775 \text{ dscf} \times 28.31685 \text{ L/ft}^3 = 1466.09 \text{ L}_{dstd}$$

$(V_m)_{dscf}$ = Volume of gas sample measured by the DGM, corrected to standard conditions.

Sum of HCl Ion (mg/L) - modified 40 CFR 60, App A, Eq. 26-4

$$N \text{ (mg/L)} = K_{HCl} (S_x - B_x)$$

$$N \text{ (mg/L)} = \left[\frac{16.0 \text{ mg}}{L} - \frac{0.5 \text{ mg}}{L} \right] \times \frac{1.028 \text{ } \mu\text{g HCl}/\mu\text{g}\cdot\text{mol}}{\mu\text{g Cl}^-/\mu\text{g}\cdot\text{mol}} = \frac{15.9124 \text{ mg}}{L}$$

Total Sample Volume (ml)

$$S \text{ (ml)} = \sum V_{NH_3}$$

$$S \text{ (ml)} = 725 \text{ ml}$$

K_{HCl} = Equation 26-4 conversion constant

MW = molecular weight (ref. ASTM D 3588)

Volume of HCl (L)

$$V_a \text{ (L)} = \frac{N \times S}{1000} \times 22.4$$

$$V_a \text{ (L)} = \frac{15.9124 \text{ mg}}{36.46094 \text{ g}} \times \frac{725 \text{ ml}}{1000 \text{ ml}} \times \frac{22.4 \text{ L ideal gas}}{\text{g-mol substance}} \times \frac{\text{g-mol HCl}}{36.46094 \text{ g}} \times \frac{\text{g}}{1000 \text{ mg}} = 0.00709 \text{ L}$$

HCl Concentration (ppmvd)

$$C_{HCl} \text{ (ppmvd)} = \frac{V_a}{(V_m)_{dstdL}} \times 10^6$$

$$C_{HCl} \text{ (ppmvd)} = \frac{0.00709 \text{ L}}{1466.09 \text{ L}_{dstd}} \times \frac{10^6 \text{ parts}}{1 \text{ part}} = 4.834 \text{ ppmvd}$$

22.4 = liters of ideal gas per mol of substance at 0°C and 1 atm (ref. Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg)

METHOD 26A (HYDROGEN CHLORIDE) - RESULTS

Plant Name	Fibrominn Biomass Power Plant	Date	07/03/07
Sampling Location	Stack Outlet	Project #	snc-07-benson.mn-comp#1
Operator	TG	Stack Type	Circular

Historical Data						
Run Number		OUT-HCl-1	OUT-HCl-2	OUT-HCl-3	Average	
Run Start Time		17:58	19:40	21:39		hh:mm
Run Stop Time		18:58	20:40	22:39		hh:mm
Meter Calibration Factor	(Y)	1.002	1.002	1.002		
Pitot Tube Coefficient	(C _p)	0.840	0.840	0.840		
Average Nozzle Diameter	(D _{na})	0.247	0.247	0.247		in
Stack Test Data						
Initial Meter Volume	(V _m) _i	259.650	313.260	365.350		ft3
Final Meter Volume	(V _m) _f	312.930	364.940	421.450		ft3
Total Meter Volume	(V _m)	53.280	51.680	56.100	53.687	ft3
Total Sampling Time	(θ)	60.0	60.0	60.0	60.0	min
Average Meter Temperature	(t _m) _{avg}	79.4	80.5	79.8	79.9	oF
Average Stack Temperature	(t _s) _{avg}	297.3	292.8	299.3	296.4	oF
Barometric Pressure	(P _b)	29.43	29.44	29.46	29.44	in Hg
Stack Static Pressure	(P _{static})	-0.23	-0.23	-0.23	-0.23	in H ₂ O
Absolute Stack Pressure	(P _s)	29.41	29.42	29.44	29.43	in Hg
Average Orifice Pressure Drop	(ΔH) _{avg}	2.88	2.63	2.87	2.79	in H ₂ O
Absolute Meter Pressure	(P _m)	29.56	29.57	29.59	29.58	in Hg
Avg Square Root Pitot Pressure	($\Delta p^{1/2}$) _{avg}	1.26	1.21	1.26	1.24	(in H ₂ O) ^{1/2}
Moisture Content Data						
Impingers 1-3 Water Volume Gain	(V _n)	362.0	359.3	369.7	363.7	ml
Impinger 4 Silica Gel Weight Gain	(W _n)	18.6	14.2	14.8	15.9	g
Total Water Volume Collected	(V _{ic})	380.6	373.6	384.5	379.5	ml
Standard Water Vapor Volume	(V _w) _{std}	17.914	17.584	18.098	17.865	scf
Standard Meter Volume	(V _m) _{std}	51.775	50.100	54.524	52.133	dscf
Calculated Stack Moisture	(B _{ws(calc)})	25.71	25.98	24.92	25.53	%
Saturated Stack Moisture	(B _{ws(svp)})	100.0	100.0	100.0	100.0	%
Reported Stack Moisture Content	(B _{ws})	25.71	25.98	24.92	25.53	%
Gas Analysis Data						
Carbon Dioxide Percentage	(%CO ₂)	14.5	14.9	14.3	14.5	%
Oxygen Percentage	(%O ₂)	5.3	4.9	5.5	5.2	%
Carbon Monoxide Percentage	(%CO)	0.0	0.0	0.0	0.0	%
Nitrogen Percentage	(%N ₂)	80.2	80.2	80.2	80.2	%
Dry Gas Molecular Weight	(M _d)	30.53	30.57	30.50	30.53	lb/lb-mole
Wet Stack Gas Molecular Weight	(M _s)	27.31	27.31	27.39	27.33	lb/lb-mole
Calculated Fuel Factor	(F _o)	1.073	1.075	1.078	1.075	
Fuel F-Factor	(F _c)	1890	1890	1890	1890	dscf/MMBtu
Percent Excess Air	(%EA)	33.7	29.9	35.0	32.9	%
Volumetric Flow Rate Data						
Average Stack Gas Velocity	(v _s)	87.95	84.21	87.58	86.58	ft/sec
Stack Cross-Sectional Area	(A _s)	63.62	63.62	63.62	63.62	ft ²
Actual Stack Flow Rate	(Q _{aw})	335,696	321,446	334,283	330,475	acfm
Wet Standard Stack Flow Rate	(Q _{sw})	13,806	13,304	13,726	13,612	wkscfh
Dry Standard Stack Flow Rate	(Q _{sd})	170,953	164,129	171,756	168,946	dscfm
Percent of Isokinetic Rate	(I)	96.4	97.2	101.6	98.4	%
HCl Rate Data						
Stack HCl Concentration	(C _{HCl})	4.834	14.840	11.020	10.231	ppm
	(C _{HCl})	4.321	12.879	9.945	9.048	ppm@7%O ₂
HCl Emission Rate	(E _{HCl})	4.69	13.83	10.75	9.76	lbs/hr
	(E _{HCl})	20.44	60.24	46.81	42.5	tons/yr
	(E _{HCl})	0.006	0.018	0.014	0.013	lbs/MMBtu
(Pt 75 App F Sect. 5.2.1) Heat Input	(HI)	784.4	777.0	769.7	777.0	MMBtu/hr

METHOD 26A (HYDROGEN CHLORIDE) SOURCE SAMPLING TITLE PAGE

Source Information				
Plant Name	Fibrominn Biomass Power Plant			
Sampling Location	Stack Outlet			
Fuel or Source Type	Biomass			
Fuel F-Factor	1890	1890	1890	

Test Information				
Starting Test Date		07/03/07		
Project #		snc-07-benson.mn-comp#1		
Operator		TG		
Standard Temperature		68	oF	
Standard Pressure		29.92	in Hg	
Minimum Required Sample Vol.	indust. spec.	35	scf	
Run Duration	chk Subpart	60	minutes	
Unit Number		OUT-HCl		
Load	% or w/DB	100%		
Base Run Number		OUT-HCl		
Number of Ports Available		2		
Number of Ports Used		1		
Port Inside Diameter		5.00	in	
Circular Stack				

Test Equipment Information					
Run		1	2	3	
Meter Box Number	from ACS	SAMP-CP-0016	SAMP-CP-0016	SAMP-CP-0016	
Meter Calibration Factor	(Y)	1.002	1.002	1.002	
Orifice Meter Coefficient	($\Delta H @$)	1.832	1.832	1.832	in H ₂ O
Pitot Identification	from ACS	SAMP-HP-0011	SAMP-HP-0011	SAMP-HP-0011	
Pitot Tube Coefficient	(C _p)	0.840	0.840	0.840	
Orsat Identification	from ACS	N/A	N/A	N/A	
Nozzle Number	from ACS	A-1	A-1	A-1	
Nozzle Diameter	(D _n)	0.247	0.247	0.247	in
Probe Number	from ACS	SAMP-HP-0011	SAMP-HP-0011	SAMP-HP-0011	
Probe Length		60.00	60.00	60.00	in
(SS, Glass) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	SAMP-BH-0027	SAMP-BH-0027	SAMP-BH-0027	
Impinger Case Number	from ACS	SAMP-BC-0021	SAMP-BC-0003	SAMP-BC-0021	


Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	5634 S. 122nd East Ave., Suite F
City, State Country Zip	Tulsa, Oklahoma 74146
Project Manager	Thomas K. Graham
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131

METHOD 1 - SAMPLE AND VELOCITY TRAVERSES FOR CIRCULAR SOURCES

Plant Name	Fibrominn Biomass Power Plant	Date	07/03/07
Sampling Location	Stack Outlet	Project #	snc-07-benson.mn-comp#1
Operator	TG	# of Ports Available	2
Stack Type	Circular	# of Ports Used	1
Stack Size	Large	Port Inside Diameter	5.00

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L _{fw})	129.00	in
Distance to Near Wall of Stack	(L _{nw})	21.00	in
Diameter of Stack	(D)	108.00	in
Area of Stack	(A _s)	63.62	ft ²

Distance from Port to Disturbances			
Distance Upstream	(A)	2358.00	in
Diameters Upstream	(A _D)	21.83	diameters
Distance Downstream	(B)	910.00	in
Diameters Downstream	(B _D)	8.43	diameters



Number of Traverse Points Required			
Diameters to Flow Disturbance		Minimum Number of Traverse Points ^a	
Down Stream	Up Stream	Particulate Points	Velocity Points
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
>= 8.00	>=2.00	8 or 12 ²	8 or 12 ²
Upstream Spec		12	12
Downstream Spec		12	12
Traverse Pts Required		12	12

¹ Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.
² 8 for Circular Stacks 12 to 24 inches
 12 for Circular Stacks over 24 inches

Location of Traverse Points in Circular Stacks									
Traverse Point	(Fraction of Stack Dimension from Inside Wall to Traverse Point)								
Number	Number of Traverse Points Across the Stack								
	2	4	6	8	10	12	14	16	18
1	.146	.067	.044	.032	.026	.021	.018	.016	.014
2	.854	.250	.146	.105	.082	.067	.057	.049	.044
3		.750	.296	.194	.146	.118	.099	.085	.075
4			.933	.704	.323	.226	.177	.146	.125
5				.854	.677	.342	.250	.201	.169
6					.956	.806	.658	.356	.269
7						.895	.774	.644	.366
8							.968	.854	.750
9								.918	.823
10									.974
11									
12									

Number of Traverse Points Used			
1	Ports by	1	Across
1	Pts Used	1	Required
		Particulate Traverse	

Traverse Point Locations			
Traverse Point Number	Fraction of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
		in	in
1	0.50	64 4/8	71 4/8
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			

METHOD 2 - DETERMINATION OF STACK GAS VELOCITY AND VOLUMETRIC FLOW RATE

Plant Name	Fibrominn Biomass Power Plant				Date	06/30/07	
Sampling Location	Stack Outlet				Project #	snc-07-benson.mn-comp#1	
Operator	TG				# of Ports Used	1	
Stack Type	Circular				Pitot Identification	samp-hp-0006	
Pitot Leak Check	<input checked="" type="checkbox"/>	PreTest	<input checked="" type="checkbox"/>	PostTest	Pitot Coefficient (C_p)	0.84	

Stack Dimensions				Velocity Traverse Data				
Diameter or Length of Stack	(D)	108.00	in	Run Number		OUT-HCI-V1		
Width of Stack	(W)		in	Run Time	12:00	Start	12:10	End
Area of Stack	(A _s)	63.62	ft2	Traverse Point	Velocity Head (Δp)	Null Angle (N_a)	Stack Temp (t_s)	Local Velocity (v_{s(i)})

Pressures			
Barometric Pressure	(P _b)	29.92	in Hg
Static Pressure	(P _{static})	-0.23	in H2O
Absolute Stack Pressure	(P _s)	29.90	in Hg

Stack Gas Composition			
Composition Data:		Actual Composition	
Carbon Dioxide Concentration	(%CO ₂)	14.4	%
Oxygen Concentration	(%O ₂)	4.8	%
Carbon Monoxide Concentration	(%CO)	0.0	%
Nitrogen Concentration	(%N ₂)	80.8	%
Stack Moisture Content	(B _{ws})	30.000	%
Stack Dry Molecular Weight	(M _d)	30.50	lb/lb-mole
Stack Wet Molecular Weight	(M _s)	26.75	lb/lb-mole

A-1	1.00	0	291	69.6
A-2	1.30	-10	291	79.3
A-3	1.30	0	290	79.3
A-4	1.10	-5	290	72.9
A-5	1.30	0	290	79.3
A-6	0.14	0	290	26.0
B-1	1.30	0	293	79.4
B-2	1.00	0	293	69.7
B-3	1.20	0	293	76.3
B-4	1.30	0	292	79.4
B-5	1.30	-10	291	79.3
B-6	1.40	-15	290	82.3

Results			
Avg Stack Gas Velocity	(v _s)	72.7	ft/sec
Avg Stack Dry Std Flow Rate	(Q _{sd})	8,192,279	dscf/hr
Avg Stack Dry Std Flow Rate	(Q _{sd})	136,538	dscf/min
Avg Stack Wet Flow Rate	(Q _{aw})	277,654	acf/min
Avg Stack Wet Std Flow Rate	(Q _{sw})	11,703,256	ascf/hr

Stack Cross Section Schematic			

Average	1.14	3	291
	1.05	= Square roots of Δp	

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	Fibrominn Biomass Power Plant				Date	07/03/07	
Sampling Location	Stack Outlet				Project #	snc-07-benson.mn-comp#1	
Operator	TG				# of Ports Used	1	
Fuel Type	Biomass		Minimum Fuel Factor	1.000	Maximum Fuel Factor	1.120	
Orsat Leak Check	<input checked="" type="checkbox"/>	PreTest	<input checked="" type="checkbox"/>	PostTest	Orsat Identification	N/A	

Gas Analysis Data										
Run Number		OUT-HCI-1			Run Start Time		17:58	Run Stop Time		18:58
Sample Analysis Time	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N ₂)	Dry Molecular Weight (M _d)	Molecular Weight Deviation (ΔM _d)	
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole	
1:00	14.5	5.3	229.3	14.5	5.3	0.0	80.2	30.53	0.00	
Results			Averages	14.5	5.3	0.0	80.2	30.53		
Average Calculated Fuel Factor				(F _o) _{avg}	1.073	Molecular Wt Deviation < 0.3?			<input checked="" type="checkbox"/>	
Average Excess Air				(%EA) _{avg}	33.7	percent	Fuel Factor in Handbook Range?			<input checked="" type="checkbox"/>

Gas Analysis Data										
Run Number		OUT-HCI-2			Run Start Time		19:40	Run Stop Time		20:40
Sample Analysis Time	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N ₂)	Dry Molecular Weight (M _d)	Molecular Weight Deviation (ΔM _d)	
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole	
1:00	14.9	4.9	260.1	14.9	4.9	0.0	80.2	30.57	0.00	
Results			Averages	14.9	4.9	0.0	80.2	30.57		
Average Calculated Fuel Factor				(F _o) _{avg}	1.075	Molecular Wt Deviation < 0.3?			<input checked="" type="checkbox"/>	
Average Excess Air				(%EA) _{avg}	29.9	percent	Fuel Factor in Handbook Range?			<input checked="" type="checkbox"/>

Gas Analysis Data										
Run Number		OUT-HCI-3			Run Start Time		21:39	Run Stop Time		22:39
Sample Analysis Time	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N ₂)	Dry Molecular Weight (M _d)	Molecular Weight Deviation (ΔM _d)	
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole	
1:00	14.3	5.5	165.1	14.3	5.5	0.0	80.2	30.50	0.00	
Results			Averages	14.3	5.5	0.0	80.2	30.50		
Average Calculated Fuel Factor				(F _o) _{avg}	1.078	Molecular Wt Deviation < 0.3?			<input checked="" type="checkbox"/>	
Average Excess Air				(%EA) _{avg}	35.0	percent	Fuel Factor in Handbook Range?			<input checked="" type="checkbox"/>

Fuel Factor Fo		
Fuel Type	Minimum	Maximum
Coal, Anthracite	1.016	1.130
Coal, Lignite	1.016	1.130
Coal, Bituminous	1.083	1.230
Oil, Distillate	1.260	1.413
Oil, Residual	1.210	1.370
Gas, Natural	1.600	1.836
Gas, Propane	1.434	1.586
Gas, Butane	1.405	1.553
Biomass	1.000	1.120
Wood Bark	1.003	1.130

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	Fibrominn Biomass Power Plant			Date	07/03/07		
Sampling Location	Stack Outlet			Project #	snc-07-benson.mn-comp#1		
Operator	TG			# of Ports Used	1		
Stack Type	Circular			Meter Box Number	SAMP-CP-0016		
Train Leak Check	<input checked="" type="checkbox"/>	PreTest	<input checked="" type="checkbox"/>	PostTest	Meter Cal Factor (Y)	1.002	

Moisture Content Data							
Run Number	OUT-HCI-1			Run Start Time	17:58	Run Stop Time	18:58
Total Meter Volume	(V _m)	53.280	dcf	Barometric Press.	(P _b)	29.43	in Hg
Avg Stack Temp	(t _s) _{avg}	297	oF	Stack Static Press.	(P _{static})	-0.23	in H2O
Avg Meter Temp	(t _m) _{avg}	79	oF	Avg Orifice Press.	(ΔH) _{avg}	2.88	in H2O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
	g	g	g	g	g	g	g
Contents		H2SO4	H2SO4		Sil Gel		
Final Value	(V _i),(W _i)	935.20	889.80	750.50	647.60	908.70	
Initial Value	(V _i),(W _i)	695.60	776.20	748.60	641.40	890.10	
Net Value	(V _n),(W _n)	239.6	113.6	1.9	6.2	18.6	
Results							
Total Weight	(W _t)	379.90	g	Water Vol Weighed	(V _{wsg(std)})	17.912	scf
Std Meter Volume	(V _{m(std)})	51.771	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws(calc)})	25.7	%	Final Moisture Content	(B _{ws})	25.7	%

Moisture Content Data							
Run Number	OUT-HCI-2			Run Start Time	19:40	Run Stop Time	20:40
Total Meter Volume	(V _m)	51.680	dcf	Barometric Press.	(P _b)	29.44	in Hg
Avg Stack Temp	(t _s) _{avg}	293	oF	Stack Static Press.	(P _{static})	-0.23	in H2O
Avg Meter Temp	(t _m) _{avg}	81	oF	Avg Orifice Press.	(ΔH) _{avg}	2.63	in H2O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
	g	g	g	g	g	g	g
Contents		H2SO4	H2SO4		Sil Gel		
Final Value	(V _i),(W _i)	967.50	821.70	741.40	643.40	901.70	
Initial Value	(V _i),(W _i)	701.70	753.70	720.30	639.60	887.50	
Net Value	(V _n),(W _n)	265.8	68.0	21.1	3.8	14.2	
Results							
Total Weight	(W _t)	372.90	g	Water Vol Weighed	(V _{wsg(std)})	17.582	scf
Std Meter Volume	(V _{m(std)})	50.102	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws})	26.0	%	Final Moisture Content	(B _{ws})	26.0	%

Moisture Content Data							
Run Number	OUT-HCI-3			Run Start Time	21:39	Run Stop Time	22:39
Total Meter Volume	(V _m)	56.100	dcf	Barometric Press.	(P _b)	29.46	in Hg
Avg Stack Temp	(t _s) _{avg}	299	oF	Stack Static Press.	(P _{static})	-0.23	in H2O
Avg Meter Temp	(t _m) _{avg}	80	oF	Avg Orifice Press.	(ΔH) _{avg}	2.87	in H2O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
	g	g	g	g	g	g	g
Contents		H2SO4	H2SO4		Sil Gel		
Final Value	(V _i),(W _i)	936.30	870.50	772.00	647.20	923.50	
Initial Value	(V _i),(W _i)	689.40	776.50	750.20	640.90	908.70	
Net Value	(V _n),(W _n)	246.9	94.0	21.8	6.3	14.8	
Results							
Total Weight	(W _t)	383.80	g	Water Vol Weighed	(V _{wsg(std)})	18.096	scf
Std Meter Volume	(V _{m(std)})	54.522	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws})	24.9	%	Final Moisture Content	(B _{ws})	24.9	%

METHOD 26A (HYDROGEN CHLORIDE) ISOKINETIC SAMPLING DATA

Plant Name	Fibrominn Biomass Power Plant	Date	7/3/2007
Sampling Location	Stack Outlet	Project #	snc-07-benson.mn-comp#1
Operator	TG	Run #	OUT-HCl-3
# of Points Across	1	# of Ports Used	1

Leak Checks					
Train	Pre	0	ft3/min @	15	in Hg
OK? <input checked="" type="checkbox"/>	Post	0	ft3/min @	15	in Hg
Pitot	Pre	3/4	in. H ₂ O for	15	sec
OK? <input checked="" type="checkbox"/>	Post	3/4	in. H ₂ O for	15	sec
Orsat	OK? <input checked="" type="checkbox"/>				

Sampling Equipment			
Meter #	SAMP-CP-0016		
Meterbox Cal. Factor (Y)	1.002		
Nozzle #	A-1		
Average Nozzle Diameter (D_{na})	0.2473	in	
Rec. Nozzle Diameter (D_{nl})	0.2520	in	
Probe # / Length	SAMP-HP-0011 / 60	in	
Liner Material	glass		
Sample Case / Oven #	SAMP-BH-0027		
Impinger Case #	SAMP-BC-0021		

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Tube Coefficient (C_p)	0.84		
Avg Stack Temp (t_s)	299	oF	
Avg Gas Meter Temp (t_m)	80		
DH @ 0.75 SCFM (ΔH@)	1.83	in H ₂ O	
Avg Pitot Tube Diff. Pressure (ΔP_{avg})	1.26	in H ₂ O	
Stack Moisture Content (B_{ws})	24.92	%	
Stack Dry Molecular Weight (M_d)	30.57	lb/lb-mole	
Estimated Orifice Flow Rate (Q_m)	0.861	acfm	
DP to DH Isokinetic Factor (K)	1.83		

Nozzle Measurements				
Pre	0.247	0.247	0.248	PASS
Post	0.247	0.247	0.248	PASS

Pressures			
Barometric Pressure (P_b)	29.46	in Hg	
Stack Static Pressure (P_{static})	-0.23	in H ₂ O	
Absolute Stack Pressure (P_s)	29.44	in Hg	
Absolute Meter Pressure (P_m)	29.59	in Hg	

Run Time			
Start	21:39	End	22:39

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8
Pre	689.40	776.50	750.20	640.90	908.70			
Post	936.30	870.50	772.00	647.20	923.50			

Wash	H ₂ O	50.0	ml	Filter #	M-1922
Volume	MeCl		ml		

Traverse Point #	Sampling Time (θ)	Timer Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp	Filter Temp	Impinger Exit Temp	Aux Temp	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})	Local Stack Velocity (v _s)	Cumulative Meter Volume (V _m) _{std}	Cumulative Percent IsoKinetic (I)	Est-Run Meter Volume (V _m) _{std}
	min	hh:mm:ss	ft ³	in H ₂ O	in H ₂ O	in H ₂ O	oF	oF	oF	oF	oF	oF	oF	in Hg	(in H ₂ O) ^{1/2}	ft/sec	scf	%	scf
A-3	0.0	0:00:00	365.350	1.600	2.922	2.900	299	267	264	67		76	76	4.0	1.26	88.04	4.464	98.6	53.566
A-3	5.0	0:05:00	369.910	1.500	2.739	2.700	300	269	265	60		76	76	4.0	1.22	85.30	9.082	102.1	54.492
A-3	10.0	0:10:00	374.630	1.600	2.922	2.900	300	268	265	61		77	77	4.0	1.26	88.10	13.674	101.9	54.697
A-3	15.0	0:15:00	379.330	1.600	2.922	2.900	298	268	266	63		78	78	4.0	1.26	87.98	18.238	101.6	54.715
A-3	20.0	0:20:00	384.010	1.600	2.922	2.900	299	268	265	64		79	79	4.0	1.26	88.04	22.785	101.4	54.683
A-3	25.0	0:25:00	388.680	1.600	2.922	2.900	299	268	264	66		80	80	4.0	1.26	88.04	27.322	101.2	54.644
A-3	30.0	0:30:00	393.350	1.500	2.739	2.700	300	268	264	58		81	81	4.0	1.22	85.30	30.860	98.8	52.903
A-3	35.0	0:35:00	397.000	1.700	3.105	3.100	299	268	263	57		81	81	5.0	1.30	90.75	36.459	102.1	54.689
A-3	40.0	0:40:00	402.770	1.700	3.105	3.100	299	268	264	56		82	82	5.0	1.30	90.75	41.069	101.7	54.759
A-3	45.0	0:45:00	407.530	1.600	2.922	2.900	300	269	265	58		82	82	5.0	1.26	88.10	45.648	101.7	54.778
A-3	50.0	0:50:00	412.260	1.500	2.739	2.700	299	268	265	57		83	83	5.0	1.22	85.25	50.101	101.7	54.655
A-3	55.0	0:55:00	416.870	1.500	2.739	2.700	299	269	265	58		83	83	5.0	1.22	85.25	54.524	101.6	54.524
Last Pt	60.0	1:00:00	421.450																
Final Val	60.0	1:00:00	421.450										Max Vac	5.0	Final Values		54.524	101.6	
Average Values				1.583		2.867	299	268	265	60		80	80		1.26	87.58			

METHOD 26A (HYDROGEN CHLORIDE) - SAMPLE RECOVERY AND INTEGRITY DATA SHEET

Plant Name	Fibrominn Biomass Power Plant	Date	07/03/07
Sampling Location	Stack Outlet	Project #	snc-07-benson.mn-comp#1
Operator	TG	Acetone Lot Number	

Run History Data				
Run Number	OUT-HCl-1	OUT-HCl-2	OUT-HCl-3	
Run Start Time	17:58	19:40	21:39	(hh:mm)
Run Stop Time	18:58	20:40	22:39	(hh:mm)
Train Prepared By	KV/SK	KV/SK	KV/SK	
Train Recovered By	KV/SK	KV/SK	KV/SK	
Recovery Date	7/3/2007	7/3/2007	7/3/2007	(mm/dd/yy)
Relinquished By	KV/SK	KV/SK	KV/SK	
Received By	TG	TG	TG	
Relinquished Date	7/3/2007	7/3/2007	7/3/2007	(mm/dd/yy)
Relinquished Time	18:58	20:40	22:39	(hh:mm)

Equipment Identification Numbers			
Filter	M-1922	M-1922	M-1922
Acetone Wash	ok	ok	ok
Silica Gel	ok	ok	ok
Impinger Case	SAMP-BC-0021	SAMP-BC-0003	SAMP-BC-0021
Sample Box	SAMP-BH-0027	SAMP-BH-0027	SAMP-BH-0027
Oven	ok	ok	ok

Sample Blank Taken YES

Moisture Content Data					
Impingers 1, 2, 3 and 4 - Liquid Volume					
Final Volume	(V _f)	3228.9	3179.7	3231.8	ml
Initial Volume	(V _i)	2867.0	2820.4	2862.2	ml
Net Volume	(V _n)	362.0	359.3	369.7	ml
Comments					
Impinger 5 - Silica Gel Weight					
Final Weight	(W _f)	908.7	901.7	923.5	g
Initial Weight	(W _i)	890.1	887.5	908.7	g
Net Weight	(W _n)	18.6	14.2	14.8	g
Comments					
Total Water Collected					
Total Volume	(V _{lc})	380.6	373.6	384.5	ml



Air Hygiene International, Inc.
5634 S. 122nd East Ave, Suite F
Tulsa, Oklahoma 74146
(888) 461-8778
www.airhygiene.com

HCl ANALYSIS

PARAMETER	UNITS	RUN			
		1	2	3	BLANK
Sample Number		IN-HCl-1	IN-HCl-2	IN-HCl-3	Blank
Lab Log Number		070307-IN-HCl1	070307-IN-HCl2	070307-IN-HCl3	070307-IN-HCl4
Concentration of Sample (S_x or B_x)	(mg Cl ⁻ /L)	110	100	115	0.521
Sample Volume (V_{HCl})	(ml)	455	430	390	N/A
DGM Volume (V_m) _{dscf}	(dscf)	18.268	11.712	24.123	N/A
DGM Volume (V_m) _{dstdL}	(L _{dstd})	517.29	331.64	683.07	N/A
Sum of HCl Ion (N)	(mg/L)	112.544	102.264	117.684	N/A
Volume of HCl (V_a)	(L)	0.03146	0.02702	0.02820	N/A
HCl Concentration (C_{HCl})	(ppmvd)	60.816	81.460	41.280	N/A

Equations & Constants:

Example Using Data from the 1st run

DGM Volume (L_{dstd})

$$(V_m)_{dstdL} (L_{dstd}) = (V_m)_{dscf} \times 28.31685$$

$$(V_m)_{dstdL} (L_{dstd}) = 18.268 \text{ dscf} \times 28.31685 \text{ L/ft}^3 = 517.29 \text{ L}_{dstd}$$

$(V_m)_{dscf}$ = Volume of gas sample measured by the DGM, corrected to standard conditions.

Sum of HCl Ion (mg/L) - modified 40 CFR 60, App A, Eq. 26-4

$$N (\text{mg/L}) = K_{HCl} (S_x - B_x)$$

$$N (\text{mg/L}) = \left[\frac{110.0 \text{ mg}}{L} - \frac{0.5 \text{ mg}}{L} \right] \times \frac{1.028 \text{ } \mu\text{g HCl}/\mu\text{g}\cdot\text{mol}}{\mu\text{g Cl}^-/\mu\text{g}\cdot\text{mol}} = \frac{112.5444 \text{ mg}}{L}$$

Total Sample Volume (ml)

$$S (\text{ml}) = \sum V_{NH_3}$$

$$S (\text{ml}) = 455 \text{ ml}$$

K_{HCl} = Equation 26-4 conversion constant
MW = molecular weight (ref. ASTM D 3588)

Volume of HCl (L)

$$V_a (L) = \frac{N \times S}{1000} \times 22.4$$

$$V_a (L) = \frac{112.5444 \text{ mg} \times 455 \text{ ml}}{36.46094 \text{ g} \times 1000} \times 22.4 \text{ L ideal gas/g-mol substance} = 0.03146 \text{ L}$$

$$V_a (L) = 112.5444 \frac{\text{mg}}{L} \times 455 \frac{\text{ml}}{L} \times \frac{L}{1000 \text{ ml}} \times \frac{22.4 \text{ L ideal gas}}{\text{g-mol substance}} \times \frac{\text{g-mol HCl}}{36.46094 \text{ g}} \times \frac{\text{g}}{1000 \text{ mg}} = 0.03146 \text{ L}$$

HCl Concentration (ppmvd)

$$C_{HCl} (\text{ppmvd}) = \frac{V_a}{(V_m)_{dstdL}} \times 10^6$$

$$C_{HCl} (\text{ppmvd}) = \frac{0.03146 \text{ L}}{517.29 \text{ L}_{dstd}} \times \frac{10^6 \text{ parts}}{1 \text{ part}} = 60.816 \text{ ppmvd}$$

22.4 = liters of ideal gas per mol of substance at 0°C and 1 atm (ref. Civil Engineering Reference Manual, 7th ed. - Michael R. Lindeburg)

METHOD 26A (HYDROGEN CHLORIDE) - RESULTS

Plant Name	Fibrominn Biomass Power Plant	Date	07/03/07
Sampling Location	SDA Inlet	Project #	snc-07-benson.mn-comp#1
Operator	TP	Stack Type	Circular

Historical Data						
Run Number		IN-HCl-1	IN-HCl-2	IN-HCl-3	Average	
Run Start Time		17:58	19:40	21:39		hh:mm
Run Stop Time		18:58	20:40	22:39		hh:mm
Meter Calibration Factor	(Y)	1.007	1.007	1.007		
Pitot Tube Coefficient	(C _p)	0.840	0.840	0.840		
Average Nozzle Diameter	(D _{na})	0.244	0.187	0.244		in
Stack Test Data						
Initial Meter Volume	(V _m) _i	49.646	69.964	82.719		ft3
Final Meter Volume	(V _m) _f	69.315	82.591	108.583		ft3
Total Meter Volume	(V _m)	19.669	12.627	25.864	19.387	ft3
Total Sampling Time	(Θ)	60.0	60.0	60.0	60.0	min
Average Meter Temperature	(t _m) _{avg}	104.5	104.2	102.0	103.5	oF
Average Stack Temperature	(t _s) _{avg}	350.0	344.2	347.8	347.3	oF
Barometric Pressure	(P _b)	29.44	29.44	29.44	29.44	in Hg
Stack Static Pressure	(P _{static})	-2.10	-2.10	-2.10	-2.10	in H2O
Absolute Stack Pressure	(P _s)	29.29	29.29	29.29	29.29	in Hg
Average Orifice Pressure Drop	(ΔH) _{avg}	0.65	0.24	0.79	0.56	in H2O
Absolute Meter Pressure	(P _m)	29.56	29.56	29.56	29.56	in Hg
Avg Square Root Pitot Pressure	(Δp ^{1/2}) _{avg}	0.66	0.72	0.75	0.71	(in H2O) ^{1/2}
Moisture Content Data						
Impingers 1-3 Water Volume Gain	(V _n)	85.8	73.5	52.2	70.5	ml
Impinger 4 Silica Gel Weight Gain	(W _n)	2.3	1.0	1.9	1.7	g
Total Water Volume Collected	(V _{lc})	88.1	74.5	54.1	72.2	ml
Standard Water Vapor Volume	(V _w) _{std}	4.145	3.508	2.546	3.400	scf
Standard Meter Volume	(V _m) _{std}	18.268	11.712	24.123	18.034	dscf
Calculated Stack Moisture	(B _{ws}) _(calc)	18.50	23.04	9.55	17.03	%
Saturated Stack Moisture	(B _{ws}) _(svp)	100.0	100.0	100.0	100.0	%
Reported Stack Moisture Content	(B _{ws})	18.50	23.04	9.55	17.03	%
Gas Analysis Data						
Carbon Dioxide Percentage	(%CO ₂)	16.6	16.1	15.6	16.1	%
Oxygen Percentage	(%O ₂)	5.2	5.5	4.9	5.2	%
Carbon Monoxide Percentage	(%CO)	0.0	0.0	0.0	0.0	%
Nitrogen Percentage	(%N ₂)	78.1	78.4	79.5	78.7	%
Dry Gas Molecular Weight	(M _d)	30.87	30.80	30.69	30.78	lb/lb-mole
Wet Stack Gas Molecular Weight	(M _s)	28.49	27.85	29.48	28.60	lb/lb-mole
Calculated Fuel Factor	(F _o)	0.942	0.954	1.024	0.973	
Fuel F-Factor	(F _c)	1890	1890	1890	1890	dscf/MMBtu
Percent Excess Air	(%EA)	33.9	36.1	30.3	33.4	%
Volumetric Flow Rate Data						
Average Stack Gas Velocity	(v _s)	47.71	52.22	54.63	51.52	ft/sec
Stack Cross-Sectional Area	(A _s)	90.76	90.76	90.76	90.76	ft2
Actual Stack Flow Rate	(Q _{aw})	259,816	284,376	297,488	280,560	acfm
Wet Standard Stack Flow Rate	(Q _{sw})	9,946	10,965	11,420	10,777	wkscfh
Dry Standard Stack Flow Rate	(Q _{sd})	135,105	140,647	172,164	149,305	dscfm
Percent of Isokinetic Rate	(I)	91.6	104.0	93.4	96.3	%
HCl Rate Data						
Stack HCl Concentration	(C _{HCl})	60.816	81.460	41.280	61.185	ppm

METHOD 26A (HYDROGEN CHLORIDE) SOURCE SAMPLING TITLE PAGE

Source Information				
Plant Name	Fibrominn Biomass Power Plant			
Sampling Location	SDA Inlet			
Fuel or Source Type	Biomass			
Fuel F-Factor	1890	1890	1890	

Test Information				
Starting Test Date		07/03/07		
Project #		snc-07-benson.mn-comp#1		
Operator		TP		
Standard Temperature		68	oF	
Standard Pressure		29.92	in Hg	
Minimum Required Sample Vol.	indust. spec.	35	scf	
Run Duration	chk Subpart	60	minutes	
Unit Number		IN-HCl		
Load	% or w/DB	100%		
Base Run Number		IN-HCl		
Number of Ports Available		2		
Number of Ports Used		1		
Port Inside Diameter		5.00	in	
Circular Stack				

Test Equipment Information					
Run		1	2	3	
Meter Box Number	from ACS	SAMP-CP-0002	SAMP-CP-0002	SAMP-CP-0002	
Meter Calibration Factor	(Y)	1.007	1.007	1.007	
Orifice Meter Coefficient	($\Delta H @$)	1.667	1.667	1.667	in H ₂ O
Pitot Identification	from ACS	SAMP-HP-0002	SAMP-HP-0002	SAMP-HP-0002	
Pitot Tube Coefficient	(C _p)	0.840	0.840	0.840	
Orsat Identification	from ACS	N/A	N/A	N/A	
Nozzle Number	from ACS	B-2	B-2	B-2	
Nozzle Diameter	(D _n)	0.244	0.187	0.244	in
Probe Number	from ACS	SAMP-HP-0002	SAMP-HP-0002	SAMP-HP-0002	
Probe Length		96.00	96.00	96.00	in
(SS, Glass) Liner Material	from list	glass	glass	glass	
Sample Case / Oven Number	from ACS	SAMP-BH-0004	SAMP-BH-0004	SAMP-BH-0004	
Impinger Case Number	from ACS	SAMP-BC-0015	SAMP-BC-0004	SAMP-BC-0015	

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	5634 S. 122nd East Ave., Suite F
City, State Country Zip	Tulsa, Oklahoma 74146
Project Manager	Thomas K. Graham
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131

METHOD 1 - SAMPLE AND VELOCITY TRAVERSES FOR CIRCULAR SOURCES

Plant Name	Fibrominn Biomass Power Plant	Date	07/03/07
Sampling Location	SDA Inlet	Project #	snc-07-benson.mn-comp#1
Operator	TP	# of Ports Available	2
Stack Type	Circular	# of Ports Used	1
Stack Size	Large	Port Inside Diameter	5.00


Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L _{fw})	136.00	in
Distance to Near Wall of Stack	(L _{nw})	7.00	in
Diameter of Stack	(D)	129.00	in
Area of Stack	(A _s)	90.76	ft ²

Distance from Port to Disturbances			
Distance Upstream	(A)	350.00	in
Diameters Upstream	(A _D)	2.71	diameters
Distance Downstream	(B)	1222.00	in
Diameters Downstream	(B _D)	9.47	diameters

Number of Traverse Points Required			
Diameters to Flow Disturbance		Minimum Number of Traverse Points ^a	
Down Stream	Up Stream	Particulate Points	Velocity Points
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
>= 8.00	>=2.00	8 or 12 ²	8 or 12 ²
Upstream Spec		12	12
Downstream Spec		12	12
Traverse Pts Required		12	12

¹ Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.
² 8 for Circular Stacks 12 to 24 inches
 12 for Circular Stacks over 24 inches

Location of Traverse Points in Circular Stacks									
Traverse Point Number	(Fraction of Stack Dimension from Inside Wall to Traverse Point)								
	Number of Traverse Points Across the Stack								
Number	2	4	6	8	10	12	14	16	18
1	.146	.067	.044	.032	.026	.021	.018	.016	.014
2	.854	.250	.146	.105	.082	.067	.057	.049	.044
3		.750	.296	.194	.146	.118	.099	.085	.075
4		.933	.704	.323	.226	.177	.146	.125	.109
5			.854	.677	.342	.250	.201	.169	.146
6			.956	.806	.658	.356	.269	.220	.188
7				.895	.774	.644	.366	.283	.236
8				.968	.854	.750	.634	.375	.296
9					.918	.823	.731	.625	.382
10					.974	.882	.799	.717	.618
11						.933	.854	.780	.704
12						.979	.901	.831	.764



Number of Traverse Points Used			
1	Ports by	1	Across
1	Pts Used	1	Required
		Particulate Traverse	

Traverse Point Locations			
Traverse Point Number	Fraction of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
		in	in
1	0.50	64 4/8	71 4/8
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			

METHOD 2 - DETERMINATION OF STACK GAS VELOCITY AND VOLUMETRIC FLOW RATE

Plant Name Fibrominn Biomass Power Plant	Date 06/30/07
Sampling Location SDA Inlet	Project # snc-07-benson.mn-comp#1
Operator TP	# of Ports Used 1
Stack Type Circular	Pitot Identification samp-hp-0006
Pitot Leak Check <input checked="" type="checkbox"/> PreTest <input checked="" type="checkbox"/> PostTest	Pitot Coefficient (C_p) 0.84

Stack Dimensions			
Diameter or Length of Stack	(D)	129.00	in
Width of Stack	(W)		in
Area of Stack	(A _s)	90.76	ft ²

Velocity Traverse Data				
Run Number		IN-HCI-V1		
Run Time	12:00	Start	12:10	End

Pressures			
Barometric Pressure	(P _b)	29.92	in Hg
Static Pressure	(P _{static})	-2.10	in H2O
Absolute Stack Pressure	(P _s)	29.77	in Hg

Traverse Point	Velocity Head (Δp)	Null Angle (N _a)	Stack Temp (t _s)	Local Velocity (v _{s(i)})
	in H2O	deg	oF	ft/sec
A-1	2.10	-5	219	96.1
A-2	2.10	5	219	96.1
A-3	1.70	5	192	84.7
A-4	2.30	0	207	99.7
A-5	2.20	0	215	98.1
A-6	1.90	0	197	89.9
B-1	2.30	-5	196	98.9
B-2	2.40	5	202	101.4
B-3	2.10	0	200	94.8
B-4	1.90	0	183	89.0
B-5	2.10	10	198	94.6
B-6	2.20	-5	202	97.1

Stack Gas Composition			
Composition Data:		Actual Composition	
Carbon Dioxide Concentration	(%CO ₂)	14.4	%
Oxygen Concentration	(%O ₂)	4.8	%
Carbon Monoxide Concentration	(%CO)	0.0	%
Nitrogen Concentration	(%N ₂)	80.8	%
Stack Moisture Content	(B _{ws})	30.000	%
Stack Dry Molecular Weight	(M _d)	30.50	lb/lb-mole
Stack Wet Molecular Weight	(M _s)	26.75	lb/lb-mole

Results			
Avg Stack Gas Velocity	(v _s)	95.0	ft/sec
Avg Stack Dry Std Flow Rate	(Q _{sd})	17,231,378	dscf/hr
Avg Stack Dry Std Flow Rate	(Q _{sd})	287,190	dscf/min
Avg Stack Wet Flow Rate	(Q _{aw})	517,452	acf/min
Avg Stack Wet Std Flow Rate	(Q _{sw})	24,616,255	ascf/hr

Stack Cross Section Schematic			

Average	2.11	3	203	
	1.45	= Square roots of Δp		

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	Fibrominn Biomass Power Plant				Date	07/03/07	
Sampling Location	SDA Inlet				Project #	snc-07-benson.mn-comp#1	
Operator	TP				# of Ports Used	1	
Fuel Type	Biomass		Minimum Fuel Factor	1.000	Maximum Fuel Factor	1.120	
Orsat Leak Check	<input checked="" type="checkbox"/>	PreTest	<input checked="" type="checkbox"/>	PostTest	Orsat Identification	N/A	

Gas Analysis Data										
Run Number		IN-HCI-1			Run Start Time		17:58	Run Stop Time		18:58
Sample Analysis Time	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N ₂)	Dry Molecular Weight (M _d)	Molecular Weight Deviation (ΔM _d)	
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole	
1:00	16.6	5.2	229.3	16.6	5.2	0.0	78.1	30.87	0.00	
Results			Averages	16.6	5.2	0.0	78.1	30.87		
Average Calculated Fuel Factor				(F _o) _{avg}	0.942	Molecular Wt Deviation < 0.3?			<input checked="" type="checkbox"/>	
Average Excess Air				(%EA) _{avg}	33.9	percent	Fuel Factor in Handbook Range?			<input checked="" type="checkbox"/>

Gas Analysis Data										
Run Number		IN-HCI-2			Run Start Time		19:40	Run Stop Time		20:40
Sample Analysis Time	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N ₂)	Dry Molecular Weight (M _d)	Molecular Weight Deviation (ΔM _d)	
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole	
1:00	16.1	5.5	260.1	16.1	5.5	0.0	78.4	30.80	0.00	
Results			Averages	16.1	5.5	0.0	78.4	30.80		
Average Calculated Fuel Factor				(F _o) _{avg}	0.954	Molecular Wt Deviation < 0.3?			<input checked="" type="checkbox"/>	
Average Excess Air				(%EA) _{avg}	36.1	percent	Fuel Factor in Handbook Range?			<input checked="" type="checkbox"/>

Gas Analysis Data										
Run Number		IN-HCI-3			Run Start Time		21:39	Run Stop Time		22:39
Sample Analysis Time	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N ₂)	Dry Molecular Weight (M _d)	Molecular Weight Deviation (ΔM _d)	
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole	
1:00	15.6	4.9	260.1	15.6	4.9	0.0	79.5	30.69	0.00	
Results			Averages	15.6	4.9	0.0	79.5	30.69		
Average Calculated Fuel Factor				(F _o) _{avg}	1.024	Molecular Wt Deviation < 0.3?			<input checked="" type="checkbox"/>	
Average Excess Air				(%EA) _{avg}	30.3	percent	Fuel Factor in Handbook Range?			<input checked="" type="checkbox"/>

Fuel Factor Fo		
Fuel Type	Minimum	Maximum
Coal, Anthracite	1.016	1.130
Coal, Lignite	1.016	1.130
Coal, Bituminous	1.083	1.230
Oil, Distillate	1.260	1.413
Oil, Residual	1.210	1.370
Gas, Natural	1.600	1.836
Gas, Propane	1.434	1.586
Gas, Butane	1.405	1.553
Biomass	1.000	1.120
Wood Bark	1.003	1.130

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	Fibrominn Biomass Power Plant			Date	07/03/07
Sampling Location	SDA Inlet			Project #	snc-07-benson.mn-comp#1
Operator	TP			# of Ports Used	1
Stack Type	Circular			Meter Box Number	SAMP-CP-0002
Train Leak Check	<input checked="" type="checkbox"/>	PreTest	<input checked="" type="checkbox"/>	PostTest	Meter Cal Factor (Y) 1.007

Moisture Content Data								
Run Number	IN-HCI-1		Run Start Time		17:58	Run Stop Time		18:58
Total Meter Volume	(V _m)	19.669	dcf	Barometric Press.	(P _b)	29.44	in Hg	
Avg Stack Temp	(t _s) _{avg}	350	oF	Stack Static Press.	(P _{static})	-2.10	in H2O	
Avg Meter Temp	(t _m) _{avg}	104	oF	Avg Orifice Press.	(ΔH) _{avg}	0.65	in H2O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8
	g	g	g	g	g	g	g	g
Contents	H2SO4		H2SO4		Sil Gel			
Final Value	(V _i),(W _i)	878.80	673.30	681.00	641.30	939.60		
Initial Value	(V _i),(W _i)	691.60	720.40	750.20	639.00	924.90		
Net Value	(V _n),(W _n)	187.2	-47.1	-69.2	2.3	14.7		
Results								
Total Weight	(W _t)	87.90	g	Water Vol Weighed	(V _{wsg(std)})	4.144	scf	
Std Meter Volume	(V _{m(std)})	18.260	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%	
Calc Moisture Content	(B _{ws(calc)})	18.5	%	Final Moisture Content	(B _{ws})	18.5	%	

Moisture Content Data								
Run Number	IN-HCI-2		Run Start Time		19:40	Run Stop Time		20:40
Total Meter Volume	(V _m)	12.627	dcf	Barometric Press.	(P _b)	29.44	in Hg	
Avg Stack Temp	(t _s) _{avg}	344	oF	Stack Static Press.	(P _{static})	-2.10	in H2O	
Avg Meter Temp	(t _m) _{avg}	104	oF	Avg Orifice Press.	(ΔH) _{avg}	0.24	in H2O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8
	g	g	g	g	g	g	g	g
Contents	H2SO4		H2SO4		Sil Gel			
Final Value	(V _i),(W _i)	858.20	694.20	714.70	650.60	901.90		
Initial Value	(V _i),(W _i)	688.30	748.70	763.70	649.60	894.90		
Net Value	(V _n),(W _n)	169.9	-54.5	-49.0	1.0	7.0		
Results								
Total Weight	(W _t)	74.40	g	Water Vol Weighed	(V _{wsg(std)})	3.508	scf	
Std Meter Volume	(V _{m(std)})	11.716	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%	
Calc Moisture Content	(B _{ws})	23.0	%	Final Moisture Content	(B _{ws})	23.0	%	

Moisture Content Data								
Run Number	IN-HCI-3		Run Start Time		21:39	Run Stop Time		22:39
Total Meter Volume	(V _m)	25.864	dcf	Barometric Press.	(P _b)	29.44	in Hg	
Avg Stack Temp	(t _s) _{avg}	348	oF	Stack Static Press.	(P _{static})	-2.10	in H2O	
Avg Meter Temp	(t _m) _{avg}	102	oF	Avg Orifice Press.	(ΔH) _{avg}	0.79	in H2O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8
	g	g	g	g	g	g	g	g
Contents	H2SO4		H2SO4		Sil Gel			
Final Value	(V _i),(W _i)	824.90	698.50	663.90	639.50	951.40		
Initial Value	(V _i),(W _i)	697.70	732.10	720.20	637.60	936.60		
Net Value	(V _n),(W _n)	127.2	-33.6	-56.3	1.9	14.8		
Results								
Total Weight	(W _t)	54.00	g	Water Vol Weighed	(V _{wsg(std)})	2.546	scf	
Std Meter Volume	(V _{m(std)})	24.124	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%	
Calc Moisture Content	(B _{ws})	9.5	%	Final Moisture Content	(B _{ws})	9.5	%	

METHOD 26A (HYDROGEN CHLORIDE) ISOKINETIC SAMPLING DATA

Plant Name	Fibrominn Biomass Power Plant	Date	7/3/2007
Sampling Location	SDA Inlet	Project #	snc-07-benson.mn-comp#1
Operator	TP	Run #	IN-HCl-2
# of Points Across	1	# of Ports Used	1

Ideal Nozzle Diameter and IsoKinetic Factor Setup			
Pitot Tube Coefficient	(C _p)	0.84	
Avg Stack Temp	(t _s)	350	oF
Avg Gas Meter Temp	(t _m)	104	
DH @ 0.75 SCFM	(ΔH@)	1.67	in H2O
Avg Pitot Tube Diff. Pressure	(ΔP _{avg})	0.66	in H2O
Stack Moisture Content	(B _w)	30.00	%
Stack Dry Molecular Weight	(M _d)	30.87	lb/lb-mole
Estimated Orifice Flow Rate	(Q _m)	0.328	acfm
DP to DH Isokinetic Factor	(K)	0.47	

Leak Checks					
Train	Pre	0	ft3/min @	15	in Hg
OK? <input checked="" type="checkbox"/>	Post	0	ft3/min @	15	in Hg
Pitot	Pre	5.5/6.8	in. H ₂ O for	60	sec
OK? <input checked="" type="checkbox"/>	Post	6.1/5.1	in. H ₂ O for	60	sec
Orsat	OK? <input checked="" type="checkbox"/>				

Sampling Equipment			
Meter #	SAMP-CP-0002		
Meterbox Cal. Factor	(Y)	1.007	
Nozzle #	B-2		
Average Nozzle Diameter	(D _{na})	0.1867	in
Rec. Nozzle Diameter	(D _{ri})	0.1877	in
Probe # / Length	SAMP-HP-0002	/ 96	in
Liner Material	glass		
Sample Case / Oven #	SAMP-BH-0004		
Impinger Case #	SAMP-BC-0004		

Pressures			
Barometric Pressure	(P _b)	29.44	in Hg
Stack Static Pressure	(P _{static})	-2.10	in H2O
Absolute Stack Pressure	(P _s)	29.29	in Hg
Absolute Meter Pressure	(P _m)	29.56	in Hg

Nozzle Measurements				
Pre	0.187	0.186	0.187	PASS
Post	0.187	0.186	0.187	PASS

Run Time			
Start	19:40	End	20:40

Weights	Imp 1	Imp 2	Imp 3	Imp 4	Imp 5	Imp 6	Imp 7	Imp 8	Wash	H ₂ O	50.0	ml	Filter #
Pre	688.30	748.70	763.70	649.60	894.90				Volume	MeCl		ml	M-1945
Post	858.20	694.20	714.70	650.60	901.90								

Traversal Point #	Sampling Time (θ)	Timer Time	Dry Gas Meter Reading (V _m)	Velocity Head (Δp)	Desired Orifice ΔH (ΔH _d)	Actual Orifice ΔH (ΔH _a)	Stack Temp (t _s)	Probe Temp	Filter Temp	Impinger Exit Temp	Aux Temp	Meter Inlet Temp (t _{mi})	Meter Outlet Temp (t _{mo})	Pump Vacuum	Square Root ΔP (ΔP ^{1/2})	Local Stack Velocity (v _s)	Cumulative Meter Volume (V _m) _{std}	Cumulative Percent IsoKinetic (I)	Est-Run Meter Volume (V _m) _{std}
	min	hh:mm:ss	ft ³	in H2O	in H2O	in H2O	oF	oF	oF	oF	oF	oF	oF	in Hg	(in H2O) ^{1/2}	ft/sec	scf	%	scf
A-3	0.0	0:00:00	69.964	0.570	0.267	0.270	341	223	224	68	225	105	105	2.0	0.75	54.56	1.970	140.3	23.639
A-3	5.0	0:05:00	72.090	0.540	0.253	0.250	342	224	226	68	223	105	105	10.0	0.73	53.14	2.975	117.8	17.851
A-3	10.0	0:10:00	73.175	0.570	0.267	0.270	342	226	227	68	224	105	105	10.0	0.75	54.60	3.925	105.6	15.700
A-3	15.0	0:15:00	74.200	0.570	0.267	0.270	344	228	231	68	223	105	105	13.0	0.75	54.66	5.014	99.6	15.041
A-3	20.0	0:20:00	75.375	0.560	0.263	0.260	344	225	233	68	224	104	104	15.0	0.75	54.18	6.374	99.2	15.296
A-3	25.0	0:25:00	76.840	0.570	0.267	0.270	344	230	242	68	223	104	104	17.0	0.75	54.66	8.007	102.8	16.014
A-3	30.0	0:30:00	78.600	0.560	0.263	0.260	344	232	237	68	223	104	104	18.0	0.75	54.18	9.752	106.8	16.718
A-3	35.0	0:35:00	80.480	0.560	0.263	0.260	345	234	233	68	225	104	104	18.0	0.75	54.22	11.298	107.5	16.946
A-3	40.0	0:40:00	82.145	0.520	0.244	0.240	345	236	241	68	226	104	104	21.0	0.72	52.24	11.480	106.0	15.306
A-3	45.0	0:45:00	82.341	0.350	0.164	0.160	345	232	242	68	225	104	104	20.5	0.59	42.86	11.567	105.2	13.880
A-3	50.0	0:50:00	82.435	0.450	0.211	0.210	347	231	245	67	224	103	103	20.5	0.67	48.66	11.641	104.6	12.699
A-3	55.0	0:55:00	82.515	0.450	0.211	0.210	347	229	231	68	223	103	103	20.5	0.67	48.66	11.712	104.0	11.712
Last Pt	60.0	1:00:00	82.591																
Final Val	60.0	1:00:00	82.591											Max Vac	21.0	Final Values	11.712	104.0	
Average Values				0.52		0.24	344	229	234	68	224	104	104		0.72	52.22			

METHOD 26A (HYDROGEN CHLORIDE) ISOKINETIC SAMPLING DATA

Plant Name Fibrominn Biomass Power Plant, Date 7/3/2007, Project # snc-07-benson.mn-comp#1, Operator TP, # of Points Across 1, # of Ports Used 1

Leak Checks table with columns: Train, Pre, Post, 0, ft3/min @, 15, in Hg. Includes Orsat OK? checkbox.

Sampling Equipment table: Meter # SAMP-CP-0002, Meterbox Cal. Factor (Y) 1.007, Nozzle # B-2, Average Nozzle Diameter 0.2440 in, Rec. Nozzle Diameter 0.1466 in, Probe # / Length SAMP-HP-0002 / 96 in, Liner Material glass, Sample Case / Oven # SAMP-BH-0004, Impinger Case # SAMP-BC-0015

Ideal Nozzle Diameter and IsoKinetic Factor Setup table: Pitot Tube Coefficient (Cp) 0.84, Avg Stack Temp (ts) 344 oF, Avg Gas Meter Temp (tm) 104, DH @ 0.75 SCFM (DH@) 1.67 in H2O, Avg Pitot Tube Diff. Pressure (DPAvg) 0.72 in H2O, Stack Moisture Content (Bws) 30.00 %, Stack Dry Molecular Weight (Msd) 30.80 lb/lb-mole, Estimated Orifice Flow Rate (Qm) 0.210 acfm, DP to DH Isokinetic Factor (K) 1.38

Nozzle Measurements table: Pre 0.244, 0.244, 0.244 PASS, Post 0.244, 0.244, 0.244 PASS

Pressures table: Barometric Pressure (Pb) 29.44 in Hg, Stack Static Pressure (Pstatic) -2.10 in H2O, Absolute Stack Pressure (Psa) 29.29 in Hg, Absolute Meter Pressure (Pm) 29.56 in Hg

Run Time table: Start 21:39, End 22:39

Weights table with columns Imp 1-8. Pre: 697.70, 732.10, 720.20, 637.60, 936.60, Imp 6, Imp 7, Imp 8; Post: 824.90, 698.50, 663.90, 639.50, 951.40

Wash Volume table: H2O 50.0 ml, MeCl, Filter # M-1945

Main data table with columns: Traverse Point #, Sampling Time (min), Timer Time (hh:mm:ss), Dry Gas Meter Reading (Vn) ft3, Velocity Head (Dp) in H2O, Desired Orifice (Delta Hs) in H2O, Actual Orifice (Delta Ha) in H2O, Stack Temp (ts) oF, Probe Temp oF, Filter Temp oF, Impinger Exit Temp oF, Aux Temp oF, Meter Inlet Temp (tmi) oF, Meter Outlet Temp (tmo) oF, Pump Vacuum in Hg, Square Root (Delta P)^1/2 in H2O^1/2, Local Stack Velocity (vs)l ft/sec, Cumulative Meter Volume (Vm)std scf, Cumulative Percent IsoKinetic (I) %, Est-Run Meter Volume (Vm)std scf. Includes Final Val, Average Values, and Max Vac at the bottom.

METHOD 26A (HYDROGEN CHLORIDE) - SAMPLE RECOVERY AND INTEGRITY DATA SHEET

Plant Name	Fibrominn Biomass Power Plant	Date	07/03/07
Sampling Location	SDA Inlet	Project #	snc-07-benson.mn-comp#1
Operator	TP	Acetone Lot Number	

Run History Data				
Run Number	IN-HCI-1	IN-HCI-2	IN-HCI-3	
Run Start Time	17:58	19:40	21:39	(hh:mm)
Run Stop Time	18:58	20:40	22:39	(hh:mm)
Train Prepared By	KV/SK	KV/SK	KV/SK	
Train Recovered By	KV/SK	KV/SK	KV/SK	
Recovery Date	7/3/2007	7/3/2007	7/3/2007	(mm/dd/yy)
Relinquished By	KV/SK	KV/SK	KV/SK	
Received By	TG	TG	TG	
Relinquished Date	7/3/2007	7/3/2007	7/3/2007	(mm/dd/yy)
Relinquished Time	18:58	20:40	22:39	(hh:mm)

Equipment Identification Numbers			
Filter	M-1945	M-1945	M-1945
Acetone Wash	ok	ok	ok
Silica Gel	ok	ok	ok
Impinger Case	SAMP-BC-0015	SAMP-BC-0004	SAMP-BC-0015
Sample Box	SAMP-BH-0004	SAMP-BH-0004	SAMP-BH-0004
Oven	ok	ok	ok

Sample Blank Taken YES

Moisture Content Data					
Impingers 1, 2, and 3 - Liquid Volume					
Final Volume	(V _f)	3178.4	3174.7	3144.4	ml
Initial Volume	(V _i)	3092.7	3101.2	3092.2	ml
Net Volume	(V _n)	85.8	73.5	52.2	ml
Comments					
Impinger 4 - Silica Gel Weight					
Final Weight	(W _f)	641.3	650.6	639.5	g
Initial Weight	(W _i)	639.0	649.6	637.6	g
Net Weight	(W _n)	2.3	1.0	1.9	g
Comments					
Total Water Collected					
Total Volume	(V _{ic})	88.1	74.5	54.1	ml

TEST RESULTS AND CALCULATIONS

PM Emissions Data

METHOD 5 (FRONTAL) AND 202 (BACKHALF) - RESULTS

Plant Name	Fibrominn Biomass Power Plant	Date	07/03/07
Sampling Location	Stack Outlet	Project #	snc-07-benson.mn-comp#1
Operator	TKG	Stack Type	Circular

Historical Data						
Run Number		OUT-PM-1	OUT-PM-2	OUT-PM-3	Average	
Run Start Time		23:42	2:44	5:27		hh:mm
Run Stop Time		2:38	5:22	7:58		hh:mm
Meter Calibration Factor	(Y)	1.002	1.002	1.002		
Pitot Tube Coefficient	(C _p)	0.840	0.840	0.840		
Average Nozzle Diameter	(D _{na})	0.226	0.230	0.226		in
Stack Test Data						
Initial Meter Volume	(V _m) _i	421.770	532.680	647.580		ft ³
Final Meter Volume	(V _m) _f	532.680	647.580	770.250		ft ³
Total Meter Volume	(V _m) _t	110.910	114.900	122.670	116.160	ft ³
Total Sampling Time	(t)	150.0	150.0	150.0	150.0	min
Average Meter Temperature	(t _m) _{avg}	78.4	80.3	80.8	79.8	oF
Average Stack Temperature	(t _s) _{avg}	293.0	297.1	296.2	295.4	oF
Barometric Pressure	(P _b)	29.49	29.49	29.49	29.49	in Hg
Stack Static Pressure	(P _{static})	-0.23	-0.23	-0.23	-0.23	in H ₂ O
Absolute Stack Pressure	(P _s)	29.47	29.47	29.47	29.47	in Hg
Average Orifice Pressure Drop	(ΔH) _{avg}	1.87	1.98	2.25	2.03	in H ₂ O
Absolute Meter Pressure	(P _m)	29.62	29.62	29.62	29.62	in Hg
Avg Square Root Pitot Pressure	(ΔP ^{1/2}) _{avg}	1.21	1.20	1.33	1.25	(in H ₂ O) ^{1/2}
Moisture Content Data						
Impingers 1-3 Water Volume Gain	(V _w)	549.6	707.4	642.4	633.1	ml
Impinger 4 Silica Gel Weight Gain	(W _n)	36.6	36.0	87.8	53.5	g
Total Water Volume Collected	(V _w) _t	586.3	743.4	730.3	686.7	ml
Standard Water Vapor Volume	(V _w) _{std}	27.595	34.994	34.374	32.321	scf
Standard Meter Volume	(V _m) _{std}	107.920	111.451	118.961	112.777	dscf
Calculated Stack Moisture	(B _{ws(calc)})	20.36	23.89	22.42	22.22	%
Saturated Stack Moisture	(B _{ws(svp)})	100.0	100.0	100.0	100.0	%
Reported Stack Moisture Content	(B _{ws})	20.36	23.89	22.42	22.22	%
Gas Analysis Data						
Carbon Dioxide Percentage	(%CO ₂)	14.0	14.0	14.0	14.0	%
Oxygen Percentage	(%O ₂)	5.0	5.0	5.0	5.0	%
Carbon Monoxide Percentage	(%CO)	0.0	0.0	0.0	0.0	%
Nitrogen Percentage	(%N ₂)	81.0	81.0	81.0	81.0	%
Dry Gas Molecular Weight	(M _d)	30.44	30.44	30.44	30.44	lb/lb-mole
Wet Stack Gas Molecular Weight	(M _w)	27.91	27.47	27.65	27.68	lb/lb-mole
Calculated Fuel Factor	(F _w)	1.135	1.135	1.135	1.135	
Fuel F-Factor	(F _c)	1890	1890	1890	1890	dscf/MMBtu
Percent Excess Air	(%EA)	30.5	30.5	30.5	30.5	%
Volumetric Flow Rate Data						
Average Stack Gas Velocity	(V _s)	84.03	83.50	92.29	86.61	ft/sec
Stack Cross-Sectional Area	(A _s)	63.62	63.62	63.62	63.62	ft ²
Actual Stack Flow Rate	(Q _{aw})	320,746	318,717	352,260	330,574	acfm
Wet Standard Stack Flow Rate	(Q _{sw})	13,293	13,137	14,538	13,656	wkscfh
Dry Standard Stack Flow Rate	(Q _{sd})	176,434	166,641	187,981	177,019	dscfm
Percent of Isokinetic Rate	(I)	99.3	100.1	100.2	99.9	%
Emission Rate Data						
Mass of Particulate on Filter	(M _f)	11.6	14.9	13.9	13.5	mg
Mass of Particulate in Acetone	(M _a)	9.7	4.4	2.0	5.4	mg
Mass of Particulate in Imp Content	(M _{ino})	220.4	272.4	256.3	249.7	mg
Mass of Particulate in Org Rinse	(M _{org})	0.2	1.1	4.1	1.8	mg
Total Mass of Particulates	(M _t)	241.8	292.7	276.3	270.3	mg
Stack Particulate Concentration	(C _s)	0.002	0.003	0.002	0.002	g/dscf
	(C _e)	0.035	0.041	0.036	0.037	gr/dscf
Particulate Emission Rate	(E)	23.72	26.25	26.20	25.39	kg/hr
	(E)	52.3	57.9	57.8	56.0	lbs/hr
	(E)	229.1	253.5	253.0	245.2	tons/yr
	(E)	0.0605	0.0732	0.0691	0.0676	lbs/MMBtu
(Pl 75 App F Sect. 5.2.1) Heat Input	(HI)	784.0	740.5	835.3	786.6	MMBtu/hr

METHOD 5 (FRONTHALF) AND 202 (BACKHALF) SOURCE SAMPLING TITLE PAGE

Source Information				
Plant Name	Fibrominn Biomass Power Plant			
Sampling Location	Stack Outlet			
Fuel or Source Type	Biomass			
Fuel F-Factor	1890	1890	1890	

Test Information				
Starting Test Date	07/03/07			
Project #	snc-07-benson.mn-comp#1			
Operator	TKG			
Standard Temperature	68	oF		
Standard Pressure	29.92	in Hg		
Minimum Required Sample Vol.	indust. spec.	100	scf	
Run Duration	chk Subpart	150	minutes	
Unit Number	OUT-PM			
Load	% or w/DB	100%		
Base Run Number	OUT-PM			
Number of Ports Available	4			
Number of Ports Used	4			
Port Inside Diameter	5.00 in			
Circular Stack				

Test Equipment Information					
Run		1	2	3	
Meter Box Number	from ACS	SAMP-CP-0016	SAMP-CP-0016	SAMP-CP-0016	
Meter Calibration Factor	(Y)	1.002	1.002	1.002	
Orifice Meter Coefficient	($\Delta H @$)	1.832	1.832	1.832	in H ₂ O
Pitot Identification	from ACS	SAMP-HP-0004	SAMP-HP-0011	SAMP-HP-0004	
Pitot Tube Coefficient	(C _p)	0.840	0.840	0.840	
Orsat Identification	from ACS	N/A	N/A	N/A	
Nozzle Number	from ACS	R#8	R#1	R#8	
Nozzle Diameter	(D _n)	0.226	0.230	0.226	in
Probe Number	from ACS	SAMP-HP-0004	SAMP-HP-0011	SAMP-HP-0004	
Probe Length		60.00	60.00	60.00	in
(SS, Glass) Liner Material	from list	inconel	inconel	inconel	
Sample Case / Oven Number	from ACS	SAMP-BH-0027	SAMP-BH-0004	SAMP-BH-0028	
Impinger Case Number	from ACS	SAMP-BC-0004	SAMP-BC-0003	SAMP-BC-0026	
Acetone Lot Number	from bottle	C38B11	C38B11	C38B11	


Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	5634 S. 122nd East Ave., Suite F
City, State Country Zip	Tulsa, Oklahoma 74146
Project Manager	Thomas K. Graham
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131

METHOD 1 - SAMPLE AND VELOCITY TRAVERSES FOR CIRCULAR SOURCES

Plant Name	Fibrominn Biomass Power Plant	Date	07/03/07
Sampling Location	Stack Outlet	Project #	snc-07-benson.mn-comp#1
Operator	TKG	# of Ports Available	4
Stack Type	Circular	# of Ports Used	4
Stack Size	Large	Port Inside Diameter	5.00

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L _{fw})	129.00	in
Distance to Near Wall of Stack	(L _{nw})	21.00	in
Diameter of Stack	(D)	108.00	in
Area of Stack	(A _s)	63.62	ft ²

Distance from Port to Disturbances			
Distance Upstream	(A)	2358.00	in
Diameters Upstream	(A _D)	21.83	diameters
Distance Downstream	(B)	910.00	in
Diameters Downstream	(B _D)	8.43	diameters



Number of Traverse Points Required			
Diameters to Flow Disturbance		Minimum Number of Traverse Points ^a	
Down Stream	Up Stream	Particulate Points	Velocity Points
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
>= 8.00	>=2.00	8 or 12 ²	8 or 12 ²
Upstream Spec		12	12
Downstream Spec		12	12
Traverse Pts Required		12	12

¹ Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.
² 8 for Circular Stacks 12 to 24 inches
 12 for Circular Stacks over 24 inches

Location of Traverse Points in Circular Stacks									
Traverse Point	(Fraction of Stack Dimension from Inside Wall to Traverse Point)								
Number	Number of Traverse Points Across the Stack								
	2	4	6	8	10	12	14	16	18
1	.146	.067	.044	.032	.026	.021	.018	.016	.014
2	.854	.250	.146	.105	.082	.067	.057	.049	.044
3		.750	.296	.194	.146	.118	.099	.085	.075
4		.933	.704	.323	.226	.177	.146	.125	.109
5			.854	.677	.342	.250	.201	.169	.146
6			.956	.806	.658	.356	.269	.220	.188
7				.895	.774	.644	.366	.283	.236
8				.968	.854	.750	.634	.375	.296
9					.918	.823	.731	.625	.382
10					.974	.882	.799	.717	.618
11						.933	.854	.780	.704
12						.979	.901	.831	.764

Number of Traverse Points Used			
4	Ports by	3	Across
12	Pts Used	12	Required
			Particulate Traverse

Traverse Point Locations			
Traverse Point Number	Fraction of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
		in	in
1	0.04	4 6/8	25 6/8
2	0.15	15 6/8	36 6/8
3	0.30	32	53
4			
5			
6			
7			
8			
9			
10			
11			
12			

METHOD 2 - DETERMINATION OF STACK GAS VELOCITY AND VOLUMETRIC FLOW RATE

Plant Name	Fibrominn Biomass Power Plant			Date	06/30/07
Sampling Location	Stack Outlet			Project #	snc-07-benson.mn-comp#1
Operator	TKG			# of Ports Used	4
Stack Type	Circular			Pitot Identification	SAMP-HP-0004
Pitot Leak Check	<input checked="" type="checkbox"/>	PreTest	<input checked="" type="checkbox"/>	PostTest	Pitot Coefficient (C_p) 0.84

Stack Dimensions				Velocity Traverse Data				
Diameter or Length of Stack	(D)	108.00	in	Run Number		OUT-PM-V1		
Width of Stack	(W)		in	Run Time	12:00	Start	12:10	End
Area of Stack	(A _s)	63.62	ft ²	Traverse Point	Velocity Head (Δp)	Null Angle (N _a)	Stack Temp (t _s)	Local Velocity (v _{s(i)})

Pressures			
Barometric Pressure	(P _b)	29.92	in Hg
Static Pressure	(P _{static})	-0.23	in H ₂ O
Absolute Stack Pressure	(P _s)	29.90	in Hg

Traverse Point	Velocity Head (Δp)	Null Angle (N _a)	Stack Temp (t _s)	Local Velocity (v _{s(i)})
A-1	1.00	0	291	69.6
A-2	1.30	-10	291	79.3
A-3	1.30	0	290	79.3
B-1	1.10	-5	290	72.9
B-2	1.30	0	290	79.3
B-3	0.14	0	290	26.0
C-1	1.30	0	293	79.4
C-2	1.00	0	293	69.7
C-3	1.20	0	293	76.3
D-1	1.30	0	292	79.4
D-2	1.30	-10	291	79.3
D-3	1.40	-15	290	82.3

Stack Gas Composition			
Composition Data:		Estimated Composition	
Carbon Dioxide Concentration	(%CO ₂)	14.4	%
Oxygen Concentration	(%O ₂)	4.8	%
Carbon Monoxide Concentration	(%CO)	0.0	%
Nitrogen Concentration	(%N ₂)	80.8	%
Stack Moisture Content	(B _{ws})	30.000	%
Stack Dry Molecular Weight	(M _d)	30.50	lb/lb-mole
Stack Wet Molecular Weight	(M _s)	26.75	lb/lb-mole

Results			
Avg Stack Gas Velocity	(v _s)	72.7	ft/sec
Avg Stack Dry Std Flow Rate	(Q _{sd})	8,192,279	dscf/hr
Avg Stack Dry Std Flow Rate	(Q _{sd})	136,538	dscf/min
Avg Stack Wet Flow Rate	(Q _{aw})	277,654	acf/min
Avg Stack Wet Std Flow Rate	(Q _{sw})	11,703,256	ascf/hr

Stack Cross Section Schematic			

Average	1.14	3	291
	1.05	= Square roots of Δp	

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name	Fibrominn Biomass Power Plant				Date	07/03/07	
Sampling Location	Stack Outlet				Project #	snc-07-benson.mn-comp#1	
Operator	TKG				# of Ports Used	4	
Fuel Type	Biomass		Minimum Fuel Factor	1.000	Maximum Fuel Factor	1.120	
Orsat Leak Check	<input checked="" type="checkbox"/>	PreTest	<input checked="" type="checkbox"/>	PostTest	Orsat Identification	N/A	

Gas Analysis Data										
Run Number		OUT-PM-1			Run Start Time		23:42	Run Stop Time		2:38
Sample Analysis Time	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N ₂)	Dry Molecular Weight (M _d)	Molecular Weight Deviation (ΔM _d)	
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole	
2:56	14.0	5.0	100.0	14.0	5.0	0.0	81.0	30.44	0.00	
Results			Averages	14.0	5.0	0.0	81.0	30.44		
Average Calculated Fuel Factor			(F _o) _{avg}	1.135	Molecular Wt Deviation < 0.3?				<input checked="" type="checkbox"/>	
Average Excess Air			(%EA) _{avg}	30.5	percent	Fuel Factor in Handbook Range?				<input checked="" type="checkbox"/>

Gas Analysis Data										
Run Number		OUT-PM-2			Run Start Time		2:44	Run Stop Time		5:22
Sample Analysis Time	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N ₂)	Dry Molecular Weight (M _d)	Molecular Weight Deviation (ΔM _d)	
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole	
2:38	14.0	5.0	100.0	14.0	5.0	0.0	81.0	30.44	0.00	
Results			Averages	14.0	5.0	0.0	81.0	30.44		
Average Calculated Fuel Factor			(F _o) _{avg}	1.135	Molecular Wt Deviation < 0.3?				<input checked="" type="checkbox"/>	
Average Excess Air			(%EA) _{avg}	30.5	percent	Fuel Factor in Handbook Range?				<input checked="" type="checkbox"/>

Gas Analysis Data										
Run Number		OUT-PM-3			Run Start Time		5:27	Run Stop Time		7:58
Sample Analysis Time	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N ₂)	Dry Molecular Weight (M _d)	Molecular Weight Deviation (ΔM _d)	
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole	
2:31	14.0	5.0	100.0	14.0	5.0	0.0	81.0	30.44	0.00	
Results			Averages	14.0	5.0	0.0	81.0	30.44		
Average Calculated Fuel Factor			(F _o) _{avg}	1.135	Molecular Wt Deviation < 0.3?				<input checked="" type="checkbox"/>	
Average Excess Air			(%EA) _{avg}	30.5	percent	Fuel Factor in Handbook Range?				<input checked="" type="checkbox"/>

Fuel Factor Fo		
Fuel Type	Minimum	Maximum
Coal, Anthracite	1.016	1.130
Coal, Lignite	1.016	1.130
Coal, Bituminous	1.083	1.230
Oil, Distillate	1.260	1.413
Oil, Residual	1.210	1.370
Gas, Natural	1.600	1.836
Gas, Propane	1.434	1.586
Gas, Butane	1.405	1.553
Biomass	1.000	1.120
Wood Bark	1.003	1.130

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name	Fibrominn Biomass Power Plant			Date	07/03/07
Sampling Location	Stack Outlet			Project #	snc-07-benson.mn-comp#1
Operator	TKG			# of Ports Used	4
Stack Type	Circular			Meter Box Number	SAMP-CP-0016
Train Leak Check	<input checked="" type="checkbox"/>	PreTest	<input checked="" type="checkbox"/>	PostTest	Meter Cal Factor (Y) 1.002

Moisture Content Data							
Run Number	OUT-PM-1			Run Start Time	23:42	Run Stop Time	2:38
Total Meter Volume	(V _m)	110.910	dcf	Barometric Press.	(P _b)	29.49	in Hg
Avg Stack Temp	(t _s) _{avg}	293	oF	Stack Static Press.	(P _{static})	-0.23	in H2O
Avg Meter Temp	(t _m) _{avg}	78	oF	Avg Orifice Press.	(ΔH) _{avg}	1.87	in H2O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
	g	g	g	g	g	g	g
Contents	DI	DI	DI	Sil Gel			
Final Value	(V _i),(W _i)	977.50	993.40	830.80	937.30		
Initial Value	(V _i),(W _i)	757.50	759.00	736.60	900.70		
Net Value	(V _n),(W _n)	220.0	234.4	94.2	36.6		
Results							
Total Weight	(W _t)	585.20	g	Water Vol Weighed	(V _{wsg(std)})	27.592	scf
Std Meter Volume	(V _{m(std)})	107.915	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws(calc)})	20.4	%	Final Moisture Content	(B _{ws})	20.4	%

Moisture Content Data							
Run Number	OUT-PM-2			Run Start Time	2:44	Run Stop Time	5:22
Total Meter Volume	(V _m)	114.900	dcf	Barometric Press.	(P _b)	29.49	in Hg
Avg Stack Temp	(t _s) _{avg}	297	oF	Stack Static Press.	(P _{static})	-0.23	in H2O
Avg Meter Temp	(t _m) _{avg}	80	oF	Avg Orifice Press.	(ΔH) _{avg}	1.98	in H2O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
	g	g	g	g	g	g	g
Contents	DI	DI	DI	Sil Gel			
Final Value	(V _i),(W _i)	1005.60	1002.90	931.20	961.50		
Initial Value	(V _i),(W _i)	753.40	748.60	731.60	925.50		
Net Value	(V _n),(W _n)	252.2	254.3	199.6	36.0		
Results							
Total Weight	(W _t)	742.10	g	Water Vol Weighed	(V _{wsg(std)})	34.990	scf
Std Meter Volume	(V _{m(std)})	111.451	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws})	23.9	%	Final Moisture Content	(B _{ws})	23.9	%

Moisture Content Data							
Run Number	OUT-PM-3			Run Start Time	5:27	Run Stop Time	7:58
Total Meter Volume	(V _m)	122.670	dcf	Barometric Press.	(P _b)	29.49	in Hg
Avg Stack Temp	(t _s) _{avg}	296	oF	Stack Static Press.	(P _{static})	-0.23	in H2O
Avg Meter Temp	(t _m) _{avg}	81	oF	Avg Orifice Press.	(ΔH) _{avg}	2.25	in H2O
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7
	g	g	g	g	g	g	g
Contents	DI	DI	DI	Sil Gel			
Final Value	(V _i),(W _i)	970.50	941.30	951.10	1003.45		
Initial Value	(V _i),(W _i)	773.40	733.30	715.00	915.70		
Net Value	(V _n),(W _n)	197.1	208.0	236.1	87.8		
Results							
Total Weight	(W _t)	728.95	g	Water Vol Weighed	(V _{wsg(std)})	34.370	scf
Std Meter Volume	(V _{m(std)})	118.956	dscf	Sat. Moisture Content	(B _{ws(svp)})	100.0	%
Calc Moisture Content	(B _{ws})	22.4	%	Final Moisture Content	(B _{ws})	22.4	%

METHOD 5 (FRONTHALF) AND 202 (BACKHALF) - SAMPLE RECOVERY AND INTEGRITY DATA SHEET

Plant Name	Fibrominn Biomass Power Plant	Date	07/03/07
Sampling Location	Stack Outlet	Project #	snc-07-benson.mn-comp#1
Operator	TKG	Acetone Lot Number	C38B11

Run History Data				
Run Number	OUT-PM-1	OUT-PM-2	OUT-PM-3	
Run Start Time	23:42	2:44	5:27	(hh:mm)
Run Stop Time	2:38	5:22	7:58	(hh:mm)
Train Prepared By	KV/SK	KV/SK	KV/SK	
Train Recovered By	KV/SK	KV/SK	KV/SK	
Recovery Date	7/3/2007	7/4/2007	7/4/2007	(mm/dd/yy)
Relinquished By	TG	TG	TG	
Received By	PS	PS	PS	
Relinquished Date	7/5/2007	7/5/2007	7/5/2007	(mm/dd/yy)
Relinquished Time	19:00	19:00	19:00	(hh:mm)

Equipment Identification Numbers			
Filter	M-1916	M-2149	M-1973
Acetone Wash	ok	ok	ok
Silica Gel	ok	ok	ok
Impinger Case	SAMP-BC-0004	SAMP-BC-0003	SAMP-BC-0026
Sample Box	SAMP-BH-0027	SAMP-BH-0004	SAMP-BH-0028
Oven	ok	ok	ok

Sample Blank Taken YES

Moisture Content Data					
Impingers 1, 2, and 3 - Liquid Volume					
Final Volume	(V _f)	2806.8	2945.0	2868.1	ml
Initial Volume	(V _i)	2257.2	2237.6	2225.7	ml
Net Volume	(V _n)	549.6	707.4	642.4	ml
Comments					
Impinger 4 - Silica Gel Weight					
Final Weight	(W _f)	937.3	961.5	1003.5	g
Initial Weight	(W _i)	900.7	925.5	915.7	g
Net Weight	(W _n)	36.6	36.0	87.8	g
Comments					
Total Water Collected					
Total Volume	(V _{lc})	586.3	743.4	730.3	ml

METHOD 5 (FRONTHALF) AND 202 (BACKHALF) - SAMPLE ANALYTICAL DATA SHEET

Plant Name	Fibrominn Biomass Power Plant	Date	07/03/07
Sampling Location	Stack Outlet	Project #	snc-07-benson.mn-comp#1
Operator	TKG	Acetone Lot Number	C38B11

Analytical Data							
Placed in Desiccator				Run	OUT-PM-1	Start Time	23:42
	Number	Date	Time	Leakage Evident?	<input type="checkbox"/>		
Filter	M-1916	07/06/07	10:30	Estimated Volume	0.00		
Probe Wash Beaker #	100-94	07/06/07	10:30				
Water Beaker #	400-54	07/06/07	10:30				
MeCl (org) Beaker #	250-22	07/06/07	10:30				

Weight Data							
Filter and Beaker Weight		Filter	Date	Time	Humidity	Temp	Cal Audit
		g	mm/dd/yy	hh:mm	%RH	oF	g
Measurement 1	(m _{1f})	49.0370	07/06/07	16:37	38%	76	
Measurement 2	(m _{2f})	49.0365	76/7	11:45	38%	75	
Measurement 3	(m _{3f})						
Measurement 4	(m _{4f})						
Probe Wash and Beaker Weight		Acetone	Date	Time	Humidity	Temp	Cal Audit
		g	mm/dd/yy	hh:mm	%RH	oF	g
Measurement 1	(m _{1a})	55.2304	07/06/07	16:37	38%	76	
Measurement 2	(m _{2a})	55.2307	76/7	11:45	38%	75	
Measurement 3	(m _{3a})						
Measurement 4	(m _{4a})						
Imp Content and Beaker Weight		Imp Water	Date	Time	Humidity	Temp	Cal Audit
		g	mm/dd/yy	hh:mm	%RH	oF	g
Measurement 1	(m _{1ino})	121.8997	07/06/07	16:37	38%	76	
Measurement 2	(m _{2ino})	121.8997	76/7	11:45	38%	75	
Measurement 3	(m _{3ino})						
Measurement 4	(m _{4ino})						
Organics and Beaker Weight		MeCl Org	Date	Time	Humidity	Temp	Cal Audit
		g	mm/dd/yy	hh:mm	%RH	oF	g
Measurement 1	(m _{1org})	99.8518	07/06/07	16:37	38%	76	
Measurement 2	(m _{2org})	99.8515	76/7	11:45	38%	75	
Measurement 3	(m _{3org})						
Measurement 4	(m _{4org})						

METHOD 5 (FRONTHALF) AND 202 (BACKHALF) - SAMPLE ANALYTICAL DATA SHEET

Plant Name	Fibrominn Biomass Power Plant	Date	07/03/07
Sampling Location	Stack Outlet	Project #	snc-07-benson.mn-comp#1
Operator	TKG	Acetone Lot Number	C38B11

Tare (Pre-Particulate) Weights					
Tare	Filter	Filter Beaker	Acetone Beaker	Imp Content Beaker	
	0.3707	48.6544	55.2202	121.6793	g
Tare	Organics Beaker	PM₁₀ Beaker			
	99.8509			g	Run OUT-PM-1

Sample Volume and Blank Concentrations			
Probe Wash Volume	(v_a)	90.0000	ml
Impinger Content Volume	(v_{ino})	925.0000	ml
Organics Wash Volume	(v_{org})	180.0000	ml
Net Wash Volume	(v_n)	1195.0000	ml
Acetone Blank Weight of Solids	(w_{ab})	0.0011	g
Imp Cont Blank Weight of Solids	(w_{inob})	0.0000	g
MeCl Blank Weight of Solids	(w_{orgb})	0.0004	g
Acetone Blank Volume	(v_{ab})	150.0000	ml
Imp Content Blank Volume	(v_{inob})	200.0000	ml
MeCl Blank Volume	(v_{orgb})	150.0000	ml
Acetone Blank Concentration	(C_a)	0.0072	mg/ml
Imp Content Blank Concentration	(C_{ino})	0.0000	mg/ml
MeCl Blank Concentration	(C_{org})	0.0030	mg/ml

Results							
		Filter_f	PM10_{at'}	Probe_{a'}	Imp Cont_{ino'}	Organics_{org'}	
Final Weight	(m_{fx})	49.0367		55.2305	121.8997	99.8516	g
Tare Weight	(m_{tx})	49.0251		55.2202	121.6793	99.8509	g
Weight Gain	(m_x)	11.6		10.3	220.4	0.7	mg
Blank Adjustment	(W_x)			0.6	0.0	0.5	mg
Total Particulates	(M_n)			241.8			mg

METHOD 5 (FRONTHALF) AND 202 (BACKHALF) - SAMPLE ANALYTICAL DATA SHEET

Plant Name	Fibrominn Biomass Power Plant	Date	07/03/07
Sampling Location	Stack Outlet	Project #	snc-07-benson.mn-comp#1
Operator	TKG	Acetone Lot Number	C38B11

Analytical Data							
Placed in Desiccator				Run	OUT-PM-2	Start Time	2:44
	Number	Date	Time	Leakage Evident?			<input type="checkbox"/>
Filter	M-2149	07/06/07	10:30	Estimated Volume			0.00
Probe Wash Beaker #	100-98	07/06/07	10:30				
Water Beaker #	400-33	07/06/07	10:30				
MeCl (org) Beaker #	250-30	07/06/07	10:30				

Weight Data							
Filter and Beaker Weight		Filter	Date	Time	Humidity	Temp	Cal Audit
		g	mm/dd/yy	hh:mm	%RH	oF	g
Measurement 1	(m _{1f})	54.8877	07/06/07	16:37	38%	76	
Measurement 2	(m _{2f})	54.8882	76/7	11:45	38%	75	
Measurement 3	(m _{3f})						
Measurement 4	(m _{4f})						
Probe Wash and Beaker Weight		Acetone	Date	Time	Humidity	Temp	Cal Audit
		g	mm/dd/yy	hh:mm	%RH	oF	g
Measurement 1	(m _{1a})	54.9307	07/06/07	16:37	38%	76	
Measurement 2	(m _{2a})	54.9309	76/7	11:45	38%	75	
Measurement 3	(m _{3a})						
Measurement 4	(m _{4a})						
Imp Content and Beaker Weight		Imp Water	Date	Time	Humidity	Temp	Cal Audit
		g	mm/dd/yy	hh:mm	%RH	oF	g
Measurement 1	(m _{1ino})	158.5654	07/06/07	16:37	38%	76	
Measurement 2	(m _{2ino})	158.5654	76/7	11:45	38%	75	
Measurement 3	(m _{3ino})						
Measurement 4	(m _{4ino})						
Organics and Beaker Weight		MeCl Org	Date	Time	Humidity	Temp	Cal Audit
		g	mm/dd/yy	hh:mm	%RH	oF	g
Measurement 1	(m _{1org})	91.4065	07/06/07	16:37	38%	76	
Measurement 2	(m _{2org})	91.4063	76/7	11:45	38%	75	
Measurement 3	(m _{3org})						
Measurement 4	(m _{4org})						

METHOD 5 (FRONTHALF) AND 202 (BACKHALF) - SAMPLE ANALYTICAL DATA SHEET

Plant Name	Fibrominn Biomass Power Plant	Date	07/03/07
Sampling Location	Stack Outlet	Project #	snc-07-benson.mn-comp#1
Operator	TKG	Acetone Lot Number	C38B11

Tare (Pre-Particulate) Weights					
Tare	Filter	Filter Beaker	Acetone Beaker	Imp Water Beaker	
	0.3587	54.5144	54.9258	158.2930	g
Tare	Organics Beaker		PM₁₀ Beaker		
	91.4049				g Run OUT-PM-2

Sample Volume and Blank Concentrations			
Probe Wash Volume	(v_a)	90.0000	ml
Impinger Content Volume	(v_{ino})	1040.0000	ml
Organics Wash Volume	(v_{org})	150.0000	ml
Net Wash Volume	(v_n)	1280.0000	ml
Acetone Blank Weight of Solids	(w_{ab})	0.0011	g
Imp Cont Blank Weight of Solids	(w_{inob})	0.0000	g
MeCl Blank Weight of Solids	(w_{orgb})	0.0004	g
Acetone Blank Volume	(v_{ab})	150.0000	ml
Imp Content Blank Volume	(v_{inob})	200.0000	ml
MeCl Blank Volume	(v_{orgb})	150.0000	ml
Acetone Blank Concentration	(C_a)	0.0072	mg/ml
Imp Content Blank Concentration	(C_{ino})	0.0000	mg/ml
MeCl Blank Concentration	(C_{org})	0.0030	mg/ml

Results								
		Filter_f	PM10_{at'}	Probe_{a'}	Imp Cont_{ino'}	Organics_{org'}		
Final Weight	(m_{fx})	54.8880		54.9308	158.5654	91.4064	g	
Tare Weight	(m_{tx})	54.8731		54.9258	158.2930	91.4049	g	
Weight Gain	(m_x)	14.9		5.0	272.4	1.5	mg	
Blank Adjustment	(w_x)			0.6	0.0	0.4	mg	
Total Particulates	(M_n)	292.7						mg

METHOD 5 (FRONTHALF) AND 202 (BACKHALF) - SAMPLE ANALYTICAL DATA SHEET

Plant Name	Fibrominn Biomass Power Plant	Date	07/03/07
Sampling Location	Stack Outlet	Project #	snc-07-benson.mn-comp#1
Operator	TKG	Acetone Lot Number	C38B11

Analytical Data							
Placed in Desiccator				Run	OUT-PM-3	Start Time	5:27
	Number	Date	Time	Leakage Evident?	<input type="checkbox"/>	Estimated Volume	0.00
Filter	M-1973	07/06/07	10:30	Estimated Volume			
Probe Wash Beaker #	250-52	07/06/07	10:30				
Water Beaker #	400-139	07/06/07	10:30				
MeCl (org) Beaker #	250-56	07/06/07	10:30				

Weight Data							
Filter and Beaker Weight		Filter	Date	Time	Humidity	Temp	Cal Audit
		g	mm/dd/yy	hh:mm	%RH	oF	g
Measurement 1	(m _{1f})	54.5513	07/06/07	16:37	38%	76	
Measurement 2	(m _{2f})	54.5518	76/7	11:45	38%	75	
Measurement 3	(m _{3f})						
Measurement 4	(m _{4f})						
Probe Wash and Beaker Weight		Acetone	Date	Time	Humidity	Temp	Cal Audit
		g	mm/dd/yy	hh:mm	%RH	oF	g
Measurement 1	(m _{1a})	102.9624	07/06/07	16:37	38%	76	
Measurement 2	(m _{2a})	102.9620	76/7	11:45	38%	75	
Measurement 3	(m _{3a})						
Measurement 4	(m _{4a})						
Imp Content and Beaker Weight		Imp Water	Date	Time	Humidity	Temp	Cal Audit
		g	mm/dd/yy	hh:mm	%RH	oF	g
Measurement 1	(m _{1ino})	160.8034	07/06/07	16:37	38%	76	
Measurement 2	(m _{2ino})	160.8034	76/7	11:45	38%	75	
Measurement 3	(m _{3ino})						
Measurement 4	(m _{4ino})						
Organics and Beaker Weight		MeCl Org	Date	Time	Humidity	Temp	Cal Audit
		g	mm/dd/yy	hh:mm	%RH	oF	g
Measurement 1	(m _{1org})	103.0957	07/06/07	16:37	38%	76	
Measurement 2	(m _{2org})	103.0953	76/7	11:45	38%	75	
Measurement 3	(m _{3org})						
Measurement 4	(m _{4org})						

METHOD 5 (FRONTHALF) AND 202 (BACKHALF) - SAMPLE ANALYTICAL DATA SHEET

Plant Name	Fibrominn Biomass Power Plant	Date	07/03/07
Sampling Location	Stack Outlet	Project #	snc-07-benson.mn-comp#1
Operator	TKG	Acetone Lot Number	C38B11

Tare (Pre-Particulate) Weights					
Tare	Filter	Filter Beaker	Acetone Beaker	Imp Water Beaker	
	0.3809	54.1568	102.9592	160.5470	g
Tare	Organics Beaker	PM₁₀ Beaker			
	103.0908			g	Run OUT-PM-3

Sample Volume and Blank Concentrations			
Probe Wash Volume	(v_a)	130.0000	ml
Impinger Content Volume	(v_{ino})	1020.0000	ml
Organics Wash Volume	(v_{org})	200.0000	ml
Net Wash Volume	(v_n)	1350.0000	ml
Acetone Blank Weight of Solids	(w_{ab})	0.0011	g
Imp Cont Blank Weight of Solids	(w_{inob})	0.0000	g
MeCl Blank Weight of Solids	(w_{orgb})	0.0004	g
Acetone Blank Volume	(v_{ab})	150.0000	ml
Imp Content Blank Volume	(v_{inob})	200.0000	ml
MeCl Blank Volume	(v_{orgb})	150.0000	ml
Acetone Blank Concentration	(C_a)	0.0072	mg/ml
Imp Content Blank Concentration	(C_{ino})	0.0000	mg/ml
MeCl Blank Concentration	(C_{org})	0.0030	mg/ml

Results							
		Filter_f	PM10_{at'}	Probe_{a'}	Imp Cont_{ino'}	Organics_{org'}	
Final Weight	(m_{fx})	54.5516		102.9622	160.8034	103.0955	g
Tare Weight	(m_{tx})	54.5377		102.9592	160.5470	103.0908	g
Weight Gain	(m_x)	13.9		3.0	256.3	4.7	mg
Blank Adjustment	(w_x)			0.9	0.0	0.6	mg
Total Particulates	(M_n)			276.3			mg

EXAMPLE CALCULATIONS (Reference Method 1 - Circular Stack)

- L_{fw} = distance to far wall of stack (in.)
- L_{nw} = distance to near wall of stack (in.) [reference]
- D = diameter of stack (in.)
- A_s = area of stack (ft²)
- B = distance downstream (in.)
- B_D = stack diameters downstream (dia.)
- A = distance upstream (in.)
- A_D = stack diameters upstream (dia.)

Diameter of Stack (in.)

$$D(in.) = L_{fw} - L_{nw}$$

$$D(in.) = 129 \text{ in.} - 21 \text{ in.} = 108 \text{ in.}$$

Stack Diameters Downstream

$$B_D(dia.) = \frac{B}{D}$$

$$B_D(dia.) = \frac{910 \text{ in.}}{108 \text{ in.}} = 8.43 \text{ diameters}$$

Stack Diameters Upstream

$$A_D(dia.) = \frac{A}{D}$$

$$A_D(dia.) = \frac{2358 \text{ in.}}{108 \text{ in.}} = 21.83 \text{ diameters}$$


Area of Stack (ft²)

$$A_s(ft^2) = \pi \times \left(\frac{D}{2 \times 12} \right)^2$$

$$A_s(ft^2) = 3.14 \times \left(\frac{108.0 \text{ in.}}{2 \times 12 \text{ in./ft}} \right)^2 = 63.62 \text{ ft}^2$$

Number of Traverse Points

Based on 40 CFR Part 60, Appendix A, Method 1, Section 2.2



Traverse Point Locations

Based on 40 CFR Part 60, Appendix A, Method 1, Section 2.3

Location of Traverse Points in Circular Stacks (Fraction of Stack Dimension from Inside Wall to Traverse Point)											
Traverse Point Number	Number of Traverse Points Across the Stack										
	2	4	6	8	10	12	14	16	18	20	24
1	.146	.067	.044	.032	.023	.021	.018	.016	.014	.013	.011
2	.854	.250	.146	.105	.082	.067	.057	.049	.044	.039	.035
3		.750	.296	.194	.146	.118	.099	.085	.075	.067	.060
4		.933	.704	.323	.226	.177	.146	.125	.109	.097	.087
5			.854	.677	.342	.250	.201	.169	.146	.129	.116
6			.956	.806	.658	.356	.269	.220	.188	.165	.146
7				.895	.774	.644	.366	.283	.236	.204	.180
8				.968	.854	.750	.634	.375	.296	.250	.218
9					.918	.823	.731	.625	.392	.306	.262
10					.974	.882	.799	.717	.618	.388	.315
11						.933	.854	.780	.704	.612	.393
12						.979	.901	.831	.764	.694	.607
13							.943	.875	.812	.750	.685
14							.982	.915	.854	.796	.738
15								.951	.891	.835	.782
16								.984	.925	.871	.820
17									.956	.903	.854
18									.986	.933	.884
19										.961	.913
20										.987	.940
21											.965
22											.989
23											.945
24											.968

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 2)

P_b = barometric pressure (in. Hg)

P_{static} = static pressure (in. H₂O)

P_s = absolute stack pressure (in. Hg)

%N₂ = nitrogen concentration (%)

%CO₂ = carbon dioxide concentration (%)

%O₂ = oxygen concentration (%)

%CO = carbon monoxide concentration (%)

MW = molecular weight (lb/lb-mole)

B_{ws} = stack moisture content (%)

M_d = stack dry molecular weight (lb/lb-mole)

M_s = stack wet molecular weight (lb/lb-mole)

T_{std} = standard temperature, 68°F, 528°R

P_{std} = standard pressure, 29.92 in. Hg

v_{sl} = local velocity (ft/sec)

v_s = average stack gas velocity (ft/sec)

Q_{sd} = average stack dry standard flow rate (dscf/hr)

Q_{aw} = average stack wet flow rate (ascf/min)

C_p = pitot tube coefficient

Δp = velocity head (in. H₂O)

A_s = area of stack (ft²)

N_a = null angle (deg.)

t_s = stack temperature (°F)

T_u = temperature offset, 460°R

K_p = pitot tube constant,

$$85.49 \text{ (ft/sec)} \left(\frac{\text{lb/lb-mole}(\text{in. Hg})}{(^{\circ}\text{R})(\text{in. Hg})} \right)^{1/2}$$

Absolute Stack Pressure (in. Hg)

$$P_s \text{ (in. Hg)} = P_b + \frac{P_{static}}{13.6}$$

$$P_s \text{ (in. Hg)} = 29.92 \text{ in. Hg} + \frac{-0.23 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O/in. Hg}} = 29.90 \text{ in. Hg}$$

Nitrogen Concentration (%)

$$\% N_2 = 100 - \% CO_2 - \% O_2 - \% CO$$

$$\% N_2 \text{ (%) } = 100 - 14.39 \% - 4.83 \% - 0 \% = 80.78 \%$$

Stack Dry Molecular Weight (lb/lb-mole)

$$M_d \text{ (lb / lb - mol)} = \sum \left(\frac{MW_{comp}}{100} \times \% \text{ component} \right)$$

$$M_d \text{ (lb/lb-mol)} = \left[\frac{44 \text{ lb/lb-mol}}{100} \times 14.39 \% \right] + \left[\frac{32 \text{ lb/lb-mol}}{100} \times 4.83 \% \right] + \text{etc.} = \frac{30.5 \text{ lb}}{\text{lb-mol}}$$

Stack Wet Molecular Weight (lb/lb-mole)

$$M_s \text{ (lb / lb - mol)} = \left[M_d \times \left(1 - \frac{B_{ws}}{100} \right) \right] + \left[MW_{H_2O} \times \frac{B_{ws}}{100} \right]$$

$$M_s \text{ (lb/lb-mol)} = \left[\frac{30.5 \text{ lb}}{\text{lb-mol}} \times \left(1 - \frac{30 \%}{100} \right) \right] + \left[\frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{30 \%}{100} \right] = \frac{26.75 \text{ lb}}{\text{lb-mol}}$$

Local Velocity (ft/sec)

$$v_{s(l)} \text{ (ft / sec)} = K_p \times C_p \times \sqrt{\Delta p} \times \sqrt{\frac{t_s + T_u}{P_s \times M_s}}$$

$$v_{sl} \text{ (ft/sec)} = \frac{85.49 \text{ ft}}{\text{sec}} \left(\frac{\text{lb/lb-mol}(\text{in. Hg})}{(^{\circ}\text{R})(\text{in. H}_2\text{O})} \right)^{1/2} \times 0.84 \times \sqrt{1.00 \text{ in. H}_2\text{O}} \times \sqrt{\frac{291 + 460 ^{\circ}\text{R}}{29.9 \text{ in. Hg} \times 26.75 \text{ lb/lb-mol}}} = \frac{69.59 \text{ ft}}{\text{sec}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 2)

P_b = barometric pressure (in. Hg)

P_{static} = static pressure (in. H₂O)

P_s = absolute stack pressure (in. Hg)

%N₂ = nitrogen concentration (%)

%CO₂ = carbon dioxide concentration (%)

%O₂ = oxygen concentration (%)

%CO = carbon monoxide concentration (%)

MW = molecular weight (lb/lb-mole)

B_{ws} = stack moisture content (%)

M_d = stack dry molecular weight (lb/lb-mole)

M_s = stack wet molecular weight (lb/lb-mole)

K_p = pitot tube constant,

$$85.49 \text{ (ft/sec)} \left(\frac{\text{(lb/lb-mole)(in. Hg)}}{(\text{°R})(\text{in. Hg})} \right)^{1/2}$$

T_{STD} = standard temperature, 68°F

P_{STD} = standard pressure, 29.92 in. Hg

v_{sl} = local velocity (ft/sec)

v_s = average stack gas velocity (ft/sec)

Q_{SD} = average stack dry standard flow rate (dscf/hr)

Q_{AW} = average stack wet flow rate (acfm/min)

C_p = pitot tube coefficient

Δp = velocity head (in. H₂O)

A_s = area of stack (ft²)

N_A = null angle (deg.)

t_s = stack temperature (°F)

T_u = temperature offset, 460°R

Average Stack Gas Velocity (ft/sec)

$$v_s \text{ (ft/sec)} = K_p \times C_p \times \left(\sqrt{\Delta p} \right)_{avg} \times \sqrt{\frac{(t_s)_{avg} + T_u}{P_s \times M_s}}$$

$$v_{sl} \text{ (ft/sec)} = \frac{85.49 \text{ ft}}{\text{sec}} \left(\frac{\text{(lb/lb-mol)(in. Hg)}}{(\text{°R})(\text{in. H}_2\text{O})} \right)^{1/2} \times 0.84 \times 1.05 \text{ in.H}_2\text{O}^{1/2} \times \sqrt{\frac{291 + 460 \text{ °R}}{29.9 \text{ in. Hg} \times 26.75 \text{ lb/lb-mol}}} = \frac{72.74 \text{ ft}}{\text{sec}}$$

Average Stack Dry Standard Flow Rate (dscfh)

$$Q_{sd} \text{ (dscfh)} = \frac{60 \times 60 \times \left(1 - \frac{B_{ws}}{100} \right) \times v_s \times A_s \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

$$Q_{sd} \text{ (dscf/hr)} = \frac{3600 \text{ sec}}{\text{hr}} \times \left(1 - \frac{30.0 \%}{100} \right) \times \frac{72.74 \text{ ft}}{\text{sec}} \times 63.62 \text{ ft}^2 \times \frac{68 + 460 \text{ °R}}{291 + 460 \text{ °R}} \times \frac{29.90 \text{ in. Hg}}{29.92 \text{ in. Hg}} = \frac{8,192,279 \text{ dscf}}{\text{hr}}$$

Average Stack Wet Flow Rate (acfm)

$$Q_{aw} \text{ (acfm)} = 60 \times v_s \times A_s$$

$$Q_{aw} \text{ (acf/min)} = \frac{60 \text{ sec}}{\text{min}} \times \frac{72.74 \text{ ft}}{\text{sec}} \times 63.62 \text{ ft}^2 = \frac{277,654 \text{ acf}}{\text{min}}$$

Average Stack Wet Standard Flow Rate (ascfh)

$$Q_{sw} \text{ (ascfh)} = \frac{60 \times Q_{aw} \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

$$Q_{sw} \text{ (ascf/hr)} = \frac{60 \text{ min}}{\text{hr}} \times \frac{277,654 \text{ acf}}{\text{min}} \times \frac{68 + 460 \text{ °R}}{291 + 460 \text{ °R}} \times \frac{29.90 \text{ in. Hg}}{29.92 \text{ in. Hg}} = \frac{11,703,256 \text{ ascf}}{\text{hr}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 3a)

%N₂ = nitrogen concentration (%)

%CO₂ = carbon dioxide concentration (%)

%O₂ = oxygen concentration (%)

ppmCO = carbon monoxide concentration (ppm)

%CO = carbon monoxide concentration (%)

M_d = stack dry molecular weight (lb/lb-mole)

(F_o)_{avg} = average calculated fuel factor

(%EA)_{avg} = average excess air (%)

Carbon Monoxide Concentration (%)

$$\% CO = \frac{ppmCO}{10,000}$$

$$\%CO (\%) = \frac{100.00 \text{ ppm}}{10,000 \text{ ppm}/\%} = 1.0E-02 \%$$

Nitrogen Concentration (%)

$$\% N_2 = 100 - \% CO_2 - \% O_2 - \% CO$$

$$\%N_2 (\%) = 100 - 14 \% - 5 \% - 0.01 \% = 80.99 \%$$

Stack Dry Molecular Weight (lb/lb-mole)

$$M_d (\text{lb} / \text{lb} - \text{mol}) = \sum \left(\frac{MW_{comp}}{100} \times \% \text{ component} \right)$$

$$M_d (\text{lb/lb-mol}) = \left[\frac{44 \text{ lb/lb-mol}}{100} \times 14 \% \right] + \left[\frac{32 \text{ lb/lb-mol}}{100} \times 5 \% \right] + \text{etc.} = \frac{30.44 \text{ lb}}{\text{lb-mol}}$$

Average Calculated Fuel Factor

$$F_{o(avg)} = \frac{[20.9 - (\% O_2)_{avg} - (0.5 \times (\% CO)_{avg})]}{[(\% CO_2)_{avg} + (\% CO)_{avg}]}$$

$$F_{o(avg)} = \frac{20.9\% - 5 \% - [0.5 \times 0.01 \%]}{14 \% + 0.01 \%} = 1.135$$

Average Excess Air (%)

$$\% EA_{avg} (\%) = \frac{100 \times [(\% O_2)_{avg} - (0.5 \times (\% CO)_{avg})]}{[0.264 \times (N_2)_{avg}] - [(\% O_2)_{avg} - (0.5 \times (\% CO)_{avg})]}$$

$$(\%EA)_{AVG} = \frac{100 \times \{ 5 \% - [0.5 \times 0.01 \%] \}}{[0.264 \times 80.99 \%] - \{ 5 \% - [0.5 \times 0.01 \%] \}} = 30.5 \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 4)

V_{mf} = final dry gas meter reading (dcf)
 V_{mi} = initial dry gas meter reading (dcf)
 V_m = total meter volume (dcf)
 $t_{m(avg)}$ = average meter temp. (°F)
 $t_{s(avg)}$ = average stack temp. (°F)
 P_b = barometric pressure (in. Hg)
 P_{static} = static pressure (in. H₂O)
 ΔH_{avg} = average orifice pressure (in. H₂O)
 V_i = initial impinger volume (ml)
 V_f = final impinger volume (ml)
 W_i = initial impinger weight (g)
 W_f = final impinger weight (g)
 V_t = total impinger volume (ml) = $\Sigma(V_f - V_i)$

W_t = total impinger weight (g) = $\Sigma(W_f - W_i)$
 K_5 = water mass to std water vapor, 0.04715 ft³/g
 K_1 = standard volume correction, 17.65°R/in. Hg
 Y = meter calibration factor
 T_u = absolute temperature offset, 460°R
 B_{ws} = final moisture content (%) = min of $B_{ws(calc)}$ and $B_{ws(svp)}$

Water Volume Weighed (dscf)

$$V_{wsg(std)} (dscf) = W_t \times K_5$$

$$V_{wsg(std)} = 585.20 \text{ g} \times 0.04715 \text{ ft}^3/\text{g} = 27.592 \text{ dscf}$$

Standard Meter Volume (dscf)

$$V_{m(std)} (dscf) = \frac{K_1 \times Y \times V_m \times \left(P_b + \frac{\Delta H_{avg}}{13.6} \right)}{(t_m)_{avg} + T_u}$$

$$V_{m(std)} = \frac{17.65 \text{ }^\circ\text{R}}{\text{in. Hg}} \times 1.00 \times 110.91 \text{ dcf} \times \frac{29.49 \text{ in. Hg} + \frac{1.87 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O / in. Hg}}}{78 \text{ }^\circ\text{F} + 460 \text{ }^\circ\text{R}} = 107.92 \text{ dscf}$$

Calculated Moisture Content (%)

$$B_{ws(calc)} (\%) = 100 \times \frac{V_{wsg(std)}}{V_{wsg(std)} + V_{m(std)}}$$

$$B_{ws(calc)} = 100 \times \frac{27.59218 \text{ dscf}}{27.59218 \text{ dscf} + 107.9155 \text{ dscf}} = 20.36208 \%$$

Saturated Moisture Content (%)

$$B_{ws(svp)} (\%) = 100 \times \frac{10^{\frac{6.691 - \frac{3144}{t_{s(avg)} + 390.86}}{P_b + \frac{P_{static}}{13.6}}}}{\leq 100}$$

$$B_{ws(svp)} = 100 \times \frac{10^{\left[\frac{6.691 - \frac{3144}{293 \text{ }^\circ\text{F} + 390.86}}{29.49 \text{ in. Hg} + \frac{-0.23 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O / in. Hg}} \right]}}{\leq 100} = 100 \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Isokinetic Sampling)

C_n = nozzle diameter constant, 0.03575
 Q_m = estimated orifice flow rate, 0.750 acfm
 else V_m/Θ from previous run
 V_m = total meter volume (acfm)
 Θ = total sampling time (min)
 t_m = average gas meter temperature (°F)
 T_u = absolute temperature offset, 460°R
 C_p = pitot tube coefficient
 B_{wm} = meter moisture content (%)
 B_{ws} = stack moisture content (%)
 t_s = average stack temperature (°F)
 M_d = stack dry molecular weight (lb/lb-mole)
 P_s = absolute stack pressure (in. Hg)
 C_k = K Factor Constant, 849.8

Δp_{avg} = average pitot tube differential pressure (in. H₂O)
 $\Delta H@$ = DH @ 0.75 SCFM (in. H₂O)
 D_{na} = actual nozzle diameter (in.)
 Δp = velocity head (in. H₂O)

Desired Orifice (in. H₂O)

$$\Delta H_d (in. H_2O) = K \times \Delta p$$

$$\Delta H_d (in. H_2O) = 1.28 \times 1.5 \text{ in. H}_2\text{O} = 1.918 \text{ in. H}_2\text{O}$$

Absolute Meter Pressure (in. Hg)

$$P_m (in. Hg) = P_b + \frac{\Delta H @}{13.6}$$

$$P_m (in. Hg) = 29.49 \text{ in. Hg} + \frac{1.83 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O/in. Hg}} = 29.62 \text{ in. Hg}$$

Recommended Nozzle Diameter (in.)

$$D_{ni} (in.) = \sqrt{\frac{C_n \times Q_m \times P_m}{(t_m + T_u) \times C_p} \times \left(\frac{1 - \frac{B_{wm}}{100}}{1 - \frac{B_{ws}}{100}} \right) \times \sqrt{(t_s + T_u) \times \left[\frac{M_d \times \left(1 - \frac{B_{ws}}{100} \right) + (18 \times B_{ws})}{P_s \times \Delta p_{avg}} \right]}}$$

$$D_{ni} (in.) = \frac{0.03575 \text{ (lb-mole} \cdot \text{°R} \cdot \text{in. H}_2\text{O)}^{1/2} \cdot \text{min} \cdot \text{in.}^2}{\text{acfm} \cdot \text{in. Hg}^{3/4} \cdot \text{lb}^{1/2}} \times \frac{0.75 \text{ acfm} \times 29.62 \text{ in. Hg}}{\left[\frac{81 \text{ °F} + 460 \text{ °R}}{0.84} \right] \times \left(\frac{1 - \frac{0.0 \%}{100}}{1 - \frac{25.0 \%}{100}} \right)} \times \sqrt{\frac{30.44 \text{ lb}}{\text{lb-mole}} \times \left(1 - \frac{25.0 \%}{100} \right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \times 25.0 \% \right)} = 0.245 \text{ in.}$$

DP to DH Isokinetic Factor

$$K = C_k \times C_p^2 \times \Delta H @ \times D_{na}^4 \times \left[\frac{M_d \times \left(1 - \frac{B_{wm}}{100} \right) + (18 \times \frac{B_{wm}}{100})}{M_d \times \left(1 - \frac{B_{ws}}{100} \right) + (18 \times \frac{B_{ws}}{100})} \right] \times \left(\frac{1 - \frac{B_{ws}}{100}}{1 - \frac{B_{wm}}{100}} \right)^2 \times \left(\frac{t_m + T_u}{t_s + T_u} \right) \times \frac{P_s}{P_m}$$

$$K = \frac{849.8}{\text{in. H}_2\text{O} \cdot \text{in.}^4} \times 0.84^2 \times 1.83 \text{ in. H}_2\text{O} \times 0.225667^4 \times \left(\frac{1 - \frac{25.0 \%}{100}}{1 - \frac{0.0 \%}{100}} \right)^2 \times \left(\frac{81 \text{ °F} + 460 \text{ °R}}{291 \text{ °F} + 460 \text{ °R}} \right) \times \left[\frac{\left(\frac{30.44 \text{ lb}}{\text{lb-mole}} \times \left(1 - \frac{0.0 \%}{100} \right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{0.0 \%}{100} \right) \right)}{\left(\frac{30.44 \text{ lb}}{\text{lb-mole}} \times \left(1 - \frac{25.0 \%}{100} \right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{25.0 \%}{100} \right) \right)} \times \frac{29.47 \text{ in. Hg}}{29.62 \text{ in. Hg}} \right] = 1.28$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 5)

K_4 = isokinetic conversion constant, 0.0945 min·in. Hg/sec·°R

$m_{\#x}$ = weight measurements (g)

v_a = acetone volume (ml)

v_{ino} = impinger content volume (ml)

v_{org} = organics wash volume (ml)

w_x = blank weight of solids (g)

v_x = blank volume (ml)

m_{fx} = final weight, avg of last two measurements (g)

m_{tx} = tare weight (g)

Total Particulates (mg)

$$M_n (mg) = \Sigma (m_x - W_x)$$

$$M_n (mg) = \Sigma [10.3 \text{ mg} - 0.645 \text{ mg}] + \text{etc...} = 241.84 \text{ mg}$$

Local Stack Velocity (ft/sec)

$$v_{s(l)} (ft/sec) = K_p \times C_p \times \sqrt{\Delta p} \times \sqrt{\frac{t_s + T_u}{P_s \times \left[M_d \times \left(1 - \frac{B_{ws}}{100} \right) + \left(18 \times \frac{B_{ws}}{100} \right) \right]}}$$

$$v_{s(l)} (ft/sec) = \frac{85.49 \text{ ft}}{\text{sec}} \left[\frac{(\text{lb/lb-mol})(\text{in. Hg})}{(^{\circ}\text{R})(\text{in. H}_2\text{O})} \right]^{1/2} \times 0.84 \times \sqrt{1.50 \text{ in. H}_2\text{O}}$$

$$\sqrt{\frac{306 \text{ } ^{\circ}\text{F} + 460 \text{ } ^{\circ}\text{R}}{29.47 \text{ in. Hg} \times \left[\frac{30.44 \text{ lb}}{\text{lb-mole}} \times \left(1 - \frac{25.0 \%}{100} \right) + \left(\frac{18 \text{ lb}}{\text{lb-mole}} \times \frac{25.0 \%}{100} \right) \right]}} = \frac{85.77 \text{ ft}}{\text{sec}}$$

Cumulative Percent Isokinetic (%)

$$I(\%) = \frac{K_4 \times ((t_s)_{avg} + T_u) \times V_m}{\left(\Theta \times (v_{s(l)})_{avg} \times P_s \times \pi \times \left(\frac{D_{na}}{2} \times \frac{1}{12} \right)^2 \right) \times \left(1 - \frac{B_{ws}}{100} \right)}$$

$$I(\%) = \frac{0.0945 \text{ min} \cdot \text{in. Hg}}{\text{sec} \cdot ^{\circ}\text{R}} \times \left[307 \text{ } ^{\circ}\text{F} + 460 \text{ } ^{\circ}\text{R} \right] \times 107.92 \text{ scf}$$

$$12.5 \text{ min} \times \frac{85.80 \text{ ft}}{\text{sec}} \times 29.47 \text{ in. Hg} \times 3.14 \times \left(\frac{0.225667 \text{ in.}}{2} \times \frac{\text{ft.}}{12 \text{ in.}} \right)^2 \times \left(1 - \frac{25 \%}{100} \right) = 98.80142 \%$$

Net Wash Volume (ml)

$$v_n (ml) = v_a + v_{ino} + v_{org}$$

$$v_n (ml) = 90 \text{ ml} + 925 \text{ ml} + 180 \text{ ml} = 1195 \text{ ml}$$

Blank Concentration (mg/ml)

$$C_x (mg/ml) = \frac{1000 \times w_x}{v_x}$$

$$C_x (mg/ml) = \frac{1000 \times 0.001075 \text{ g}}{150 \text{ ml}} = \frac{0.007167 \text{ mg}}{\text{ml}}$$

Blank Adjustment (lesser of)

$$W_x (mg) = m_x \dots \text{or} \dots v_x \times C_x$$

$$W_x (mg) = 10.3 \text{ mg or } 90 \text{ ml} \times \frac{0.007167 \text{ mg}}{\text{ml}} = 0.645 \text{ mg}$$

Weight Gain (mg)

$$m_x (mg) = (m_{fx} - m_{tx}) \times 1000$$

$$m_x (mg) = [55.2305 \text{ mg} - 55.2202 \text{ mg}] \times 1000 = 10.3 \text{ mg}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 5)

M_n = total particulates (mg)

$V_{m(std)}$ = standard meter volume (dscf)

Q_{sd} = dry standard stack flow rate (dscfm)

F_d = fuel f-factor (dscf/MMBtu)

% O_2 = oxygen percentage (%)

Q_{sw} = wet standard stack flow rate (ascfm)

Stack Particulate Concentration (g/dscf)

$$c_s (g / dscf) = 0.001 \times \frac{M_n}{V_{m(std)}}$$

$$c_s (g/dscf) = \frac{g}{1000 \text{ mg}} \times \frac{241.84 \text{ mg}}{107.92 \text{ dscf}} = \frac{0.00 \text{ g}}{\text{dscf}}$$

Stack Particulate Concentration (gr/dscf)

$$c'_s (gr / dscf) = 0.001 \times \frac{M_n}{V_{m(std)}} \times \frac{7000}{453.592}$$

$$c'_s (gr/dscf) = \frac{g}{1000 \text{ mg}} \times \frac{241.84 \text{ mg}}{107.92 \text{ dscf}} \times \frac{7000 \text{ gr}}{\text{lb}} \times \frac{\text{lb}}{453.592 \text{ g}} = \frac{0.034583 \text{ gr}}{\text{dscf}}$$

Particulate Emissions Rate (kg/hr)

$$E (kg / hr) = c_s \times Q_{sd} \times \frac{60}{1000}$$

$$E (kg/hr) = \frac{\text{kg}}{1000 \text{ g}} \times \frac{60 \text{ min}}{\text{hr}} \times \frac{0.00 \text{ g}}{\text{dscf}} \times \frac{176,434 \text{ dscf}}{\text{min}} = \frac{23.72 \text{ kg}}{\text{hr}}$$

Particulate Emissions Rate (lb/hr)

$$E' (lb / hr) = \frac{M_n \times Q_{sd}}{V_{m(std)}} \times \frac{60}{453.592 \times 1000}$$

$$E' (lb/hr) = \frac{g}{1000 \text{ mg}} \times \frac{60 \text{ min}}{\text{hr}} \times \frac{\text{lb}}{453.592 \text{ g}} \times \frac{241.84 \text{ mg}}{107.92 \text{ dscf}} \times \frac{176,434 \text{ dscf}}{\text{min}} = \frac{52.29946 \text{ lb}}{\text{hr}}$$

Particulate Emissions Rate (ton/yr)

$$E'' (ton / yr) = E' \times \frac{8760}{2000}$$

$$E'' (ton/yr) = \frac{\text{ton}}{2000 \text{ lb}} \times \frac{8760 \text{ hr}}{\text{yr}} \times \frac{52.29946 \text{ lb}}{\text{hr}} = \frac{229.07 \text{ ton}}{\text{yr}}$$

Particulate Emissions Rate (lb/MMBtu)

$$E''' (lb / MMBtu) = \frac{M_n \times F_d}{V_{m(std)} \times 1000 \times 453.592} \times \left(\frac{20.9}{20.9 - \%O_2} \right)$$

$$E''' (lb/MMBtu) = \frac{g}{1000 \text{ mg}} \times \frac{\text{lb}}{453.592 \text{ g}} \times \frac{241.84 \text{ mg}}{107.92 \text{ dscf}} \times \frac{1,890 \text{ dscf}}{\text{MMBtu}} \times \left(\frac{20.9}{20.9 - 5.0 \%} \right) = \frac{0.06052 \text{ lb}}{\text{MMBtu}}$$

Heat Input (MMBtu/hr)

$$HI (MMBtu / hr) = Q_{sw} \times 1000 \times \left(\frac{100 - B_{ws}}{100 \times F_d} \right) \times \left(\frac{20.9 - \%O_2}{20.9} \right)$$

$$HI (MMBtu/hr) = \frac{13,292.7 \text{ wkscf}}{\text{hr}} \times \frac{10^3 \text{ scf}}{\text{kscf}} \times \left(\frac{100 - 20.4 \%}{100 \times 1,890 \text{ dscf/MMBtu}} \right) \times \left(\frac{20.9 - 5.0 \%}{20.9} \right) = \frac{784 \text{ MMBtu}}{\text{hr}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

TEST RESULTS AND CALCULATIONS

Opacity Emissions Data

Company: Fibrominn, LLC
Equipment: Biomass Boiler Stack Exhaust
Location: Benson, Minnesota
Date: July 2, 2007
Project #: snc-07-benson.mn-comp#1

Run 1

Average Opacity: 2.69 %
Maximum Opacity: 15 %
6 Minute Average: 3.07 %
6 Minute Maximum: 14.58 %
Readings at 20 %: 0 readings

TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.
0.00	0	N/A	15.00	15	13.75	30.00	0	1.67	45.00	5	0.21
0.25	0	N/A	15.25	15	13.96	30.25	0	1.67	45.25	5	0.42
0.50	0	N/A	15.50	15	14.17	30.50	0	1.67	45.50	5	0.63
0.75	0	N/A	15.75	15	14.38	30.75	0	1.67	45.75	5	0.83
1.00	0	N/A	16.00	15	14.58	31.00	0	1.67	46.00	0	0.83
1.25	0	N/A	16.25	15	14.58	31.25	0	1.67	46.25	0	0.83
1.50	0	N/A	16.50	15	14.58	31.50	0	1.67	46.50	0	0.83
1.75	0	N/A	16.75	15	14.58	31.75	0	1.67	46.75	0	0.83
2.00	0	N/A	17.00	10	14.38	32.00	0	1.46	47.00	0	0.83
2.25	0	N/A	17.25	10	14.17	32.25	0	1.25	47.25	0	0.83
2.50	0	N/A	17.50	10	13.96	32.50	0	1.04	47.50	0	0.83
2.75	0	N/A	17.75	10	13.75	32.75	0	0.83	47.75	0	0.83
3.00	0	N/A	18.00	10	13.54	33.00	0	0.63	48.00	0	0.83
3.25	0	N/A	18.25	10	13.33	33.25	0	0.42	48.25	0	0.83
3.50	0	N/A	18.50	5	12.92	33.50	0	0.21	48.50	0	0.83
3.75	0	N/A	18.75	5	12.50	33.75	0	0.00	48.75	0	0.83
4.00	0	N/A	19.00	0	12.61	34.00	0	0.00	49.00	0	0.83
4.25	0	N/A	19.25	0	12.73	34.25	0	0.00	49.25	0	0.83
4.50	0	N/A	19.50	0	12.62	34.50	0	0.00	49.50	0	0.83
4.75	0	N/A	19.75	0	12.50	34.75	0	0.00	49.75	0	0.83
5.00	0	N/A	20.00	5	12.00	35.00	0	0.00	50.00	0	0.83
5.25	0	N/A	20.25	5	11.50	35.25	0	0.00	50.25	0	0.83
5.50	0	N/A	20.50	5	11.00	35.50	0	0.00	50.50	0	0.83
5.75	0	0.00	20.75	5	10.50	35.75	0	0.00	50.75	0	0.83
6.00	0	0.00	21.00	5	10.00	36.00	0	0.00	51.00	0	0.63
6.25	0	0.00	21.25	5	9.50	36.25	0	0.00	51.25	0	0.42
6.50	0	0.00	21.50	5	9.00	36.50	0	0.00	51.50	0	0.21
6.75	0	0.00	21.75	5	8.50	36.75	0	0.00	51.75	0	0.00
7.00	0	0.00	22.00	5	8.00	37.00	0	0.00	52.00	0	0.00
7.25	0	0.00	22.25	5	7.50	37.25	0	0.00	52.25	0	0.00
7.50	0	0.00	22.50	5	7.00	37.50	0	0.00	52.50	0	0.00
7.75	0	0.00	22.75	5	6.50	37.75	0	0.00	52.75	0	0.00
8.00	0	0.00	23.00	0	6.00	38.00	0	0.00	53.00	0	0.00
8.25	0	0.00	23.25	0	5.50	38.25	0	0.00	53.25	0	0.00
8.50	0	0.00	23.50	0	5.00	38.50	0	0.00	53.50	0	0.00
8.75	0	0.00	23.75	0	4.50	38.75	0	0.00	53.75	0	0.00
9.00	10	0.42	24.00	0	4.00	39.00	0	0.00	54.00	0	0.00
9.25	10	0.83	24.25	0	3.50	39.25	0	0.00	54.25	0	0.00
9.50	10	1.25	24.50	0	3.25	39.50	0	0.00	54.50	0	0.00
9.75	10	1.67	24.75	0	3.00	39.75	0	0.00	54.75	0	0.00
10.00	10	2.08	25.00	0	2.86	40.00	0	0.00	55.00	0	0.00
10.25	15	2.71	25.25	0	2.73	40.25	0	0.00	55.25	0	0.00
10.50	15	3.33	25.50	0	2.61	40.50	0	0.00	55.50	0	0.00
10.75	15	3.96	25.75	0	2.50	40.75	0	0.00	55.75	0	0.00
11.00	15	4.58	26.00	5	2.50	41.00	0	0.00	56.00	0	0.00
11.25	15	5.21	26.25	5	2.50	41.25	0	0.00	56.25	0	0.00
11.50	15	5.83	26.50	5	2.50	41.50	0	0.00	56.50	0	0.00
11.75	15	6.46	26.75	5	2.50	41.75	0	0.00	56.75	0	0.00
12.00	15	7.08	27.00	5	2.50	42.00	0	0.00	57.00	0	0.00
12.25	15	7.71	27.25	5	2.50	42.25	0	0.00	57.25	0	0.00
12.50	15	8.33	27.50	5	2.50	42.50	0	0.00	57.50	0	0.00
12.75	15	8.96	27.75	5	2.50	42.75	0	0.00	57.75	0	0.00
13.00	10	9.38	28.00	0	2.29	43.00	0	0.00	58.00	0	0.00
13.25	10	9.79	28.25	0	2.08	43.25	0	0.00	58.25	0	0.00
13.50	15	10.42	28.50	0	1.88	43.50	0	0.00	58.50	0	0.00
13.75	15	11.04	28.75	0	1.67	43.75	0	0.00	58.75	0	0.00
14.00	15	11.67	29.00	0	1.67	44.00	0	0.00	59.00	0	0.00
14.25	15	12.29	29.25	0	1.67	44.25	0	0.00	59.25	0	0.00
14.50	15	12.92	29.50	0	1.67	44.50	0	0.00	59.50	0	0.00
14.75	15	13.54	29.75	0	1.67	44.75	0	0.00	59.75	0	0.00

Company: Fibrominn, LLC
Equipment: Biomass Boiler Stack Exhaust
Location: Benson, Minnesota
Date: July 2, 2007
Project #: snc-07-benson.mn-comp#1

Run 2

Average Opacity: 2.94 %
Maximum Opacity: 15 %
6 Minute Average: 2.78 %
6 Minute Maximum: 10.83 %
Readings at 20 %: 0 readings

TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.
0.00	5	N/A	15.00	5	6.67	30.00	0	0.00	45.00	0	2.50
0.25	5	N/A	15.25	5	6.46	30.25	0	0.00	45.25	0	2.50
0.50	5	N/A	15.50	5	6.46	30.50	0	0.00	45.50	0	2.50
0.75	5	N/A	15.75	5	6.25	30.75	0	0.00	45.75	0	2.50
1.00	5	N/A	16.00	0	5.83	31.00	0	0.00	46.00	0	2.50
1.25	5	N/A	16.25	0	5.42	31.25	0	0.00	46.25	0	2.50
1.50	5	N/A	16.50	0	5.00	31.50	0	0.00	46.50	0	2.50
1.75	5	N/A	16.75	0	4.58	31.75	0	0.00	46.75	5	2.71
2.00	10	N/A	17.00	0	4.38	32.00	0	0.00	47.00	5	2.92
2.25	10	N/A	17.25	0	3.96	32.25	0	0.00	47.25	5	3.13
2.50	10	N/A	17.50	0	3.75	32.50	0	0.00	47.50	5	3.33
2.75	10	N/A	17.75	0	3.54	32.75	0	0.00	47.75	5	3.54
3.00	15	N/A	18.00	0	3.33	33.00	0	0.00	48.00	5	3.54
3.25	15	N/A	18.25	0	3.13	33.25	0	0.00	48.25	5	3.54
3.50	15	N/A	18.50	0	2.92	33.50	0	0.00	48.50	5	3.54
3.75	15	N/A	18.75	0	2.50	33.75	0	0.00	48.75	0	3.33
4.00	10	N/A	19.00	0	2.29	34.00	0	0.00	49.00	0	3.13
4.25	10	N/A	19.25	0	2.08	34.25	0	0.00	49.25	0	2.92
4.50	10	N/A	19.50	0	1.88	34.50	0	0.00	49.50	0	2.71
4.75	10	N/A	19.75	0	1.67	34.75	0	0.00	49.75	0	2.50
5.00	15	N/A	20.00	0	1.46	35.00	0	0.00	50.00	0	2.29
5.25	10	N/A	20.25	0	1.25	35.25	0	0.00	50.25	0	2.08
5.50	10	N/A	20.50	0	1.04	35.50	0	0.00	50.50	0	1.88
5.75	5	9.17	20.75	0	0.83	35.75	0	0.00	50.75	5	1.88
6.00	10	9.38	21.00	0	0.63	36.00	0	0.00	51.00	5	2.08
6.25	10	9.58	21.25	0	0.42	36.25	0	0.00	51.25	0	2.08
6.50	10	9.79	21.50	0	0.21	36.50	0	0.00	51.50	0	2.08
6.75	10	10.00	21.75	0	0.00	36.75	0	0.00	51.75	5	2.29
7.00	10	10.21	22.00	0	0.00	37.00	0	0.00	52.00	5	2.50
7.25	10	10.42	22.25	0	0.00	37.25	0	0.00	52.25	5	2.71
7.50	10	10.63	22.50	0	0.00	37.50	0	0.00	52.50	5	2.92
7.75	10	10.83	22.75	0	0.00	37.75	0	0.00	52.75	0	2.71
8.00	10	10.83	23.00	0	0.00	38.00	0	0.00	53.00	0	2.50
8.25	10	10.83	23.25	0	0.00	38.25	0	0.00	53.25	0	2.29
8.50	10	10.83	23.50	0	0.00	38.50	0	0.00	53.50	0	2.08
8.75	5	10.63	23.75	0	0.00	38.75	0	0.00	53.75	5	2.08
9.00	5	10.21	24.00	0	0.00	39.00	0	0.00	54.00	5	2.08
9.25	10	10.00	24.25	0	0.00	39.25	0	0.00	54.25	5	2.08
9.50	5	9.58	24.50	0	0.00	39.50	0	0.00	54.50	5	2.08
9.75	10	9.38	24.75	0	0.00	39.75	0	0.00	54.75	5	2.29
10.00	10	9.38	25.00	0	0.00	40.00	0	0.00	55.00	5	2.50
10.25	10	9.38	25.25	0	0.00	40.25	0	0.00	55.25	5	2.71
10.50	10	9.38	25.50	0	0.00	40.50	0	0.00	55.50	5	2.92
10.75	10	9.38	25.75	0	0.00	40.75	0	0.00	55.75	5	3.13
11.00	5	8.96	26.00	0	0.00	41.00	0	0.00	56.00	5	3.33
11.25	10	8.96	26.25	0	0.00	41.25	0	0.00	56.25	5	3.54
11.50	5	8.75	26.50	0	0.00	41.50	0	0.00	56.50	5	3.75
11.75	5	8.75	26.75	0	0.00	41.75	0	0.00	56.75	0	3.54
12.00	5	8.54	27.00	0	0.00	42.00	5	0.21	57.00	0	3.33
12.25	5	8.33	27.25	0	0.00	42.25	5	0.42	57.25	0	3.33
12.50	5	8.13	27.50	0	0.00	42.50	5	0.63	57.50	0	3.33
12.75	10	8.13	27.75	0	0.00	42.75	5	0.83	57.75	0	3.13
13.00	5	7.92	28.00	0	0.00	43.00	5	1.04	58.00	0	2.92
13.25	5	7.71	28.25	0	0.00	43.25	5	1.25	58.25	0	2.71
13.50	5	7.50	28.50	0	0.00	43.50	5	1.46	58.50	0	2.50
13.75	5	7.29	28.75	0	0.00	43.75	5	1.67	58.75	0	2.50
14.00	5	7.08	29.00	0	0.00	44.00	5	1.88	59.00	0	2.50
14.25	5	6.88	29.25	0	0.00	44.25	5	2.08	59.25	0	2.50
14.50	5	6.67	29.50	0	0.00	44.50	5	2.29	59.50	0	2.50
14.75	5	6.67	29.75	0	0.00	44.75	5	2.50	59.75	0	2.29

Company: Fibrominn, LLC
Equipment: Biomass Boiler Stack Exhaust
Location: Benson, Minnesota
Date: July 2, 2007
Project #: snc-07-benson.mn-comp#1

Run 3

Average Opacity: 0.83 %
Maximum Opacity: 5 %
6 Minute Average: 0.92 %
6 Minute Maximum: 5.00 %
Readings at 20 %: 0 readings


TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.	TIME (min)	OPACITY (%)	6 MIN AVG.
0.00	0	N/A	15.00	5	4.38	30.00	0	0.00	45.00	0	0.00
0.25	0	N/A	15.25	5	4.58	30.25	0	0.00	45.25	0	0.00
0.50	0	N/A	15.50	5	4.79	30.50	0	0.00	45.50	0	0.00
0.75	0	N/A	15.75	5	5.00	30.75	0	0.00	45.75	0	0.00
1.00	0	N/A	16.00	5	5.00	31.00	0	0.00	46.00	0	0.00
1.25	0	N/A	16.25	5	5.00	31.25	0	0.00	46.25	0	0.00
1.50	0	N/A	16.50	5	5.00	31.50	0	0.00	46.50	0	0.00
1.75	0	N/A	16.75	5	5.00	31.75	0	0.00	46.75	0	0.00
2.00	0	N/A	17.00	5	5.00	32.00	0	0.00	47.00	0	0.00
2.25	0	N/A	17.25	5	5.00	32.25	0	0.00	47.25	0	0.00
2.50	0	N/A	17.50	5	5.00	32.50	0	0.00	47.50	0	0.00
2.75	0	N/A	17.75	5	5.00	32.75	0	0.00	47.75	0	0.00
3.00	0	N/A	18.00	5	5.00	33.00	0	0.00	48.00	0	0.00
3.25	0	N/A	18.25	5	5.00	33.25	0	0.00	48.25	0	0.00
3.50	0	N/A	18.50	5	5.00	33.50	0	0.00	48.50	0	0.00
3.75	0	N/A	18.75	5	5.00	33.75	0	0.00	48.75	0	0.00
4.00	0	N/A	19.00	5	5.00	34.00	0	0.00	49.00	0	0.00
4.25	0	N/A	19.25	5	5.00	34.25	0	0.00	49.25	0	0.00
4.50	0	N/A	19.50	5	5.00	34.50	0	0.00	49.50	0	0.00
4.75	0	N/A	19.75	5	5.00	34.75	0	0.00	49.75	0	0.00
5.00	0	N/A	20.00	0	4.79	35.00	0	0.00	50.00	0	0.00
5.25	0	N/A	20.25	0	4.58	35.25	0	0.00	50.25	0	0.00
5.50	0	N/A	20.50	0	4.38	35.50	0	0.00	50.50	0	0.00
5.75	0	0.00	20.75	0	4.17	35.75	0	0.00	50.75	0	0.00
6.00	0	0.00	21.00	0	3.96	36.00	0	0.00	51.00	0	0.00
6.25	0	0.00	21.25	0	3.75	36.25	0	0.00	51.25	0	0.00
6.50	0	0.00	21.50	0	3.54	36.50	0	0.00	51.50	0	0.00
6.75	0	0.00	21.75	0	3.33	36.75	0	0.00	51.75	0	0.00
7.00	0	0.00	22.00	0	3.13	37.00	0	0.00	52.00	0	0.00
7.25	0	0.00	22.25	0	2.92	37.25	0	0.00	52.25	0	0.00
7.50	0	0.00	22.50	0	2.71	37.50	0	0.00	52.50	0	0.00
7.75	0	0.00	22.75	0	2.50	37.75	0	0.00	52.75	0	0.00
8.00	0	0.00	23.00	0	2.29	38.00	0	0.00	53.00	0	0.00
8.25	0	0.00	23.25	0	2.08	38.25	0	0.00	53.25	0	0.00
8.50	0	0.00	23.50	0	1.88	38.50	0	0.00	53.50	0	0.00
8.75	0	0.00	23.75	0	1.67	38.75	0	0.00	53.75	0	0.00
9.00	0	0.00	24.00	0	1.46	39.00	0	0.00	54.00	0	0.00
9.25	0	0.00	24.25	0	1.25	39.25	0	0.00	54.25	0	0.00
9.50	0	0.00	24.50	0	1.04	39.50	0	0.00	54.50	0	0.00
9.75	0	0.00	24.75	0	0.83	39.75	0	0.00	54.75	0	0.00
10.00	5	0.21	25.00	0	0.63	40.00	0	0.00	55.00	0	0.00
10.25	5	0.42	25.25	0	0.42	40.25	0	0.00	55.25	0	0.00
10.50	5	0.63	25.50	0	0.21	40.50	0	0.00	55.50	0	0.00
10.75	5	0.83	25.75	0	0.00	40.75	0	0.00	55.75	0	0.00
11.00	5	1.04	26.00	0	0.00	41.00	0	0.00	56.00	0	0.00
11.25	5	1.25	26.25	0	0.00	41.25	0	0.00	56.25	0	0.00
11.50	5	1.46	26.50	0	0.00	41.50	0	0.00	56.50	0	0.00
11.75	5	1.67	26.75	0	0.00	41.75	0	0.00	56.75	0	0.00
12.00	5	1.88	27.00	0	0.00	42.00	0	0.00	57.00	0	0.00
12.25	5	2.08	27.25	0	0.00	42.25	0	0.00	57.25	0	0.00
12.50	5	2.29	27.50	0	0.00	42.50	0	0.00	57.50	0	0.00
12.75	5	2.50	27.75	0	0.00	42.75	0	0.00	57.75	0	0.00
13.00	5	2.71	28.00	0	0.00	43.00	0	0.00	58.00	0	0.00
13.25	5	2.92	28.25	0	0.00	43.25	0	0.00	58.25	0	0.00
13.50	5	3.13	28.50	0	0.00	43.50	0	0.00	58.50	0	0.00
13.75	5	3.33	28.75	0	0.00	43.75	0	0.00	58.75	0	0.00
14.00	5	3.54	29.00	0	0.00	44.00	0	0.00	59.00	0	0.00
14.25	5	3.75	29.25	0	0.00	44.25	0	0.00	59.25	0	0.00
14.50	5	3.96	29.50	0	0.00	44.50	0	0.00	59.50	0	0.00
14.75	5	4.17	29.75	0	0.00	44.75	0	0.00	59.75	0	0.00

Company: Fibrominn, LLC
Equipment: Biomass Boiler Stack Exhaust
Location: Benson, Minnesota
Date: July 2, 2007
Project #: snc-07-benson.mn-comp#1


Run 1

Average Opacity: 2.69 %
Maximum Opacity: 15 %
6 Minute Average: 3.07 %
6 Minute Maximum: 14.58 %
Readings at 20 %: 0 readings

OPACITY READINGS (15 second intervals)



OPACITY RESULTS (6 minute averages)




Company: Fibrominn, LLC
Equipment: Biomass Boiler Stack Exhaust
Location: Benson, Minnesota
Date: July 2, 2007
Project #: snc-07-benson.mn-comp#1


Run 2

Average Opacity: 2.94 %
Maximum Opacity: 15 %
6 Minute Average: 2.78 %
6 Minute Maximum: 10.83 %
Readings at 20 %: 0 readings

OPACITY READINGS (15 second intervals)



OPACITY RESULTS (6 minute averages)




Company: Fibrominn, LLC
Equipment: Biomass Boiler Stack Exhaust
Location: Benson, Minnesota
Date: July 2, 2007
Project #: snc-07-benson.mn-comp#1


Run 3

Average Opacity: 0.83 %
Maximum Opacity: 5 %
6 Minute Average: 0.92 %
6 Minute Maximum: 5.00 %
Readings at 20 %: 0 readings

OPACITY READINGS (15 second intervals)



OPACITY RESULTS (6 minute averages)



Method Used (Circle One)
 Method 9 203A 203B Other: _____

VISUAL EMISSIONS OBSERVATION FORM

Company Name
Fibromin, LLC

Facility Name
Fibromin Biomass Power Plant

Street Address
900 Industry Dr

City, State, Zip
Benson MN 56015

Form Number _____ Page **1** of **6**

Continued on Form Number _____

Process
Boiler Unit # **1** Operating Mode **Full**

Control Equipment
Bag House / SDA Operating Mode **Full**

Observation Date
9-July-07 Time Zone **Central** Start Time **17:58** End Time **18:58**

Describe Emissions Point
Barely visible grayish

Height of Emiss. Pt. Height of Emiss. Pt. Rel. to Observer
 Start **300 ft** End **300 ft** Start **300 ft** End _____

Distance to Emiss. Pt. Direction to Emiss. Pt. (Degrees)
 Start **900 ft** End **900 ft** Start **90°** End **90°**


Min	Sec	Time				Comments
		0	15	30	45	
1	0	0	0	0	0	
2	0	0	0	0	0	
3	0	0	0	0	0	
4	0	0	0	0	0	
5	0	0	0	0	0	
6	0	0	0	0	0	
7	0	0	0	0	0	
8	0	0	0	0	0	
9	0	0	0	0	0	
10	10	10	10	10		
11	10	15	15	15		
12	15	15	15	15		
13	15	15	15	15		
14	10	10	15	15		
15	15	15	15	15		
16	15	15	15	15		
17	15	15	15	15		
18	10	10	10	10		
19	10	10	5	5		
20	10	10	10	10		
21	5	5	5	5		
22	5	5	5	5		
23	5	5	5	5		
24	0	0	0	0		
25	0	0	0	0		
26	0	0	0	0		
27	5	5	5	5		
28	5	5	5	5		
29	0	0	0	0		
30	0	0	0	0		

Vertical Angle to Obs. Pt. Direction to Obs. Pt. (Degrees)
 Start **50°** End **50°** Start **90°** End **90°**

Distance and Direction to Observation Point from Emission Point
 Start **0** End **0**

Describe Emissions
 Start **Barely visible** End **None visible**
 Emission Color _____ Water Droplet Plume _____
 Start **Dark greyish blue** End **None**

Describe Plume Background
 Start **sky** End **sky**
 Background Color _____ Sky Conditions _____
 Start **blue** End **blue** Start **overcast** End **clear**
 Wind Speed _____ Wind Direction _____
 Start **calm** End **calm** Start _____ End _____
 Ambient Temp. _____ Wet Bulb Temp. _____ RH Percent _____
 Start **84°** End **81°**



Observer's Name (Print) **Rob White**

Observer's Signature _____ Date **9-July-07**

Organization **Air Hygiene**

Certified By **ETA** Date **28-Mar-07**

Additional Information

Method Used (Circle One)
 Method 203A 203B Other: _____

VISUAL EMISSIONS OBSERVATION FORM

Form Number _____ Page 2 of 6
 Continued on Form Number _____

Company Name
Fibraminn, LLC
 Facility Name
Fibraminn Biomass Power Plant
 Street Address
900 Industry Dr.
 City State Zip
Benson MN 56215

Observation Date
3 July 07 Time Zone
MDT Central Start Time
1758 End Time
1858

Process Unit# Operating Mode
Boiler 1 Full
 Control Equipment Operating Mode
Bag House / SPA Full


Min. Sec.	Time				Comments
	0	15	30	45	
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	0	0	0	0	
14	0	0	0	0	
15	0	0	0	0	
16	5	5	5	5	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Describe Emissions Point
Barely visible
 Height of Emiss. Pt. Height of Emiss. Pt. Rel. to Observer
 Start 300 ft End 300 ft Start 300 ft End 300 ft
 Distance to Emiss. Pt. Direction to Emiss. Pt. (Degrees)
 Start 900 ft End 900 ft Start 90° End 90°

Vertical Angle to Obs. Pt. Direction to Obs. Pt. (Degrees)
 Start 5° End 50° Start 90° End 90°
 Distance and Direction to Observation Point from Emission Point
 Start 0° 0' End 0° 0'

Describe Emissions
 Start Barely visible End None visible
 Emission Color Water Droplet Plume
 Start Grey End Clear Start N/A End N/A

Describe Plume Background
 Start sky End sky
 Background Color Sky Conditions
 Start Blue End Blue Start Overcast End Clear
 Wind Speed Wind Direction
 Start Calm End Calm Start ↙ End ↘
 Ambient Temp. Wet Bulb Temp. RH Percent
 Start 74° End 81°



Observer's Name (Print) Ruby White
 Observer's Signature [Signature] Date 4 July 07
 Organization Air Hygiene
 Certified By ETA Date 28 Mar 07

Additional Information

Method Used (Circle One) Method 9 203A 203B Other: _____

VISUAL EMISSIONS OBSERVATION FORM

Company Name Pi brominn, LLC
 Facility Name Pi brominn Biomass Power Plant
 Street Address 400 Industry Dr.
 City Benson State MM Zip 56215

Form Number _____ Page 3 of 6
 Continued on Form Number _____

Process Boiler Unit # _____ Operating Mode Full
 Control Equipment Bag House / SADA Operating Mode Full

Observation Date 3 July Time Zone Central Start Time 1440 End Time 1845

Describe Emissions Port
Back visible
 Height of Emiss. Pt. Start 300 ft End 300 ft Start 300 ft End 300 ft
 Distance to Emiss. Pt. Start 900 ft End 900 ft Start 90° End 90°


Min.	Sec.	Time Zone			Comments
		0	15	30	

Vertical Angle to Obs. Pt. Start 50° End 50° Direction to Obs. Pt. (Degrees) Start 90° End 90°
 Distance and Direction to Observation Point from Emission Point Start 0 End 0

1	5	5	5	5	
2	5	5	5	5	
3	10	10	10	10	
4	15	15	15	15	
5	10	10	10	10	
6	15	10	10	5	
7	10	10	10	10	
8	10	10	10	10	
9	10	10	10	5	
10	5	10	5	10	
11	10	10	10	10	
12	5	10	5	5	
13	5	5	5	10	
14	5	5	5	5	
15	5	5	5	5	
16	5	5	5	5	
17	0	0	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Describe Emissions Start Back visible End None visible
 Emission Color Start W/gy End Clear Start N/A End N/A

Describe Plume Background Start sky End sky
 Background Color Start Blue End Blue Sky Conditions Start Clear End Clear
 Wind Speed Start calm End calm Wind Direction Start - End -
 Ambient Temp. Start 81° End 76° Wet Bulb Temp. _____ RH Percent _____



Observer's Name (Print) Rob White
 Observer's Signature RW Date 4 July 03
 Organization Air Hygiene
 Certified By EIA Date 38 MM 03

Additional Information

Method Used (Circle One)
 Method 9 203A 203B Other: _____

VISUAL EMISSIONS OBSERVATION FORM

Company Name
 Fibrominn LLC

Facility Name
 Fibrominn Biomass Paper Plant

Street Address
 900 Industry Dr

City State Zip
 Wernon MN 56215

Form Number _____ Page **B4.6**

Continued on Form Number _____

Process Unit # Operating Mode
 Boiler 1 Full

Control Equipment Operating Mode
 Bag House / SDA Full

Observation Date Time Zone Start Time End Time
 3 July 09 Central 1940 2040

Describe Emissions Port
 Barely Visible

Height of Emiss. Pt. Height of Emiss. Pt. Rel. to Observer
 Start 300 ft End 300 ft Start 300 ft End 300 ft

Distance to Emiss. Pt. Direction to Emiss. Pt. (Degrees)
 Start 400 ft End 400 ft Start 90° End 90°

Min.	Sec.				Comments
	0	15	30	45	

Vertical Angle to Obs. Pt. Direction to Obs. Pt. (Degrees)
 Start 50° End 50° Start 90° End 90°

Distance and Direction to Observation Point from Emission Point
 Start 0° End 0°

1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	
11	0	0	0	0	
12	0	0	0	0	
13	5	5	5	5	
14	5	5	5	5	
15	5	5	5	5	
16	0	0	0	0	
17	0	0	0	0	
18	5	5	5	5	
19	5	5	5	5	
20	0	0	0	0	
21	0	0	0	0	
22	5	5	0	0	
23	5	5	5	5	
24	0	0	0	0	
25	5	5	5	5	
26	5	5	5	5	
27	5	5	5	5	
28	0	0	0	0	
29	0	0	0	0	
30	0	0	0	0	

Describe Emissions
 Start Barely Visible End Barely Visible

Emission Color Water Droplet Plume
 Start Grey End Clear Start - End -

Describe Plume Background
 Start Sky End Sky

Background Color Sky Conditions
 Start Blue End Blue Start Clear End Clear

Wind Speed Wind Direction
 Start Calm End Calm Start - End -

Ambient Temp. Wet Bulb Temp. RH Percent
 Start 80° End 76°

Source Layout Sketch

Draw North Arrow

TN MN

300 FEET

FEET

Side View

Stack with Plume

Sun

Wind

Latitude Longitude Declination

Observer's Name (Print) **Rob White**

Observer's Signature **[Signature]** Date **21 July 09**

Organization **Air Hygiene**

Certified By **EJA** Date **28 Jan 09**

Additional Information

Method Used (Circle One) Method A 203A 203B Other: _____

VISUAL EMISSIONS OBSERVATION FORM

Form Number _____ Page 6 of 6

Company Name Libromin LLC
 Facility Name Fibromin Bioma & Paper Plant
 Street Address 900 Industry Dr.
 City Ben Lom State MA Zip 01621

Continued on Form Number _____

Process Paper Unit # _____ Operating Mode Full
 Control Equipment Bag House / SIDA Operating Mode Full

Observation Date 4-23-07 Time Zone Central Start Time 1452 End Time 1552


Describe Emissions Point
Light Grey Very Fine
 Height of Emiss. Pt. _____ Height of Emiss. Pt. Rel. to Observer
 Start 300 ft End 300 ft Start 300 ft End 300 ft
 Distance to Emiss. Pt. _____ Direction to Emiss. Pt. (Degrees)
 Start 900 ft End 900 ft Start 30° End 30°

Min.	Sec.	Time Zone				Comments
		0	15	30	45	
1		0	0	0	0	
2		0	0	0	0	
3		0	0	0	0	
4		0	0	0	0	
5		0	0	0	0	
6		0	0	0	0	
7		0	0	0	0	
8		0	0	0	0	
9		0	0	0	0	
10		0	0	0	0	
11		5	5	5	5	
12		5	5	5	5	
13		5	5	5	5	
14		5	5	5	5	
15		5	5	5	5	
16		5	5	5	5	
17		5	5	5	5	
18		5	5	5	5	
19		5	5	5	5	
20		5	5	5	5	
21		0	0	0	0	
22		0	0	0	0	
23		0	0	0	0	
24		0	0	0	0	
25		0	0	0	0	
26		0	0	0	0	
27		0	0	0	0	
28		0	0	0	0	
29		0	0	0	0	
30		0	0	0	0	

Vertical Angle to Obs. Pt. _____ Direction to Obs. Pt. (Degrees)
 Start 18° End 18° Start 30° End 30°
 Distance and Direction to Observation Point from Emission Point
 Start 0 End 0 End 0 End 0

Describe Emissions
 Start Grey End Clear Start - End -
 Emission Color _____ Water Droplet Plume _____

Describe Plume Background
 Start Blue End Blue Sky Conditions Partly Cloudy clear
 Background Color _____ Wind Speed _____ Wind Direction _____
 Start 5-7 End calm Start W End W
 Ambient Temp. _____ Wet Bulb Temp. _____ RH Percent _____
 Start 79° End 79°



Observer's Name (Print) Rob White

Observer's Signature [Signature] Date 21 July 07

Organization Air Region

Certified By EJA Date 25 Nov 07

Additional Information

Method Used (Circle One)
 Method B 203A 203B Other: _____

VISUAL EMISSIONS OBSERVATION FORM

Form Number _____ Page 5 of 6
 Continued on Form Number _____

Company Name: F. Bramann, LLC
 Facility Name: F. Bramann Biomass Power Plant
 Street Address: 900 Industrial Dr
 City: Bonson State: MN Zip: 56215

Observation Date: 4 July 07 Time Zone: Central Start Time: 1452 End Time: 1552

Process: Boiler Unit #: 1 Operating Mode: Full
 Control Equipment: Boiler House Operating Mode: Full


Min.	Sec.	Time Zone				Comments
		0	15	30	45	
1	0	0	0	0	0	
2	0	0	0	0	0	
3	0	0	0	0	0	
4	0	0	0	0	0	
5	0	0	0	0	0	
6	0	0	0	0	0	
7	0	0	0	0	0	
8	0	0	0	0	0	
9	0	0	0	0	0	
10	0	0	0	0	0	
11	0	0	0	0	0	
12	0	0	0	0	0	
13	0	0	0	0	0	
14	0	0	0	0	0	
15	0	0	0	0	0	
16	0	0	0	0	0	
17	0	0	0	0	0	
18	0	0	0	0	0	
19	0	0	0	0	0	
20	0	0	0	0	0	
21	0	0	0	0	0	
22	0	0	0	0	0	
23	0	0	0	0	0	
24	0	0	0	0	0	
25	0	0	0	0	0	
26	0	0	0	0	0	
27	0	0	0	0	0	
28	0	0	0	0	0	
29	0	0	0	0	0	
30	0	0	0	0	0	

Describe Emissions Port
Light Grey very faint
 Height of Emiss. Pt. Start 300ft End 300ft Start 300ft End 300ft
 Distance to Emiss. Pt. Start 800ft End 800ft Start 30° End 30°

Vertical Angle to Obs. Pt. Start 18° End 30° Direction to Obs. Pt. (Degrees) Start 30° End 30°
 Distance and Direction to Observation Point from Emission Point Start 0° End 0°

Describe Emissions Start Barely visible End NONE visible
 Emission Color Start Grey End clear Water Droplet Plume Start NONE End NONE

Describe Plume Background Start sky End sky
 Background Color Start blue End blue Sky Conditions Start Blue Cloudy End clear
 Wind Speed Start 5-7 End calm Wind Direction Start NW End -
 Ambient Temp. Start 79° End 79° Wet Bulb Temp. RH Percent



Latitude _____ Longitude _____ Declination _____
 Additional information _____

Observer's Name (Print) Rob White
 Observer's Signature [Signature] Date 4 July 07
 Organization Air Hygiene
 Certified By ETA Date 18-Mar-07

APPENDIX B

UNIT OPERATION PARAMETERS

Fibrominn, LLC

Air Permit # :	15100038-004
Plant Name or Location:	Fibrominn Biomass Power Plant
Date:	July 3, 2007
Project Number:	snc-07-benson.mn-comp#1
Manufacturer & Equipment:	Biomass Boiler
Unit Number:	1

		RUN					
	UNITS	Out-1	Out-2	Out-3	In-1	In-2	In-3
Start Time	hh:mm:ss	17:58:14	19:40:14	21:39:14	17:58:14	19:40:14	21:39:14
End Time	hh:mm:ss	18:57:44	20:39:44	22:38:44	18:57:44	20:39:44	22:38:44
Bar. Pressure	in. Hg	29.43	29.44	29.46	29.43	29.44	29.46
Amb. Temp.	°F	81	78	77	81	78	77
Rel. Humidity	%	71	72	71	71	72	71
Spec. Humidity	lb water / lb air	0.016438	0.014868	0.014450	0.016438	0.014868	0.014450
Unit Number		Outlet	Outlet	Outlet	Inlet	Inlet	Inlet
Stack Flow (M2)	SCFH	10,257,198	9,847,715	10,305,362	8,106,276	8,438,795	10,329,857
Stack Moisture	% Method 4	25.7	26.0	24.9	18.5	23.0	9.5
Heat Input	MMBtu/hr	784.4	774.1	777.9	784.4	774.1	777.9
Gross Power Output	gross MW	61.3	61.8	62.8	61.3	61.8	62.8
Steam Rate	lb/hr	487,155	487,320	490,767	487,155	487,320	490,767
Biomass Flow	TPH	83.9	83.3	88.5	83.9	83.3	88.5
Urea Injection	gal/hr	89.3	89.0	94.1	89.3	89.0	94.1
Feedwater Flow	lb/hr	496,079	486,901	492,715	496,079	486,901	492,715
Secondary Air Flow	lb/hr	354,766	339,054	354,522	354,766	339,054	354,522
Primary Air Flow	lb/hr	249,174	244,227	258,475	249,174	244,227	258,475
Dist. Air Flow	lb/hr	70,974	71,209	72,455	70,974	71,209	72,455
SDA Slurry Flow	GPM	27.1	22.3	30.9	27.1	22.3	30.9
SDA Quench Flow	GPM	14.4	14.5	8.6	14.4	14.5	8.6
Sootblower Flow	lb/hr	4,414	2,176	2,649	4,414	2,176	2,649
SH Steam Temp	°F	968	971	969	968	971	969
SH Steam Pres.	psi	1,500	1,504	1,499	1,500	1,504	1,499

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEGF)	SH OUTLET FLUE GAS TEMP (DEGF)
7/3/07 17:58	61.27	488,136.59	376.44	501,145.31	83.70	0.00	272.39	542.42	968.81	1,497.90	862.92	798.83
7/3/07 17:59	61.16	488,086.69	376.25	500,904.50	84.48	0.00	272.27	542.05	969.56	1,497.29	862.24	798.57
7/3/07 18:00	60.74	484,075.91	376.09	500,663.69	83.76	0.00	272.18	541.91	967.59	1,490.67	861.05	798.34
7/3/07 18:01	60.80	485,474.81	375.93	500,422.91	85.20	0.00	272.19	541.86	968.04	1,492.36	861.16	799.15
7/3/07 18:02	60.63	485,193.50	375.89	500,453.09	87.56	0.00	272.08	542.01	968.16	1,490.60	861.32	799.55
7/3/07 18:03	60.83	486,385.41	375.88	501,128.50	90.16	0.00	272.02	542.20	965.21	1,494.05	861.06	799.79
7/3/07 18:04	61.01	489,298.00	375.90	501,803.91	89.60	0.00	271.90	542.56	964.02	1,499.60	860.86	801.23
7/3/07 18:05	60.53	484,985.59	375.96	502,479.31	92.86	0.00	271.84	542.80	963.40	1,490.59	860.68	801.23
7/3/07 18:06	60.36	483,758.00	375.99	503,154.69	89.56	0.00	271.79	542.77	963.95	1,489.91	860.56	801.77
7/3/07 18:07	60.47	484,567.81	376.01	503,830.09	90.29	0.00	271.76	542.83	965.78	1,493.58	860.80	805.17
7/3/07 18:08	60.53	484,910.41	376.01	504,505.50	88.82	0.00	271.71	543.07	967.53	1,496.25	861.33	809.32
7/3/07 18:09	60.83	485,765.09	376.04	505,180.91	84.80	0.00	271.67	543.31	968.85	1,501.01	861.65	812.58
7/3/07 18:10	61.04	487,715.59	376.08	505,856.31	85.80	0.00	271.69	543.40	970.59	1,504.36	862.19	815.70
7/3/07 18:11	61.15	487,510.31	376.11	506,531.69	86.34	0.00	271.71	543.65	973.55	1,505.10	863.42	817.88
7/3/07 18:12	61.37	488,347.31	376.10	507,207.09	88.38	0.00	271.76	543.60	973.57	1,507.88	864.33	817.36
7/3/07 18:13	62.13	493,857.91	375.99	507,882.50	91.67	0.00	271.86	543.65	974.59	1,519.40	865.30	816.98
7/3/07 18:14	62.34	496,012.69	375.95	508,557.91	90.22	0.00	271.98	543.87	974.99	1,522.49	866.52	816.42
7/3/07 18:15	61.81	492,298.59	375.90	509,233.31	91.50	0.00	272.12	543.78	972.14	1,510.94	867.30	815.49
7/3/07 18:16	61.98	493,674.09	375.69	509,908.69	90.31	0.00	272.32	543.53	969.66	1,515.19	867.25	814.02
7/3/07 18:17	62.83	503,093.41	375.55	510,584.09	89.77	0.00	272.50	543.40	969.35	1,520.27	867.34	813.04
7/3/07 18:18	62.86	504,764.69	375.31	511,259.50	90.54	0.00	272.59	543.35	969.57	1,517.38	867.59	812.19
7/3/07 18:19	63.14	506,108.09	375.13	511,934.91	87.10	0.00	272.81	543.02	968.45	1,515.36	867.34	811.34
7/3/07 18:20	63.55	508,853.19	374.99	512,943.09	84.73	0.00	273.05	542.87	969.83	1,514.36	867.68	811.56
7/3/07 18:21	63.59	509,087.91	374.94	509,906.31	88.10	0.00	273.23	542.74	969.02	1,511.55	868.17	811.32
7/3/07 18:22	63.57	507,268.50	374.99	506,869.50	86.28	0.00	273.58	543.06	969.90	1,507.37	866.85	811.08
7/3/07 18:23	62.81	500,432.31	375.07	503,832.69	82.66	0.00	273.81	543.51	968.94	1,498.19	865.40	809.62
7/3/07 18:24	63.01	502,944.09	375.15	500,795.91	80.91	0.00	274.00	543.64	967.26	1,501.56	865.27	809.38
7/3/07 18:25	62.07	495,316.50	375.14	497,759.19	79.22	0.00	273.99	543.58	965.85	1,491.81	865.62	809.28
7/3/07 18:26	61.61	489,745.19	375.10	494,722.41	79.81	0.00	274.01	543.56	964.33	1,488.29	866.01	809.06
7/3/07 18:27	61.21	486,545.09	375.03	491,685.59	78.41	0.00	273.84	543.60	962.88	1,487.62	866.47	809.16
7/3/07 18:28	61.50	489,173.19	374.92	490,544.09	80.41	0.00	273.64	543.91	962.88	1,494.39	867.17	809.40
7/3/07 18:29	61.48	487,661.81	374.75	490,979.69	83.87	0.00	273.34	544.61	965.99	1,492.10	868.38	810.33
7/3/07 18:30	61.49	487,025.69	374.50	491,415.19	85.72	0.00	273.07	544.90	967.40	1,492.60	868.69	809.93
7/3/07 18:31	61.58	486,501.50	374.10	491,850.69	85.41	0.00	272.84	544.81	969.42	1,490.95	868.44	809.11
7/3/07 18:32	61.99	487,999.31	373.53	492,286.19	84.37	0.00	272.66	544.56	971.56	1,498.85	868.06	808.91
7/3/07 18:33	61.76	485,925.31	373.04	492,721.69	85.52	0.00	272.59	544.48	973.51	1,494.36	868.19	809.34
7/3/07 18:34	62.07	488,774.69	372.56	493,157.19	79.70	0.00	272.55	544.58	973.73	1,501.14	868.59	809.48
7/3/07 18:35	61.65	484,684.41	372.09	493,592.81	78.13	0.00	272.48	544.64	972.78	1,493.76	869.28	809.61
7/3/07 18:36	61.18	481,761.59	371.52	494,028.31	75.25	0.00	272.41	544.59	970.11	1,486.49	869.47	809.39
7/3/07 18:37	61.17	481,675.81	370.89	492,172.00	74.76	0.00	272.38	544.54	966.79	1,488.88	869.02	808.68
7/3/07 18:38	61.45	486,131.09	370.27	489,898.09	75.10	0.00	272.30	544.75	964.85	1,497.29	868.87	808.57
7/3/07 18:39	60.45	478,490.31	369.73	487,624.19	76.29	0.00	272.15	544.88	963.15	1,485.02	868.61	807.78
7/3/07 18:40	60.34	475,073.31	369.22	485,350.31	77.55	0.00	272.08	544.79	962.31	1,488.63	867.95	806.91
7/3/07 18:41	59.99	473,907.41	368.84	484,864.09	77.59	0.00	271.91	544.87	963.17	1,490.88	867.75	806.84
7/3/07 18:42	60.11	476,127.91	368.47	486,195.69	76.58	0.00	271.71	545.02	964.75	1,498.61	867.74	807.09
7/3/07 18:43	60.11	468,449.41	368.24	487,527.31	78.28	0.00	271.47	545.37	967.43	1,490.04	868.03	807.32
7/3/07 18:44	60.38	479,075.69	367.97	488,858.91	80.06	0.00	271.25	545.64	968.91	1,503.60	867.94	808.12
7/3/07 18:45	60.63	477,294.81	367.80	490,190.50	79.06	0.00	271.10	546.35	971.97	1,502.87	868.52	808.73
7/3/07 18:46	61.30	483,785.19	367.67	491,522.09	78.10	0.00	270.94	546.81	972.60	1,506.12	868.85	808.94
7/3/07 18:47	61.30	483,052.19	367.50	492,853.69	78.80	0.00	270.94	547.01	972.33	1,505.09	868.98	808.84

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEGF)	SH OUTLET FLUE GAS TEMP (DEGF)
7/3/07 18:48	61.15	482,549.81	367.35	490,359.59	82.70	0.00	271.02	546.97	970.95	1,503.22	868.76	809.24
7/3/07 18:49	60.87	483,148.41	367.26	487,784.09	81.81	0.00	271.12	547.07	970.37	1,503.27	868.76	811.32
7/3/07 18:50	60.45	476,989.91	367.19	485,208.69	83.67	0.00	271.20	547.18	970.11	1,496.00	868.96	813.34
7/3/07 18:51	60.37	478,693.81	367.06	483,281.69	84.80	0.00	271.31	546.98	967.38	1,498.56	868.19	813.93
7/3/07 18:52	60.10	478,800.81	367.03	482,217.19	84.31	0.00	271.37	546.78	964.61	1,497.97	867.42	812.78
7/3/07 18:53	60.34	478,741.31	366.89	481,152.69	86.21	0.00	271.39	546.80	963.77	1,501.49	866.86	812.32
7/3/07 18:54	60.47	482,411.09	366.82	480,088.19	85.43	0.00	271.28	546.81	963.18	1,503.12	866.63	811.79
7/3/07 18:55	60.61	481,428.00	366.77	479,023.81	83.96	0.00	271.25	546.59	962.92	1,502.56	866.09	810.90
7/3/07 18:56	60.53	483,667.91	366.69	477,959.31	82.91	0.00	271.17	546.40	963.43	1,503.39	865.74	810.17
7/3/07 18:57	59.87	476,110.91	366.59	476,894.81	82.23	0.00	271.08	546.17	964.61	1,496.28	865.40	809.69
7/3/07 18:58	59.52	473,685.81	366.47	475,853.81	82.81	0.00	271.08	545.73	963.01	1,495.54	864.31	808.02
7/3/07 18:59	58.99	469,806.19	366.33	474,851.09	84.45	0.00	270.99	545.62	962.62	1,493.11	863.34	807.02
7/3/07 19:00	58.67	467,136.41	366.18	473,848.50	84.49	0.00	270.81	545.79	963.81	1,492.03	862.71	806.90
7/3/07 19:01	59.09	469,554.00	366.12	472,845.91	86.51	0.00	270.61	545.67	964.15	1,498.10	862.33	806.80
7/3/07 19:02	59.06	469,645.50	366.04	471,843.31	88.55	0.00	270.38	545.69	964.81	1,499.30	861.97	806.80
7/3/07 19:03	58.45	464,292.59	365.98	470,840.69	88.69	0.00	270.17	545.61	965.93	1,493.95	861.78	806.27
7/3/07 19:04	58.69	464,512.19	365.83	469,838.00	88.24	0.00	270.04	545.47	966.83	1,496.79	861.36	805.77
7/3/07 19:05	58.93	466,653.59	365.76	468,835.41	88.82	0.00	269.87	545.44	967.00	1,500.62	860.86	805.14
7/3/07 19:06	58.56	463,886.81	365.65	467,832.81	88.96	0.00	269.72	545.36	966.91	1,496.09	860.49	805.03
7/3/07 19:07	58.78	464,516.09	365.52	466,830.19	85.22	0.00	269.64	545.22	966.29	1,498.58	860.15	804.36
7/3/07 19:08	58.66	464,878.91	365.47	465,827.50	87.59	0.00	269.54	545.04	966.59	1,497.22	859.74	804.13
7/3/07 19:09	58.45	462,512.81	365.30	464,824.91	81.83	0.00	269.52	544.64	964.95	1,495.80	859.05	804.63
7/3/07 19:10	58.27	462,132.91	365.22	463,822.31	81.41	0.00	269.48	544.51	965.18	1,496.48	858.55	804.84
7/3/07 19:11	57.85	460,401.31	365.08	462,819.69	79.56	0.00	269.38	544.31	964.17	1,497.96	858.00	804.70
7/3/07 19:12	57.94	459,471.59	364.93	461,817.09	81.25	0.00	269.27	544.24	964.85	1,495.29	857.59	803.84
7/3/07 19:13	57.64	457,519.41	364.82	460,814.41	83.05	0.00	269.17	544.12	964.38	1,495.24	857.15	803.07
7/3/07 19:14	58.11	460,076.91	364.69	459,811.81	83.90	0.00	269.02	544.25	967.04	1,501.66	857.31	802.86
7/3/07 19:15	57.83	457,365.09	364.57	458,809.19	84.16	0.00	268.84	544.37	969.81	1,495.30	857.58	804.22
7/3/07 19:16	57.78	456,720.00	364.47	457,806.59	87.39	0.00	268.74	544.20	969.97	1,496.74	857.31	804.14
7/3/07 19:17	57.51	454,307.69	364.35	456,804.00	85.84	0.00	268.60	544.15	970.46	1,495.50	856.83	804.53
7/3/07 19:18	57.83	456,986.19	364.23	455,801.31	83.25	0.00	268.51	544.29	971.33	1,499.57	856.83	805.71
7/3/07 19:19	57.30	452,093.69	364.09	455,008.09	82.91	0.00	268.38	544.07	968.61	1,494.35	856.22	804.93
7/3/07 19:20	57.47	453,722.69	363.92	456,649.81	82.99	0.00	268.27	544.05	967.65	1,498.17	855.58	804.07
7/3/07 19:21	57.47	454,911.91	363.81	458,291.59	82.99	0.00	268.16	544.08	967.34	1,498.15	855.48	803.97
7/3/07 19:22	57.30	452,150.31	363.70	459,933.41	80.18	0.00	268.04	543.91	966.43	1,496.81	855.20	802.86
7/3/07 19:23	57.23	450,182.19	363.56	461,575.09	78.22	0.00	267.91	543.81	966.20	1,495.12	854.75	802.11
7/3/07 19:24	57.99	455,740.59	363.44	463,216.91	81.71	0.00	267.82	543.94	969.08	1,505.54	854.69	803.08
7/3/07 19:25	57.82	454,537.91	363.40	463,740.59	80.80	0.00	267.71	544.07	971.06	1,499.14	855.07	802.89
7/3/07 19:26	58.02	457,966.41	363.28	464,060.41	80.88	0.00	267.72	543.75	971.34	1,503.25	854.87	802.84
7/3/07 19:27	57.87	455,126.59	363.17	464,380.31	81.24	0.00	267.80	543.53	971.64	1,498.40	855.01	802.74
7/3/07 19:28	57.87	455,172.91	363.07	464,700.19	78.43	0.00	267.84	543.34	971.14	1,499.44	854.90	802.73
7/3/07 19:29	57.74	454,765.31	362.96	465,020.09	77.04	0.00	267.89	543.21	969.74	1,497.22	854.87	802.33
7/3/07 19:30	57.66	453,256.81	362.85	465,339.91	77.18	0.00	267.87	543.04	969.21	1,498.11	854.83	802.24
7/3/07 19:31	57.74	456,191.81	362.72	465,659.81	75.43	0.00	267.86	542.85	968.41	1,498.55	854.70	801.89
7/3/07 19:32	58.91	464,232.91	362.60	466,068.19	76.25	0.00	267.82	542.87	970.67	1,510.79	855.28	802.59
7/3/07 19:33	59.30	466,487.81	362.60	467,803.69	78.31	0.00	267.77	542.98	972.22	1,509.93	856.23	803.70
7/3/07 19:34	59.68	472,593.81	362.60	469,539.19	80.77	0.00	267.87	542.64	972.85	1,510.21	856.77	804.38
7/3/07 19:35	60.14	474,043.91	362.48	471,274.69	79.28	0.00	268.08	542.27	972.40	1,506.33	856.83	804.31
7/3/07 19:36	60.49	477,190.00	362.36	473,010.19	78.99	0.00	268.35	541.70	971.31	1,509.36	856.43	803.29
7/3/07 19:37	60.34	475,219.41	362.19	474,745.69	83.20	0.00	268.63	541.13	970.38	1,502.06	855.82	802.65

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEGF)	SH OUTLET FLUE GAS TEMP (DEGF)
7/3/07 19:38	60.55	478,515.00	362.02	476,481.09	80.67	0.00	268.91	540.55	969.40	1,504.26	855.39	801.98
7/3/07 19:39	60.41	480,184.50	361.91	478,216.59	76.30	0.00	269.20	540.16	970.21	1,504.34	855.44	802.26
7/3/07 19:40	60.26	479,779.31	361.88	479,952.09	77.28	0.00	269.43	539.72	970.32	1,503.12	855.76	802.35
7/3/07 19:41	60.06	474,495.41	361.87	481,002.41	75.60	0.00	269.70	539.24	970.37	1,497.03	856.18	803.38
7/3/07 19:42	59.88	472,782.81	361.96	481,141.31	74.92	0.00	269.84	539.17	972.06	1,495.10	857.28	805.74
7/3/07 19:43	60.22	472,864.41	361.98	481,280.19	77.83	0.00	269.90	538.91	971.02	1,498.72	857.97	806.37
7/3/07 19:44	60.88	478,851.31	362.15	481,419.00	75.75	0.00	269.84	538.98	971.46	1,505.45	858.68	806.86
7/3/07 19:45	60.92	480,140.69	362.20	481,557.91	79.68	0.00	269.79	539.01	971.82	1,505.37	859.70	807.03
7/3/07 19:46	61.02	478,677.81	362.37	481,696.81	77.32	0.00	269.86	538.78	970.76	1,499.99	860.09	807.00
7/3/07 19:47	61.12	480,225.31	362.46	481,835.59	80.86	0.00	269.90	538.56	970.26	1,503.38	860.42	806.56
7/3/07 19:48	61.85	487,273.09	362.54	481,974.50	82.68	0.00	270.05	538.58	970.84	1,509.43	860.99	806.72
7/3/07 19:49	61.26	481,255.41	362.68	482,113.41	80.71	0.00	270.17	538.59	971.99	1,498.23	861.95	806.79
7/3/07 19:50	61.21	480,957.69	362.73	482,564.69	81.75	0.00	270.30	538.24	971.22	1,498.91	862.27	807.10
7/3/07 19:51	61.81	485,965.69	362.80	483,565.59	80.45	0.00	270.48	538.26	972.30	1,506.92	862.95	807.23
7/3/07 19:52	62.05	487,939.41	362.91	484,566.50	77.16	0.00	270.64	538.35	973.76	1,508.64	863.85	808.05
7/3/07 19:53	62.12	487,954.59	363.09	485,567.41	78.69	0.00	270.76	538.52	975.56	1,507.63	865.10	809.44
7/3/07 19:54	62.28	488,223.19	363.20	486,568.31	82.37	0.00	270.91	538.39	974.74	1,508.93	865.80	810.19
7/3/07 19:55	62.32	489,797.81	363.32	487,569.19	73.45	0.00	271.06	538.34	974.17	1,509.41	866.16	809.88
7/3/07 19:56	62.13	488,220.91	363.47	487,691.31	81.62	0.00	271.22	538.42	973.43	1,505.84	866.70	809.83
7/3/07 19:57	62.11	488,718.91	363.59	487,429.19	81.46	0.00	271.31	538.45	972.29	1,505.18	867.15	810.42
7/3/07 19:58	62.40	491,866.00	363.75	487,167.19	82.43	0.00	271.46	538.52	971.59	1,511.27	867.67	810.71
7/3/07 19:59	62.48	493,146.50	363.93	486,905.19	83.97	0.00	271.51	538.86	972.30	1,513.62	868.30	811.57
7/3/07 20:00	62.56	493,140.81	364.10	486,643.09	84.11	0.00	271.59	538.95	970.69	1,514.66	868.55	811.01
7/3/07 20:01	62.61	493,856.31	364.24	486,381.09	89.35	0.00	271.70	539.06	971.10	1,515.27	868.53	811.48
7/3/07 20:02	62.53	493,944.31	364.39	486,119.09	96.85	0.00	271.82	539.29	968.94	1,512.61	868.33	811.28
7/3/07 20:03	62.08	491,656.31	364.51	485,857.00	98.43	0.00	271.93	539.39	967.08	1,504.57	867.91	811.13
7/3/07 20:04	62.07	491,717.41	364.65	485,595.00	95.16	0.00	271.97	539.58	965.07	1,504.73	867.57	811.23
7/3/07 20:05	61.60	487,721.31	364.72	485,333.00	88.40	0.00	271.94	539.81	964.53	1,495.41	867.59	811.01
7/3/07 20:06	61.44	488,635.31	364.82	485,070.91	82.65	0.00	271.96	539.92	964.27	1,497.55	867.67	811.18
7/3/07 20:07	61.05	483,812.41	364.89	484,808.91	80.65	0.00	271.88	539.99	964.61	1,485.51	867.48	810.47
7/3/07 20:08	60.99	483,983.50	364.95	484,546.91	79.95	0.00	271.83	539.91	965.00	1,486.76	867.01	810.56
7/3/07 20:09	61.04	483,611.91	365.06	484,284.81	82.27	0.00	271.72	539.97	967.05	1,488.19	867.34	810.83
7/3/07 20:10	60.69	480,262.59	365.12	484,022.81	83.65	0.00	271.60	540.09	968.07	1,483.77	867.30	811.17
7/3/07 20:11	60.65	479,971.19	365.20	481,614.31	84.20	0.00	271.53	540.09	968.22	1,487.30	866.93	810.41
7/3/07 20:12	60.72	480,453.31	365.28	478,851.59	81.23	0.00	271.38	540.29	968.98	1,490.98	866.73	810.20
7/3/07 20:13	60.06	469,300.69	365.37	476,088.81	80.94	0.00	271.23	540.55	969.98	1,486.34	867.03	810.31
7/3/07 20:14	59.84	470,209.59	365.42	475,805.31	82.70	0.00	271.12	540.57	969.02	1,491.31	866.53	809.95
7/3/07 20:15	61.23	481,574.19	365.43	477,584.69	86.82	0.00	270.90	540.97	971.45	1,505.89	866.27	809.34
7/3/07 20:16	61.32	479,078.50	365.49	479,364.00	87.39	0.00	270.65	541.39	974.92	1,500.03	866.73	809.08
7/3/07 20:17	61.55	479,602.31	365.49	481,143.41	89.90	0.00	270.64	541.17	975.07	1,501.08	866.22	808.29
7/3/07 20:18	61.69	483,240.31	365.44	482,922.69	91.72	0.00	270.76	541.06	975.68	1,505.79	866.03	808.16
7/3/07 20:19	61.62	482,814.81	365.43	484,702.09	89.09	0.00	270.83	540.98	974.93	1,503.46	866.05	808.76
7/3/07 20:20	61.89	484,704.81	365.45	486,481.41	90.28	0.00	270.91	541.06	974.73	1,507.04	866.36	809.21
7/3/07 20:21	62.15	488,478.09	365.52	488,260.81	87.80	0.00	271.01	541.08	972.89	1,508.96	866.45	809.80
7/3/07 20:22	62.41	490,825.69	365.57	490,040.09	85.43	0.00	271.13	541.09	972.06	1,512.23	866.64	809.94
7/3/07 20:23	62.96	494,296.69	365.65	491,819.50	81.18	0.00	271.20	541.06	971.67	1,519.92	866.95	810.33
7/3/07 20:24	62.86	494,242.50	365.77	493,598.81	82.41	0.00	271.34	541.10	971.32	1,517.25	867.51	810.71
7/3/07 20:25	62.52	491,152.41	365.79	495,378.19	86.44	0.00	271.51	540.90	968.90	1,510.77	867.47	810.36
7/3/07 20:26	62.77	495,860.59	365.87	495,562.00	87.07	0.00	271.65	540.60	967.13	1,517.59	867.02	810.38
7/3/07 20:27	62.61	494,759.50	365.93	495,560.31	86.33	0.00	271.80	540.77	968.51	1,513.42	867.60	810.71

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEGF)	SH OUTLET FLUE GAS TEMP (DEGF)
7/3/07 20:28	62.39	494,307.69	366.01	495,558.59	88.92	0.00	271.89	540.56	966.90	1,509.19	867.40	810.71
7/3/07 20:29	62.89	497,937.59	366.05	495,556.91	86.47	0.00	271.94	540.40	967.27	1,512.48	867.46	810.46
7/3/07 20:30	63.01	498,710.31	366.19	495,555.19	82.29	0.00	271.93	540.26	968.48	1,511.21	867.89	810.00
7/3/07 20:31	62.81	495,165.41	366.33	495,553.50	79.81	0.00	272.05	540.06	968.80	1,506.25	868.21	809.72
7/3/07 20:32	63.15	499,352.31	366.49	495,551.81	81.75	0.00	272.11	540.18	970.51	1,509.26	869.40	810.52
7/3/07 20:33	62.57	495,297.50	366.73	495,550.19	81.21	0.00	272.17	540.16	970.33	1,501.83	870.70	811.18
7/3/07 20:34	62.62	495,212.81	366.98	495,548.41	82.73	0.00	272.30	540.23	970.78	1,501.49	871.76	811.65
7/3/07 20:35	62.59	494,314.69	367.18	495,546.81	80.71	0.00	272.31	540.35	971.40	1,500.61	872.87	812.02
7/3/07 20:36	62.89	495,358.81	367.39	495,545.09	78.33	0.00	272.32	540.36	971.46	1,503.19	873.73	812.59
7/3/07 20:37	63.05	496,946.09	367.53	495,543.41	82.09	0.00	272.33	540.51	972.06	1,506.29	874.76	813.87
7/3/07 20:38	62.95	495,935.31	367.78	495,541.69	83.71	0.00	272.39	540.72	972.85	1,502.22	875.87	814.72
7/3/07 20:39	63.14	498,615.50	367.97	495,975.50	84.53	0.00	272.45	540.65	972.05	1,505.61	876.65	815.21
7/3/07 20:40	63.79	503,774.91	368.15	497,745.59	82.86	0.00	272.53	540.88	973.34	1,512.34	877.71	816.06
7/3/07 20:41	64.32	503,254.69	368.35	499,515.59	77.41	0.00	272.60	541.18	974.85	1,510.51	878.90	816.72
7/3/07 20:42	65.07	512,236.81	368.58	501,285.69	80.49	0.00	272.78	541.39	976.32	1,519.47	879.90	817.87
7/3/07 20:43	64.97	511,547.00	368.80	503,055.69	83.69	0.00	272.97	541.66	976.62	1,514.59	880.88	818.88
7/3/07 20:44	64.86	512,033.31	369.02	504,825.81	85.54	0.00	273.27	541.69	975.01	1,510.52	881.33	818.97
7/3/07 20:45	64.63	509,372.91	369.12	505,744.69	85.43	0.00	273.55	541.61	971.41	1,506.28	881.08	818.70
7/3/07 20:46	64.78	512,086.00	369.26	504,466.09	85.97	0.00	273.76	541.77	969.85	1,507.55	880.97	818.57
7/3/07 20:47	64.36	508,100.91	369.40	503,187.41	85.50	0.00	273.96	541.74	966.28	1,503.14	880.60	817.67
7/3/07 20:48	64.14	507,821.59	369.53	501,908.81	88.13	0.00	274.10	541.99	965.12	1,499.84	880.54	817.92
7/3/07 20:49	63.60	503,926.41	369.63	500,630.09	87.24	0.00	274.16	542.06	963.64	1,494.98	880.37	817.80
7/3/07 20:50	63.21	501,053.69	369.70	499,351.50	87.99	0.00	274.13	542.10	962.97	1,492.86	879.86	816.79
7/3/07 20:51	63.04	498,655.50	369.80	498,072.81	88.06	0.00	274.01	542.22	962.53	1,495.76	879.18	816.26
7/3/07 20:52	62.52	493,801.09	369.91	496,794.19	87.54	0.00	273.82	542.60	964.92	1,490.21	879.14	815.95
7/3/07 20:53	62.29	490,230.91	370.01	495,515.50	87.17	0.00	273.53	542.69	964.98	1,490.65	878.61	815.19
7/3/07 20:54	62.81	493,512.50	370.10	494,236.91	88.39	0.00	273.35	542.84	967.59	1,500.89	878.45	815.10
7/3/07 20:55	62.56	487,478.50	370.21	493,287.00	89.74	0.00	273.11	543.37	971.30	1,490.72	879.00	816.17
7/3/07 20:56	62.22	487,830.69	370.36	492,745.81	88.10	0.00	272.90	543.42	970.74	1,493.48	876.97	815.50
7/3/07 20:57	62.19	486,538.41	370.40	492,204.50	89.85	0.00	272.79	544.08	970.87	1,493.71	873.85	814.21
7/3/07 20:58	61.68	481,095.50	370.51	491,663.31	87.51	0.00	272.57	544.72	970.35	1,482.92	873.17	814.19
7/3/07 20:59	61.65	483,349.50	370.59	491,122.00	83.40	0.00	272.37	544.75	968.30	1,483.37	872.27	813.37
7/3/07 21:00	62.12	485,361.31	370.63	490,580.81	81.60	0.00	272.19	544.97	969.55	1,491.55	872.51	813.54
7/3/07 21:01	61.55	480,897.19	370.71	490,923.31	85.56	0.00	272.00	545.31	971.20	1,485.16	873.53	814.19
7/3/07 21:02	61.71	480,372.31	370.69	492,052.31	89.35	0.00	271.87	545.36	971.21	1,487.56	874.03	813.91
7/3/07 21:03	61.81	484,205.31	370.64	493,181.31	89.00	0.00	271.77	545.79	972.44	1,495.67	874.83	814.25
7/3/07 21:04	61.83	483,001.41	370.56	494,310.19	88.81	0.00	271.65	546.38	973.07	1,495.90	875.67	814.67
7/3/07 21:05	61.94	483,763.19	370.36	495,439.19	90.01	0.00	271.53	546.71	973.04	1,498.73	876.25	814.68
7/3/07 21:06	61.82	482,706.41	370.08	496,568.09	89.93	0.00	271.43	546.83	971.99	1,496.94	876.72	814.78
7/3/07 21:07	61.58	481,883.50	369.74	497,697.09	89.17	0.00	271.36	546.79	970.33	1,496.30	876.81	814.70
7/3/07 21:08	61.83	483,975.31	369.35	498,826.09	87.56	0.00	271.24	546.95	969.72	1,500.84	876.77	814.52
7/3/07 21:09	62.23	485,997.81	368.98	499,955.00	87.45	0.00	271.12	547.48	971.84	1,505.49	877.44	815.36
7/3/07 21:10	62.00	485,061.41	368.61	501,084.00	88.11	0.00	271.04	547.74	971.32	1,501.54	877.72	815.31
7/3/07 21:11	62.12	485,619.41	368.08	502,212.91	85.25	0.00	270.97	548.05	971.48	1,503.61	877.93	815.31
7/3/07 21:12	62.69	490,251.41	367.60	503,341.91	81.93	0.00	270.93	548.21	971.52	1,512.04	878.28	815.72
7/3/07 21:13	62.64	489,802.69	367.21	504,470.91	82.28	0.00	270.88	548.31	971.60	1,509.37	878.70	816.21
7/3/07 21:14	62.91	493,445.00	366.88	505,599.81	81.66	0.00	270.90	548.01	969.49	1,513.97	878.55	816.43
7/3/07 21:15	63.14	491,543.31	366.61	506,728.81	81.97	0.00	270.92	548.05	971.41	1,513.58	879.17	817.36
7/3/07 21:16	63.22	494,718.50	366.41	507,857.81	81.12	0.00	271.02	547.75	970.09	1,518.72	879.40	817.65
7/3/07 21:17	63.26	492,418.69	366.29	508,986.69	83.89	0.00	271.13	547.66	971.59	1,515.30	880.06	818.54

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEGF)	SH OUTLET FLUE GAS TEMP (DEGF)
7/3/07 21:18	63.47	497,525.91	366.16	510,115.69	83.41	0.00	271.23	547.40	970.73	1,518.23	880.09	818.54
7/3/07 21:19	64.44	505,401.31	366.04	511,244.69	88.28	0.00	271.35	547.24	972.29	1,524.61	880.09	818.68
7/3/07 21:20	65.52	514,772.69	365.93	511,570.31	93.36	0.00	271.54	546.97	974.13	1,530.04	880.38	819.51
7/3/07 21:21	65.16	513,430.69	365.90	511,622.19	94.03	0.00	271.87	546.57	975.15	1,520.73	880.97	820.54
7/3/07 21:22	65.12	512,710.50	365.87	511,674.00	92.93	0.00	272.28	545.71	971.71	1,514.93	880.75	820.21
7/3/07 21:23	64.95	511,112.00	365.91	511,725.91	91.91	0.00	272.73	545.29	970.54	1,509.07	881.02	820.89
7/3/07 21:24	64.34	507,814.81	365.96	511,777.81	87.80	0.00	273.02	544.96	967.97	1,500.72	881.41	821.21
7/3/07 21:25	63.76	502,525.31	366.01	510,219.50	85.50	0.00	273.25	544.47	963.98	1,493.72	881.02	820.13
7/3/07 21:26	63.68	503,243.19	365.98	508,289.59	84.41	0.00	273.38	544.19	962.61	1,498.69	880.75	819.64
7/3/07 21:27	63.85	503,660.41	366.06	506,359.81	82.66	0.00	273.29	544.38	964.23	1,500.41	881.07	820.02
7/3/07 21:28	63.84	503,203.19	366.15	504,429.91	86.10	0.00	273.20	544.47	965.54	1,501.98	881.44	820.52
7/3/07 21:29	63.82	501,847.81	366.29	503,383.31	86.26	0.00	273.10	544.57	968.70	1,500.73	882.21	820.96
7/3/07 21:30	63.49	496,314.31	366.40	503,594.69	86.47	0.00	272.99	544.64	971.14	1,496.27	882.92	821.31
7/3/07 21:31	64.01	501,363.81	366.51	503,806.09	86.44	0.00	272.97	544.55	972.43	1,504.94	883.21	821.28
7/3/07 21:32	64.47	504,732.41	366.63	504,017.50	85.55	0.00	272.88	544.90	974.57	1,508.01	884.17	821.83
7/3/07 21:33	64.27	502,249.09	366.79	504,228.91	84.50	0.00	272.84	545.18	975.38	1,503.42	885.10	822.61
7/3/07 21:34	64.26	503,025.69	366.92	504,440.41	87.28	0.00	272.98	545.09	973.35	1,503.04	885.40	822.85
7/3/07 21:35	64.30	504,735.50	367.04	504,651.81	92.91	0.00	273.05	545.23	972.58	1,505.88	885.85	823.17
7/3/07 21:36	64.35	504,455.69	367.17	504,863.19	94.96	0.00	273.14	545.53	972.64	1,504.20	886.62	824.18
7/3/07 21:37	64.32	504,800.19	367.29	505,074.59	92.64	0.00	273.23	545.67	971.74	1,503.36	887.09	825.11
7/3/07 21:38	64.34	503,691.59	367.48	505,286.00	92.78	0.00	273.33	545.97	971.08	1,503.59	886.32	825.76
7/3/07 21:39	63.91	500,186.19	367.66	505,497.41	90.81	0.00	273.45	546.64	971.15	1,497.87	883.56	823.69
7/3/07 21:40	64.01	501,661.41	367.83	505,708.81	89.52	0.00	273.49	546.84	969.35	1,500.56	882.54	822.94
7/3/07 21:41	64.54	505,054.81	368.06	505,920.31	85.82	0.00	273.49	547.35	971.82	1,506.54	883.04	823.66
7/3/07 21:42	64.77	505,990.19	368.37	507,410.69	85.94	0.00	273.45	548.03	975.04	1,506.50	884.89	825.21
7/3/07 21:43	65.00	508,343.69	368.64	510,995.50	89.25	0.00	273.43	548.26	975.70	1,508.02	886.28	826.01
7/3/07 21:44	65.75	515,423.59	368.92	514,580.31	90.38	0.00	273.53	548.70	976.93	1,515.40	887.88	826.63
7/3/07 21:45	65.98	516,649.59	369.16	518,165.09	93.26	0.00	273.62	549.51	978.69	1,513.60	890.14	828.44
7/3/07 21:46	66.07	518,619.91	369.40	519,788.41	95.61	0.00	273.79	550.18	977.12	1,515.45	891.48	828.93
7/3/07 21:47	65.82	516,217.81	369.55	519,703.09	94.33	0.00	273.95	550.67	975.52	1,510.11	892.46	829.13
7/3/07 21:48	65.78	517,274.50	369.61	519,617.81	90.94	0.00	274.14	550.85	974.00	1,508.25	893.14	829.53
7/3/07 21:49	65.20	513,619.41	369.62	519,532.41	93.59	0.00	274.22	550.85	970.54	1,500.81	893.25	829.41
7/3/07 21:50	65.34	515,442.31	369.58	519,447.09	94.68	0.00	274.27	550.81	967.30	1,503.98	893.07	829.09
7/3/07 21:51	65.14	514,637.69	369.53	519,361.81	95.12	0.00	274.24	551.14	966.89	1,502.17	893.54	829.77
7/3/07 21:52	65.07	514,729.41	369.42	519,276.41	96.51	0.00	274.23	551.16	965.64	1,501.96	893.37	829.15
7/3/07 21:53	65.37	516,402.00	369.25	519,191.09	95.30	0.00	274.10	551.13	968.12	1,506.31	893.15	828.59
7/3/07 21:54	65.49	517,110.50	368.99	519,105.69	94.87	0.00	274.08	550.93	969.83	1,506.92	893.06	828.40
7/3/07 21:55	65.48	515,889.09	368.83	519,020.41	92.05	0.00	274.03	550.52	970.43	1,505.50	892.55	828.06
7/3/07 21:56	65.75	517,888.81	368.66	518,935.09	89.50	0.00	274.06	550.07	970.09	1,507.91	891.88	827.44
7/3/07 21:57	66.00	519,634.31	368.63	518,849.69	89.31	0.00	274.10	550.05	971.83	1,511.22	892.30	827.95
7/3/07 21:58	65.15	512,524.81	368.71	518,764.41	89.51	0.00	274.16	549.91	969.62	1,497.64	892.49	828.02
7/3/07 21:59	64.68	509,771.31	368.77	517,017.09	86.77	0.00	274.28	549.70	966.15	1,493.82	892.16	827.67
7/3/07 22:00	63.74	502,390.81	368.89	513,338.41	86.95	0.00	274.30	549.70	962.77	1,487.03	891.72	827.25
7/3/07 22:01	63.28	498,881.69	368.90	509,659.81	91.37	0.00	274.15	549.88	960.16	1,487.57	891.22	826.89
7/3/07 22:02	63.47	500,456.41	369.04	505,981.09	91.41	0.00	273.86	550.47	961.39	1,492.32	891.38	827.08
7/3/07 22:03	63.34	498,284.31	369.20	502,302.41	92.14	0.00	273.52	550.80	962.20	1,493.30	891.53	826.81
7/3/07 22:04	62.36	488,892.31	369.32	498,623.81	89.15	0.00	273.33	550.83	963.36	1,483.73	891.43	826.68
7/3/07 22:05	62.07	485,186.09	369.40	494,945.09	88.90	0.00	273.11	550.72	963.12	1,485.70	890.41	825.72
7/3/07 22:06	62.38	486,757.50	369.44	491,266.41	89.34	0.00	272.94	551.11	965.51	1,490.35	890.17	825.65
7/3/07 22:07	62.46	487,133.59	369.48	488,886.50	90.34	0.00	272.61	551.74	967.75	1,493.35	890.47	826.29

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEGF)	SH OUTLET FLUE GAS TEMP (DEGF)
7/3/07 22:08	62.46	485,939.69	369.60	486,713.50	88.60	0.00	272.26	552.31	969.53	1,493.44	890.42	826.45
7/3/07 22:09	62.71	488,113.09	369.67	484,540.59	86.60	0.00	272.07	552.58	969.16	1,497.30	889.85	825.50
7/3/07 22:10	62.46	484,054.59	369.76	482,367.69	73.22	0.00	271.94	553.06	970.64	1,489.60	889.83	825.08
7/3/07 22:11	62.12	483,613.59	369.76	480,194.81	80.45	0.00	271.92	553.10	967.15	1,486.52	888.58	823.80
7/3/07 22:12	62.08	483,707.59	369.79	478,021.91	82.35	0.00	271.86	553.44	966.49	1,488.85	887.72	822.93
7/3/07 22:13	61.70	481,251.81	369.81	475,849.00	82.89	0.00	271.75	553.96	966.08	1,485.59	887.35	822.65
7/3/07 22:14	61.42	477,521.00	369.80	473,676.09	80.64	0.00	271.64	554.32	966.31	1,485.72	887.27	822.56
7/3/07 22:15	60.67	467,609.09	369.80	472,268.09	79.34	0.00	271.55	554.45	965.09	1,483.34	886.60	821.61
7/3/07 22:16	60.63	472,614.59	369.78	472,419.09	81.56	0.00	271.34	554.82	966.65	1,494.87	886.18	821.50
7/3/07 22:17	60.49	472,508.19	369.76	472,570.00	84.26	0.00	270.94	555.38	968.12	1,495.79	886.30	821.63
7/3/07 22:18	60.27	468,905.50	369.79	472,721.00	84.50	0.00	270.67	555.68	968.71	1,493.45	886.20	822.13
7/3/07 22:19	59.93	466,795.19	369.77	472,871.91	86.13	0.00	270.48	555.93	968.91	1,493.71	885.96	822.30
7/3/07 22:20	60.15	467,052.31	369.72	473,022.91	85.66	0.00	270.24	556.31	968.56	1,497.83	885.62	822.24
7/3/07 22:21	60.77	472,022.19	369.71	473,173.91	87.37	0.00	270.04	556.87	969.72	1,504.38	885.84	822.64
7/3/07 22:22	60.99	478,777.69	369.75	473,860.41	87.18	0.00	269.86	557.37	970.78	1,508.18	886.12	823.04
7/3/07 22:23	61.17	476,144.81	369.77	475,129.19	85.97	0.00	269.76	557.54	970.18	1,502.84	885.95	822.69
7/3/07 22:24	61.48	476,264.59	369.76	476,397.91	86.78	0.00	269.83	557.64	969.68	1,504.72	885.61	822.31
7/3/07 22:25	61.63	481,645.09	369.76	477,666.59	86.10	0.00	269.91	557.93	970.81	1,507.88	885.86	822.59
7/3/07 22:26	61.89	478,360.50	369.77	478,935.31	86.90	0.00	270.04	558.01	970.53	1,501.62	886.16	822.60
7/3/07 22:27	61.96	478,498.50	369.79	477,880.81	88.52	0.00	270.18	557.78	970.37	1,498.05	885.90	822.42
7/3/07 22:28	61.46	476,247.50	369.77	476,290.09	88.98	0.00	270.31	557.40	968.30	1,498.65	885.36	821.95
7/3/07 22:29	61.10	476,884.81	369.73	474,699.41	89.18	0.00	270.44	557.26	967.40	1,499.05	884.95	821.42
7/3/07 22:30	60.70	472,329.19	369.69	473,108.81	88.65	0.00	270.38	557.18	966.93	1,495.36	884.68	821.07
7/3/07 22:31	60.68	472,146.31	369.71	471,518.09	89.51	0.00	270.35	556.95	965.94	1,497.31	884.04	820.10
7/3/07 22:32	60.27	469,083.19	369.63	469,927.41	88.43	0.00	270.21	556.77	966.22	1,492.84	883.63	819.72
7/3/07 22:33	60.20	473,560.19	369.62	468,336.69	89.55	0.00	270.08	556.49	966.18	1,499.88	883.22	819.72
7/3/07 22:34	60.36	473,857.41	369.62	466,746.00	89.07	0.00	269.93	556.40	967.49	1,499.27	883.13	819.80
7/3/07 22:35	59.68	461,196.50	369.56	465,879.91	87.72	0.00	269.73	556.31	967.79	1,490.96	882.64	818.59
7/3/07 22:36	59.79	464,970.09	369.59	470,729.81	88.87	0.00	269.59	556.11	967.87	1,498.77	881.52	817.13
7/3/07 22:37	60.44	472,979.19	369.73	475,579.69	89.56	0.00	269.35	556.52	973.61	1,507.46	879.51	819.37
7/3/07 22:38	60.79	470,301.31	369.84	478,929.81	90.87	0.00	269.16	556.44	975.95	1,503.21	876.49	819.38
7/3/07 22:39	61.34	478,208.09	369.83	481,854.81	91.91	0.00	269.10	555.88	974.81	1,508.60	874.61	817.23
7/3/07 22:40	62.45	482,713.50	369.81	484,779.91	93.43	0.00	269.11	555.41	975.31	1,511.96	874.57	818.56
7/3/07 22:41	62.57	482,922.69	369.85	487,705.00	95.15	0.00	269.26	555.16	976.88	1,507.58	876.26	820.83
7/3/07 22:42	62.03	480,414.59	369.89	490,630.00	93.92	0.00	269.46	554.34	975.76	1,501.64	875.40	821.90
7/3/07 22:43	61.52	477,509.19	369.89	491,533.69	86.70	0.00	269.82	553.38	972.87	1,499.18	873.99	822.92
7/3/07 22:44	60.77	473,108.41	369.87	490,755.31	83.32	0.00	270.03	552.65	969.10	1,495.11	873.99	823.64
7/3/07 22:45	60.64	471,426.91	369.81	489,976.91	89.57	0.00	270.09	552.10	966.09	1,495.67	873.81	822.21
7/3/07 22:46	60.68	473,563.31	369.80	489,198.59	91.49	0.00	269.97	551.71	966.69	1,498.64	873.20	821.17
7/3/07 22:47	60.57	472,959.81	369.86	488,419.59	91.52	0.00	269.77	551.66	972.23	1,498.37	871.90	822.18
7/3/07 22:48	59.68	464,490.91	369.90	487,638.91	95.01	0.00	269.57	550.88	971.11	1,493.03	869.37	819.58
7/3/07 22:49	60.19	468,531.31	369.91	486,858.19	94.64	0.00	269.41	550.42	971.81	1,499.90	868.54	818.32
7/3/07 22:50	60.39	470,718.31	369.90	487,516.81	93.96	0.00	269.09	550.35	972.47	1,500.74	869.93	819.71
7/3/07 22:51	60.47	471,077.00	370.02	488,507.69	89.11	0.00	268.79	550.37	972.80	1,501.80	871.62	821.42
7/3/07 22:52	60.24	468,121.59	370.19	489,498.41	82.97	0.00	268.63	550.63	975.58	1,496.53	872.50	824.50
7/3/07 22:53	60.70	471,101.81	370.38	490,489.31	73.58	0.00	268.55	550.64	975.78	1,502.27	873.93	826.89
7/3/07 22:54	60.59	466,688.59	370.51	491,480.09	71.72	0.00	268.53	550.56	973.50	1,497.59	875.65	827.43
7/3/07 22:55	61.00	472,708.19	370.64	492,470.81	76.12	0.00	268.45	550.67	972.87	1,504.44	876.88	827.48
7/3/07 22:56	61.95	480,180.81	370.78	493,348.81	85.05	0.00	268.39	551.02	974.80	1,507.72	878.09	828.56
7/3/07 22:57	61.12	472,524.81	370.99	494,051.50	88.73	0.00	268.51	551.06	974.27	1,498.58	878.02	829.00

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE	STEAM	SDA INLET	TOAL	BIOMASS	PROPANE	FWP DISCH	ECONOMIZER	SH OUT	SH OUTLET	SH OUTLET	SH OUTLET
	OUTPUT	FLOW	TEMP	FEEDWATER	FUEL FLOW	FLOW	TEMP	OUT FW	STEAM	STEAM	FLUE GAS	FLUE GAS
	(gross MW)	(LB/HR)	(DEGF)	FLOW (LB/HR)	(TPH)	(SCFH)	(DEGF)	TEMP (DEGF)	TEMP	PRESS (PSI)	TEMP (DEGF)	TEMP (DEGF)
7/3/07 22:58	60.88	472,262.31	371.15	494,754.31	88.89	0.00	268.70	550.72	973.19	1,497.47	877.24	827.38
7/3/07 22:59	61.25	480,434.50	371.27	495,457.00	84.02	0.00	268.83	550.45	972.83	1,507.21	877.63	827.08
7/3/07 23:00	61.55	477,825.50	371.35	496,159.69	79.49	0.00	268.93	550.65	972.11	1,502.37	879.34	827.74
7/3/07 23:01	61.95	479,148.50	371.47	496,862.41	79.91	0.00	269.09	550.53	970.11	1,504.69	879.99	828.03
7/3/07 23:02	62.27	484,024.09	371.63	497,221.81	80.79	0.00	269.21	550.70	972.02	1,505.96	880.66	829.64
7/3/07 23:03	61.69	478,613.41	371.78	496,171.50	79.47	0.00	269.33	550.53	971.80	1,498.60	881.56	830.62
7/3/07 23:04	61.34	483,131.41	371.92	495,121.09	78.59	0.00	269.46	550.34	972.56	1,503.93	882.47	830.49
7/3/07 23:05	61.39	480,335.81	371.96	494,070.81	80.67	0.00	269.61	550.20	971.02	1,501.77	882.13	830.22
7/3/07 23:06	62.37	482,877.81	372.06	493,883.31	83.80	0.00	269.65	550.52	971.14	1,506.12	881.69	831.19
7/3/07 23:07	62.61	486,755.50	372.22	494,924.81	85.13	0.00	269.59	550.90	971.22	1,507.80	881.10	831.95
7/3/07 23:08	63.41	494,239.69	372.37	495,966.31	85.52	0.00	269.67	551.18	972.92	1,518.56	881.25	832.77
7/3/07 23:09	63.09	489,581.69	372.60	497,007.81	85.35	0.00	269.87	551.24	974.92	1,509.49	882.38	834.33
7/3/07 23:10	63.11	489,982.69	372.68	498,049.31	85.02	0.00	270.12	550.86	971.48	1,508.52	882.03	832.99
7/3/07 23:11	63.15	490,968.59	372.71	496,718.91	83.55	0.00	270.34	550.62	968.03	1,509.71	881.63	832.12
7/3/07 23:12	62.95	490,007.09	372.79	495,296.19	81.47	0.00	270.50	550.64	967.99	1,504.30	881.38	832.03
7/3/07 23:13	62.38	486,330.69	372.76	493,873.41	80.40	0.00	270.70	549.94	964.74	1,494.30	880.40	830.05
7/3/07 23:14	62.08	484,040.41	372.62	492,450.69	79.41	0.00	270.85	549.30	963.39	1,490.94	879.57	827.25
7/3/07 23:15	61.89	482,235.09	372.57	491,028.00	79.66	0.00	270.85	548.98	967.14	1,490.30	879.37	825.06
7/3/07 23:16	61.07	474,520.09	372.62	489,605.19	83.16	0.00	270.84	548.99	971.61	1,487.65	877.16	823.87
7/3/07 23:17	60.50	467,476.41	372.78	489,384.31	85.61	0.00	270.76	549.11	975.88	1,485.65	875.29	823.52
7/3/07 23:18	60.15	465,792.00	372.94	489,328.41	84.40	0.00	270.64	549.22	976.89	1,488.74	875.51	821.77
7/3/07 23:19	60.01	464,460.50	373.07	489,272.59	84.09	0.00	270.40	549.23	975.93	1,492.51	876.72	822.29
7/3/07 23:20	60.28	464,283.31	373.19	489,216.81	85.07	0.00	269.98	549.53	976.24	1,496.26	878.30	823.91
7/3/07 23:21	61.12	472,856.00	373.36	489,161.00	80.95	0.00	269.67	550.03	979.47	1,504.83	878.54	825.85
7/3/07 23:22	60.83	469,089.09	373.52	490,111.41	83.22	0.00	269.42	550.40	980.66	1,499.97	879.03	827.33
7/3/07 23:23	61.71	473,283.50	373.68	491,178.81	83.82	0.00	269.35	550.54	978.62	1,505.57	880.57	828.55
7/3/07 23:24	62.24	480,005.91	373.83	492,246.31	82.88	0.00	269.34	550.83	978.61	1,507.45	882.79	828.39
7/3/07 23:25	62.30	481,944.69	374.03	493,313.69	80.98	0.00	269.48	550.81	977.54	1,507.15	883.24	827.62
7/3/07 23:26	62.53	485,041.69	374.19	494,381.09	79.27	0.00	269.68	550.89	977.38	1,507.41	881.26	827.05
7/3/07 23:27	62.82	485,763.50	374.40	495,448.50	82.52	0.00	269.90	551.08	977.51	1,508.68	880.05	825.80
7/3/07 23:28	62.49	482,783.00	374.58	496,515.91	84.29	0.00	270.15	550.95	974.86	1,502.40	880.36	824.80
7/3/07 23:29	62.16	481,859.91	374.73	497,583.31	82.74	0.00	270.33	550.92	971.51	1,499.08	881.51	825.40
7/3/07 23:30	62.11	484,410.19	374.86	497,982.31	83.57	0.00	270.47	550.64	969.28	1,502.97	882.01	826.09
7/3/07 23:31	62.33	484,639.09	374.99	497,987.19	84.34	0.00	270.52	550.89	969.94	1,503.54	881.29	826.62
7/3/07 23:32	62.28	483,993.91	375.15	497,992.19	84.33	0.00	270.49	551.16	970.97	1,501.42	881.50	827.42
7/3/07 23:33	62.52	485,887.81	375.33	497,997.09	85.46	0.00	270.49	551.21	970.48	1,504.92	882.83	828.06
7/3/07 23:34	62.16	483,008.59	375.46	498,002.00	86.24	0.00	270.47	551.32	970.10	1,499.14	883.64	826.39
7/3/07 23:35	62.48	485,736.81	375.58	498,006.91	87.80	0.00	270.50	551.31	970.63	1,505.02	883.00	824.87
7/3/07 23:36	63.11	489,758.41	375.78	498,011.91	88.18	0.00	270.50	551.59	972.92	1,511.35	881.43	824.77
7/3/07 23:37	62.78	486,838.00	375.97	498,016.81	86.72	0.00	270.53	551.86	974.19	1,504.54	880.74	823.21
7/3/07 23:38	62.81	487,230.31	376.12	498,021.81	87.41	0.00	270.61	551.68	973.19	1,504.24	880.91	822.25
7/3/07 23:39	63.15	489,623.09	376.29	498,026.69	87.38	0.00	270.73	551.87	973.39	1,509.62	882.41	824.18
7/3/07 23:40	62.79	487,616.91	376.45	498,031.59	87.44	0.00	270.79	551.90	971.27	1,501.95	882.94	825.19
7/3/07 23:41	63.02	489,073.81	376.61	498,036.50	87.80	0.00	270.90	551.78	969.99	1,507.33	882.17	826.39
7/3/07 23:42	62.94	488,649.09	376.78	498,041.50	86.77	0.00	270.99	551.71	969.24	1,505.59	882.71	827.48
7/3/07 23:43	62.81	487,904.59	376.94	498,046.41	86.28	0.00	271.09	551.72	968.58	1,502.81	884.33	827.91
7/3/07 23:44	62.57	487,252.50	377.08	498,051.31	87.14	0.00	271.15	551.35	966.61	1,498.62	884.88	824.82
7/3/07 23:45	62.63	487,723.31	377.21	498,056.31	87.33	0.00	271.21	550.97	966.16	1,499.49	882.23	822.14
7/3/07 23:46	62.61	487,199.31	377.36	498,061.19	86.19	0.00	271.25	550.91	968.44	1,499.82	878.96	820.88
7/3/07 23:47	62.30	483,746.50	377.54	498,066.09	87.58	0.00	271.29	550.78	967.29	1,493.70	877.91	818.80

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE	STEAM	SDA INLET	TOAL	BIOMASS	PROPANE	FWP DISCH	ECONOMIZER	SH OUT	SH OUTLET	SH OUTLET	SH OUTLET
	OUTPUT	FLOW	TEMP	FEEDWATER	FUEL FLOW	FLOW	TEMP	OUT FW	STEAM	STEAM	FLUE GAS	FLUE GAS
	(gross MW)	(LB/HR)	(DEGF)	FLOW (LB/HR)	(TPH)	(SCFH)	(DEGF)	TEMP (DEGF)	TEMP	PRESS (PSI)	TEMP (DEGF)	TEMP (DEGF)
7/3/07 23:48	61.93	482,199.91	377.67	497,977.00	89.20	0.00	271.30	550.59	966.53	1,491.27	878.18	818.94
7/3/07 23:49	62.00	480,873.91	377.76	497,645.09	94.88	0.00	271.24	550.59	967.60	1,492.49	879.16	821.29
7/3/07 23:50	62.01	479,447.31	377.82	497,313.09	91.22	0.00	271.14	550.64	967.99	1,495.10	878.21	822.08
7/3/07 23:51	62.03	478,822.09	377.96	496,981.09	87.82	0.00	270.98	550.86	970.01	1,497.02	877.28	823.47
7/3/07 23:52	61.69	477,122.19	378.09	496,649.19	85.23	0.00	270.87	551.19	971.14	1,495.44	878.38	824.95
7/3/07 23:53	61.30	474,082.09	378.14	496,317.19	83.43	0.00	270.79	551.22	969.50	1,495.71	879.12	823.76
7/3/07 23:54	61.96	481,063.59	378.23	495,985.31	79.55	0.00	270.70	551.46	970.54	1,504.95	879.46	821.12
7/3/07 23:55	61.96	479,274.59	378.37	495,864.59	75.44	0.00	270.50	551.71	972.67	1,500.67	877.88	820.19
7/3/07 23:56	61.42	474,405.91	378.47	495,887.19	75.17	0.00	270.44	551.59	971.47	1,496.61	875.25	818.32
7/3/07 23:57	60.91	472,529.09	378.51	495,909.81	75.14	0.00	270.39	551.42	969.02	1,495.45	874.34	814.82
7/3/07 23:58	61.67	479,040.59	378.53	495,932.41	74.78	0.00	270.37	551.59	969.02	1,505.14	875.20	815.15
7/3/07 23:59	61.04	473,935.31	378.55	495,955.00	77.38	0.00	270.22	551.82	969.08	1,496.34	876.65	816.54
7/4/07 0:00	61.15	474,714.50	378.61	495,977.69	79.64	0.00	270.18	551.77	968.04	1,500.69	875.89	817.85
7/4/07 0:01	61.29	477,290.09	378.77	496,000.31	80.40	0.00	270.15	552.02	969.05	1,500.49	875.97	820.26
7/4/07 0:02	61.50	476,774.31	378.88	496,022.91	78.41	0.00	270.11	552.29	968.11	1,501.15	877.60	822.59
7/4/07 0:03	61.17	475,279.19	378.99	496,045.50	81.44	0.00	270.12	552.66	968.68	1,497.95	879.67	821.39
7/4/07 0:04	61.34	477,512.59	379.15	496,068.09	82.45	0.00	270.13	552.84	968.19	1,503.86	880.24	819.71
7/4/07 0:05	60.84	471,748.69	379.32	496,090.81	86.23	0.00	270.08	553.16	969.67	1,496.06	878.50	819.73
7/4/07 0:06	61.44	475,719.50	379.46	496,113.31	83.01	0.00	270.07	553.32	969.57	1,502.00	876.65	818.33
7/4/07 0:07	62.10	481,038.00	379.58	496,113.31	81.49	0.00	270.02	553.84	971.13	1,506.04	877.83	815.84
7/4/07 0:08	62.00	480,739.81	379.72	495,359.41	83.41	0.00	269.98	554.15	971.46	1,503.37	879.85	817.08
7/4/07 0:09	62.39	484,686.19	379.85	494,605.50	81.73	0.00	270.01	554.31	972.20	1,506.94	881.36	819.50
7/4/07 0:10	62.76	485,700.91	379.95	493,851.59	84.80	0.00	270.09	554.30	971.88	1,507.87	881.09	821.80
7/4/07 0:11	62.42	482,511.09	380.07	493,097.69	84.45	0.00	270.21	554.53	972.85	1,500.95	881.90	824.24
7/4/07 0:12	62.01	479,436.91	380.12	492,343.81	81.21	0.00	270.29	554.41	969.32	1,497.63	882.86	825.29
7/4/07 0:13	62.51	484,097.09	380.14	492,920.19	80.74	0.00	270.43	554.41	968.74	1,505.48	883.79	821.49
7/4/07 0:14	62.73	485,514.69	380.24	494,680.41	81.89	0.00	270.47	554.61	972.61	1,505.47	882.59	818.18
7/4/07 0:15	62.90	486,078.41	380.35	496,440.50	79.83	0.00	270.53	554.28	972.89	1,507.18	878.10	816.09
7/4/07 0:16	63.02	486,503.81	380.39	498,200.69	76.30	0.00	270.60	554.10	974.35	1,506.08	875.49	812.95
7/4/07 0:17	63.77	491,888.91	380.42	499,960.81	78.77	0.00	270.66	553.93	975.86	1,516.74	875.64	811.36
7/4/07 0:18	64.00	493,588.09	380.43	501,721.00	83.26	0.00	270.76	553.88	977.56	1,520.41	876.93	808.40
7/4/07 0:19	64.26	496,059.59	380.42	503,481.09	81.85	0.00	270.94	553.51	976.55	1,524.56	875.66	806.14
7/4/07 0:20	64.13	494,316.91	380.39	505,241.31	79.25	0.00	271.10	553.23	977.08	1,518.10	872.53	806.24
7/4/07 0:21	64.12	495,349.31	380.34	507,001.41	64.79	0.00	271.30	552.70	973.28	1,514.01	870.84	803.66
7/4/07 0:22	64.32	498,880.31	380.32	508,761.59	73.99	0.00	271.44	552.53	972.09	1,512.96	871.98	803.46
7/4/07 0:23	64.06	497,663.31	380.35	510,521.69	80.06	0.00	271.62	552.24	969.46	1,509.14	873.16	806.20
7/4/07 0:24	63.74	494,459.09	380.41	510,703.41	81.21	0.00	271.76	551.82	967.06	1,503.77	873.21	808.48
7/4/07 0:25	63.57	493,425.19	380.47	510,019.41	85.30	0.00	271.83	551.52	965.55	1,501.39	872.29	810.57
7/4/07 0:26	63.44	492,568.50	380.58	509,335.50	85.53	0.00	271.83	551.48	965.14	1,499.18	873.02	812.89
7/4/07 0:27	62.61	486,537.41	380.52	508,651.59	88.17	0.00	271.77	551.06	962.67	1,487.75	873.53	812.24
7/4/07 0:28	63.19	489,779.81	380.31	507,967.69	91.98	0.00	271.73	550.27	964.84	1,498.99	873.00	805.12
7/4/07 0:29	63.48	491,594.19	380.09	507,283.69	97.41	0.00	271.55	549.75	971.29	1,504.19	869.18	803.15
7/4/07 0:30	63.64	490,799.31	379.89	506,118.50	100.00	0.00	271.42	549.15	974.87	1,506.12	864.45	801.65
7/4/07 0:31	63.19	486,338.81	379.63	504,743.00	95.93	0.00	271.46	548.42	976.18	1,495.26	862.41	796.88
7/4/07 0:32	63.36	488,464.31	379.38	503,367.41	90.02	0.00	271.48	547.58	974.16	1,500.72	862.14	795.86
7/4/07 0:33	63.01	485,007.31	379.11	501,991.91	92.77	0.00	271.46	546.98	973.35	1,493.60	862.47	797.63
7/4/07 0:34	62.93	485,730.69	378.86	500,616.31	91.40	0.00	271.38	546.23	970.79	1,492.71	860.94	799.15
7/4/07 0:35	63.04	487,462.41	378.61	499,240.81	91.93	0.00	271.37	545.58	969.04	1,496.24	859.08	800.33
7/4/07 0:36	62.63	484,595.81	378.38	497,865.19	88.79	0.00	271.27	545.08	966.95	1,489.05	858.85	801.33
7/4/07 0:37	62.51	485,190.09	378.10	496,489.69	87.60	0.00	271.21	544.56	965.72	1,489.49	859.24	799.28

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEGF)	SH OUTLET FLUE GAS TEMP (DEGF)
7/4/07 0:38	61.94	480,876.91	377.87	495,114.09	87.48	0.00	271.21	543.86	964.09	1,482.15	858.97	795.13
7/4/07 0:39	61.43	476,273.31	377.63	493,738.50	87.58	0.00	271.15	543.45	964.25	1,481.45	856.77	794.51
7/4/07 0:40	60.71	470,563.59	377.48	492,394.41	84.64	0.00	271.04	543.19	964.65	1,483.90	855.03	793.34
7/4/07 0:41	60.48	470,300.41	377.37	491,131.50	83.75	0.00	270.82	543.20	965.49	1,489.67	855.78	791.52
7/4/07 0:42	59.40	460,433.09	377.25	489,868.59	81.45	0.00	270.52	543.34	966.80	1,484.70	857.29	793.49
7/4/07 0:43	60.19	467,032.59	377.01	488,605.59	80.02	0.00	270.19	543.32	967.62	1,496.43	857.73	795.16
7/4/07 0:44	60.34	467,277.91	376.88	487,811.09	79.30	0.00	269.77	543.54	970.50	1,498.43	857.19	797.11
7/4/07 0:45	61.02	472,271.50	376.71	488,332.50	78.53	0.00	269.47	543.75	972.43	1,503.87	857.55	799.37
7/4/07 0:46	60.85	471,054.69	376.56	488,853.91	79.63	0.00	269.28	543.95	973.20	1,501.03	858.75	800.84
7/4/07 0:47	61.03	470,892.59	376.36	489,375.31	78.50	0.00	269.22	544.16	974.24	1,501.56	859.28	799.22
7/4/07 0:48	60.91	469,580.00	376.25	489,896.81	76.73	0.00	269.25	544.26	974.41	1,498.99	858.72	796.90
7/4/07 0:49	61.02	472,122.59	376.07	490,418.19	76.72	0.00	269.22	544.19	972.24	1,501.49	857.78	795.34
7/4/07 0:50	60.81	470,901.69	375.88	490,939.59	81.25	0.00	269.27	544.30	971.20	1,501.28	856.91	793.60
7/4/07 0:51	60.94	470,967.50	375.74	491,461.09	80.77	0.00	269.29	544.30	969.51	1,500.74	856.92	793.47
7/4/07 0:52	60.88	471,152.81	375.53	491,982.50	81.90	0.00	269.31	544.35	969.18	1,501.33	857.65	795.43
7/4/07 0:53	61.11	471,548.81	375.39	492,503.91	82.85	0.00	269.30	544.41	970.31	1,499.62	857.93	797.27
7/4/07 0:54	61.06	472,045.91	375.24	493,025.31	82.95	0.00	269.31	544.17	969.62	1,500.57	857.52	797.94
7/4/07 0:55	61.08	473,805.81	375.06	493,546.81	78.93	0.00	269.36	543.97	968.23	1,503.14	856.83	798.89
7/4/07 0:56	62.09	478,793.19	374.91	494,045.69	78.86	0.00	269.39	544.14	969.94	1,508.56	857.82	799.70
7/4/07 0:57	62.19	479,765.41	374.80	492,762.59	77.41	0.00	269.33	544.29	972.25	1,503.36	859.43	799.54
7/4/07 0:58	61.65	476,639.69	374.63	491,479.59	78.18	0.00	269.47	544.02	971.22	1,498.70	859.54	798.32
7/4/07 0:59	61.56	477,597.59	374.38	490,196.59	80.51	0.00	269.64	543.49	970.11	1,501.44	858.85	796.58
7/4/07 1:00	61.68	482,408.50	374.08	488,913.50	79.26	0.00	269.74	543.28	970.89	1,506.91	858.69	795.39
7/4/07 1:01	60.74	469,468.41	373.84	487,630.50	80.88	0.00	269.75	543.24	969.31	1,492.65	859.34	796.02
7/4/07 1:02	60.68	469,724.91	373.66	487,530.00	81.15	0.00	269.81	543.10	966.26	1,496.46	858.89	796.47
7/4/07 1:03	61.31	475,927.19	373.55	487,832.50	79.82	0.00	269.78	543.34	968.43	1,503.42	859.03	796.85
7/4/07 1:04	61.53	477,468.59	373.46	488,135.00	76.40	0.00	269.59	543.40	969.12	1,504.09	859.04	797.97
7/4/07 1:05	61.63	479,995.31	373.39	488,437.50	75.88	0.00	269.53	543.39	971.05	1,505.88	859.60	799.97
7/4/07 1:06	61.85	478,560.19	373.27	488,739.91	69.84	0.00	269.54	543.22	970.64	1,503.50	860.06	800.97
7/4/07 1:07	61.97	475,303.59	373.15	489,042.41	72.51	0.00	269.62	543.04	969.62	1,498.49	859.90	801.47
7/4/07 1:08	62.15	481,377.91	373.07	489,344.91	73.80	0.00	269.71	542.86	967.48	1,502.37	859.31	802.41
7/4/07 1:09	62.14	483,335.41	372.93	489,647.41	72.95	0.00	269.85	542.60	965.33	1,501.69	858.51	802.78
7/4/07 1:10	61.99	479,402.19	372.88	489,949.91	73.32	0.00	270.03	542.27	964.79	1,499.09	857.84	802.08
7/4/07 1:11	61.55	474,966.31	372.73	490,252.41	75.97	0.00	270.12	541.79	963.65	1,496.22	857.17	803.37
7/4/07 1:12	61.82	479,386.09	372.64	489,874.50	78.78	0.00	270.32	541.52	963.48	1,501.75	856.86	805.98
7/4/07 1:13	61.20	474,372.41	372.50	488,757.09	81.41	0.00	270.27	541.55	965.12	1,493.30	856.59	808.29
7/4/07 1:14	61.31	475,544.69	372.35	487,767.69	82.27	0.00	270.31	541.00	963.71	1,497.77	855.36	809.41
7/4/07 1:15	61.13	474,575.69	372.08	486,987.59	85.28	0.00	270.33	540.73	964.85	1,498.07	854.59	810.73
7/4/07 1:16	60.73	472,870.50	371.78	486,207.59	86.41	0.00	270.25	540.37	966.44	1,498.45	854.66	810.78
7/4/07 1:17	60.82	471,189.09	371.49	485,427.59	82.09	0.00	270.15	540.00	967.04	1,498.07	854.47	809.73
7/4/07 1:18	61.16	475,973.19	371.21	484,647.59	70.96	0.00	270.06	539.85	968.78	1,503.06	854.77	808.37
7/4/07 1:19	61.77	478,286.81	370.96	483,867.50	63.73	0.00	269.84	539.81	970.78	1,507.03	855.54	807.62
7/4/07 1:20	61.80	478,510.09	370.74	483,087.50	71.04	0.00	269.73	539.58	971.38	1,505.24	856.25	807.29
7/4/07 1:21	61.46	474,704.50	370.53	482,307.50	71.44	0.00	269.74	539.12	970.25	1,500.66	856.50	806.15
7/4/07 1:22	61.79	478,507.50	370.27	481,527.50	73.92	0.00	269.75	538.92	970.04	1,504.56	856.72	805.34
7/4/07 1:23	61.40	474,324.09	370.07	480,747.50	74.39	0.00	269.77	538.87	969.82	1,497.09	857.11	804.69
7/4/07 1:24	60.76	471,799.59	369.87	479,967.41	75.65	0.00	269.85	538.70	967.74	1,493.39	857.01	803.41
7/4/07 1:25	61.06	473,523.09	369.67	478,209.09	77.61	0.00	269.91	538.66	967.28	1,499.24	857.11	803.03
7/4/07 1:26	60.26	467,871.69	369.47	476,173.50	78.57	0.00	269.86	538.63	966.26	1,493.19	857.15	802.62
7/4/07 1:27	60.41	467,808.91	369.28	474,137.91	77.94	0.00	269.82	538.51	965.82	1,497.15	856.98	802.07

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEGF)	SH OUTLET FLUE GAS TEMP (DEGF)
7/4/07 1:28	60.53	468,975.50	369.11	472,102.31	79.96	0.00	269.71	538.71	968.06	1,497.88	857.38	801.98
7/4/07 1:29	60.12	466,041.09	368.98	470,066.59	78.78	0.00	269.65	538.68	968.22	1,497.17	857.48	801.73
7/4/07 1:30	59.97	461,581.19	368.85	468,031.00	79.56	0.00	269.59	538.62	969.15	1,493.98	857.47	801.62
7/4/07 1:31	60.28	466,049.09	368.72	465,995.41	77.72	0.00	269.53	538.76	970.43	1,501.32	857.74	801.78
7/4/07 1:32	59.72	460,189.59	368.59	463,959.81	76.81	0.00	269.42	538.97	971.46	1,494.22	858.22	802.01
7/4/07 1:33	59.38	457,999.69	368.44	461,924.09	77.01	0.00	269.33	539.00	970.03	1,492.18	858.00	801.45
7/4/07 1:34	59.57	459,456.19	368.27	459,888.50	76.16	0.00	269.30	539.11	969.45	1,497.53	857.60	800.89
7/4/07 1:35	59.55	458,494.19	368.13	457,852.91	74.88	0.00	269.17	539.70	970.48	1,495.95	856.20	800.95
7/4/07 1:36	58.40	449,526.81	368.11	455,817.31	75.72	0.00	269.01	540.59	970.45	1,486.79	853.93	799.20
7/4/07 1:37	58.57	451,177.19	368.02	454,064.19	74.02	0.00	268.97	540.96	969.16	1,493.08	853.05	798.73
7/4/07 1:38	58.01	447,647.31	367.96	454,216.09	76.56	0.00	268.80	541.33	969.45	1,488.69	853.04	799.02
7/4/07 1:39	58.11	447,398.69	367.89	454,368.09	76.50	0.00	268.59	541.51	968.13	1,493.20	853.24	799.37
7/4/07 1:40	57.53	443,660.50	367.73	454,520.00	74.26	0.00	268.34	541.77	967.91	1,488.52	853.69	799.56
7/4/07 1:41	56.95	439,672.59	367.54	454,671.91	73.75	0.00	268.13	541.87	966.14	1,489.11	853.83	799.35
7/4/07 1:42	57.34	442,078.59	367.32	454,823.81	78.09	0.00	267.88	542.54	968.21	1,495.53	854.57	800.12
7/4/07 1:43	58.19	449,448.09	367.08	454,975.69	77.45	0.00	267.52	543.50	970.95	1,505.20	855.95	801.33
7/4/07 1:44	58.32	447,475.31	366.84	457,826.00	76.74	0.00	267.32	544.45	973.99	1,500.66	857.57	802.52
7/4/07 1:45	58.35	449,040.91	366.50	460,781.41	76.59	0.00	267.22	544.41	973.08	1,502.59	858.21	802.64
7/4/07 1:46	59.20	455,543.81	366.06	463,736.81	75.60	0.00	267.18	544.60	974.31	1,508.25	858.99	803.63
7/4/07 1:47	59.31	455,253.31	365.65	466,692.19	74.00	0.00	267.20	544.82	974.93	1,505.79	860.12	804.53
7/4/07 1:48	59.86	459,943.59	365.17	469,647.59	73.03	0.00	267.28	545.05	974.14	1,508.53	860.94	805.05
7/4/07 1:49	60.23	461,690.19	364.70	472,603.00	71.74	0.00	267.41	545.45	973.28	1,508.47	861.93	806.00
7/4/07 1:50	60.58	465,478.91	364.18	475,558.41	77.20	0.00	267.59	545.91	973.37	1,505.95	863.12	807.16
7/4/07 1:51	61.36	472,673.31	363.64	478,513.81	76.10	0.00	267.77	546.12	972.20	1,511.10	864.12	808.00
7/4/07 1:52	61.73	474,570.31	363.25	481,469.19	77.43	0.00	267.99	546.39	972.82	1,507.51	865.28	809.24
7/4/07 1:53	61.88	475,546.09	362.91	484,424.59	77.05	0.00	268.25	546.19	971.08	1,506.19	865.71	809.39
7/4/07 1:54	61.79	475,302.50	362.53	485,313.00	78.13	0.00	268.56	546.08	970.72	1,502.81	866.19	809.82
7/4/07 1:55	62.39	479,035.91	362.37	484,481.69	78.65	0.00	268.78	545.89	970.18	1,506.80	866.81	810.53
7/4/07 1:56	61.67	473,547.81	362.27	483,650.41	77.71	0.00	269.05	545.63	969.60	1,497.04	867.28	810.94
7/4/07 1:57	61.84	480,067.19	362.18	482,819.00	77.20	0.00	269.32	545.46	968.19	1,506.30	867.21	812.43
7/4/07 1:58	61.46	471,835.69	362.09	481,987.69	77.47	0.00	269.41	545.54	968.53	1,493.78	867.71	813.38
7/4/07 1:59	61.19	472,430.50	361.94	481,525.19	77.78	0.00	269.58	545.37	965.34	1,495.98	866.96	813.09
7/4/07 2:00	60.86	470,125.41	361.96	481,211.59	78.84	0.00	269.63	545.29	963.27	1,494.24	866.10	811.84
7/4/07 2:01	61.76	475,478.91	361.93	480,898.00	81.86	0.00	269.58	545.49	963.55	1,503.55	865.80	811.89
7/4/07 2:02	61.64	475,839.00	361.97	480,584.41	81.59	0.00	269.53	545.55	964.13	1,499.57	865.85	811.51
7/4/07 2:03	62.23	480,629.59	361.97	480,270.81	81.20	0.00	269.60	545.18	963.87	1,506.89	865.35	810.77
7/4/07 2:04	62.08	479,249.69	362.03	479,957.19	81.25	0.00	269.68	544.99	966.32	1,503.06	865.66	810.84
7/4/07 2:05	61.70	476,380.81	362.04	479,643.50	81.59	0.00	269.81	544.61	966.51	1,500.87	865.76	811.13
7/4/07 2:06	62.08	479,542.91	362.13	479,329.91	75.98	0.00	269.97	544.55	966.66	1,505.59	866.09	811.44
7/4/07 2:07	61.83	477,945.81	362.40	479,016.31	77.15	0.00	270.16	544.76	967.79	1,499.48	867.10	812.41
7/4/07 2:08	61.08	470,470.09	362.53	478,702.69	78.41	0.00	270.28	544.61	966.18	1,492.65	867.56	813.21
7/4/07 2:09	61.18	472,193.69	362.64	478,075.41	75.51	0.00	270.43	544.32	965.02	1,497.29	867.57	813.16
7/4/07 2:10	61.28	473,124.59	362.77	477,411.69	78.46	0.00	270.38	544.35	965.29	1,498.71	867.75	814.07
7/4/07 2:11	60.80	469,093.59	362.88	476,747.91	80.14	0.00	270.31	544.35	965.14	1,493.36	867.78	813.44
7/4/07 2:12	60.04	463,907.59	362.84	476,084.19	81.28	0.00	270.26	544.04	963.97	1,491.51	866.83	812.24
7/4/07 2:13	60.24	464,926.50	362.76	475,420.41	83.61	0.00	270.18	543.79	964.19	1,496.18	865.58	810.71
7/4/07 2:14	60.88	469,600.59	362.68	474,756.69	82.94	0.00	269.91	543.66	965.08	1,504.40	864.67	810.56
7/4/07 2:15	61.69	475,531.91	362.66	475,298.19	83.26	0.00	269.68	544.07	969.05	1,507.20	865.01	811.22
7/4/07 2:16	61.34	471,838.00	362.74	476,326.09	80.73	0.00	269.59	544.09	969.22	1,501.55	865.30	811.79
7/4/07 2:17	60.79	468,386.31	362.81	477,353.91	75.60	0.00	269.64	544.02	968.41	1,496.69	865.33	812.10

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE	STEAM	SDA INLET	TOAL	BIOMASS	PROPANE	FWP DISCH	ECONOMIZER	SH OUT	SH OUTLET	SH OUTLET	SH OUTLET
	OUTPUT	FLOW	TEMP	FEEDWATER	FUEL FLOW	FLOW	TEMP	OUT FW	STEAM	STEAM	FLUE GAS	FLUE GAS
	(gross MW)	(LB/HR)	(DEGF)	FLOW (LB/HR)	(TPH)	(SCFH)	(DEGF)	TEMP (DEGF)	TEMP	PRESS (PSI)	TEMP (DEGF)	TEMP (DEGF)
7/4/07 2:18	61.74	477,157.81	362.93	478,587.09	76.77	0.00	269.70	544.04	968.42	1,507.18	865.62	812.75
7/4/07 2:19	61.29	472,058.09	363.08	479,844.09	79.50	0.00	269.67	544.32	968.68	1,497.88	866.31	813.14
7/4/07 2:20	60.54	467,224.09	363.12	480,209.09	82.47	0.00	269.71	544.25	965.11	1,493.86	866.01	812.44
7/4/07 2:21	60.38	465,358.50	363.17	480,084.91	85.05	0.00	269.75	544.18	963.03	1,493.86	865.47	811.71
7/4/07 2:22	60.81	470,952.00	363.17	479,960.81	81.97	0.00	269.66	544.42	964.49	1,502.11	865.62	812.11
7/4/07 2:23	60.34	467,042.31	363.26	479,836.59	78.50	0.00	269.52	544.75	966.47	1,496.76	866.06	813.13
7/4/07 2:24	60.24	466,324.41	363.34	479,712.41	76.60	0.00	269.46	544.73	967.01	1,498.70	865.99	812.73
7/4/07 2:25	60.22	464,609.50	363.34	479,588.19	75.46	0.00	269.35	544.64	968.29	1,499.31	865.61	813.00
7/4/07 2:26	60.84	469,818.41	363.38	479,342.09	74.84	0.00	269.21	544.79	970.71	1,504.10	865.79	813.87
7/4/07 2:27	59.89	461,922.50	363.41	478,273.31	75.76	0.00	269.13	544.73	969.88	1,495.11	865.67	813.75
7/4/07 2:28	60.08	464,684.81	363.42	477,204.50	77.30	0.00	269.13	544.60	968.38	1,499.75	865.10	812.97
7/4/07 2:29	60.27	465,518.81	363.42	476,135.81	75.09	0.00	269.09	544.72	968.59	1,499.30	865.08	812.41
7/4/07 2:30	60.29	465,786.19	363.45	475,116.50	74.85	0.00	269.02	544.68	967.78	1,500.52	864.97	811.56
7/4/07 2:31	59.30	458,515.41	363.40	474,101.00	73.18	0.00	268.98	544.44	965.87	1,490.72	864.45	810.89
7/4/07 2:32	59.63	461,477.69	363.35	473,085.50	72.26	0.00	269.00	544.40	965.88	1,497.11	863.64	810.48
7/4/07 2:33	60.22	465,254.00	363.31	473,260.19	76.49	0.00	268.89	544.58	967.77	1,503.09	863.72	810.76
7/4/07 2:34	60.83	469,507.59	363.44	475,017.81	78.29	0.00	268.76	544.98	970.77	1,506.38	864.81	812.13
7/4/07 2:35	61.60	471,524.59	363.61	476,775.50	77.21	0.00	268.76	545.31	972.88	1,507.03	866.65	813.56
7/4/07 2:36	62.21	478,017.59	363.83	481,401.00	76.40	0.00	268.86	545.58	976.03	1,509.19	868.54	816.08
7/4/07 2:37	63.00	484,233.09	364.07	486,360.00	70.76	0.00	268.97	545.51	977.02	1,509.86	870.21	817.55
7/4/07 2:38	62.84	483,753.31	364.19	491,319.00	71.72	0.00	269.25	545.30	975.72	1,506.72	871.30	818.43
7/4/07 2:39	62.83	482,949.09	364.32	492,423.81	71.14	0.00	269.54	545.15	973.23	1,505.94	872.05	818.77
7/4/07 2:40	62.90	484,766.19	364.40	491,810.50	73.55	0.00	269.86	545.19	971.19	1,506.21	872.54	819.42
7/4/07 2:41	63.09	486,834.59	364.52	491,197.09	74.78	0.00	270.12	545.37	969.75	1,507.28	873.05	820.52
7/4/07 2:42	63.06	487,294.09	364.61	490,583.81	74.33	0.00	270.31	545.45	968.18	1,506.84	873.41	820.76
7/4/07 2:43	63.13	487,738.09	364.70	489,970.50	75.37	0.00	270.45	545.20	967.67	1,507.05	873.47	821.09
7/4/07 2:44	63.14	488,230.31	364.84	489,357.19	75.13	0.00	270.58	545.28	967.82	1,504.25	873.70	820.62
7/4/07 2:45	63.32	489,400.50	364.93	488,743.81	76.58	0.00	270.71	545.29	968.12	1,507.27	873.80	820.60
7/4/07 2:46	63.03	486,723.31	365.04	488,130.50	79.64	0.00	270.77	545.10	966.94	1,502.64	873.60	819.55
7/4/07 2:47	62.87	486,259.59	365.04	487,517.19	78.89	0.00	270.92	544.86	966.36	1,499.64	873.40	819.00
7/4/07 2:48	62.86	486,636.50	365.12	486,903.91	81.80	0.00	270.94	544.67	966.36	1,501.22	873.25	818.08
7/4/07 2:49	62.68	483,675.59	365.19	486,290.50	78.49	0.00	270.97	544.64	968.88	1,497.24	873.49	818.88
7/4/07 2:50	62.43	482,209.09	365.30	485,677.19	78.30	0.00	270.94	544.45	969.96	1,495.73	873.59	819.97
7/4/07 2:51	62.22	477,664.31	365.38	485,172.91	74.99	0.00	270.92	544.29	970.39	1,494.80	873.30	820.09
7/4/07 2:52	62.69	483,625.91	365.48	486,937.41	74.10	0.00	270.91	544.40	971.74	1,501.76	873.18	820.76
7/4/07 2:53	61.92	477,498.91	365.53	485,948.09	78.49	0.00	270.83	544.34	971.16	1,495.93	873.29	820.91
7/4/07 2:54	62.36	476,016.91	365.61	484,451.19	79.22	0.00	270.83	544.29	969.75	1,496.50	872.77	820.36
7/4/07 2:55	62.81	483,921.81	365.69	491,135.59	81.69	0.00	270.74	544.31	970.10	1,505.20	872.92	819.78
7/4/07 2:56	62.22	478,733.91	365.78	490,258.81	81.56	0.00	270.71	544.34	969.86	1,499.48	873.02	819.36
7/4/07 2:57	62.93	485,827.19	365.85	489,847.31	82.85	0.00	270.75	544.21	969.90	1,505.93	873.00	818.87
7/4/07 2:58	62.96	484,667.00	366.00	492,662.19	83.47	0.00	270.85	544.17	971.57	1,504.05	873.48	819.30
7/4/07 2:59	62.33	480,042.91	366.07	491,625.59	83.55	0.00	270.91	543.79	971.06	1,498.18	873.54	819.17
7/4/07 3:00	62.86	482,923.19	366.10	488,266.59	81.06	0.00	270.98	543.82	971.29	1,504.45	873.36	819.52
7/4/07 3:01	63.22	485,893.81	366.20	496,062.09	82.18	0.00	271.01	544.06	973.26	1,506.98	874.04	820.86
7/4/07 3:02	62.83	483,782.59	366.34	493,853.59	83.71	0.00	271.05	544.18	973.21	1,500.35	874.60	820.91
7/4/07 3:03	62.99	485,287.81	366.42	493,618.31	81.31	0.00	271.11	544.13	972.12	1,502.64	874.56	820.17
7/4/07 3:04	62.84	484,637.59	366.50	494,393.19	79.18	0.00	271.17	544.16	971.24	1,499.94	874.64	819.42
7/4/07 3:05	62.94	485,280.09	366.57	491,353.41	79.92	0.00	271.17	544.29	969.84	1,503.43	874.62	819.24
7/4/07 3:06	62.74	483,567.31	366.62	494,850.19	79.22	0.00	271.16	544.51	969.77	1,498.20	874.84	818.89
7/4/07 3:07	63.12	486,958.59	366.71	493,540.69	81.48	0.00	271.09	544.43	968.93	1,505.75	874.59	819.02

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEGF)	SH OUTLET FLUE GAS TEMP (DEGF)
7/4/07 3:08	63.01	486,100.91	366.72	493,943.91	83.23	0.00	271.10	544.49	969.41	1,504.43	874.84	818.91
7/4/07 3:09	62.81	484,947.69	366.81	494,166.81	86.75	0.00	271.07	544.42	969.15	1,499.88	874.55	818.87
7/4/07 3:10	62.70	485,009.59	366.84	493,255.00	85.32	0.00	271.09	544.23	967.88	1,498.60	873.97	818.91
7/4/07 3:11	62.53	482,996.41	366.84	490,774.09	89.21	0.00	271.05	544.01	966.94	1,497.34	873.63	819.09
7/4/07 3:12	61.17	471,528.09	366.84	487,088.81	85.02	0.00	271.05	543.83	964.57	1,488.99	872.84	818.60
7/4/07 3:13	61.44	476,369.31	366.81	483,403.59	86.15	0.00	271.00	543.64	963.67	1,496.36	871.97	818.01
7/4/07 3:14	60.84	471,328.50	366.80	479,332.41	85.02	0.00	270.87	543.90	965.57	1,490.26	872.18	818.08
7/4/07 3:15	60.47	466,886.19	366.75	475,058.81	81.44	0.00	270.65	543.60	965.31	1,491.84	872.00	817.99
7/4/07 3:16	60.68	468,872.91	366.78	475,331.19	80.49	0.00	270.45	543.47	966.73	1,497.65	871.44	818.14
7/4/07 3:17	60.37	466,510.81	366.73	477,292.00	78.35	0.00	270.21	543.51	967.76	1,497.46	871.03	817.24
7/4/07 3:18	61.73	476,403.91	366.74	479,252.81	79.37	0.00	269.97	543.62	969.62	1,506.93	870.68	817.64
7/4/07 3:19	61.89	476,806.19	366.81	481,213.59	80.60	0.00	269.79	543.91	971.60	1,504.48	871.45	818.60
7/4/07 3:20	61.78	475,316.09	366.83	483,999.50	80.47	0.00	269.79	543.66	970.11	1,504.43	871.28	818.07
7/4/07 3:21	63.34	489,626.31	366.90	488,346.00	85.50	0.00	269.87	543.79	971.47	1,515.44	871.79	818.87
7/4/07 3:22	62.89	484,601.69	367.02	492,692.59	83.58	0.00	269.96	544.08	973.43	1,504.20	873.03	820.07
7/4/07 3:23	62.42	482,090.50	367.04	494,164.19	81.56	0.00	270.17	543.61	970.40	1,500.72	872.79	819.29
7/4/07 3:24	63.09	486,903.41	367.05	492,511.00	80.25	0.00	270.45	543.49	969.84	1,507.80	872.76	819.02
7/4/07 3:25	62.43	480,552.59	367.09	490,857.69	80.55	0.00	270.62	543.72	970.28	1,498.77	872.92	819.32
7/4/07 3:26	62.45	481,798.09	367.06	489,940.59	78.14	0.00	270.70	543.55	968.38	1,501.07	872.68	818.59
7/4/07 3:27	62.66	483,886.59	367.07	489,074.81	81.29	0.00	270.74	543.64	969.48	1,505.32	872.90	820.02
7/4/07 3:28	62.67	481,691.59	367.14	488,209.09	80.74	0.00	270.66	543.88	971.94	1,501.72	873.87	821.05
7/4/07 3:29	62.26	480,777.69	367.13	487,343.41	81.69	0.00	270.65	543.72	971.01	1,499.62	873.72	820.96
7/4/07 3:30	62.58	481,617.59	367.14	487,974.50	80.49	0.00	270.56	543.70	971.17	1,503.30	873.59	820.85
7/4/07 3:31	63.18	487,245.69	367.20	488,313.19	81.62	0.00	270.46	543.97	971.28	1,509.01	873.77	821.13
7/4/07 3:32	62.89	485,207.50	367.25	488,651.81	85.36	0.00	270.44	543.92	970.12	1,503.32	873.78	821.46
7/4/07 3:33	62.80	485,597.69	367.26	488,990.41	82.69	0.00	270.45	543.73	968.56	1,502.97	873.51	821.06
7/4/07 3:34	63.51	490,953.19	367.28	489,329.09	77.89	0.00	270.52	543.71	968.48	1,512.45	873.39	821.04
7/4/07 3:35	63.20	487,732.81	367.37	489,667.81	81.91	0.00	270.58	543.72	968.72	1,506.09	873.80	821.09
7/4/07 3:36	63.01	486,726.69	367.35	490,006.41	82.12	0.00	270.71	543.42	967.84	1,503.04	873.41	821.11
7/4/07 3:37	63.16	486,633.19	367.39	490,345.09	81.14	0.00	270.80	543.33	968.64	1,504.59	873.51	820.86
7/4/07 3:38	62.91	484,590.00	367.39	490,683.69	81.79	0.00	270.86	543.35	970.49	1,497.79	874.17	820.78
7/4/07 3:39	62.75	483,840.91	367.37	491,018.31	81.30	0.00	270.96	542.95	969.56	1,497.05	874.15	820.06
7/4/07 3:40	62.44	482,233.59	367.38	491,292.31	81.97	0.00	271.04	542.62	968.88	1,495.41	873.98	819.40
7/4/07 3:41	62.55	482,600.41	367.36	491,566.41	81.09	0.00	271.06	542.48	970.12	1,496.89	874.00	818.96
7/4/07 3:42	63.34	487,377.00	367.40	491,840.41	79.36	0.00	271.01	542.38	971.05	1,508.64	874.23	818.68
7/4/07 3:43	63.24	485,877.59	367.46	492,114.50	76.32	0.00	270.97	542.42	972.53	1,505.89	874.91	819.00
7/4/07 3:44	63.51	487,749.00	367.49	492,388.50	75.82	0.00	271.02	542.24	973.57	1,507.94	875.45	819.42
7/4/07 3:45	63.44	487,039.91	367.52	492,662.59	76.00	0.00	271.09	542.17	974.16	1,505.89	875.45	819.66
7/4/07 3:46	63.24	484,672.69	367.61	492,936.59	78.12	0.00	271.16	542.59	974.85	1,501.27	872.89	817.92
7/4/07 3:47	63.25	485,317.09	367.72	493,210.69	80.30	0.00	271.24	543.12	973.83	1,501.53	871.42	817.23
7/4/07 3:48	63.11	485,143.41	367.85	493,484.69	81.96	0.00	271.29	543.54	973.25	1,499.54	871.38	816.92
7/4/07 3:49	62.98	483,485.41	367.93	493,758.81	82.53	0.00	271.29	543.66	971.98	1,498.97	871.97	816.72
7/4/07 3:50	63.27	485,986.31	367.99	494,032.81	80.93	0.00	271.29	543.74	972.05	1,504.30	872.82	817.12
7/4/07 3:51	63.38	486,936.50	368.09	494,306.81	80.44	0.00	271.25	543.89	973.11	1,505.64	874.23	818.32
7/4/07 3:52	63.37	486,137.09	368.13	494,580.91	80.07	0.00	271.21	544.22	973.35	1,504.49	875.49	819.35
7/4/07 3:53	63.20	485,264.69	368.11	494,854.91	80.32	0.00	271.20	544.42	972.53	1,501.35	876.24	819.76
7/4/07 3:54	63.49	488,228.41	368.01	495,128.91	82.44	0.00	271.21	544.85	973.48	1,506.22	877.30	820.83
7/4/07 3:55	63.30	486,825.69	367.85	495,403.00	82.60	0.00	271.16	544.92	972.71	1,502.12	878.03	821.69
7/4/07 3:56	63.47	487,933.69	367.63	495,677.00	84.57	0.00	271.17	544.86	971.87	1,505.49	878.48	822.09
7/4/07 3:57	63.58	488,810.91	367.41	495,951.09	80.75	0.00	271.12	544.97	973.25	1,506.48	879.36	823.34

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEGF)	SH OUTLET FLUE GAS TEMP (DEGF)
7/4/07 3:58	63.26	486,096.91	367.12	496,225.09	82.72	0.00	271.13	544.87	971.97	1,500.89	879.74	823.13
7/4/07 3:59	63.38	488,428.91	366.77	496,499.19	81.58	0.00	271.09	544.81	970.13	1,503.25	879.50	822.73
7/4/07 4:00	63.70	490,975.81	366.40	496,773.19	79.16	0.00	271.06	545.11	970.70	1,508.78	879.94	823.40
7/4/07 4:01	63.44	488,163.09	365.98	497,047.31	80.44	0.00	271.05	545.30	970.14	1,503.10	880.35	823.54
7/4/07 4:02	63.60	490,080.41	365.61	497,321.31	77.00	0.00	271.08	545.18	968.85	1,507.45	880.20	823.24
7/4/07 4:03	63.48	489,939.50	365.29	497,595.31	78.56	0.00	271.09	544.94	968.20	1,503.99	880.26	823.14
7/4/07 4:04	63.48	489,915.69	365.06	497,869.41	78.51	0.00	271.12	544.78	967.74	1,503.97	880.17	823.13
7/4/07 4:05	63.49	489,937.50	364.81	498,143.41	76.35	0.00	271.14	544.60	968.01	1,503.26	880.25	823.87
7/4/07 4:06	63.51	489,982.50	364.67	498,417.41	75.53	0.00	271.14	544.48	967.67	1,503.86	880.18	824.06
7/4/07 4:07	63.75	492,051.31	364.58	497,869.19	75.04	0.00	271.18	544.57	968.05	1,509.07	880.51	824.41
7/4/07 4:08	63.66	490,951.41	364.59	497,317.50	75.82	0.00	271.18	544.88	969.46	1,505.58	881.41	825.10
7/4/07 4:09	63.61	490,595.69	364.69	496,765.81	77.03	0.00	271.27	545.08	969.66	1,505.32	882.06	826.10
7/4/07 4:10	64.00	492,875.50	364.79	496,214.09	80.25	0.00	271.27	545.38	970.97	1,512.06	882.78	826.92
7/4/07 4:11	63.79	490,175.09	364.90	495,662.41	81.75	0.00	271.37	545.53	971.45	1,505.83	883.37	826.92
7/4/07 4:12	63.59	489,239.41	365.02	495,110.81	79.32	0.00	271.41	545.57	970.53	1,501.22	883.53	826.91
7/4/07 4:13	63.30	487,658.31	365.11	494,559.09	76.24	0.00	271.49	545.69	970.06	1,495.49	883.69	827.07
7/4/07 4:14	63.65	490,667.41	365.18	494,007.41	76.44	0.00	271.47	545.67	968.57	1,502.76	883.45	826.62
7/4/07 4:15	63.35	488,690.81	365.30	493,455.69	78.36	0.00	271.46	545.87	968.41	1,497.11	883.41	826.35
7/4/07 4:16	63.13	485,973.31	365.44	492,904.00	83.41	0.00	271.47	546.12	968.21	1,492.58	883.51	826.53
7/4/07 4:17	63.20	486,151.69	365.53	492,352.31	83.43	0.00	271.42	546.18	968.09	1,496.13	883.38	826.23
7/4/07 4:18	63.49	488,187.91	365.64	491,800.59	81.17	0.00	271.41	546.53	970.05	1,501.97	883.63	826.35
7/4/07 4:19	63.24	486,566.81	365.80	491,248.91	80.71	0.00	271.40	546.81	970.69	1,495.65	883.88	826.42
7/4/07 4:20	63.35	486,908.00	365.96	490,697.19	83.45	0.00	271.37	546.94	970.81	1,498.00	883.88	826.20
7/4/07 4:21	63.26	486,131.50	366.05	490,145.50	86.47	0.00	271.35	547.18	971.86	1,496.04	883.98	826.07
7/4/07 4:22	63.52	487,979.31	366.18	489,593.81	88.09	0.00	271.38	547.25	971.20	1,502.48	883.87	825.75
7/4/07 4:23	63.65	488,683.91	366.35	489,042.19	85.79	0.00	271.42	547.54	972.34	1,504.94	884.21	826.03
7/4/07 4:24	63.39	487,494.31	366.51	488,490.50	84.69	0.00	271.46	547.63	970.66	1,499.37	883.99	825.39
7/4/07 4:25	63.48	489,072.41	366.61	487,938.81	87.31	0.00	271.53	547.51	969.03	1,501.19	883.54	824.72
7/4/07 4:26	63.74	490,587.81	366.77	487,387.09	90.81	0.00	271.55	547.84	969.73	1,506.43	883.96	825.72
7/4/07 4:27	63.39	486,899.31	366.99	486,835.41	88.93	0.00	271.56	548.00	968.21	1,498.94	884.09	826.01
7/4/07 4:28	63.39	487,678.81	367.20	486,283.69	88.72	0.00	271.64	548.15	968.17	1,499.03	884.29	826.38
7/4/07 4:29	63.34	487,750.50	367.43	485,732.00	83.93	0.00	271.63	548.40	969.37	1,498.16	884.77	826.94
7/4/07 4:30	63.09	485,287.31	367.57	485,180.31	82.90	0.00	271.59	548.37	968.28	1,493.82	884.68	826.92
7/4/07 4:31	63.14	486,143.19	367.71	484,628.59	79.53	0.00	271.55	548.40	968.67	1,496.19	884.36	826.68
7/4/07 4:32	62.74	483,839.81	367.82	484,076.91	77.67	0.00	271.53	548.41	967.39	1,489.79	883.80	826.20
7/4/07 4:33	62.28	480,455.19	367.89	483,525.31	78.61	0.00	271.45	548.43	966.73	1,486.45	883.26	825.69
7/4/07 4:34	62.59	482,615.41	368.01	482,973.50	78.11	0.00	271.39	548.61	967.32	1,494.39	883.14	826.10
7/4/07 4:35	62.36	480,095.00	368.20	482,421.81	78.26	0.00	271.18	549.01	969.15	1,493.32	883.66	826.86
7/4/07 4:36	62.14	479,926.69	368.45	481,870.19	81.83	0.00	271.09	549.28	970.05	1,495.44	884.21	827.23
7/4/07 4:37	60.95	468,890.69	368.64	481,229.09	81.29	0.00	270.98	549.31	969.63	1,489.27	884.35	827.84
7/4/07 4:38	60.85	468,489.81	368.84	480,527.31	82.43	0.00	270.85	549.54	969.60	1,490.58	884.14	827.96
7/4/07 4:39	60.88	469,639.91	368.99	479,825.59	82.07	0.00	270.57	549.95	969.60	1,494.96	883.91	827.54
7/4/07 4:40	60.41	465,994.59	369.11	479,123.91	80.88	0.00	270.31	550.21	969.53	1,492.89	883.70	827.31
7/4/07 4:41	60.91	468,514.91	369.22	478,422.09	82.80	0.00	270.11	550.26	969.81	1,500.12	883.24	827.12
7/4/07 4:42	61.65	474,504.09	369.26	477,720.41	79.65	0.00	269.93	550.30	971.45	1,505.85	882.80	826.52
7/4/07 4:43	61.59	473,618.31	369.31	478,174.91	82.95	0.00	269.81	550.30	972.44	1,501.93	882.41	825.83
7/4/07 4:44	61.41	472,310.81	369.34	478,896.19	83.04	0.00	269.86	550.11	972.22	1,501.15	881.69	825.50
7/4/07 4:45	61.60	472,282.50	369.36	479,617.59	80.91	0.00	269.98	550.01	971.70	1,500.55	881.09	824.76
7/4/07 4:46	61.19	470,538.50	369.39	480,338.91	79.13	0.00	270.06	549.91	970.16	1,497.94	880.42	824.09
7/4/07 4:47	61.05	469,911.91	369.43	481,060.31	80.06	0.00	270.06	549.94	968.91	1,497.23	879.95	823.28

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEGF)	SH OUTLET FLUE GAS TEMP (DEGF)
7/4/07 4:48	60.42	466,389.81	369.43	481,781.59	79.34	0.00	270.02	549.86	967.16	1,494.17	879.43	822.25
7/4/07 4:49	61.19	472,341.91	369.47	482,502.91	82.19	0.00	269.92	549.76	966.67	1,503.16	878.99	821.79
7/4/07 4:50	61.33	473,969.31	369.48	483,224.31	82.92	0.00	269.80	549.82	967.85	1,503.88	878.79	821.35
7/4/07 4:51	61.95	478,787.81	369.41	483,945.59	79.15	0.00	269.73	549.64	968.78	1,507.43	878.23	820.52
7/4/07 4:52	61.91	476,030.41	369.32	483,749.00	83.42	0.00	269.71	549.34	969.92	1,503.52	877.78	820.28
7/4/07 4:53	61.93	476,754.00	369.20	483,118.81	83.01	0.00	269.81	549.01	970.23	1,501.88	877.11	819.62
7/4/07 4:54	61.61	475,581.59	369.05	482,488.59	80.99	0.00	269.86	548.49	969.29	1,502.13	876.18	818.74
7/4/07 4:55	61.54	474,297.00	368.93	481,858.41	82.19	0.00	269.91	548.34	969.91	1,500.13	875.93	818.84
7/4/07 4:56	60.38	469,106.59	368.89	481,228.19	81.21	0.00	269.87	548.31	969.05	1,489.65	876.04	818.79
7/4/07 4:57	60.29	466,053.00	368.85	480,598.00	78.80	0.00	269.86	547.98	966.88	1,493.85	875.66	817.99
7/4/07 4:58	60.68	469,747.50	368.76	479,967.81	78.23	0.00	269.72	547.83	967.11	1,500.53	875.50	817.80
7/4/07 4:59	60.83	470,279.81	368.67	479,337.59	76.52	0.00	269.49	547.87	968.94	1,501.11	875.71	817.73
7/4/07 5:00	60.14	464,748.31	368.54	478,707.41	79.19	0.00	269.39	547.53	968.68	1,495.97	875.29	817.03
7/4/07 5:01	60.89	470,398.09	368.32	478,077.31	82.53	0.00	269.31	547.22	970.11	1,502.96	874.83	816.81
7/4/07 5:02	60.78	468,159.31	368.14	477,901.81	83.83	0.00	269.17	547.07	971.72	1,500.83	874.73	816.61
7/4/07 5:03	60.51	466,250.31	367.96	478,374.00	86.71	0.00	269.12	546.66	971.41	1,498.76	874.11	815.84
7/4/07 5:04	61.15	471,115.19	367.74	478,846.31	86.34	0.00	269.12	546.20	971.31	1,502.13	873.58	815.65
7/4/07 5:05	61.06	469,501.59	367.59	479,318.50	85.76	0.00	269.10	546.01	972.92	1,501.39	873.76	815.84
7/4/07 5:06	61.02	471,201.69	367.51	479,790.69	84.97	0.00	269.11	545.73	972.62	1,499.73	873.93	815.84
7/4/07 5:07	61.30	471,667.50	367.45	480,262.91	89.11	0.00	269.15	545.35	972.05	1,504.42	873.85	815.58
7/4/07 5:08	61.30	472,005.69	367.36	480,735.19	89.29	0.00	269.26	545.11	972.08	1,503.26	873.99	815.61
7/4/07 5:09	61.69	473,950.69	367.32	481,207.41	88.35	0.00	269.33	544.91	972.04	1,503.80	874.14	815.69
7/4/07 5:10	61.29	470,647.81	367.26	481,679.59	83.70	0.00	269.37	544.72	971.65	1,501.09	874.26	815.63
7/4/07 5:11	61.56	474,586.81	367.11	482,151.81	81.97	0.00	269.44	544.45	970.82	1,504.37	873.77	814.83
7/4/07 5:12	61.54	474,267.09	367.02	482,624.09	84.38	0.00	269.50	544.21	970.92	1,501.72	873.34	814.48
7/4/07 5:13	61.27	472,792.09	366.84	483,096.31	87.86	0.00	269.53	543.82	970.32	1,499.11	872.86	814.15
7/4/07 5:14	61.24	472,081.19	366.66	483,568.50	86.17	0.00	269.60	543.36	969.41	1,500.91	871.92	813.32
7/4/07 5:15	62.18	477,676.69	366.51	484,040.81	83.75	0.00	269.63	543.20	970.86	1,505.96	871.45	813.30
7/4/07 5:16	61.48	474,659.91	366.29	483,495.59	81.44	0.00	269.60	542.67	970.48	1,498.66	870.84	812.90
7/4/07 5:17	60.58	466,165.00	366.05	481,501.50	80.04	0.00	269.69	541.89	968.52	1,494.02	869.69	811.84
7/4/07 5:18	60.68	468,332.19	365.81	479,507.50	80.05	0.00	269.78	541.49	968.25	1,496.70	868.70	811.23
7/4/07 5:19	61.26	471,266.09	365.66	477,513.41	76.31	0.00	269.66	541.65	969.52	1,502.60	868.67	811.56
7/4/07 5:20	59.85	460,403.81	365.59	475,519.31	77.03	0.00	269.58	541.62	969.44	1,490.59	868.92	811.34
7/4/07 5:21	59.90	462,262.41	365.53	473,525.19	78.69	0.00	269.54	541.53	968.46	1,495.73	868.63	809.57
7/4/07 5:22	61.10	471,213.19	365.65	473,031.81	77.66	0.00	269.33	541.84	972.17	1,506.59	867.75	810.36
7/4/07 5:23	60.98	468,579.09	365.86	476,413.19	74.59	0.00	269.14	542.30	976.12	1,501.47	866.05	811.94
7/4/07 5:24	61.36	472,059.31	365.98	479,794.59	73.74	0.00	269.16	542.05	975.12	1,505.63	865.12	810.90
7/4/07 5:25	62.70	482,381.31	366.16	483,176.00	68.96	0.00	269.19	542.03	976.00	1,513.61	865.84	812.38
7/4/07 5:26	62.42	478,705.09	366.30	486,557.41	69.64	0.00	269.28	542.09	976.09	1,503.57	868.21	815.21
7/4/07 5:27	62.34	479,847.59	366.46	488,943.59	71.52	0.00	269.50	541.99	974.23	1,505.33	869.12	817.69
7/4/07 5:28	61.90	476,130.09	366.72	489,447.19	76.80	0.00	269.71	542.28	975.20	1,498.91	869.24	821.96
7/4/07 5:29	61.95	475,528.81	366.94	489,950.91	78.49	0.00	269.91	542.32	971.52	1,502.10	870.45	824.47
7/4/07 5:30	62.15	478,218.09	367.10	490,454.50	78.62	0.00	270.03	542.27	968.56	1,502.67	871.80	825.10
7/4/07 5:31	62.32	480,864.81	367.22	490,958.19	78.91	0.00	270.04	542.59	969.17	1,504.25	872.96	824.46
7/4/07 5:32	62.36	480,373.50	367.40	491,461.81	80.36	0.00	270.03	542.75	970.93	1,504.01	872.38	824.97
7/4/07 5:33	62.64	481,356.19	367.63	491,965.50	79.28	0.00	270.05	543.10	974.48	1,503.42	871.62	825.37
7/4/07 5:34	62.59	482,679.59	367.84	492,469.09	80.43	0.00	270.03	543.25	973.93	1,503.98	871.25	823.48
7/4/07 5:35	63.03	486,471.81	367.98	492,972.81	83.00	0.00	270.05	543.23	972.61	1,507.45	872.05	823.63
7/4/07 5:36	62.90	484,981.59	368.06	493,476.41	81.88	0.00	270.09	543.16	972.36	1,503.36	873.44	824.67
7/4/07 5:37	62.85	485,096.41	368.14	493,980.00	81.87	0.00	270.14	543.00	972.43	1,502.59	873.25	825.98

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEGF)	SH OUTLET FLUE GAS TEMP (DEGF)
7/4/07 5:38	63.05	485,930.00	368.31	494,483.69	80.45	0.00	270.24	543.35	973.09	1,504.82	873.79	827.77
7/4/07 5:39	63.24	488,166.59	368.47	494,987.31	82.44	0.00	270.29	543.66	971.68	1,506.97	875.61	829.10
7/4/07 5:40	62.90	484,862.19	368.66	495,491.00	82.76	0.00	270.37	543.74	969.37	1,502.16	876.87	828.58
7/4/07 5:41	62.81	483,758.09	368.84	495,994.59	83.63	0.00	270.44	543.84	968.85	1,499.72	877.29	828.17
7/4/07 5:42	62.65	483,051.69	368.97	496,707.50	88.04	0.00	270.44	543.91	968.08	1,500.30	876.51	827.93
7/4/07 5:43	62.64	483,370.91	369.18	497,788.41	88.26	0.00	270.44	544.37	969.82	1,498.20	875.84	827.03
7/4/07 5:44	61.93	474,953.09	369.31	498,869.31	89.31	0.00	270.49	544.42	969.36	1,493.17	875.23	825.01
7/4/07 5:45	62.01	479,622.50	369.32	499,950.31	84.89	0.00	270.46	544.27	968.31	1,500.15	875.18	824.46
7/4/07 5:46	62.89	485,604.09	369.35	501,031.19	83.55	0.00	270.39	544.19	968.18	1,505.55	875.08	824.35
7/4/07 5:47	63.13	487,894.81	369.35	502,112.09	82.61	0.00	270.29	544.19	969.21	1,508.41	874.56	824.37
7/4/07 5:48	63.47	488,295.41	369.44	501,699.81	78.40	0.00	270.30	544.20	971.36	1,510.98	875.09	825.22
7/4/07 5:49	63.14	486,369.31	369.51	501,229.41	77.80	0.00	270.47	544.07	971.88	1,504.57	876.05	825.48
7/4/07 5:50	63.43	488,950.50	369.58	500,759.00	79.09	0.00	270.64	543.85	972.18	1,508.95	875.81	824.92
7/4/07 5:51	63.57	489,791.91	369.66	500,288.69	79.63	0.00	270.74	543.91	972.97	1,507.78	875.70	826.12
7/4/07 5:52	63.51	490,348.50	369.85	499,818.31	80.83	0.00	270.91	544.15	970.67	1,507.35	875.04	826.74
7/4/07 5:53	63.52	490,646.91	370.03	499,347.81	87.24	0.00	271.03	544.17	968.54	1,508.31	874.66	827.10
7/4/07 5:54	63.47	490,768.31	370.26	498,877.50	86.64	0.00	271.09	544.30	968.51	1,508.15	875.35	828.40
7/4/07 5:55	63.22	488,441.91	370.41	498,407.09	88.18	0.00	271.14	544.31	967.30	1,504.94	876.06	828.59
7/4/07 5:56	63.14	490,227.69	370.57	497,936.69	83.95	0.00	271.15	544.21	964.27	1,503.06	876.03	828.33
7/4/07 5:57	63.30	491,605.09	370.64	497,466.31	86.06	0.00	271.15	544.15	964.29	1,506.15	875.62	828.36
7/4/07 5:58	63.21	489,929.81	370.71	496,995.91	83.96	0.00	271.12	543.98	964.85	1,503.35	875.37	828.02
7/4/07 5:59	63.05	487,164.31	370.69	496,525.50	82.03	0.00	271.11	543.85	966.31	1,498.61	875.52	826.91
7/4/07 6:00	62.99	487,626.31	370.66	496,055.09	81.74	0.00	271.14	543.71	968.85	1,496.74	875.38	822.81
7/4/07 6:01	62.64	482,738.31	370.71	495,584.69	80.27	0.00	271.15	543.53	971.27	1,490.64	873.30	819.91
7/4/07 6:02	62.36	480,963.31	370.74	495,114.31	80.24	0.00	271.11	543.42	972.27	1,488.85	870.02	818.09
7/4/07 6:03	62.55	481,781.81	370.77	494,643.91	82.86	0.00	270.95	543.59	974.11	1,492.68	869.37	815.76
7/4/07 6:04	62.31	480,354.81	370.84	494,173.50	80.91	0.00	270.76	543.68	974.12	1,492.93	870.44	815.58
7/4/07 6:05	62.15	478,138.41	370.89	493,688.00	77.70	0.00	270.61	543.66	973.94	1,495.42	871.96	816.71
7/4/07 6:06	62.19	478,360.31	370.97	492,976.09	79.39	0.00	270.51	543.87	976.49	1,496.10	872.27	818.58
7/4/07 6:07	62.09	477,825.31	370.99	492,264.19	81.75	0.00	270.40	543.97	977.90	1,497.80	871.92	820.32
7/4/07 6:08	62.47	477,560.81	371.04	491,552.19	82.33	0.00	270.28	544.06	976.67	1,502.88	872.96	821.67
7/4/07 6:09	61.55	474,139.91	371.05	490,840.31	78.59	0.00	270.18	544.04	973.85	1,496.09	874.38	821.28
7/4/07 6:10	61.89	476,341.09	371.00	490,070.69	76.82	0.00	270.12	543.98	971.98	1,501.07	874.43	818.89
7/4/07 6:11	62.21	479,939.19	371.01	489,287.69	77.42	0.00	270.01	544.23	972.63	1,502.51	872.67	817.82
7/4/07 6:12	61.27	472,078.81	371.06	488,504.69	80.98	0.00	269.93	544.21	970.56	1,494.14	870.01	816.17
7/4/07 6:13	62.36	481,424.91	371.07	489,937.19	82.14	0.00	269.90	544.26	969.12	1,507.22	869.11	813.88
7/4/07 6:14	62.33	480,657.41	371.10	491,674.19	82.80	0.00	269.86	544.68	971.44	1,502.89	870.90	815.11
7/4/07 6:15	62.59	481,620.09	371.18	493,411.19	82.71	0.00	269.86	544.84	970.98	1,503.37	872.10	815.70
7/4/07 6:16	62.88	484,331.00	371.21	495,148.19	80.84	0.00	269.95	544.82	972.27	1,506.81	871.86	817.34
7/4/07 6:17	63.57	489,378.41	371.32	496,885.19	75.81	0.00	270.07	545.24	975.74	1,513.29	872.57	820.61
7/4/07 6:18	63.54	488,294.41	371.40	498,622.19	74.97	0.00	270.20	545.28	974.63	1,511.27	874.14	822.20
7/4/07 6:19	63.44	487,919.59	371.50	500,359.19	77.31	0.00	270.37	545.42	974.94	1,507.06	875.81	822.20
7/4/07 6:20	63.85	492,362.19	371.56	501,415.81	82.01	0.00	270.50	545.19	973.79	1,513.78	876.19	821.12
7/4/07 6:21	63.34	487,273.19	371.60	499,951.00	79.49	0.00	270.65	545.24	973.66	1,503.54	874.76	821.50
7/4/07 6:22	63.30	488,296.31	371.67	498,486.31	76.08	0.00	270.75	545.10	971.45	1,503.94	872.85	820.04
7/4/07 6:23	63.44	489,117.09	371.72	497,021.50	76.36	0.00	270.84	545.12	969.76	1,506.73	872.83	818.05
7/4/07 6:24	63.08	486,760.09	371.78	495,556.69	78.14	0.00	270.88	545.33	969.23	1,499.06	874.16	818.76
7/4/07 6:25	62.74	485,540.91	371.82	494,091.91	80.17	0.00	270.89	545.01	965.58	1,494.85	874.22	818.68
7/4/07 6:26	62.72	485,017.59	371.87	492,627.09	81.97	0.00	270.88	545.00	965.72	1,495.41	873.44	820.70
7/4/07 6:27	62.39	483,321.50	371.98	491,162.31	82.81	0.00	270.80	545.20	965.79	1,492.72	873.81	822.87

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEGF)	SH OUTLET FLUE GAS TEMP (DEGF)
7/4/07 6:28	61.35	475,055.09	372.15	489,697.59	80.31	0.00	270.71	545.44	964.65	1,488.07	875.38	824.10
7/4/07 6:29	61.56	477,086.00	372.32	489,194.91	77.74	0.00	270.61	545.72	964.99	1,494.23	876.91	822.04
7/4/07 6:30	62.15	481,706.81	372.53	488,890.41	83.14	0.00	270.40	546.04	967.21	1,501.19	876.51	819.65
7/4/07 6:31	62.35	480,778.50	372.74	488,585.91	83.04	0.00	270.14	546.48	970.09	1,499.80	873.80	818.71
7/4/07 6:32	60.87	469,031.00	372.95	488,577.19	82.94	0.00	270.08	546.47	968.67	1,490.72	872.08	816.58
7/4/07 6:33	60.86	469,528.59	373.03	489,052.59	82.23	0.00	270.07	546.67	968.67	1,493.02	872.09	814.75
7/4/07 6:34	61.19	471,632.59	373.14	489,528.00	82.47	0.00	269.94	547.15	969.04	1,499.19	873.27	815.89
7/4/07 6:35	60.71	468,511.81	373.32	490,003.50	79.10	0.00	269.80	547.55	970.47	1,493.22	873.95	817.51
7/4/07 6:36	61.20	472,761.81	373.37	490,478.91	81.36	0.00	269.75	547.62	970.08	1,501.30	872.60	818.75
7/4/07 6:37	61.27	470,608.81	373.47	490,954.31	80.83	0.00	269.68	547.93	970.02	1,499.43	872.91	820.55
7/4/07 6:38	61.53	474,149.50	373.59	491,429.81	81.04	0.00	269.60	548.38	970.74	1,501.60	874.62	821.72
7/4/07 6:39	61.09	471,344.09	373.64	491,905.19	80.90	0.00	269.61	548.46	969.02	1,499.92	875.35	818.86
7/4/07 6:40	61.91	477,215.91	373.69	492,380.59	77.79	0.00	269.65	548.73	971.20	1,505.31	874.23	818.72
7/4/07 6:41	62.11	477,137.19	373.78	493,423.09	74.90	0.00	269.68	548.93	972.01	1,503.71	872.06	818.62
7/4/07 6:42	61.50	474,254.69	373.80	495,051.69	77.05	0.00	269.75	548.95	970.18	1,498.93	871.10	816.02
7/4/07 6:43	63.22	486,917.81	373.84	496,680.31	75.80	0.00	269.82	549.28	970.15	1,512.92	871.78	814.80
7/4/07 6:44	62.56	481,636.69	373.91	496,709.41	78.50	0.00	269.84	549.67	971.00	1,500.83	873.80	816.96
7/4/07 6:45	62.80	483,226.09	374.01	496,447.00	80.88	0.00	269.99	549.54	969.95	1,502.45	873.66	818.30
7/4/07 6:46	63.49	490,255.81	374.07	496,184.59	81.17	0.00	270.14	549.56	970.48	1,513.82	872.91	820.02
7/4/07 6:47	62.99	485,577.00	374.13	495,922.19	82.30	0.00	270.31	549.83	970.74	1,502.30	874.06	821.73
7/4/07 6:48	62.69	484,426.50	374.16	495,659.81	84.39	0.00	270.45	549.69	968.11	1,499.92	874.89	820.37
7/4/07 6:49	63.05	487,911.41	374.12	495,397.31	82.27	0.00	270.55	549.49	968.03	1,505.56	875.01	816.54
7/4/07 6:50	63.19	487,130.31	374.08	495,134.91	82.08	0.00	270.51	549.23	968.76	1,506.57	872.42	814.66
7/4/07 6:51	62.93	485,602.09	374.02	494,872.50	79.22	0.00	270.52	549.06	969.57	1,499.90	869.43	813.59
7/4/07 6:52	62.64	483,951.81	374.01	494,610.09	77.30	0.00	270.56	548.85	967.90	1,496.20	869.11	810.33
7/4/07 6:53	62.43	482,932.81	374.05	494,347.69	80.20	0.00	270.59	548.57	966.30	1,495.32	869.61	809.62
7/4/07 6:54	62.74	486,203.31	374.10	494,085.31	82.10	0.00	270.56	548.51	966.55	1,501.61	870.86	811.66
7/4/07 6:55	62.11	479,098.91	374.12	493,822.81	85.89	0.00	270.49	548.21	966.38	1,492.75	870.56	813.12
7/4/07 6:56	62.34	482,260.31	374.18	493,560.41	87.78	0.00	270.43	547.88	966.84	1,499.05	870.23	815.09
7/4/07 6:57	61.67	477,533.00	374.17	493,216.81	85.11	0.00	270.30	547.76	967.08	1,496.92	871.63	817.23
7/4/07 6:58	60.83	470,094.81	374.18	491,656.09	85.14	0.00	270.27	547.57	967.26	1,489.31	872.78	814.81
7/4/07 6:59	60.75	469,203.69	374.15	490,095.31	79.11	0.00	270.20	547.24	968.13	1,493.59	871.67	809.11
7/4/07 7:00	59.82	461,696.81	374.09	488,534.50	78.42	0.00	270.04	546.90	969.13	1,488.16	867.17	806.76
7/4/07 7:01	59.81	462,350.81	374.02	486,973.69	80.15	0.00	269.89	546.61	968.71	1,492.24	862.89	803.78
7/4/07 7:02	60.27	465,186.69	373.88	485,412.91	82.38	0.00	269.53	546.46	969.57	1,500.57	861.82	800.22
7/4/07 7:03	60.54	466,175.81	373.70	484,851.91	83.83	0.00	269.17	546.51	971.65	1,499.58	862.28	797.87
7/4/07 7:04	60.87	468,522.81	373.54	486,328.50	83.49	0.00	269.02	546.23	972.65	1,501.15	861.66	795.87
7/4/07 7:05	61.61	474,221.91	373.41	487,805.09	84.17	0.00	268.98	545.90	973.54	1,507.17	858.36	796.00
7/4/07 7:06	62.32	478,923.31	373.27	489,281.69	82.54	0.00	269.03	545.67	974.24	1,511.03	856.43	795.04
7/4/07 7:07	61.66	477,148.59	373.19	490,758.31	81.22	0.00	269.15	545.49	973.73	1,501.26	857.35	793.63
7/4/07 7:08	61.42	472,473.81	373.12	491,820.59	81.24	0.00	269.38	545.27	971.51	1,498.45	858.68	795.74
7/4/07 7:09	61.47	475,415.50	373.14	491,813.00	86.04	0.00	269.54	545.21	970.23	1,500.63	859.70	798.85
7/4/07 7:10	61.24	472,965.41	373.26	491,805.41	89.48	0.00	269.60	545.12	968.77	1,497.27	859.01	801.23
7/4/07 7:11	60.62	468,970.91	373.24	491,797.81	85.11	0.00	269.60	545.03	966.76	1,493.72	859.06	803.10
7/4/07 7:12	61.03	471,126.31	373.19	491,790.19	80.86	0.00	269.53	545.24	967.41	1,499.13	860.70	805.54
7/4/07 7:13	60.57	468,925.50	373.21	491,782.59	79.73	0.00	269.42	545.24	968.23	1,497.16	862.41	801.21
7/4/07 7:14	61.16	473,224.81	373.21	491,775.00	77.93	0.00	269.33	545.21	970.82	1,503.12	860.71	797.94
7/4/07 7:15	61.33	474,742.81	373.27	491,767.50	76.62	0.00	269.18	545.19	973.99	1,503.97	856.95	797.46
7/4/07 7:16	61.03	471,250.69	373.31	491,708.09	76.08	0.00	269.10	545.12	975.42	1,498.90	855.39	794.69
7/4/07 7:17	61.24	471,454.91	373.30	491,635.50	77.64	0.00	269.05	545.02	974.83	1,501.41	856.11	792.66

	5250-JI-013	3311-FI-015	3223-TIC-036	4331-FIC-078	8243-SCI-211	3233-FI-510	4331-TI-071	4331-TI-100	3311-TIC-010	3311-PI-012	3223-TI-015A	3223-TI-015B
	TURBINE OUTPUT (gross MW)	STEAM FLOW (LB/HR)	SDA INLET TEMP (DEGF)	TOAL FEEDWATER FLOW (LB/HR)	BIOMASS FUEL FLOW (TPH)	PROPANE FLOW (SCFH)	FWP DISCH TEMP (DEGF)	ECONOMIZER OUT FW TEMP (DEGF)	SH OUT STEAM TEMP	SH OUTLET STEAM PRESS (PSI)	SH OUTLET FLUE GAS TEMP (DEGF)	SH OUTLET FLUE GAS TEMP (DEGF)
7/4/07 7:18	62.26	478,826.19	373.24	491,562.91	78.30	0.00	268.99	545.12	975.72	1,507.62	857.94	795.56
7/4/07 7:19	61.79	476,361.09	373.28	491,490.31	75.93	0.00	268.96	545.03	976.42	1,498.30	858.52	798.61
7/4/07 7:20	62.00	475,780.59	373.24	491,803.31	81.03	0.00	269.13	544.42	973.69	1,503.56	857.03	799.97
7/4/07 7:21	63.01	485,202.91	373.21	493,199.81	81.54	0.00	269.32	544.30	974.22	1,509.32	857.72	802.23
7/4/07 7:22	63.01	484,887.00	373.19	494,596.31	78.76	0.00	269.41	544.38	974.54	1,506.76	859.57	803.09
7/4/07 7:23	62.09	479,001.81	373.17	495,992.81	76.58	0.00	269.61	543.79	972.26	1,498.93	860.20	798.41
7/4/07 7:24	62.69	482,983.59	373.06	495,818.91	75.30	0.00	269.84	543.32	972.28	1,502.89	858.62	797.50
7/4/07 7:25	62.69	483,736.31	373.02	495,462.31	78.55	0.00	269.97	542.94	971.37	1,503.94	856.15	796.64
7/4/07 7:26	62.83	485,130.41	372.99	495,105.81	80.65	0.00	270.11	542.61	970.63	1,504.72	856.14	793.16
7/4/07 7:27	62.17	480,269.41	372.99	494,749.19	79.02	0.00	270.17	542.30	969.88	1,495.85	857.20	794.07
7/4/07 7:28	62.47	481,795.41	372.88	494,392.59	82.01	0.00	270.29	541.68	968.45	1,501.30	857.43	795.88
7/4/07 7:29	62.98	487,350.50	372.77	494,036.00	85.04	0.00	270.32	541.39	970.50	1,507.72	856.53	797.54
7/4/07 7:30	62.49	483,117.09	372.58	493,679.50	85.37	0.00	270.35	540.89	970.93	1,500.22	855.45	798.46
7/4/07 7:31	62.73	484,895.19	372.36	495,759.81	87.22	0.00	270.38	540.45	970.89	1,504.50	855.22	799.18
7/4/07 7:32	63.56	489,632.91	372.19	498,905.50	83.31	0.00	270.39	540.64	974.70	1,513.27	855.90	798.60
7/4/07 7:33	63.14	486,316.19	372.08	502,051.19	85.48	0.00	270.44	540.41	974.95	1,504.03	855.04	794.94
7/4/07 7:34	63.71	490,735.81	371.95	503,016.31	83.48	0.00	270.59	540.08	974.83	1,514.41	853.87	793.03
7/4/07 7:35	63.89	490,766.81	371.92	502,696.31	82.24	0.00	270.67	539.91	976.32	1,515.61	853.39	792.03
7/4/07 7:36	63.74	490,221.91	371.88	502,376.31	82.88	0.00	270.76	539.62	975.62	1,511.43	853.06	790.80
7/4/07 7:37	63.60	490,632.31	371.80	502,056.31	86.30	0.00	270.94	539.05	972.35	1,508.74	853.14	792.03
7/4/07 7:38	63.58	490,506.41	371.74	501,736.31	85.14	0.00	271.02	538.72	971.82	1,509.37	853.00	793.35
7/4/07 7:39	63.97	494,105.69	371.65	501,416.31	88.72	0.00	271.10	538.40	970.77	1,515.68	852.65	793.78
7/4/07 7:40	63.36	489,948.31	371.70	501,096.31	90.38	0.00	271.18	538.07	969.69	1,503.13	852.22	794.71
7/4/07 7:41	63.33	491,323.81	371.60	500,776.31	88.24	0.00	271.26	537.55	967.48	1,503.98	852.36	795.38
7/4/07 7:42	63.42	490,760.59	371.57	500,456.31	87.27	0.00	271.30	537.29	967.53	1,506.19	853.03	794.02
7/4/07 7:43	63.39	490,469.31	371.50	500,136.31	86.08	0.00	271.30	537.27	969.22	1,503.91	853.86	794.67
7/4/07 7:44	63.22	489,372.09	371.56	499,816.31	82.98	0.00	271.32	537.00	967.99	1,501.00	854.44	794.34
7/4/07 7:45	63.00	487,321.00	371.58	499,496.31	82.94	0.00	271.37	536.88	967.97	1,496.48	854.66	793.20
7/4/07 7:46	63.32	490,014.00	371.61	499,176.31	85.04	0.00	271.32	536.90	969.92	1,503.23	855.72	793.71
7/4/07 7:47	62.54	483,339.81	371.59	498,856.31	85.44	0.00	271.31	536.86	969.34	1,486.70	856.52	795.40
7/4/07 7:48	62.41	483,678.69	371.63	497,022.31	85.94	0.00	271.32	536.71	967.50	1,487.49	856.30	795.87
7/4/07 7:49	62.39	484,129.00	371.70	493,306.41	84.56	0.00	271.25	536.94	966.71	1,490.41	856.44	796.76
7/4/07 7:50	61.68	477,066.91	371.75	489,590.59	86.70	0.00	271.14	537.42	967.92	1,480.67	857.14	798.97
7/4/07 7:51	60.83	471,067.31	371.74	485,874.69	87.28	0.00	271.00	537.45	965.46	1,482.80	857.44	799.54
7/4/07 7:52	60.32	469,261.31	371.88	483,444.59	88.58	0.00	270.84	537.73	964.20	1,486.02	857.28	799.46
7/4/07 7:53	60.69	473,625.00	371.81	483,634.81	89.26	0.00	270.58	538.14	962.51	1,495.65	856.86	800.07
7/4/07 7:54	60.59	471,138.69	371.92	483,825.00	87.14	0.00	270.26	538.80	962.68	1,494.84	856.51	801.22
7/4/07 7:55	60.56	472,026.19	372.05	484,015.19	85.88	0.00	270.02	539.08	963.11	1,497.26	856.15	801.53
7/4/07 7:56	60.93	473,436.69	372.06	484,205.41	83.91	0.00	269.88	539.51	965.51	1,501.59	856.40	802.63
7/4/07 7:57	61.41	475,712.69	372.12	484,395.59	83.75	0.00	269.81	540.07	969.73	1,502.95	857.23	806.43
7/4/07 7:58	61.31	475,155.50	372.22	484,585.81	82.21	0.00	269.74	540.37	970.38	1,502.40	857.56	809.63

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/3/07 17:58	838.81	357,984.91	253,824.41	70,636.34	4.29	27.88	14.45	279.68	31.40	54.55	0.00	9,451.33
7/3/07 17:59	837.81	366,817.41	255,239.09	70,716.20	3.11	27.75	14.43	280.37	31.95	54.25	0.00	8,964.34
7/3/07 18:00	836.97	332,846.91	252,867.09	69,765.38	5.10	27.50	14.42	279.68	31.15	54.15	0.00	8,964.68
7/3/07 18:01	836.97	354,401.81	252,233.70	70,157.15	3.04	27.59	14.40	279.57	31.55	53.70	0.00	10,916.42
7/3/07 18:02	839.17	367,838.81	253,064.09	70,553.02	3.70	27.50	14.38	279.01	31.80	53.80	0.00	10,477.17
7/3/07 18:03	841.10	364,736.59	255,877.80	70,502.44	4.65	27.63	14.37	279.33	30.95	53.95	0.00	10,395.19
7/3/07 18:04	842.69	368,985.59	256,492.91	71,091.09	5.14	27.72	14.35	279.36	35.30	59.95	0.00	10,416.11
7/3/07 18:05	844.44	353,924.09	253,599.20	71,190.32	5.14	27.59	14.34	279.37	35.10	60.10	0.00	10,265.00
7/3/07 18:06	845.34	359,792.91	253,453.41	70,812.86	5.14	27.50	14.46	279.35	35.10	60.00	0.00	9,746.15
7/3/07 18:07	842.98	361,886.19	254,262.30	70,095.70	5.14	26.69	14.48	279.01	35.05	60.05	0.00	9,674.07
7/3/07 18:08	840.10	358,251.69	254,462.20	70,812.19	4.88	26.54	14.57	279.35	34.45	58.30	0.00	9,555.29
7/3/07 18:09	837.72	362,253.81	253,223.00	70,545.20	4.64	26.50	14.66	280.02	33.25	57.25	0.00	9,816.95
7/3/07 18:10	835.25	358,501.09	253,514.20	70,875.93	4.21	26.52	14.77	280.35	33.00	56.10	0.00	7,584.30
7/3/07 18:11	833.98	365,329.09	251,438.91	70,288.87	4.17	26.75	14.75	280.72	31.65	54.60	0.00	0.00
7/3/07 18:12	834.43	354,931.91	249,897.80	70,490.19	3.43	26.67	14.73	280.70	31.25	54.50	0.00	0.00
7/3/07 18:13	835.93	368,209.50	253,064.59	70,636.17	3.25	26.91	14.71	280.70	31.10	53.95	0.00	0.00
7/3/07 18:14	838.05	361,923.19	251,517.80	70,073.53	4.23	27.00	14.69	280.70	31.45	54.35	0.00	0.00
7/3/07 18:15	839.06	348,112.00	249,380.09	69,927.13	5.97	27.00	14.67	279.65	31.40	53.85	0.00	0.00
7/3/07 18:16	839.53	353,198.69	250,019.41	69,853.72	3.34	27.38	14.65	279.36	31.85	53.75	0.00	0.00
7/3/07 18:17	840.15	364,267.81	253,072.50	70,749.84	1.95	26.77	14.63	279.01	31.50	54.25	0.00	0.00
7/3/07 18:18	840.88	348,526.91	251,065.59	70,184.72	4.37	26.70	14.61	279.35	31.80	54.20	0.00	0.00
7/3/07 18:19	841.15	347,270.81	249,923.09	70,314.23	4.10	26.97	14.59	279.36	31.80	53.80	0.00	0.00
7/3/07 18:20	842.01	377,579.91	252,039.59	70,411.80	3.74	26.88	14.57	279.36	31.85	54.10	0.00	0.00
7/3/07 18:21	842.33	355,848.81	251,389.50	70,779.19	4.04	27.19	14.55	279.65	32.00	54.05	0.00	8,984.01
7/3/07 18:22	842.17	360,474.41	251,696.00	70,757.98	4.61	27.00	14.45	280.36	31.40	54.00	0.00	7,731.49
7/3/07 18:23	842.66	353,353.69	251,610.50	70,782.98	6.14	26.75	14.45	280.35	31.05	53.95	0.00	5,646.17
7/3/07 18:24	843.64	358,298.59	253,515.00	71,113.44	6.04	27.13	14.45	280.35	34.15	60.00	0.00	6,052.77
7/3/07 18:25	844.31	354,345.50	253,593.00	71,284.66	6.04	25.88	14.45	280.04	34.85	60.20	0.00	6,454.37
7/3/07 18:26	844.52	356,739.50	248,624.41	70,242.13	6.04	26.88	14.46	279.67	35.00	59.90	0.00	7,981.46
7/3/07 18:27	844.51	363,938.81	250,489.80	70,821.77	6.04	26.79	14.46	279.67	35.05	59.95	0.00	8,327.63
7/3/07 18:28	844.93	358,595.59	251,387.30	71,225.91	4.26	26.91	14.46	280.01	35.25	59.65	0.00	8,307.46
7/3/07 18:29	845.63	364,923.00	251,668.70	72,119.02	4.32	26.25	14.55	280.02	35.45	59.25	0.00	8,418.50
7/3/07 18:30	845.85	347,456.50	248,083.80	71,184.00	5.15	25.97	14.71	279.67	34.70	58.70	0.00	6,600.71
7/3/07 18:31	845.34	326,522.91	246,692.80	70,986.62	3.35	26.79	14.76	279.01	34.00	58.85	0.00	6,374.60
7/3/07 18:32	844.79	356,891.19	252,061.41	70,841.57	4.82	27.00	14.71	279.01	33.55	57.80	0.00	5,609.78
7/3/07 18:33	844.77	354,230.41	247,632.20	70,854.55	5.51	27.72	14.65	278.01	33.65	56.30	0.00	6,191.95
7/3/07 18:34	846.10	361,836.59	253,310.00	71,415.81	3.08	27.88	14.60	278.02	32.70	56.70	0.00	5,779.01
7/3/07 18:35	847.10	350,444.00	249,059.91	71,794.34	6.37	27.91	14.54	277.35	33.05	55.60	0.00	7,946.97
7/3/07 18:36	847.21	349,433.00	246,075.50	70,750.15	3.62	27.84	14.49	276.65	32.05	55.45	0.00	7,834.11
7/3/07 18:37	847.26	362,274.09	246,352.80	71,710.91	3.88	27.88	14.43	275.70	32.10	55.15	0.00	0.00
7/3/07 18:38	847.36	356,710.09	250,640.80	72,335.77	4.58	27.72	14.38	274.65	31.55	55.40	0.00	0.00
7/3/07 18:39	847.27	342,181.81	246,715.59	71,312.47	7.38	27.75	14.32	273.98	31.85	55.20	0.00	0.00
7/3/07 18:40	847.24	354,855.00	246,786.91	70,788.91	4.39	28.05	14.31	273.53	31.20	54.70	0.00	0.00
7/3/07 18:41	846.91	353,999.59	250,451.00	73,408.38	3.75	27.05	14.31	273.00	31.65	54.70	0.00	0.00
7/3/07 18:42	846.81	355,930.81	247,020.41	71,489.59	6.17	26.91	14.31	273.00	32.10	54.65	0.00	0.00
7/3/07 18:43	846.93	342,670.31	241,662.59	72,129.74	4.70	26.75	14.27	273.00	31.20	54.35	0.00	0.00
7/3/07 18:44	846.13	354,175.09	247,192.09	71,839.20	8.65	27.84	14.19	272.69	35.00	60.20	0.00	0.00
7/3/07 18:45	846.42	354,134.41	245,465.91	71,856.06	8.65	27.81	14.11	272.70	35.15	59.75	0.00	0.00
7/3/07 18:46	846.65	352,993.41	244,883.00	71,965.21	8.65	27.73	14.01	272.32	35.25	60.10	0.00	0.00
7/3/07 18:47	847.04	357,133.41	248,615.80	71,944.02	8.65	27.78	14.10	272.32	34.90	59.90	0.00	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/3/07 18:48	846.03	344,713.19	243,462.00	71,038.12	6.71	27.41	13.94	272.03	35.10	60.10	0.00	5,510.92
7/3/07 18:49	843.85	348,769.31	243,344.91	71,808.52	6.77	27.72	13.94	272.16	34.60	59.15	0.00	0.00
7/3/07 18:50	841.46	344,125.91	238,569.50	70,462.80	4.16	27.41	13.94	272.03	33.70	58.15	0.00	6,447.05
7/3/07 18:51	839.36	353,214.81	244,438.50	71,728.11	4.30	27.24	13.95	272.03	33.45	56.90	0.00	0.00
7/3/07 18:52	838.22	348,530.31	242,701.09	71,285.79	7.62	26.75	13.95	272.03	32.80	56.40	0.00	7,195.63
7/3/07 18:53	838.49	344,441.69	241,801.91	70,831.28	5.01	26.29	13.95	272.72	32.75	55.60	0.00	0.00
7/3/07 18:54	839.31	345,860.81	241,933.70	70,949.35	5.76	25.50	13.95	272.72	31.95	54.85	0.00	5,233.00
7/3/07 18:55	839.85	347,862.00	240,988.91	70,776.52	6.58	25.66	13.95	272.72	32.20	53.90	0.00	0.00
7/3/07 18:56	839.95	341,487.09	239,054.80	70,129.48	5.62	25.88	13.95	273.00	31.70	54.00	0.00	0.00
7/3/07 18:57	839.65	348,974.50	237,938.20	71,011.27	6.19	25.75	14.03	273.00	31.75	54.25	0.00	0.00
7/3/07 18:58	838.81	341,472.19	239,785.09	70,631.30	6.14	25.38	13.99	273.09	31.20	53.85	0.00	0.00
7/3/07 18:59	838.53	335,927.31	237,969.59	70,417.30	5.79	24.85	13.79	273.03	33.15	54.00	0.00	4,462.45
7/3/07 19:00	838.42	343,854.09	236,142.20	70,483.31	2.77	24.72	13.89	273.40	31.65	53.95	0.00	0.00
7/3/07 19:01	837.85	346,325.69	243,575.50	70,755.47	4.33	23.88	13.98	273.65	32.65	53.65	0.00	6,734.49
7/3/07 19:02	836.93	343,285.19	237,276.00	70,106.39	6.63	24.00	14.08	273.65	31.10	53.90	0.00	0.00
7/3/07 19:03	836.79	330,794.91	234,975.20	71,014.01	4.21	23.88	14.17	273.97	31.45	53.90	0.00	6,118.29
7/3/07 19:04	836.90	356,497.19	242,548.09	70,418.86	5.05	23.84	14.48	273.96	35.15	59.95	0.00	0.00
7/3/07 19:05	837.21	342,883.31	234,960.70	70,659.61	5.05	23.82	14.37	273.97	35.15	59.90	0.00	9,750.66
7/3/07 19:06	836.47	339,642.59	236,325.30	70,761.80	5.05	23.88	14.26	274.45	35.00	60.00	0.00	0.00
7/3/07 19:07	836.14	337,549.31	234,409.20	70,047.79	5.05	24.13	14.13	274.31	35.45	60.05	0.00	3,174.21
7/3/07 19:08	836.11	342,898.81	235,216.80	70,324.94	2.70	23.00	14.10	273.97	34.80	59.55	0.00	0.00
7/3/07 19:09	834.02	339,376.09	235,367.30	70,191.08	6.25	22.81	14.14	273.96	34.10	58.35	0.00	0.00
7/3/07 19:10	832.81	346,789.91	240,278.59	70,680.73	4.11	23.00	14.17	275.01	33.10	57.45	0.00	3,907.99
7/3/07 19:11	831.66	353,522.09	242,684.70	71,701.24	7.83	23.00	14.21	275.34	32.95	56.85	0.00	0.00
7/3/07 19:12	831.59	338,686.91	234,159.91	70,381.16	5.65	22.25	14.24	275.34	32.10	54.80	0.00	6,287.72
7/3/07 19:13	830.92	331,470.19	234,612.00	71,531.70	5.76	22.13	14.28	274.99	31.45	54.25	0.00	0.00
7/3/07 19:14	831.63	342,314.81	232,957.09	70,533.23	5.27	22.13	14.32	275.01	31.65	53.90	0.00	5,795.58
7/3/07 19:15	831.19	337,522.09	235,702.50	71,152.75	5.14	21.88	14.35	274.98	31.20	54.10	0.00	0.00
7/3/07 19:16	830.59	334,079.69	231,799.91	70,731.53	5.77	22.66	14.39	275.02	32.25	54.15	0.00	7,289.00
7/3/07 19:17	829.98	331,013.09	231,285.50	70,858.45	6.60	22.00	14.43	275.36	31.25	53.85	0.00	0.00
7/3/07 19:18	829.02	354,104.31	239,426.80	71,947.06	3.98	21.60	14.46	275.34	32.15	54.25	0.00	0.00
7/3/07 19:19	828.64	336,210.81	232,052.50	71,584.92	8.30	21.75	14.50	275.70	31.65	53.95	0.00	0.00
7/3/07 19:20	828.84	341,639.59	237,604.09	71,871.45	4.92	21.88	14.53	275.70	30.95	54.20	0.00	0.00
7/3/07 19:21	828.54	348,776.09	237,425.70	71,629.09	6.48	21.34	14.57	275.70	31.85	54.10	0.00	3,890.79
7/3/07 19:22	828.70	330,687.91	231,592.00	71,903.12	5.49	21.38	14.61	275.70	31.70	53.85	0.00	0.00
7/3/07 19:23	828.74	325,386.50	229,154.91	70,919.45	6.34	21.50	14.64	275.70	31.25	53.95	0.00	6,047.91
7/3/07 19:24	828.91	345,036.31	229,796.00	70,835.46	4.00	21.38	14.54	275.70	34.20	60.05	0.00	0.00
7/3/07 19:25	830.22	345,455.41	235,021.91	71,725.67	4.00	21.97	14.48	276.01	35.05	60.05	0.00	6,193.18
7/3/07 19:26	829.99	343,621.91	236,374.80	72,208.61	4.00	22.97	14.43	275.70	34.65	59.85	0.00	0.00
7/3/07 19:27	829.91	331,074.81	235,638.30	70,710.30	4.00	22.06	14.38	274.99	34.70	60.05	0.00	8,664.24
7/3/07 19:28	829.75	336,185.19	238,241.91	71,594.98	5.99	22.00	14.43	275.01	34.30	59.15	0.00	0.00
7/3/07 19:29	830.09	324,212.59	235,319.30	71,743.71	5.17	21.78	14.32	275.01	33.50	57.85	0.00	8,743.41
7/3/07 19:30	830.24	338,823.09	241,491.50	70,824.73	5.94	20.88	14.21	274.99	33.40	56.95	0.00	0.00
7/3/07 19:31	830.55	323,886.69	238,552.70	69,871.24	5.20	21.97	14.10	275.01	31.85	55.40	0.00	0.00
7/3/07 19:32	831.43	350,909.19	241,516.20	70,969.00	2.73	21.88	13.99	275.01	31.60	54.20	0.00	1,625.65
7/3/07 19:33	831.89	334,686.69	238,607.00	70,856.08	5.31	22.00	13.88	275.17	31.85	54.00	0.00	0.00
7/3/07 19:34	832.28	335,726.81	233,778.50	70,405.24	4.17	22.88	13.77	275.34	31.55	54.15	0.00	5,934.00
7/3/07 19:35	832.25	327,963.00	233,406.09	70,445.38	3.40	23.13	13.78	275.01	31.10	53.65	0.00	0.00
7/3/07 19:36	832.15	333,988.50	242,069.20	71,199.32	3.38	22.11	13.90	274.62	31.25	54.15	0.00	8,017.19
7/3/07 19:37	831.58	327,701.81	237,175.70	69,982.19	4.56	21.91	14.01	274.31	31.25	54.35	0.00	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/3/07 19:38	831.43	329,986.19	234,660.00	71,010.30	2.42	21.22	14.13	274.33	30.85	54.25	0.00	9,687.48
7/3/07 19:39	831.48	328,983.91	235,168.50	69,924.00	3.39	20.91	14.24	274.62	31.85	54.25	0.00	0.00
7/3/07 19:40	832.28	331,963.31	236,280.80	70,044.81	3.94	20.97	14.36	274.99	32.25	53.95	0.00	2,158.28
7/3/07 19:41	832.51	326,629.09	237,128.30	69,490.95	5.24	22.25	14.47	276.00	31.95	53.65	0.00	739.77
7/3/07 19:42	832.09	335,433.19	236,696.80	69,995.88	2.52	21.00	14.59	276.00	31.80	54.05	0.00	0.00
7/3/07 19:43	832.43	336,932.19	239,345.00	70,177.06	4.38	21.13	14.70	276.65	31.98	54.15	0.00	5,339.48
7/3/07 19:44	833.73	335,638.00	239,394.59	69,759.08	4.55	21.00	14.82	276.65	34.75	59.85	0.00	0.00
7/3/07 19:45	835.54	336,949.69	239,635.30	70,010.63	4.55	21.00	14.93	277.68	35.05	60.05	0.00	5,649.79
7/3/07 19:46	836.61	324,194.41	237,592.50	69,922.30	4.55	21.66	14.88	277.68	35.05	59.85	0.00	0.00
7/3/07 19:47	837.98	331,525.59	240,010.80	70,225.28	4.55	21.75	14.86	277.34	34.75	59.85	0.00	6,462.28
7/3/07 19:48	839.27	340,299.09	237,460.41	70,152.41	4.75	21.63	14.85	276.66	34.60	59.00	0.00	0.00
7/3/07 19:49	840.59	328,026.81	239,346.00	70,008.38	5.42	21.63	14.84	276.67	33.70	58.05	0.00	10,442.02
7/3/07 19:50	840.00	334,660.19	236,221.70	69,733.76	3.15	21.88	14.83	276.34	33.50	57.10	0.00	0.00
7/3/07 19:51	840.71	342,001.81	244,498.70	70,431.61	2.91	21.75	14.82	276.34	32.30	55.85	0.00	3,047.13
7/3/07 19:52	841.78	335,375.59	240,545.00	71,030.70	4.13	21.66	14.81	276.35	31.45	54.55	0.00	0.00
7/3/07 19:53	842.26	334,320.81	244,806.70	70,113.18	3.38	22.00	14.82	276.67	31.30	53.95	0.00	0.00
7/3/07 19:54	842.41	336,187.81	245,499.00	70,975.45	5.15	22.88	14.82	276.67	31.85	53.95	0.00	2,501.03
7/3/07 19:55	843.48	338,689.69	245,871.09	70,924.55	5.89	22.53	14.82	276.67	31.85	54.05	0.00	0.00
7/3/07 19:56	844.72	326,992.41	237,808.09	69,944.47	4.37	22.38	14.83	276.34	31.65	54.40	0.00	6,372.02
7/3/07 19:57	844.91	338,263.09	241,253.80	70,642.92	3.82	23.13	14.83	276.32	31.35	54.05	0.00	0.00
7/3/07 19:58	845.85	331,902.41	238,962.09	71,974.59	2.86	22.50	14.83	276.00	30.80	54.05	0.00	8,715.54
7/3/07 19:59	846.88	347,913.00	247,044.30	72,490.95	2.05	22.28	14.83	276.33	31.30	54.25	0.00	0.00
7/3/07 20:00	847.77	335,087.31	239,434.00	71,965.98	6.18	23.00	14.83	275.98	30.55	54.25	0.00	10,261.44
7/3/07 20:01	848.15	346,892.31	243,536.50	71,762.09	3.12	22.97	14.83	275.70	31.40	53.75	0.00	0.00
7/3/07 20:02	848.41	339,088.41	244,053.50	72,195.48	5.45	23.00	14.83	275.70	31.90	53.75	0.00	0.00
7/3/07 20:03	847.76	337,837.00	244,595.20	72,159.36	5.58	22.75	14.84	275.70	31.35	53.95	0.00	0.00
7/3/07 20:04	846.72	339,403.31	243,584.41	71,858.63	4.51	21.78	14.90	275.70	35.00	60.00	0.00	0.00
7/3/07 20:05	846.40	327,821.31	239,694.00	71,346.21	4.51	22.19	14.95	275.70	35.60	59.90	0.00	6,226.78
7/3/07 20:06	845.90	350,494.91	247,742.50	71,694.43	4.51	22.09	14.99	276.01	35.05	59.90	0.00	0.00
7/3/07 20:07	846.18	331,156.41	238,816.70	70,766.41	4.51	21.88	15.03	276.34	34.90	60.20	0.00	8,142.12
7/3/07 20:08	845.44	341,877.81	243,139.59	71,978.60	3.04	21.91	15.08	276.65	34.50	59.15	0.00	0.00
7/3/07 20:09	845.03	342,850.09	246,443.80	71,420.27	4.62	21.88	15.08	276.65	34.15	58.55	0.00	8,268.03
7/3/07 20:10	844.40	337,662.31	242,384.80	71,503.01	4.38	21.88	15.05	276.65	33.70	57.70	0.00	0.00
7/3/07 20:11	844.78	342,816.09	241,799.91	70,922.95	5.17	22.00	15.11	276.66	32.75	57.25	0.00	4,115.32
7/3/07 20:12	845.41	342,200.00	244,853.80	71,388.16	4.28	21.75	15.18	276.35	32.30	56.35	0.00	0.00
7/3/07 20:13	845.98	352,481.09	240,566.91	71,027.30	5.25	21.75	15.24	276.66	32.45	55.65	0.00	0.00
7/3/07 20:14	845.35	337,484.31	242,482.20	71,719.87	4.04	21.84	15.30	276.66	31.85	54.80	0.00	3,378.48
7/3/07 20:15	846.34	339,329.69	243,502.50	72,027.33	1.87	21.88	15.37	276.66	32.15	54.05	0.00	0.00
7/3/07 20:16	847.54	329,897.50	239,255.30	71,125.06	3.38	21.78	15.43	276.34	31.65	53.90	0.00	7,945.36
7/3/07 20:17	847.22	334,327.59	241,278.80	71,503.48	3.81	22.75	15.49	276.35	31.65	54.15	0.00	0.00
7/3/07 20:18	847.10	350,651.59	252,680.91	71,809.37	2.77	22.25	15.56	276.01	32.05	53.95	0.00	8,570.04
7/3/07 20:19	846.01	339,781.31	245,283.80	71,500.92	4.41	21.00	15.62	275.53	30.85	54.25	0.00	0.00
7/3/07 20:20	845.89	341,825.41	243,635.91	71,299.28	3.08	21.00	15.67	276.03	31.45	54.00	0.00	3,029.09
7/3/07 20:21	845.54	341,592.31	246,617.91	71,952.05	3.42	21.00	15.60	275.70	31.75	54.25	0.00	0.00
7/3/07 20:22	845.80	336,463.09	245,383.80	70,648.73	4.38	20.78	15.53	275.70	31.90	53.75	0.00	0.00
7/3/07 20:23	846.51	341,506.41	247,370.50	71,677.93	3.32	21.00	15.47	275.70	31.70	53.95	0.00	4,685.64
7/3/07 20:24	847.08	339,347.69	246,403.80	71,627.17	3.25	21.50	15.40	276.34	34.75	60.00	0.00	0.00
7/3/07 20:25	847.37	336,931.19	245,265.70	70,467.66	3.25	21.97	15.45	276.00	33.90	60.05	0.00	6,008.81
7/3/07 20:26	847.12	342,995.81	248,235.20	72,192.38	3.25	21.88	15.48	276.01	34.90	59.70	0.00	0.00
7/3/07 20:27	847.98	341,919.81	248,687.00	72,215.40	3.25	21.59	15.51	275.70	34.70	60.10	0.00	8,528.81

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/3/07 20:28	847.79	343,054.19	247,183.41	71,656.52	6.50	21.75	15.34	275.34	34.65	59.70	0.00	0.00
7/3/07 20:29	848.53	330,119.00	248,826.30	71,051.14	3.73	23.13	15.05	275.35	34.65	58.15	0.00	0.00
7/3/07 20:30	849.69	338,464.50	251,770.80	72,109.51	4.93	22.06	14.75	275.01	33.90	58.05	0.00	0.00
7/3/07 20:31	851.17	346,915.81	249,950.70	71,050.33	6.43	22.91	11.84	275.01	32.65	57.25	0.00	0.00
7/3/07 20:32	852.90	360,419.31	259,358.50	71,996.23	4.22	23.81	11.39	276.01	33.00	56.60	0.00	0.00
7/3/07 20:33	854.16	337,249.09	248,417.80	71,239.23	7.82	23.97	11.25	277.34	32.95	55.90	0.00	0.00
7/3/07 20:34	855.66	339,312.59	249,213.70	71,238.86	3.62	23.75	11.21	278.32	31.85	55.20	0.00	0.00
7/3/07 20:35	857.07	351,971.00	254,265.59	72,216.71	3.88	24.13	11.18	278.70	32.35	54.90	0.00	0.00
7/3/07 20:36	857.77	342,849.91	248,863.30	72,258.25	4.04	24.63	11.30	279.35	31.35	54.20	0.00	0.00
7/3/07 20:37	858.29	349,249.81	255,222.20	71,435.60	4.88	25.13	11.07	279.35	31.25	53.80	0.00	0.00
7/3/07 20:38	859.06	346,153.31	245,189.50	72,107.12	4.95	25.53	10.83	280.04	31.35	54.20	0.00	0.00
7/3/07 20:39	858.88	341,856.00	253,203.00	72,391.77	4.23	25.88	10.60	280.35	32.05	53.80	0.00	0.00
7/3/07 20:40	859.34	339,946.50	249,259.00	71,345.04	4.81	25.77	10.36	280.35	31.70	54.55	0.00	0.00
7/3/07 20:41	860.62	333,665.59	247,339.70	71,610.05	4.72	25.94	10.13	280.35	31.40	54.10	0.00	0.00
7/3/07 20:42	861.77	343,487.81	247,606.09	71,869.93	2.49	26.88	9.89	281.01	31.10	54.15	0.00	0.00
7/3/07 20:43	862.68	335,868.31	247,785.50	72,566.72	4.11	27.75	9.85	281.03	31.70	53.55	0.00	0.00
7/3/07 20:44	862.93	345,759.00	252,129.00	72,823.34	3.45	28.00	10.05	280.35	34.60	59.95	0.00	0.00
7/3/07 20:45	862.35	337,824.09	246,542.70	71,712.15	3.45	27.19	10.25	280.35	34.85	60.05	0.00	0.00
7/3/07 20:46	862.97	358,601.00	255,990.41	72,304.20	3.45	25.91	10.35	281.04	35.25	60.00	0.00	0.00
7/3/07 20:47	863.03	351,268.19	248,245.80	71,838.16	3.45	25.63	10.43	281.03	34.40	60.05	0.00	0.00
7/3/07 20:48	862.44	348,118.41	253,886.80	72,378.70	4.61	26.00	10.51	281.37	34.90	59.30	0.00	0.00
7/3/07 20:49	861.29	343,455.91	247,917.00	73,199.09	4.78	26.86	10.31	281.37	34.90	59.40	0.00	0.00
7/3/07 20:50	860.86	344,200.59	249,054.09	73,415.21	5.20	26.59	10.17	281.67	34.50	58.95	0.00	0.00
7/3/07 20:51	860.40	335,577.19	246,587.70	72,869.43	5.81	26.51	10.12	281.37	34.30	59.20	0.00	0.00
7/3/07 20:52	860.82	340,317.09	245,174.30	73,070.27	4.42	26.50	10.08	281.37	34.90	59.20	0.00	0.00
7/3/07 20:53	860.60	338,530.50	247,701.91	72,352.98	4.30	27.00	10.16	281.37	34.45	59.00	0.00	0.00
7/3/07 20:54	860.92	347,737.59	248,106.00	72,046.42	3.27	26.25	10.15	281.66	34.10	59.00	0.00	0.00
7/3/07 20:55	861.09	338,071.09	244,157.91	71,748.28	3.48	25.80	10.13	282.04	33.75	58.50	0.00	10,165.42
7/3/07 20:56	858.23	345,278.69	246,300.00	72,801.74	3.22	26.50	10.12	282.35	33.45	57.40	0.00	8,643.76
7/3/07 20:57	856.03	349,511.81	249,737.59	73,950.95	6.82	25.97	10.11	282.02	33.60	56.90	0.00	8,125.30
7/3/07 20:58	855.53	331,394.19	243,411.80	71,820.91	4.27	25.88	10.10	282.35	33.00	56.95	0.00	7,803.33
7/3/07 20:59	855.53	334,175.09	243,961.00	72,351.69	3.60	25.97	10.09	282.84	32.60	56.30	0.00	6,401.40
7/3/07 21:00	856.42	338,929.91	245,655.80	71,375.60	3.02	24.75	10.08	283.99	33.10	55.85	0.00	6,212.87
7/3/07 21:01	857.39	333,752.31	243,994.70	71,933.55	3.03	25.75	10.07	284.66	31.65	54.70	0.00	6,441.64
7/3/07 21:02	857.71	342,707.50	249,673.00	71,724.96	2.79	26.84	10.06	285.35	31.65	54.75	0.00	8,332.90
7/3/07 21:03	858.26	350,048.59	248,842.59	72,285.18	3.11	27.00	10.05	285.20	32.55	54.45	0.00	6,426.81
7/3/07 21:04	858.64	349,454.59	247,012.30	72,559.55	4.27	26.88	10.04	285.06	34.80	60.00	0.00	6,837.96
7/3/07 21:05	858.90	350,875.59	252,139.91	71,884.82	4.27	26.97	10.03	285.06	35.15	60.10	0.00	8,585.37
7/3/07 21:06	858.48	343,538.09	244,714.41	72,655.07	4.27	26.75	10.02	284.38	34.80	60.00	0.00	6,925.10
7/3/07 21:07	857.98	342,621.31	246,892.91	71,994.12	4.27	26.75	10.01	283.99	34.90	60.10	0.00	6,992.20
7/3/07 21:08	858.38	336,013.09	245,944.91	71,705.19	3.95	26.84	10.00	283.04	34.50	60.30	0.00	6,402.76
7/3/07 21:09	859.79	350,648.31	247,798.30	72,454.07	2.48	27.13	9.98	282.36	34.70	59.70	0.00	5,724.77
7/3/07 21:10	860.14	339,422.50	246,319.50	72,663.62	6.69	27.91	9.97	281.37	34.55	59.00	0.00	5,820.60
7/3/07 21:11	860.44	345,835.19	246,682.70	72,239.48	4.67	29.00	9.96	280.72	34.70	59.00	0.00	0.00
7/3/07 21:12	860.23	353,408.31	252,109.80	72,269.64	4.57	28.38	9.94	279.67	34.65	59.10	0.00	0.00
7/3/07 21:13	860.18	355,878.81	251,922.30	72,639.72	5.63	28.08	9.92	278.70	33.80	58.35	0.00	0.00
7/3/07 21:14	859.39	341,819.19	245,802.00	71,766.77	6.98	27.91	9.91	278.01	33.40	57.45	0.00	0.00
7/3/07 21:15	859.69	349,640.31	249,339.09	71,758.83	5.06	27.28	9.89	278.01	33.40	57.20	0.00	0.00
7/3/07 21:16	859.49	335,490.00	243,614.70	72,407.99	4.63	29.34	9.87	277.70	32.70	56.30	0.00	0.00
7/3/07 21:17	860.03	364,541.41	248,013.00	72,032.05	3.27	28.80	9.86	277.03	32.95	56.35	0.00	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/3/07 21:18	859.87	342,817.09	246,351.91	72,003.12	3.30	28.78	9.84	277.03	32.50	55.40	0.00	0.00
7/3/07 21:19	860.33	322,527.59	245,560.30	72,238.62	2.29	28.75	9.82	276.53	32.35	54.65	0.00	0.00
7/3/07 21:20	860.37	341,178.81	243,235.30	72,195.84	3.35	28.00	9.81	276.34	30.95	53.80	0.00	0.00
7/3/07 21:21	860.82	357,255.81	252,307.30	72,774.73	5.81	28.95	9.79	276.34	32.35	54.25	0.00	0.00
7/3/07 21:22	860.05	341,072.41	247,861.41	72,491.30	7.00	29.51	9.77	276.34	32.30	54.20	0.00	0.00
7/3/07 21:23	860.05	337,067.91	247,000.41	72,479.60	3.46	28.38	9.76	276.33	31.85	54.05	0.00	0.00
7/3/07 21:24	859.93	346,776.81	249,843.70	72,252.77	4.38	28.00	9.74	276.66	35.45	60.05	0.00	0.00
7/3/07 21:25	859.41	348,438.81	250,908.20	73,283.81	4.38	27.78	9.72	276.34	34.90	60.05	0.00	0.00
7/3/07 21:26	859.12	347,200.00	247,689.09	72,687.18	4.38	27.13	9.96	276.65	35.45	59.85	0.00	0.00
7/3/07 21:27	860.07	351,293.31	250,189.41	73,307.13	4.38	27.13	9.82	277.33	34.65	60.05	0.00	0.00
7/3/07 21:28	860.76	338,900.91	251,586.50	73,697.70	5.46	27.97	9.61	277.99	35.05	59.90	0.00	0.00
7/3/07 21:29	861.63	338,869.31	247,101.20	73,353.92	4.20	27.97	9.54	277.68	35.40	60.40	0.00	0.00
7/3/07 21:30	862.46	335,922.31	244,329.00	72,475.52	3.43	27.75	9.47	278.01	34.30	59.50	0.00	0.00
7/3/07 21:31	863.11	341,802.09	249,461.70	72,456.39	1.97	29.68	9.41	278.01	34.50	59.35	0.00	0.00
7/3/07 21:32	864.29	344,369.81	250,856.70	72,703.76	4.11	29.12	9.34	278.01	33.95	59.00	0.00	0.00
7/3/07 21:33	865.17	345,813.19	249,185.59	72,381.41	4.72	29.84	9.27	278.00	34.20	58.80	0.00	0.00
7/3/07 21:34	865.05	341,609.69	250,558.09	72,817.45	4.80	30.13	9.21	277.03	33.90	58.80	0.00	0.00
7/3/07 21:35	865.28	336,950.41	248,450.09	72,170.27	3.04	29.00	9.14	277.03	34.00	58.20	0.00	0.00
7/3/07 21:36	865.94	351,722.41	251,005.30	72,317.30	3.84	29.00	9.07	277.18	33.75	57.75	0.00	0.00
7/3/07 21:37	866.12	350,690.59	251,356.50	72,021.47	3.05	29.70	9.01	277.19	33.40	57.90	0.00	1,288.83
7/3/07 21:38	864.03	348,359.09	251,918.41	72,939.96	3.24	30.00	8.94	277.70	34.05	57.20	0.00	5,927.83
7/3/07 21:39	863.72	350,278.59	251,341.30	72,837.69	3.57	29.88	8.87	277.84	34.20	57.05	0.00	8,106.36
7/3/07 21:40	864.24	345,361.50	252,691.09	72,725.71	5.61	29.88	8.80	278.01	33.35	56.95	0.00	8,555.44
7/3/07 21:41	866.14	347,955.81	250,567.50	71,772.17	3.20	29.22	8.74	278.69	33.30	56.95	0.00	8,106.31
7/3/07 21:42	868.22	352,127.19	251,631.09	72,651.16	1.36	29.50	8.67	279.01	32.80	56.20	0.00	8,884.01
7/3/07 21:43	869.92	349,140.41	251,692.70	71,647.75	2.93	31.38	8.37	279.68	32.80	55.20	0.00	7,362.99
7/3/07 21:44	871.70	355,703.69	256,071.50	71,896.01	5.06	32.50	7.73	279.68	35.00	60.00	0.00	7,117.54
7/3/07 21:45	873.22	362,900.81	254,617.80	72,314.36	5.06	30.69	7.91	279.36	35.35	59.90	0.00	5,858.39
7/3/07 21:46	874.05	353,415.91	257,239.80	72,243.77	5.06	30.75	8.03	279.67	34.85	60.20	0.00	5,475.67
7/3/07 21:47	874.87	341,814.69	254,758.91	72,356.08	5.06	30.47	8.16	279.65	34.65	59.85	0.00	5,658.47
7/3/07 21:48	875.20	355,243.41	256,698.70	72,271.94	3.85	31.00	8.29	279.65	35.05	60.20	0.00	6,844.48
7/3/07 21:49	874.86	350,338.59	256,768.91	72,472.98	5.19	31.00	8.42	279.65	35.00	60.05	0.00	8,621.14
7/3/07 21:50	874.63	350,106.50	256,569.50	72,115.33	4.40	30.91	8.61	279.65	34.90	59.85	0.00	8,069.69
7/3/07 21:51	875.26	360,348.69	260,884.50	72,765.22	4.93	30.00	8.58	279.67	35.35	59.90	0.00	7,969.41
7/3/07 21:52	875.39	339,887.81	255,298.30	72,046.41	5.18	31.88	8.56	279.01	35.45	60.00	0.00	7,580.51
7/3/07 21:53	875.79	351,735.09	257,091.80	72,733.15	3.08	31.28	8.53	278.69	35.00	60.05	0.00	0.00
7/3/07 21:54	875.72	354,259.00	258,929.30	72,672.09	3.58	32.31	8.51	278.01	34.75	59.70	0.00	0.00
7/3/07 21:55	874.87	355,508.31	258,649.20	72,468.27	5.23	32.75	8.48	277.69	34.70	58.90	0.00	0.00
7/3/07 21:56	874.40	338,095.09	259,906.41	71,764.02	5.50	31.66	8.46	277.03	34.50	58.50	0.00	0.00
7/3/07 21:57	875.10	371,074.00	261,870.70	72,337.04	3.52	31.74	8.44	277.03	34.15	58.30	0.00	0.00
7/3/07 21:58	875.44	357,243.00	261,709.20	71,689.74	6.77	33.25	8.41	277.02	34.35	57.90	0.00	0.00
7/3/07 21:59	875.54	361,579.00	266,628.81	72,772.02	5.65	32.81	8.39	277.03	33.60	58.10	0.00	0.00
7/3/07 22:00	875.11	355,571.91	262,175.41	72,490.88	7.22	32.44	8.36	277.03	34.35	58.50	0.00	0.00
7/3/07 22:01	874.45	347,045.59	259,750.70	71,827.26	6.37	31.84	8.34	276.65	34.35	58.30	0.00	0.00
7/3/07 22:02	875.31	361,966.50	263,248.81	72,379.48	3.54	31.88	8.31	277.02	34.20	59.05	0.00	0.00
7/3/07 22:03	876.02	351,839.69	260,862.59	72,736.02	5.06	32.00	8.31	277.34	34.55	59.35	0.00	0.00
7/3/07 22:04	876.12	356,539.91	263,608.41	72,465.86	4.20	31.91	8.33	277.34	35.03	60.15	0.00	0.00
7/3/07 22:05	875.23	357,938.00	261,651.41	72,234.05	4.20	31.13	8.34	277.03	35.20	59.90	0.00	0.00
7/3/07 22:06	875.12	361,506.19	260,512.00	72,399.41	4.20	30.16	8.35	277.34	34.55	60.20	0.00	0.00
7/3/07 22:07	875.29	354,866.00	261,074.30	72,622.06	4.20	30.38	8.36	277.01	34.55	59.95	0.00	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/3/07 22:08	875.76	368,084.50	262,887.09	72,730.27	5.01	31.75	8.37	277.70	35.75	60.50	0.00	0.00
7/3/07 22:09	875.90	359,408.91	267,383.81	72,598.63	6.72	31.88	8.38	277.33	35.25	60.50	0.00	0.00
7/3/07 22:10	876.60	363,808.41	260,490.70	72,270.39	5.15	31.75	8.40	277.33	35.25	60.30	0.00	0.00
7/3/07 22:11	875.78	355,648.31	263,126.41	72,839.54	5.93	31.80	8.41	276.66	35.45	60.50	0.00	0.00
7/3/07 22:12	876.11	367,806.50	264,465.91	73,406.65	5.46	31.38	8.42	277.02	35.35	59.95	0.00	0.00
7/3/07 22:13	876.02	356,927.50	259,133.20	71,945.95	7.44	30.81	8.37	277.02	35.30	60.55	0.00	0.00
7/3/07 22:14	875.73	361,268.31	261,316.09	72,731.66	4.40	30.78	8.49	276.66	35.20	60.70	0.00	0.00
7/3/07 22:15	874.76	342,812.91	258,903.20	72,344.77	6.72	30.86	8.59	277.03	35.45	60.80	0.00	0.00
7/3/07 22:16	874.73	369,305.00	262,659.41	73,191.12	3.46	30.88	8.60	277.03	35.45	60.60	0.00	0.00
7/3/07 22:17	875.28	362,472.31	262,733.00	72,251.21	5.85	30.59	8.61	277.03	35.60	60.90	0.00	0.00
7/3/07 22:18	874.28	352,664.81	258,524.30	72,461.52	6.64	30.63	8.62	277.03	34.70	61.00	0.00	0.00
7/3/07 22:19	873.10	356,479.69	258,111.00	72,240.95	5.40	30.61	8.71	277.34	35.70	61.10	0.00	0.00
7/3/07 22:20	871.88	352,348.50	258,733.20	72,366.47	6.23	30.50	8.74	278.03	35.55	60.95	0.00	0.00
7/3/07 22:21	871.89	360,016.69	260,460.41	72,959.29	4.69	29.50	8.78	278.01	35.25	60.85	0.00	0.00
7/3/07 22:22	872.53	361,975.41	267,540.09	73,078.03	4.96	29.88	8.81	278.01	35.85	60.95	0.00	0.00
7/3/07 22:23	872.41	351,746.59	256,661.30	72,288.75	6.79	30.13	8.85	278.70	34.20	61.35	0.00	0.00
7/3/07 22:24	872.17	345,685.31	255,661.30	72,263.11	4.73	29.88	8.89	278.69	34.90	60.05	0.00	0.00
7/3/07 22:25	872.75	347,337.59	256,071.70	72,586.95	4.73	30.00	8.92	278.33	35.45	60.00	0.00	0.00
7/3/07 22:26	873.00	341,856.59	252,483.09	72,340.43	4.73	30.75	8.96	278.01	35.15	60.10	0.00	0.00
7/3/07 22:27	873.05	354,840.31	260,251.20	71,862.39	4.73	31.00	8.99	278.32	34.60	60.40	0.00	0.00
7/3/07 22:28	872.14	348,107.31	253,531.30	72,529.31	5.02	31.00	9.03	278.68	34.95	59.60	0.00	0.00
7/3/07 22:29	871.97	344,340.31	253,938.80	73,406.48	4.65	31.03	9.07	278.33	34.70	59.50	0.00	0.00
7/3/07 22:30	872.07	350,519.09	253,574.50	71,754.51	5.75	30.13	9.10	278.33	34.35	59.70	0.00	0.00
7/3/07 22:31	871.92	351,473.41	254,602.70	71,590.21	5.44	30.66	9.14	278.02	34.65	59.30	0.00	0.00
7/3/07 22:32	871.82	346,715.19	252,324.70	72,188.96	5.31	31.06	9.17	278.00	34.10	59.40	0.00	0.00
7/3/07 22:33	870.97	361,704.91	262,915.81	72,745.40	5.01	31.13	9.21	278.00	34.65	58.75	0.00	0.00
7/3/07 22:34	870.71	353,227.59	257,745.20	73,374.48	7.71	30.22	9.24	278.01	33.95	58.65	0.00	0.00
7/3/07 22:35	870.70	360,931.91	253,357.50	72,353.14	6.65	29.88	9.28	278.00	33.85	58.85	0.00	13,685.58
7/3/07 22:36	870.40	362,640.00	258,716.59	72,816.06	4.69	30.00	9.32	278.01	34.05	58.05	0.00	13,719.04
7/3/07 22:37	871.35	366,466.09	262,373.81	73,538.56	4.37	29.13	9.35	278.01	33.60	57.65	0.00	13,696.46
7/3/07 22:38	871.85	341,321.69	253,348.59	72,550.72	6.69	29.07	9.39	278.38	33.30	56.70	0.00	13,601.08
7/3/07 22:39	871.62	347,383.19	254,890.09	73,071.66	4.95	30.25	9.42	278.33	32.50	56.35	0.00	5,335.00
7/3/07 22:40	868.66	345,697.09	253,206.70	72,393.34	5.70	29.00	9.45	278.69	32.60	54.75	0.00	11,121.60
7/3/07 22:41	864.62	356,058.81	255,685.20	72,685.30	3.79	29.00	9.15	279.01	31.45	53.85	0.00	12,261.91
7/3/07 22:42	861.65	351,907.50	253,989.41	71,783.70	4.58	29.81	9.06	278.32	31.55	54.20	0.00	12,077.83
7/3/07 22:43	857.60	357,737.81	257,582.59	73,550.37	5.32	29.38	8.99	278.32	31.35	53.95	0.00	11,841.49
7/3/07 22:44	852.78	354,697.81	255,786.70	72,168.93	3.66	28.63	8.92	279.01	34.05	59.95	0.00	11,657.77
7/3/07 22:45	851.94	356,723.19	255,341.80	73,220.95	3.66	28.63	8.86	279.01	34.95	59.95	0.00	11,090.85
7/3/07 22:46	852.76	346,389.19	255,178.20	72,803.68	3.66	28.75	8.79	279.01	35.40	60.00	0.00	11,038.18
7/3/07 22:47	855.21	377,354.31	267,328.31	73,158.88	3.66	28.97	8.72	279.01	35.85	60.05	0.00	10,918.75
7/3/07 22:48	856.59	351,866.91	259,074.20	73,138.11	8.35	29.59	8.65	279.01	34.70	59.50	0.00	10,842.76
7/3/07 22:49	857.41	329,406.31	257,183.00	73,093.36	3.93	29.88	8.59	279.35	34.20	58.40	0.00	9,065.93
7/3/07 22:50	855.45	355,701.31	259,805.00	73,383.96	4.78	29.13	8.52	279.68	33.40	57.15	0.00	9,527.72
7/3/07 22:51	853.85	356,464.09	258,939.00	72,899.84	5.80	29.63	8.45	280.35	33.05	57.10	0.00	9,428.28
7/3/07 22:52	853.70	348,106.09	255,202.09	72,825.11	5.22	29.97	8.38	281.03	33.95	57.50	0.00	9,036.29
7/3/07 22:53	852.18	361,455.31	260,483.41	73,184.00	3.48	30.75	8.32	281.68	33.65	57.00	0.00	9,508.70
7/3/07 22:54	850.63	343,199.59	258,191.20	72,476.93	7.15	30.28	8.25	281.68	32.25	56.05	0.00	11,973.21
7/3/07 22:55	851.56	349,064.91	257,839.59	72,514.38	3.82	30.97	8.18	281.68	31.40	55.65	0.00	10,572.85
7/3/07 22:56	854.28	357,468.09	257,582.41	73,200.45	3.03	30.13	8.11	282.19	32.05	54.90	0.00	10,460.02
7/3/07 22:57	855.70	348,738.91	257,660.20	72,971.48	6.15	31.59	8.05	282.64	31.70	53.95	0.00	10,452.58

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/3/07 22:58	857.41	354,998.69	257,228.59	72,188.38	4.53	32.00	8.01	282.35	32.20	54.00	0.00	10,327.22
7/3/07 22:59	857.97	351,112.69	258,183.20	72,882.92	3.81	31.00	8.01	282.34	31.55	54.10	0.00	8,967.18
7/3/07 23:00	857.89	353,915.00	258,397.20	73,665.02	7.17	30.97	8.01	282.49	31.00	53.95	0.00	9,143.74
7/3/07 23:01	857.28	352,120.81	257,955.20	72,338.84	6.57	31.98	8.01	282.35	31.35	53.65	0.00	9,059.61
7/3/07 23:02	857.45	353,756.41	257,637.91	72,749.28	3.39	31.27	8.00	282.35	31.00	54.25	0.00	8,670.04
7/3/07 23:03	855.84	338,297.59	255,420.09	72,423.00	5.87	31.72	8.00	283.03	31.40	54.05	0.00	8,983.24
7/3/07 23:04	855.68	371,942.41	269,845.41	74,629.64	5.53	32.00	8.00	283.04	35.25	59.80	0.00	10,922.25
7/3/07 23:05	854.78	344,531.00	256,265.50	72,067.55	5.53	32.00	7.99	282.65	34.50	60.15	0.00	10,406.80
7/3/07 23:06	855.14	354,545.41	256,992.50	71,740.05	5.53	32.00	7.91	282.64	33.90	59.80	0.00	10,451.25
7/3/07 23:07	856.20	351,578.00	257,796.80	72,424.59	5.53	32.75	7.84	283.33	35.05	59.90	0.00	10,474.67
7/3/07 23:08	856.92	362,470.00	259,378.00	72,724.78	3.59	32.94	7.76	283.68	34.65	59.70	0.00	4,875.95
7/3/07 23:09	856.78	351,848.31	259,653.20	72,961.31	5.41	32.75	7.68	283.68	34.35	58.50	0.00	9,101.60
7/3/07 23:10	855.63	376,504.41	258,951.09	73,589.42	5.50	33.75	7.69	283.33	33.75	58.35	0.00	8,383.61
7/3/07 23:11	855.19	350,965.69	256,455.50	72,466.50	7.01	33.50	7.71	283.68	33.35	57.50	0.00	8,853.52
7/3/07 23:12	855.08	354,587.31	257,974.91	72,489.80	3.39	33.00	7.72	283.70	32.90	57.25	0.00	8,510.59
7/3/07 23:13	852.95	345,709.81	255,995.70	72,337.66	4.96	32.94	7.73	283.68	32.83	56.08	0.00	3,894.89
7/3/07 23:14	852.55	359,277.59	260,404.50	72,458.15	5.85	32.81	7.72	283.33	33.38	55.67	0.00	12,560.37
7/3/07 23:15	854.18	368,166.50	261,286.80	72,497.33	4.73	32.75	7.67	283.33	32.65	54.90	0.00	12,511.52
7/3/07 23:16	857.10	353,407.09	260,965.70	72,464.00	5.12	32.56	7.63	283.31	31.45	54.60	0.00	12,741.26
7/3/07 23:17	859.56	351,628.31	259,542.09	73,248.19	4.01	32.75	7.68	283.70	32.15	54.70	0.00	12,732.54
7/3/07 23:18	861.44	364,652.91	262,899.81	72,665.85	5.17	32.94	7.69	283.68	31.25	54.90	0.00	3,634.17
7/3/07 23:19	860.32	361,157.81	262,000.59	72,541.80	5.44	31.89	7.69	283.70	32.00	54.55	0.00	11,814.91
7/3/07 23:20	857.21	349,761.81	260,175.09	72,486.66	3.94	32.00	7.70	283.68	31.65	53.80	0.00	12,088.38
7/3/07 23:21	856.47	364,363.59	263,705.09	72,287.44	3.60	31.83	7.71	283.70	31.35	54.25	0.00	10,684.83
7/3/07 23:22	855.43	354,169.31	260,802.59	72,292.05	5.58	32.75	7.71	284.23	31.40	54.35	0.00	11,280.25
7/3/07 23:23	853.69	357,763.19	260,931.80	72,118.59	3.63	33.00	7.87	284.36	33.10	54.45	0.00	11,190.78
7/3/07 23:24	855.01	367,667.00	263,517.41	73,023.27	5.11	32.25	7.84	284.38	34.60	60.10	0.00	11,220.87
7/3/07 23:25	856.24	357,218.59	262,081.70	72,753.39	5.11	32.94	7.81	284.38	35.55	59.90	0.00	11,075.90
7/3/07 23:26	858.70	358,424.31	264,453.69	73,100.66	5.11	32.75	7.77	284.66	35.15	59.85	0.00	10,923.00
7/3/07 23:27	861.93	361,605.41	265,231.19	73,459.30	5.11	32.25	7.74	285.04	34.55	60.05	0.00	11,218.77
7/3/07 23:28	863.49	355,629.69	260,204.09	72,907.10	7.29	32.25	7.71	285.06	34.90	59.85	0.00	8,875.70
7/3/07 23:29	861.98	359,564.41	261,341.00	72,660.59	4.18	32.75	7.68	285.04	34.75	59.65	0.00	8,916.27
7/3/07 23:30	859.30	360,895.41	265,612.69	73,001.38	4.95	32.31	7.65	285.04	34.60	59.35	0.00	8,977.98
7/3/07 23:31	858.63	356,520.41	264,342.50	73,185.78	8.02	32.44	7.61	285.06	34.15	58.45	0.00	9,228.13
7/3/07 23:32	857.86	354,114.00	261,686.09	72,363.67	6.03	32.81	7.58	285.71	34.35	58.10	0.00	9,579.52
7/3/07 23:33	857.34	353,178.81	261,536.70	73,114.13	5.07	33.94	7.55	286.01	34.20	58.20	0.00	10,679.48
7/3/07 23:34	859.46	349,877.41	261,053.09	72,685.40	6.08	33.00	7.52	286.01	33.85	58.75	0.00	9,684.92
7/3/07 23:35	862.05	361,765.81	264,236.81	72,292.79	4.12	33.00	7.49	285.71	34.15	58.35	0.00	9,435.51
7/3/07 23:36	865.26	359,997.81	265,055.81	72,444.39	4.75	32.75	7.46	285.72	34.70	58.40	0.00	9,237.38
7/3/07 23:37	868.65	350,797.50	261,036.30	73,198.66	4.28	32.75	7.42	285.71	34.10	58.40	0.00	9,590.34
7/3/07 23:38	870.05	355,050.31	261,087.00	71,871.30	4.40	34.00	7.39	285.71	34.05	58.95	0.00	8,618.45
7/3/07 23:39	868.64	365,193.69	263,210.81	72,759.44	3.69	32.81	7.36	285.71	34.15	58.75	0.00	8,601.56
7/3/07 23:40	866.48	354,128.91	262,183.91	72,073.30	6.06	34.00	7.33	286.01	33.80	58.55	0.00	8,397.85
7/3/07 23:41	865.02	370,604.00	265,437.69	72,326.69	3.66	33.81	7.30	286.69	34.15	58.60	0.00	8,616.69
7/3/07 23:42	862.64	362,338.91	264,619.69	72,376.28	5.09	33.50	7.26	286.40	33.40	58.35	0.00	8,608.03
7/3/07 23:43	861.91	361,963.91	264,648.69	72,512.42	5.09	33.50	7.23	286.39	33.55	58.20	0.00	11,586.93
7/3/07 23:44	863.63	361,588.41	266,853.09	73,044.59	6.27	33.56	7.20	286.01	34.45	59.90	0.00	11,498.71
7/3/07 23:45	865.62	361,527.19	266,971.59	72,813.23	6.27	33.00	7.17	286.40	34.40	59.95	0.00	11,215.88
7/3/07 23:46	868.33	366,043.19	264,762.00	72,740.17	6.27	32.75	7.14	286.39	35.15	59.80	0.00	11,165.59
7/3/07 23:47	870.40	362,366.41	266,603.81	73,104.90	6.27	33.56	7.11	287.00	34.45	60.20	0.00	8,676.66

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/3/07 23:48	869.61	354,666.69	265,206.00	72,944.52	5.65	34.00	7.20	287.00	35.40	60.15	0.00	10,062.95
7/3/07 23:49	865.89	370,706.31	263,585.69	72,201.77	4.77	34.00	7.23	287.00	35.40	60.20	0.00	10,297.44
7/3/07 23:50	862.63	359,485.81	266,018.31	72,347.30	4.79	33.75	7.26	286.69	34.45	60.50	0.00	10,186.74
7/3/07 23:51	860.27	354,577.31	262,356.91	72,785.32	4.36	33.75	7.30	287.02	35.80	60.55	0.00	10,385.67
7/3/07 23:52	858.39	367,862.09	266,893.41	72,317.13	4.24	33.75	7.33	287.33	35.65	60.60	0.00	4,980.66
7/3/07 23:53	858.20	355,205.59	264,896.81	72,228.13	6.61	34.06	7.36	287.33	35.15	60.75	0.00	10,377.55
7/3/07 23:54	860.84	366,826.41	266,691.09	72,360.61	4.78	33.75	7.39	287.33	35.30	60.75	0.00	10,398.52
7/3/07 23:55	863.64	359,898.69	264,616.91	72,844.64	4.40	33.75	7.43	287.33	35.50	60.75	0.00	10,336.56
7/3/07 23:56	865.39	363,595.09	265,581.81	72,056.77	5.12	34.50	7.46	287.63	35.00	61.05	0.00	10,343.42
7/3/07 23:57	866.89	359,735.31	265,545.81	72,546.34	4.16	33.94	7.49	287.64	35.95	61.25	0.00	0.00
7/3/07 23:58	866.58	369,707.41	267,602.31	72,753.49	4.64	33.81	7.52	287.33	36.05	61.15	0.00	8,960.62
7/3/07 23:59	863.79	338,840.81	264,914.69	72,336.91	7.47	34.25	7.56	287.33	35.75	60.90	0.00	8,428.90
7/4/07 0:00	861.18	356,764.31	264,894.81	72,071.16	4.51	34.50	7.49	287.33	34.90	60.60	0.00	8,639.42
7/4/07 0:01	858.76	365,248.81	265,037.31	73,006.31	4.05	34.50	7.42	287.64	35.20	60.90	0.00	8,988.17
7/4/07 0:02	856.79	360,886.41	263,320.91	72,453.66	6.12	34.50	7.34	287.33	36.00	60.85	0.00	8,667.37
7/4/07 0:03	858.04	364,671.59	265,550.09	72,923.29	6.09	34.75	7.27	288.36	34.95	61.05	0.00	10,375.29
7/4/07 0:04	860.13	357,820.81	265,635.91	73,141.01	6.96	34.50	7.20	288.36	34.55	60.05	0.00	10,344.92
7/4/07 0:05	862.59	351,182.09	263,204.31	72,162.41	6.96	34.00	7.12	288.36	34.60	59.95	0.00	10,377.42
7/4/07 0:06	865.35	364,049.81	262,881.69	72,632.98	6.96	34.75	7.05	288.74	34.90	59.95	0.00	10,378.46
7/4/07 0:07	868.82	365,549.00	260,730.00	72,390.13	6.96	34.75	6.98	288.36	35.05	60.00	0.00	8,134.07
7/4/07 0:08	868.45	352,768.00	264,132.69	72,947.58	6.94	34.75	6.91	288.36	34.90	60.25	0.00	9,137.98
7/4/07 0:09	865.39	363,220.31	266,767.81	74,032.60	5.40	34.94	6.74	288.02	35.45	60.40	0.00	8,670.95
7/4/07 0:10	862.59	349,854.69	265,639.31	73,422.14	8.30	34.81	6.70	288.01	35.75	60.40	0.00	9,034.65
7/4/07 0:11	859.41	357,329.59	261,360.30	73,434.81	5.70	35.00	6.65	288.00	35.25	60.15	0.00	8,807.74
7/4/07 0:12	857.00	354,775.31	259,810.30	72,450.48	6.52	35.50	6.61	288.00	35.25	60.45	0.00	12,631.65
7/4/07 0:13	857.56	354,832.19	260,958.50	72,287.88	5.51	35.27	6.57	288.00	34.45	60.20	0.00	11,392.43
7/4/07 0:14	860.53	355,400.91	260,041.41	73,430.87	4.11	35.69	6.52	288.00	35.10	60.50	0.00	11,419.37
7/4/07 0:15	862.58	354,266.50	259,641.30	72,967.59	5.76	35.75	6.48	288.33	35.60	60.60	0.00	11,294.67
7/4/07 0:16	865.45	353,934.00	257,778.59	72,601.58	3.47	35.81	6.37	288.74	34.95	61.00	0.00	11,261.92
7/4/07 0:17	867.55	353,846.91	256,941.59	72,538.59	2.46	35.94	6.44	288.69	34.70	61.55	0.00	12,295.45
7/4/07 0:18	870.01	364,476.00	261,735.20	73,175.42	3.99	35.50	6.52	288.71	35.60	60.85	0.00	10,968.17
7/4/07 0:19	871.74	356,397.19	263,346.00	73,432.18	6.07	36.56	6.59	288.71	35.50	60.95	0.00	10,699.79
7/4/07 0:20	873.10	364,531.09	256,134.00	72,869.98	4.98	36.69	6.67	288.71	35.95	61.10	0.00	10,646.63
7/4/07 0:21	873.98	351,658.41	258,105.80	72,455.62	4.36	36.50	6.74	288.36	35.90	61.35	0.00	10,681.96
7/4/07 0:22	874.68	365,749.91	260,425.50	72,736.70	3.06	36.25	6.82	288.36	35.53	60.85	0.00	9,317.69
7/4/07 0:23	871.27	367,721.31	265,971.19	73,473.98	6.74	36.00	6.89	288.71	36.25	61.10	0.00	8,984.29
7/4/07 0:24	866.07	356,133.31	259,774.41	72,513.70	5.53	36.00	6.97	288.71	35.10	60.05	0.00	8,972.06
7/4/07 0:25	862.07	371,333.31	259,770.09	72,372.12	5.53	35.50	7.04	288.71	34.90	60.05	0.00	9,314.24
7/4/07 0:26	858.53	367,867.41	262,621.69	74,147.36	5.54	35.44	7.12	289.02	34.95	60.05	0.00	9,027.54
7/4/07 0:27	856.19	333,608.00	257,196.30	72,690.86	5.53	35.75	7.19	288.02	34.90	59.95	0.00	11,764.95
7/4/07 0:28	856.32	356,027.19	258,822.41	72,226.43	2.71	35.56	7.27	288.01	34.85	59.85	0.00	11,481.17
7/4/07 0:29	857.14	352,854.50	258,832.80	72,443.95	2.90	34.25	7.34	288.00	35.10	59.90	0.00	11,326.82
7/4/07 0:30	857.95	347,444.91	259,954.00	72,989.13	3.25	33.75	7.11	288.01	34.80	59.75	0.00	11,159.23
7/4/07 0:31	858.77	353,152.19	259,575.91	72,891.52	4.81	35.50	6.87	287.98	34.70	60.00	0.00	4,395.28
7/4/07 0:32	857.88	359,155.91	262,495.59	72,924.52	4.37	36.25	6.90	287.64	35.25	59.95	0.00	10,303.04
7/4/07 0:33	853.85	354,999.31	259,970.09	72,994.89	5.11	35.50	6.93	286.69	35.00	60.30	0.00	10,322.17
7/4/07 0:34	848.27	357,341.91	259,536.20	72,130.15	3.72	35.50	6.95	286.69	35.00	60.45	0.00	10,374.12
7/4/07 0:35	843.79	362,130.41	261,632.09	72,817.78	3.74	34.50	6.98	286.69	35.25	60.95	0.00	10,127.61
7/4/07 0:36	840.75	344,052.91	260,997.09	72,559.46	5.72	34.50	7.08	286.71	36.80	61.55	0.00	5,384.37
7/4/07 0:37	840.62	341,664.31	263,617.41	73,164.38	4.30	34.44	7.19	286.69	37.25	62.05	0.00	10,436.33

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/4/07 0:38	841.49	352,559.31	260,675.09	72,372.16	6.93	33.44	7.30	286.69	36.05	62.20	0.00	10,383.39
7/4/07 0:39	843.01	359,778.50	260,354.20	72,038.38	3.50	33.69	7.41	286.69	36.35	62.15	0.00	10,412.62
7/4/07 0:40	844.86	360,628.50	264,981.19	73,756.11	4.55	33.75	7.52	287.64	35.85	62.60	0.00	10,345.59
7/4/07 0:41	846.70	355,372.69	263,020.31	73,021.78	6.16	33.75	7.17	287.33	37.05	62.85	0.00	8,544.38
7/4/07 0:42	846.54	346,009.50	258,688.50	72,077.65	6.11	33.50	7.33	287.00	37.00	63.60	0.00	9,464.98
7/4/07 0:43	843.94	355,122.69	260,910.91	72,835.71	4.20	33.25	7.42	287.00	36.65	64.40	0.00	9,532.68
7/4/07 0:44	842.55	351,971.91	260,242.80	73,134.86	4.72	32.75	7.91	287.02	36.05	59.95	0.00	9,066.60
7/4/07 0:45	840.38	362,561.59	264,908.19	73,482.72	4.72	33.06	7.65	287.02	34.80	60.00	0.00	9,054.37
7/4/07 0:46	840.26	352,839.81	259,307.91	73,111.98	4.72	32.00	8.11	287.02	35.35	60.10	0.00	12,187.04
7/4/07 0:47	840.97	353,544.69	261,488.30	72,827.98	4.72	32.00	7.99	287.00	35.40	59.95	0.00	11,218.63
7/4/07 0:48	842.13	359,678.31	260,177.00	72,882.70	5.25	31.78	7.89	287.00	33.70	60.60	0.00	10,739.14
7/4/07 0:49	842.12	356,945.41	262,891.09	73,537.56	6.25	32.19	8.00	287.00	35.40	61.30	0.00	10,741.44
7/4/07 0:50	842.83	362,221.41	262,393.50	74,006.49	6.81	32.00	8.09	287.00	36.50	61.90	0.00	10,833.18
7/4/07 0:51	843.28	351,846.91	262,128.30	73,322.88	7.06	31.75	8.12	287.00	36.75	61.85	0.00	9,961.47
7/4/07 0:52	842.16	351,081.09	258,489.59	72,502.11	6.17	30.88	8.21	287.00	36.80	62.60	0.00	10,190.46
7/4/07 0:53	840.55	358,541.09	258,810.50	73,289.66	3.59	31.09	8.38	287.00	35.95	63.15	0.00	10,113.28
7/4/07 0:54	838.74	364,399.31	261,926.41	73,991.90	5.47	31.63	8.21	287.33	37.15	63.50	0.00	10,141.56
7/4/07 0:55	837.06	357,046.31	260,007.50	72,611.08	7.25	31.91	8.24	286.66	37.75	63.75	0.00	9,644.99
7/4/07 0:56	837.57	354,589.31	258,681.70	73,317.92	5.53	31.50	8.27	286.69	37.20	63.90	0.00	8,921.76
7/4/07 0:57	839.18	371,155.59	256,867.50	73,539.13	3.74	32.00	8.24	287.02	37.50	64.40	0.00	8,835.05
7/4/07 0:58	839.59	323,765.81	255,048.59	73,019.35	5.12	31.88	8.22	286.40	37.50	64.60	0.00	8,675.69
7/4/07 0:59	838.88	353,333.41	256,734.30	73,395.41	6.05	32.00	8.20	286.00	37.80	64.50	0.00	8,611.05
7/4/07 1:00	839.10	373,381.59	263,149.81	74,364.55	5.80	31.72	8.31	285.73	37.75	64.15	0.00	0.00
7/4/07 1:01	839.10	350,104.00	258,957.41	73,271.81	8.35	31.63	8.30	285.71	37.15	64.25	0.00	9,496.84
7/4/07 1:02	838.63	347,133.81	257,040.09	73,356.73	5.25	31.91	8.30	285.73	36.85	64.15	0.00	9,452.95
7/4/07 1:03	838.92	362,548.09	257,454.59	73,218.52	3.87	31.50	8.17	285.71	37.15	64.20	0.00	9,253.55
7/4/07 1:04	838.65	348,600.69	257,022.91	73,188.98	5.89	31.57	8.21	286.00	35.95	60.15	0.00	9,488.46
7/4/07 1:05	838.78	359,372.81	256,886.41	73,378.34	5.89	31.91	8.28	286.40	34.55	59.90	0.00	9,279.95
7/4/07 1:06	839.73	340,354.09	254,536.30	72,497.32	5.89	31.73	8.24	285.69	35.15	59.95	0.00	10,452.42
7/4/07 1:07	840.87	337,750.81	253,212.00	72,930.84	5.89	31.19	8.32	285.71	34.15	59.90	0.00	10,565.56
7/4/07 1:08	841.47	356,011.59	256,100.50	72,958.19	2.29	30.71	8.54	286.00	34.70	59.25	0.00	10,450.71
7/4/07 1:09	842.32	352,118.09	253,041.09	72,381.07	5.01	30.63	8.54	286.00	33.90	58.65	0.00	10,556.26
7/4/07 1:10	843.95	347,798.81	253,971.70	72,813.23	2.84	31.00	8.51	285.69	33.80	58.35	0.00	8,976.78
7/4/07 1:11	842.62	366,806.81	254,398.80	72,851.63	5.22	31.05	8.74	285.71	34.00	57.85	0.00	9,535.20
7/4/07 1:12	839.38	348,420.81	255,569.70	73,350.33	6.03	30.13	8.97	285.33	34.50	57.20	0.00	9,462.25
7/4/07 1:13	836.74	347,748.50	250,390.41	72,687.61	3.09	28.97	9.20	285.04	32.80	56.45	0.00	9,986.96
7/4/07 1:14	832.87	349,426.19	252,943.20	72,973.71	4.01	30.00	9.18	284.66	31.50	55.30	0.00	10,005.96
7/4/07 1:15	829.63	360,900.31	260,498.30	74,212.60	5.45	28.88	9.23	284.66	32.25	53.95	0.00	0.00
7/4/07 1:16	828.19	362,857.19	259,354.91	73,866.23	6.98	29.03	9.28	284.38	32.10	53.85	0.00	0.00
7/4/07 1:17	828.00	343,807.41	253,671.00	72,692.98	7.10	28.64	9.26	284.38	31.20	53.75	0.00	0.00
7/4/07 1:18	829.40	348,321.69	257,273.70	72,607.82	4.46	29.09	9.17	284.02	31.65	53.75	0.00	0.00
7/4/07 1:19	831.03	358,059.41	257,048.41	73,848.30	4.84	29.03	9.05	284.02	30.95	53.70	0.00	0.00
7/4/07 1:20	832.21	353,326.41	257,222.50	74,211.54	6.37	29.00	9.13	283.68	31.90	54.70	0.00	0.00
7/4/07 1:21	832.93	347,091.81	252,862.50	73,725.59	5.69	28.88	9.22	283.04	31.70	54.70	0.00	0.00
7/4/07 1:22	833.78	355,040.69	258,380.30	74,040.56	4.42	28.13	9.31	283.04	31.33	54.80	0.00	0.00
7/4/07 1:23	834.76	347,499.09	253,808.20	72,964.04	5.71	28.00	9.39	283.04	32.15	54.40	0.00	0.00
7/4/07 1:24	835.37	347,109.00	255,135.80	74,248.91	6.83	28.00	9.44	283.02	35.20	59.90	0.00	0.00
7/4/07 1:25	835.90	364,886.00	261,259.80	74,223.58	6.83	27.97	9.57	283.04	34.50	60.00	0.00	0.00
7/4/07 1:26	835.96	354,556.50	260,982.09	73,192.44	6.83	27.75	9.52	283.04	34.35	60.05	0.00	0.00
7/4/07 1:27	836.41	353,515.50	255,259.70	73,250.78	6.83	27.75	9.47	283.02	35.35	60.00	0.00	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/4/07 1:28	837.57	354,938.59	257,232.00	73,816.58	3.68	28.28	9.51	282.64	34.95	59.95	0.00	0.00
7/4/07 1:29	837.71	358,732.50	259,203.41	73,061.42	6.21	26.88	9.56	282.35	35.45	59.75	0.00	0.00
7/4/07 1:30	837.99	354,603.91	255,181.80	73,732.76	5.48	26.88	9.61	282.35	35.65	60.20	0.00	0.00
7/4/07 1:31	837.93	357,259.59	257,331.20	74,132.82	4.49	27.34	9.66	282.35	35.00	59.95	0.00	0.00
7/4/07 1:32	838.21	343,813.59	255,687.50	73,669.75	5.60	27.85	9.71	282.04	35.35	60.00	0.00	0.00
7/4/07 1:33	837.85	350,798.50	257,396.50	73,649.04	6.08	27.91	9.76	282.04	34.85	59.75	0.00	0.00
7/4/07 1:34	837.40	355,923.69	253,647.41	73,163.95	5.09	28.20	9.81	282.35	35.25	59.95	0.00	5,446.04
7/4/07 1:35	835.97	350,936.41	255,646.59	73,083.59	4.93	26.88	9.86	282.37	35.25	59.90	0.00	6,674.35
7/4/07 1:36	835.61	343,316.00	253,598.59	73,158.94	4.75	27.09	9.91	282.35	34.85	59.75	0.00	8,260.52
7/4/07 1:37	835.60	355,305.41	256,439.91	72,968.32	5.00	26.99	9.98	282.02	34.50	59.65	0.00	9,175.73
7/4/07 1:38	835.67	350,107.41	253,620.41	72,308.66	5.50	26.86	9.91	282.04	34.10	59.60	0.00	8,480.89
7/4/07 1:39	835.29	353,187.41	254,740.80	73,412.41	5.42	27.23	9.85	282.04	34.45	59.05	0.00	8,184.04
7/4/07 1:40	835.47	350,320.91	257,283.09	73,396.94	5.75	27.00	9.98	282.04	32.35	58.95	0.00	6,875.02
7/4/07 1:41	834.48	352,410.50	261,961.59	73,268.98	7.38	27.00	9.98	281.66	30.75	58.60	0.00	5,952.58
7/4/07 1:42	834.57	365,746.69	261,116.00	72,556.09	4.74	26.91	9.85	282.04	31.75	58.30	0.00	5,090.55
7/4/07 1:43	835.29	362,002.91	260,466.00	72,583.41	5.17	27.03	9.73	282.02	33.10	58.78	0.00	5,275.63
7/4/07 1:44	836.50	367,329.19	264,171.81	73,489.81	4.99	26.66	9.61	282.02	34.95	59.95	0.00	7,247.46
7/4/07 1:45	836.22	361,356.19	260,447.50	73,327.53	4.99	27.91	9.49	281.37	34.60	60.15	0.00	6,891.96
7/4/07 1:46	836.41	363,148.50	260,499.09	73,117.02	4.99	27.03	9.37	281.37	35.45	59.95	0.00	7,211.01
7/4/07 1:47	836.97	363,013.69	263,758.31	72,572.11	4.99	27.24	9.25	281.04	34.95	59.95	0.00	7,839.17
7/4/07 1:48	837.89	365,678.69	264,643.50	73,563.48	5.03	29.13	9.10	281.01	35.60	60.05	0.00	8,039.50
7/4/07 1:49	838.68	359,429.91	264,582.31	72,979.23	6.37	28.59	9.10	279.65	35.05	60.10	0.00	7,479.42
7/4/07 1:50	839.49	360,351.59	259,548.59	72,696.08	5.36	29.07	9.11	279.35	35.25	60.35	0.00	0.00
7/4/07 1:51	839.98	354,075.31	261,823.30	73,347.56	5.28	29.04	9.12	278.32	34.45	60.30	0.00	0.00
7/4/07 1:52	840.93	369,300.19	265,026.00	73,142.19	4.90	28.91	9.12	277.68	34.90	60.30	0.00	0.00
7/4/07 1:53	841.31	363,877.09	262,897.69	71,935.48	6.99	28.78	9.13	276.65	34.85	60.35	0.00	0.00
7/4/07 1:54	841.89	357,453.09	261,297.09	72,742.88	4.93	28.97	9.14	276.67	35.35	60.05	0.00	0.00
7/4/07 1:55	842.14	365,714.50	262,458.59	71,960.98	4.65	29.13	9.15	276.67	34.90	59.95	0.00	0.00
7/4/07 1:56	842.22	350,008.91	259,887.20	72,355.55	5.94	28.80	9.00	276.67	34.95	59.90	0.00	5,736.27
7/4/07 1:57	840.73	363,702.81	263,316.31	72,264.21	4.49	29.78	8.99	276.65	35.50	59.80	0.00	0.00
7/4/07 1:58	840.62	337,717.50	256,885.41	71,938.21	4.84	29.00	8.98	276.67	34.30	59.35	0.00	6,683.90
7/4/07 1:59	840.12	346,313.59	260,043.70	72,793.42	3.67	29.78	8.97	276.65	34.20	59.30	0.00	0.00
7/4/07 2:00	840.37	347,851.00	259,814.41	72,021.28	6.23	29.00	8.96	276.34	34.05	58.10	0.00	8,195.45
7/4/07 2:01	841.21	364,078.50	259,650.59	72,128.41	3.19	28.63	8.94	276.32	33.75	57.75	0.00	0.00
7/4/07 2:02	842.48	353,732.41	258,450.00	72,440.98	4.39	28.94	8.93	276.65	33.20	57.35	0.00	4,151.93
7/4/07 2:03	842.81	358,982.31	262,521.81	72,265.96	6.00	29.84	8.92	276.65	34.10	56.50	0.00	0.00
7/4/07 2:04	842.81	335,101.00	258,435.50	71,675.98	3.58	29.00	8.92	276.65	35.60	60.05	0.00	0.00
7/4/07 2:05	842.01	349,062.50	261,830.41	72,176.67	3.58	29.63	8.94	277.03	35.05	60.00	0.00	0.00
7/4/07 2:06	842.36	354,017.31	260,192.00	73,177.44	3.58	29.88	8.96	277.34	34.90	60.20	0.00	0.00
7/4/07 2:07	843.25	358,929.91	262,877.09	72,659.28	3.58	29.00	8.97	277.34	35.30	60.05	0.00	4,690.08
7/4/07 2:08	842.49	344,010.91	257,310.00	72,395.24	6.65	29.75	9.05	277.34	34.35	59.40	0.00	0.00
7/4/07 2:09	842.11	354,837.31	260,575.50	72,499.86	4.34	30.00	9.06	277.34	34.55	58.95	0.00	6,802.64
7/4/07 2:10	841.90	380,884.31	261,549.09	72,258.76	5.90	29.38	9.07	277.34	34.20	58.80	0.00	0.00
7/4/07 2:11	842.46	349,262.50	256,510.30	72,118.72	6.09	29.50	9.08	277.03	33.55	57.80	0.00	6,679.93
7/4/07 2:12	841.29	348,333.31	255,373.80	72,026.59	6.38	29.75	9.09	277.03	33.15	57.25	0.00	0.00
7/4/07 2:13	840.43	358,406.81	259,248.91	71,807.98	4.46	29.34	9.10	276.34	32.80	56.40	0.00	9,963.60
7/4/07 2:14	839.01	336,796.09	256,881.30	71,642.94	5.77	28.63	9.11	276.34	32.60	56.30	0.00	0.00
7/4/07 2:15	840.02	360,589.41	256,231.91	72,449.54	3.33	28.75	9.12	277.03	32.40	55.20	0.00	3,065.90
7/4/07 2:16	840.03	347,026.59	255,521.30	72,380.88	7.01	28.75	9.13	277.34	33.20	54.80	0.00	0.00
7/4/07 2:17	839.57	347,467.00	252,090.20	71,966.10	6.38	29.44	9.14	277.34	31.55	54.10	0.00	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/4/07 2:18	839.47	350,150.00	256,074.00	73,167.34	4.03	28.18	9.15	277.34	31.05	53.70	0.00	4,129.76
7/4/07 2:19	840.15	349,290.50	257,982.20	72,763.56	3.82	27.88	9.16	278.32	31.90	54.25	0.00	0.00
7/4/07 2:20	839.20	347,151.19	253,946.30	73,082.22	7.02	28.56	9.17	278.32	30.75	53.80	0.00	6,352.82
7/4/07 2:21	838.22	345,233.81	253,748.80	72,193.89	6.02	28.66	9.18	278.01	31.85	53.95	0.00	0.00
7/4/07 2:22	838.64	355,156.91	255,959.70	72,455.04	4.61	28.50	9.32	278.01	32.17	54.30	0.00	5,833.90
7/4/07 2:23	837.99	354,314.19	255,643.70	73,179.17	6.50	27.82	9.53	278.34	31.88	54.20	0.00	0.00
7/4/07 2:24	837.74	352,603.31	253,383.50	72,266.36	5.70	28.13	9.62	278.70	35.35	59.75	0.00	6,996.02
7/4/07 2:25	837.48	337,684.00	251,841.70	72,214.41	5.70	27.25	9.71	278.32	35.15	59.90	0.00	0.00
7/4/07 2:26	837.60	354,751.69	254,901.80	73,632.52	5.70	26.80	9.81	278.30	35.45	60.00	0.00	0.00
7/4/07 2:27	837.37	342,296.19	250,311.80	73,254.73	5.70	27.39	10.00	278.32	34.55	59.95	0.00	0.00
7/4/07 2:28	837.22	337,932.31	248,878.00	72,215.57	5.30	27.97	9.96	278.03	34.55	59.30	0.00	0.00
7/4/07 2:29	837.80	350,858.41	250,877.09	72,714.51	4.11	27.84	9.92	277.99	34.15	58.65	0.00	4,020.36
7/4/07 2:30	838.32	357,574.59	254,375.91	73,891.40	5.81	27.78	9.88	277.68	33.90	57.60	0.00	0.00
7/4/07 2:31	837.36	337,254.91	247,062.91	72,811.53	9.11	28.09	9.83	277.03	32.80	56.80	0.00	6,244.66
7/4/07 2:32	836.66	352,685.31	256,680.30	71,820.13	4.43	28.00	9.79	277.03	32.45	56.40	0.00	0.00
7/4/07 2:33	837.95	368,131.59	265,869.09	72,914.41	4.05	27.00	9.71	277.01	32.35	55.25	0.00	6,941.21
7/4/07 2:34	839.59	368,502.59	265,126.50	71,882.73	6.35	26.97	9.69	277.68	32.25	54.65	0.00	0.00
7/4/07 2:35	841.20	351,835.41	263,506.31	73,202.45	6.33	27.97	9.67	278.32	31.55	54.55	0.00	8,821.45
7/4/07 2:36	842.87	363,990.81	262,313.41	72,514.89	4.33	28.12	9.64	279.01	31.25	54.10	0.00	0.00
7/4/07 2:37	844.63	361,068.59	261,414.70	72,057.88	4.74	27.88	9.55	278.68	31.15	53.85	0.00	8,641.88
7/4/07 2:38	845.09	357,292.59	260,813.50	72,880.70	4.77	27.97	9.55	278.70	30.95	54.00	0.00	0.00
7/4/07 2:39	845.53	364,269.00	262,329.69	73,273.38	6.38	28.00	9.55	279.32	31.35	54.10	0.00	0.00
7/4/07 2:40	845.77	363,529.41	260,079.30	73,277.54	6.79	27.88	9.55	279.01	31.50	54.00	0.00	1,789.28
7/4/07 2:41	846.37	367,383.19	264,751.69	73,760.23	5.10	28.13	9.59	279.35	30.75	53.95	0.00	0.00
7/4/07 2:42	846.61	362,743.59	262,918.09	73,871.93	7.47	27.95	9.57	279.65	31.30	54.00	0.00	6,136.54
7/4/07 2:43	846.65	359,774.19	260,505.09	73,150.33	6.33	27.97	9.55	279.65	31.90	54.35	0.00	0.00
7/4/07 2:44	847.56	349,696.09	258,461.50	73,010.11	4.99	28.00	9.53	279.65	35.70	59.80	0.00	8,262.50
7/4/07 2:45	847.82	363,181.41	261,193.09	73,872.46	4.99	27.75	9.50	279.65	35.05	59.85	0.00	0.00
7/4/07 2:46	848.31	341,482.59	255,996.09	73,327.34	4.99	27.97	9.48	279.65	34.25	59.85	0.00	9,902.83
7/4/07 2:47	848.05	347,235.19	260,610.59	73,810.43	4.99	27.97	9.46	279.65	35.50	60.05	0.00	0.00
7/4/07 2:48	848.60	356,189.09	257,119.20	73,427.13	7.04	27.88	9.45	280.01	34.75	59.35	0.00	0.00
7/4/07 2:49	848.91	357,111.59	255,824.70	73,555.33	5.24	27.51	9.47	280.01	34.50	58.40	0.00	2,090.09
7/4/07 2:50	847.93	357,472.91	262,338.81	73,463.73	6.70	28.00	9.49	280.35	32.80	58.30	0.00	0.00
7/4/07 2:51	847.59	345,254.00	255,479.59	72,831.34	6.27	27.55	9.51	280.04	33.10	57.65	0.00	5,665.46
7/4/07 2:52	847.39	359,315.59	257,867.70	73,627.56	3.73	27.03	9.53	280.04	33.00	57.30	0.00	0.00
7/4/07 2:53	846.82	341,823.31	255,239.80	73,090.02	6.79	27.00	9.55	280.04	32.60	56.95	0.00	5,811.95
7/4/07 2:54	846.51	355,064.31	254,695.59	73,088.30	4.66	26.97	9.57	280.35	32.30	56.15	0.00	0.00
7/4/07 2:55	847.26	350,383.09	255,381.50	72,956.12	3.38	27.00	9.59	280.37	32.75	55.45	0.00	6,384.56
7/4/07 2:56	847.82	345,946.31	252,878.59	73,120.63	5.77	26.88	9.61	280.35	32.40	55.30	0.00	0.00
7/4/07 2:57	848.58	343,032.50	255,627.59	73,884.37	5.31	27.03	9.63	280.35	32.65	54.95	0.00	10,558.78
7/4/07 2:58	849.29	349,855.59	256,655.70	74,017.63	4.73	27.09	9.65	280.73	31.40	54.40	0.00	0.00
7/4/07 2:59	849.32	350,137.00	253,087.30	73,242.30	6.04	27.00	9.67	280.35	31.50	54.05	0.00	1,076.75
7/4/07 3:00	848.97	352,188.59	253,816.80	73,106.85	4.83	27.00	9.69	280.35	31.25	53.80	0.00	0.00
7/4/07 3:01	849.49	353,051.91	255,522.00	73,560.62	3.64	26.00	9.71	280.35	31.35	54.20	0.00	0.00
7/4/07 3:02	850.02	348,625.59	250,950.00	72,945.36	5.27	26.88	9.73	280.70	31.60	54.05	0.00	2,963.45
7/4/07 3:03	850.60	351,446.19	254,410.50	73,550.00	4.52	27.46	9.75	280.70	31.65	53.75	0.00	0.00
7/4/07 3:04	850.98	349,150.00	254,800.09	73,941.43	5.86	26.78	9.77	280.73	35.10	60.10	0.00	6,366.35
7/4/07 3:05	850.81	343,475.19	252,454.41	73,255.66	5.86	27.09	9.79	280.73	35.00	60.10	0.00	0.00
7/4/07 3:06	851.59	339,399.41	250,246.70	73,265.50	5.86	27.05	9.81	281.04	34.80	60.40	0.00	8,937.12
7/4/07 3:07	851.34	360,989.50	257,464.59	73,765.06	5.86	26.88	9.83	281.04	35.40	60.10	0.00	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/4/07 3:08	851.61	340,757.50	250,208.70	73,167.67	6.56	26.75	9.83	281.37	35.10	59.10	0.00	10,459.47
7/4/07 3:09	851.30	347,413.31	253,016.80	74,112.63	4.76	27.00	9.87	281.37	35.30	58.50	0.00	0.00
7/4/07 3:10	850.35	354,741.00	252,691.80	72,699.20	4.69	26.69	9.90	281.37	35.00	57.50	0.00	0.00
7/4/07 3:11	848.81	368,310.19	254,915.41	73,370.92	6.09	27.00	9.93	281.04	33.45	57.30	0.00	1,246.47
7/4/07 3:12	847.22	349,386.41	249,377.41	72,670.34	7.86	26.25	9.97	281.06	33.20	56.30	0.00	0.00
7/4/07 3:13	846.57	350,757.31	251,872.09	72,864.80	4.89	26.38	10.00	280.73	33.00	56.50	0.00	6,418.07
7/4/07 3:14	846.63	341,866.81	248,400.09	72,902.98	4.44	26.38	10.03	281.04	32.10	55.10	0.00	0.00
7/4/07 3:15	845.73	343,364.59	252,333.20	73,134.73	5.15	26.25	10.03	281.04	31.60	54.20	0.00	8,239.42
7/4/07 3:16	845.00	359,089.50	254,821.20	73,686.54	5.43	26.22	10.10	281.37	31.50	53.80	0.00	0.00
7/4/07 3:17	845.34	340,500.31	252,847.91	72,802.31	7.71	25.50	10.16	281.37	32.80	53.60	0.00	8,558.19
7/4/07 3:18	846.11	363,781.59	258,101.09	73,452.89	4.43	25.14	10.23	282.35	33.30	54.20	0.00	0.00
7/4/07 3:19	847.23	372,320.81	266,017.50	73,219.76	6.72	25.38	10.30	282.64	31.70	53.90	0.00	3,988.81
7/4/07 3:20	847.54	351,703.09	256,581.91	72,856.39	8.82	25.16	10.36	282.64	30.00	53.90	0.00	0.00
7/4/07 3:21	848.94	359,447.81	256,457.09	72,737.25	4.45	25.38	10.43	282.64	31.60	54.30	0.00	0.00
7/4/07 3:22	850.29	358,329.00	254,126.50	73,368.55	5.29	25.25	10.49	282.64	31.90	53.80	0.00	3,491.56
7/4/07 3:23	850.16	346,806.19	253,374.50	72,839.13	6.13	25.50	10.56	282.02	32.10	53.70	0.00	0.00
7/4/07 3:24	850.35	357,908.09	261,025.41	73,729.61	4.76	24.78	10.63	282.02	34.70	60.05	0.00	8,167.94
7/4/07 3:25	850.74	345,443.50	252,437.91	73,037.28	4.76	24.63	10.75	282.35	35.20	59.90	0.00	0.00
7/4/07 3:26	851.18	347,782.41	256,047.70	73,870.36	4.76	25.04	10.72	282.64	35.70	60.00	0.00	8,792.12
7/4/07 3:27	850.51	358,382.41	258,159.20	73,158.61	4.76	24.91	10.69	283.33	35.70	60.00	0.00	0.00
7/4/07 3:28	850.80	360,593.00	256,637.50	72,654.04	6.05	24.29	10.65	283.33	35.40	59.10	0.00	2,759.18
7/4/07 3:29	850.25	352,828.69	255,395.00	72,721.52	6.61	23.72	10.62	282.64	34.50	59.40	0.00	0.00
7/4/07 3:30	850.63	352,052.09	252,942.91	72,585.35	6.21	24.50	10.59	283.04	34.10	58.10	0.00	0.00
7/4/07 3:31	851.19	352,202.69	255,547.70	73,313.69	3.57	24.81	10.56	283.04	34.30	58.40	0.00	4,812.95
7/4/07 3:32	850.92	345,989.91	253,694.41	72,068.70	7.24	25.50	10.52	283.04	33.30	57.80	0.00	0.00
7/4/07 3:33	850.84	337,435.69	250,155.59	71,873.59	5.13	26.00	10.49	283.04	35.60	57.60	0.00	5,988.31
7/4/07 3:34	851.27	351,369.81	253,485.50	72,772.70	4.35	25.03	10.46	283.04	33.30	57.90	0.00	0.00
7/4/07 3:35	851.83	349,734.50	254,525.00	73,347.13	7.09	24.75	10.43	283.02	32.50	56.60	0.00	8,635.39
7/4/07 3:36	851.20	352,099.00	252,678.50	72,823.57	7.32	25.22	10.39	283.33	34.10	57.20	0.00	0.00
7/4/07 3:37	851.40	350,868.31	256,158.50	73,872.02	6.61	24.88	10.36	283.68	32.20	55.40	0.00	0.00
7/4/07 3:38	852.54	355,819.19	250,286.41	72,700.20	4.83	24.88	10.33	283.68	33.30	54.90	0.00	0.00
7/4/07 3:39	852.69	342,950.69	250,276.59	73,236.20	5.68	25.75	10.29	283.33	33.40	54.80	0.00	0.00
7/4/07 3:40	852.51	336,796.41	249,708.20	72,799.49	5.55	25.02	10.41	283.30	31.50	54.90	0.00	0.00
7/4/07 3:41	853.23	345,475.31	250,149.50	72,170.71	4.39	25.00	10.56	283.04	31.90	54.20	0.00	0.00
7/4/07 3:42	854.38	356,723.91	254,071.20	73,934.34	4.60	24.88	10.52	283.33	31.80	54.40	0.00	0.00
7/4/07 3:43	855.37	344,130.31	250,417.59	72,992.59	6.76	24.88	10.49	283.33	32.20	53.60	0.00	0.00
7/4/07 3:44	855.77	353,767.59	249,074.30	74,028.55	3.96	25.67	10.45	283.02	35.20	59.90	0.00	0.00
7/4/07 3:45	854.75	341,785.31	250,000.00	73,266.17	3.96	25.75	10.42	283.33	35.60	60.00	0.00	6,761.52
7/4/07 3:46	854.06	357,095.91	250,555.30	73,262.02	3.96	25.65	10.38	283.33	33.20	60.10	0.00	9,380.16
7/4/07 3:47	853.76	343,511.19	249,092.30	73,028.20	3.96	24.92	10.35	283.71	35.30	59.80	0.00	8,327.99
7/4/07 3:48	854.72	346,000.00	249,248.91	73,237.88	5.52	25.00	10.31	283.68	34.40	59.20	0.00	8,299.78
7/4/07 3:49	855.36	337,510.09	249,981.00	73,261.52	4.92	26.03	10.28	283.68	34.40	59.40	0.00	7,287.89
7/4/07 3:50	856.11	342,770.19	250,682.09	72,706.19	4.15	25.70	10.24	283.99	34.50	58.70	0.00	6,569.72
7/4/07 3:51	856.87	350,653.09	256,004.00	73,847.27	5.14	24.75	10.20	284.02	35.60	58.70	0.00	6,076.29
7/4/07 3:52	857.02	348,578.69	250,802.00	73,396.52	6.91	25.88	10.17	284.61	35.70	58.00	0.00	5,973.88
7/4/07 3:53	856.93	339,354.69	250,239.41	73,518.66	6.52	26.00	10.13	284.66	34.90	58.40	0.00	5,821.92
7/4/07 3:54	857.13	357,027.31	251,382.30	73,035.33	3.97	25.88	10.10	284.02	32.90	57.80	0.00	6,302.77
7/4/07 3:55	857.04	341,973.09	249,491.70	72,746.42	5.51	25.88	9.94	284.02	33.20	57.80	0.00	7,484.90
7/4/07 3:56	857.00	339,825.41	251,016.80	72,596.00	4.17	27.00	9.77	283.68	32.90	57.00	0.00	7,190.48
7/4/07 3:57	857.25	344,057.59	249,336.91	72,533.82	4.22	27.00	9.76	283.68	32.60	56.60	0.00	8,172.77

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/4/07 3:58	857.25	336,024.41	248,660.80	72,092.84	5.09	27.13	9.73	282.64	32.50	56.70	0.00	7,783.55
7/4/07 3:59	857.09	336,205.91	249,563.00	72,785.66	4.65	27.97	9.69	282.64	33.10	56.50	0.00	6,006.63
7/4/07 4:00	857.29	352,767.41	254,247.50	73,395.60	3.86	27.00	9.63	282.02	32.20	56.00	0.00	4,144.16
7/4/07 4:01	857.59	342,452.59	249,890.91	73,363.34	5.93	28.03	9.56	281.68	32.50	54.60	0.00	0.00
7/4/07 4:02	857.78	355,391.91	250,045.50	72,324.65	5.61	27.94	9.48	280.70	33.90	55.40	0.00	0.00
7/4/07 4:03	857.50	337,428.09	249,409.80	72,098.78	5.37	27.34	9.41	280.70	31.90	54.40	0.00	0.00
7/4/07 4:04	857.30	342,661.81	250,046.20	72,408.94	4.28	28.25	9.42	280.70	34.70	60.00	0.00	0.00
7/4/07 4:05	857.08	344,535.31	248,782.50	72,039.07	4.28	27.41	9.40	280.04	34.80	60.20	0.00	0.00
7/4/07 4:06	857.10	340,216.81	249,087.50	72,699.98	4.28	27.88	9.37	279.68	35.00	60.00	0.00	0.00
7/4/07 4:07	857.78	341,622.09	248,275.20	72,296.81	4.28	27.00	12.32	278.89	34.50	59.70	0.00	0.00
7/4/07 4:08	858.75	337,136.41	247,857.09	72,260.31	3.90	27.18	12.42	278.34	35.00	59.90	0.00	0.00
7/4/07 4:09	859.19	346,698.41	249,469.00	71,995.35	4.84	27.88	12.52	276.67	35.30	59.80	0.00	0.00
7/4/07 4:10	860.12	352,304.59	249,529.30	72,726.79	4.08	27.97	12.62	276.01	34.90	59.90	0.00	0.00
7/4/07 4:11	860.97	348,710.50	247,403.41	72,400.13	6.92	26.88	12.72	275.34	34.70	59.70	0.00	0.00
7/4/07 4:12	860.99	342,633.59	246,738.91	72,371.52	4.84	27.88	12.83	275.34	35.10	59.50	0.00	0.00
7/4/07 4:13	860.90	341,225.50	244,648.59	72,541.12	3.69	26.97	12.93	274.65	34.30	59.50	0.00	0.00
7/4/07 4:14	860.94	342,305.81	248,860.20	73,074.69	3.63	26.88	13.03	275.01	34.10	59.20	0.00	0.00
7/4/07 4:15	861.39	337,107.81	244,865.50	72,094.42	6.51	26.88	13.13	274.31	34.90	59.10	0.00	0.00
7/4/07 4:16	861.02	333,444.91	247,252.20	72,904.65	3.33	26.75	13.23	274.31	34.70	58.60	0.00	0.00
7/4/07 4:17	861.12	344,755.09	247,246.91	72,854.52	6.01	27.00	13.33	274.65	33.60	57.90	0.00	0.00
7/4/07 4:18	862.40	352,716.00	254,000.41	73,597.98	4.25	25.74	13.48	274.31	33.80	58.20	0.00	0.00
7/4/07 4:19	863.07	340,896.59	244,498.70	72,181.94	7.03	26.23	13.59	274.31	33.90	58.00	0.00	0.00
7/4/07 4:20	863.26	344,927.69	246,912.20	73,116.74	3.80	27.01	13.58	274.34	33.90	57.40	0.00	0.00
7/4/07 4:21	863.98	340,846.09	241,436.20	72,820.03	4.29	26.00	13.58	274.62	32.70	57.90	0.00	0.00
7/4/07 4:22	864.50	336,537.91	244,429.30	72,890.97	3.53	25.88	13.57	274.62	35.50	57.50	0.00	0.00
7/4/07 4:23	865.34	343,769.09	243,710.20	72,585.98	3.60	25.81	13.57	274.62	33.80	57.00	0.00	0.00
7/4/07 4:24	865.34	331,904.81	242,502.00	72,474.02	7.17	27.00	13.56	274.62	35.40	59.90	0.00	0.00
7/4/07 4:25	865.34	335,151.41	244,309.70	72,877.02	7.17	26.30	13.56	274.31	34.30	59.90	0.00	0.00
7/4/07 4:26	865.87	349,114.81	246,900.41	73,202.06	7.17	25.88	13.55	274.31	34.90	60.10	0.00	0.00
7/4/07 4:27	865.82	343,399.81	245,424.30	72,559.58	7.17	25.88	13.59	274.31	35.80	59.90	0.00	0.00
7/4/07 4:28	865.82	339,777.59	243,839.20	72,467.95	5.68	26.47	13.63	275.01	34.70	59.50	0.00	0.00
7/4/07 4:29	866.32	345,725.81	245,059.09	72,736.93	3.83	26.88	13.67	275.34	36.10	59.60	0.00	0.00
7/4/07 4:30	865.43	333,046.69	241,438.20	72,973.80	5.82	26.75	13.71	275.34	36.10	59.70	0.00	0.00
7/4/07 4:31	865.17	347,867.69	250,869.91	73,033.79	3.70	26.63	13.75	275.36	35.40	59.60	0.00	0.00
7/4/07 4:32	864.47	334,529.50	241,507.41	72,276.97	7.14	26.59	13.79	275.34	35.10	60.10	0.00	0.00
7/4/07 4:33	864.07	334,436.59	243,437.00	71,887.56	4.38	26.57	13.83	275.34	34.70	59.40	0.00	0.00
7/4/07 4:34	863.98	336,888.69	243,377.50	72,542.51	3.74	26.31	13.87	275.70	34.20	59.30	0.00	0.00
7/4/07 4:35	864.58	338,349.41	241,290.00	72,598.83	6.15	25.51	13.91	276.32	34.10	59.40	0.00	0.00
7/4/07 4:36	865.09	344,834.91	243,506.91	72,859.67	5.05	25.56	13.95	276.34	35.80	59.40	0.00	0.00
7/4/07 4:37	864.19	339,884.19	241,783.00	72,246.27	8.51	26.00	13.99	277.01	34.70	59.40	0.00	0.00
7/4/07 4:38	863.59	351,534.69	240,291.80	71,913.00	5.79	25.22	14.03	276.65	34.90	59.20	0.00	0.00
7/4/07 4:39	863.83	334,344.69	238,878.30	71,916.87	4.87	24.88	14.07	276.67	35.10	58.60	0.00	0.00
7/4/07 4:40	863.39	330,335.09	240,688.80	72,586.98	5.23	25.00	14.11	276.65	34.00	58.70	0.00	0.00
7/4/07 4:41	862.36	341,455.31	240,776.59	72,473.44	5.02	24.75	14.15	277.34	35.10	58.80	0.00	0.00
7/4/07 4:42	862.30	334,842.19	240,529.70	72,303.38	4.56	24.50	14.20	277.34	34.60	58.30	0.00	0.00
7/4/07 4:43	862.39	333,176.50	243,841.70	72,040.62	5.23	24.13	14.24	277.68	33.90	58.70	0.00	0.00
7/4/07 4:44	861.73	313,411.69	238,169.80	72,221.75	4.67	23.97	14.28	277.70	35.80	59.70	0.00	0.00
7/4/07 4:45	861.56	343,467.00	243,521.50	73,180.35	4.67	23.85	14.32	278.01	35.10	60.00	0.00	0.00
7/4/07 4:46	861.35	339,822.31	238,425.41	71,492.56	4.67	24.00	14.36	277.99	34.80	60.00	0.00	0.00
7/4/07 4:47	861.79	341,334.31	240,017.80	71,706.35	4.67	23.75	14.40	278.01	34.80	59.90	0.00	0.00

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/4/07 4:48	861.84	331,052.09	235,752.70	71,639.49	5.27	23.89	14.44	278.32	34.90	60.40	0.00	0.00
7/4/07 4:49	861.59	350,272.81	247,597.80	72,789.88	4.06	23.03	14.48	278.70	34.60	59.80	0.00	0.00
7/4/07 4:50	861.71	332,193.59	234,311.50	71,740.15	6.14	22.88	14.52	278.68	35.30	59.50	0.00	0.00
7/4/07 4:51	862.03	332,383.50	237,316.00	72,423.27	3.53	22.66	14.56	279.01	35.10	59.60	0.00	0.00
7/4/07 4:52	861.75	328,402.69	237,133.41	71,982.49	5.76	22.92	14.60	279.01	34.10	59.20	0.00	0.00
7/4/07 4:53	861.35	335,935.91	240,349.80	72,230.42	5.04	22.81	14.64	279.01	33.50	58.80	0.00	0.00
7/4/07 4:54	860.75	337,070.00	239,615.50	72,755.80	7.77	23.00	14.68	278.68	34.50	58.80	0.00	0.00
7/4/07 4:55	860.85	341,308.19	238,730.09	71,883.41	6.92	22.00	14.72	278.68	32.60	57.30	0.00	0.00
7/4/07 4:56	860.81	330,634.31	237,776.30	72,303.28	6.51	22.86	14.76	278.68	32.30	57.50	0.00	0.00
7/4/07 4:57	860.48	335,266.09	238,904.50	72,130.93	4.82	22.78	14.80	278.68	33.50	57.20	0.00	0.00
7/4/07 4:58	860.57	332,084.91	237,321.59	72,446.49	4.35	22.22	14.84	278.70	33.10	56.10	0.00	0.00
7/4/07 4:59	860.96	334,389.31	238,473.91	72,809.00	4.20	22.00	14.88	278.61	33.70	56.50	0.00	0.00
7/4/07 5:00	860.66	331,726.19	239,933.30	72,627.03	6.41	21.88	14.92	278.01	32.20	55.30	0.00	0.00
7/4/07 5:01	860.53	356,851.91	241,573.91	72,516.37	4.94	21.88	14.96	278.32	32.00	55.60	0.00	0.00
7/4/07 5:02	860.56	331,060.19	238,118.50	73,148.45	5.54	21.09	15.00	278.32	31.50	55.10	0.00	0.00
7/4/07 5:03	860.23	337,172.69	239,053.41	73,109.47	6.02	22.00	15.04	278.32	32.10	54.90	0.00	0.00
7/4/07 5:04	859.72	337,469.31	238,249.30	73,040.83	4.48	21.83	15.08	278.01	35.30	60.10	0.00	0.00
7/4/07 5:05	860.07	332,849.09	238,507.41	73,678.19	4.48	20.91	15.12	278.32	33.50	59.80	0.00	0.00
7/4/07 5:06	860.30	334,705.41	236,590.09	72,977.36	4.48	22.62	15.16	278.32	35.90	59.80	0.00	0.00
7/4/07 5:07	860.40	331,354.69	239,253.59	73,520.41	4.48	22.88	15.05	278.70	34.60	60.00	0.00	0.00
7/4/07 5:08	860.94	343,604.69	243,383.91	74,213.80	5.62	22.13	14.93	278.01	34.90	59.50	0.00	0.00
7/4/07 5:09	861.38	351,052.59	248,110.20	74,256.75	6.41	21.75	14.82	278.01	36.00	59.20	0.00	0.00
7/4/07 5:10	861.41	342,563.19	238,294.20	73,620.96	7.25	22.78	14.71	277.70	32.90	58.10	0.00	0.00
7/4/07 5:11	861.39	335,774.81	239,871.80	73,403.64	4.03	22.86	14.60	277.70	33.20	58.00	0.00	0.00
7/4/07 5:12	861.33	334,931.59	239,194.59	73,218.34	4.69	23.00	14.48	276.67	33.20	56.90	0.00	0.00
7/4/07 5:13	860.48	332,001.41	239,597.30	74,791.39	4.43	22.72	14.37	276.03	33.20	56.90	0.00	0.00
7/4/07 5:14	859.80	327,968.00	231,844.00	73,776.91	5.54	23.13	14.25	275.70	32.10	56.60	0.00	0.00
7/4/07 5:15	859.89	330,027.91	232,405.50	74,935.46	2.50	22.47	14.02	276.01	33.20	54.80	0.00	0.00
7/4/07 5:16	859.28	326,878.91	233,559.80	74,221.88	5.23	22.63	13.79	275.70	31.10	55.30	0.00	0.00
7/4/07 5:17	857.90	324,560.00	234,023.00	74,464.80	6.10	23.13	13.68	275.70	31.00	54.50	0.00	0.00
7/4/07 5:18	856.86	335,059.50	239,279.41	73,702.63	4.30	22.03	13.65	275.70	31.00	54.40	0.00	0.00
7/4/07 5:19	857.16	366,371.19	255,904.30	74,380.01	4.02	21.97	13.61	276.56	31.60	54.00	0.00	0.00
7/4/07 5:20	857.60	341,399.31	245,305.41	73,522.76	8.11	21.97	13.58	276.67	32.10	53.80	0.00	14,480.33
7/4/07 5:21	858.43	342,153.91	245,415.91	73,465.34	5.20	22.88	13.55	276.67	30.60	54.40	0.00	13,709.46
7/4/07 5:22	861.22	346,134.50	248,296.30	73,565.05	2.79	22.72	13.52	277.34	31.10	54.10	0.00	13,750.21
7/4/07 5:23	863.95	334,052.69	247,825.80	74,718.38	3.64	22.65	13.49	277.37	31.60	53.80	0.00	13,742.06
7/4/07 5:24	865.27	317,227.69	249,010.30	74,530.78	4.39	23.86	13.45	277.68	34.50	59.80	0.00	10,918.24
7/4/07 5:25	865.50	355,558.91	251,106.41	74,056.98	4.39	23.03	13.80	277.70	34.60	60.10	0.00	11,802.88
7/4/07 5:26	861.97	361,129.50	249,678.91	73,595.92	4.39	23.41	13.71	278.15	35.00	60.00	0.00	11,288.29
7/4/07 5:27	859.25	350,045.91	249,742.80	74,033.80	4.39	23.88	13.65	278.70	34.50	59.90	0.00	11,192.44
7/4/07 5:28	857.42	345,883.00	247,948.91	73,325.20	5.21	24.13	13.60	278.68	36.10	59.70	0.00	11,582.59
7/4/07 5:29	853.45	352,370.59	257,600.59	74,796.40	3.99	22.91	13.54	279.01	34.50	59.20	0.00	5,961.27
7/4/07 5:30	852.03	340,030.00	250,463.80	73,345.43	6.30	23.13	13.49	278.70	33.70	58.40	0.00	11,398.78
7/4/07 5:31	853.64	351,121.81	253,618.09	74,485.55	4.03	23.86	13.43	278.32	35.20	58.20	0.00	11,155.14
7/4/07 5:32	855.87	345,663.19	251,808.20	73,761.07	7.02	25.02	13.37	278.70	34.00	58.00	0.00	10,727.70
7/4/07 5:33	859.19	360,652.41	254,856.41	73,132.91	4.84	25.50	13.32	278.70	34.30	57.40	0.00	10,666.34
7/4/07 5:34	862.42	358,019.41	251,644.59	74,110.64	5.21	26.00	13.26	278.68	33.40	57.40	0.00	574.97
7/4/07 5:35	861.94	332,256.81	252,177.30	73,856.67	4.79	26.13	13.20	278.32	33.90	57.50	0.00	9,111.12
7/4/07 5:36	859.06	346,817.81	249,999.00	73,050.30	4.97	25.72	13.15	278.01	34.30	57.00	0.00	8,513.52
7/4/07 5:37	857.35	346,667.19	252,651.80	73,119.88	3.10	25.72	13.09	278.01	33.20	56.10	0.00	9,071.05

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/4/07 5:38	856.16	357,370.59	253,247.80	73,500.49	4.70	26.00	13.04	278.32	32.00	56.50	0.00	9,035.96
7/4/07 5:39	854.78	349,955.59	257,786.30	74,651.39	5.00	27.13	12.98	278.30	33.90	56.80	0.00	10,032.88
7/4/07 5:40	855.43	348,402.41	255,070.30	74,086.20	7.40	26.88	12.92	278.32	32.60	57.00	0.00	10,628.08
7/4/07 5:41	856.78	363,468.81	256,910.59	74,312.80	5.09	26.88	12.87	278.32	33.60	57.10	0.00	10,427.71
7/4/07 5:42	857.87	351,673.31	253,815.41	73,570.05	7.78	27.03	12.81	278.30	33.20	55.80	0.00	10,386.17
7/4/07 5:43	861.00	380,291.19	264,710.81	74,509.66	4.32	27.16	12.76	278.32	32.90	55.70	0.00	10,485.51
7/4/07 5:44	862.86	344,611.69	251,064.41	73,557.80	6.04	27.26	12.70	278.32	34.10	60.10	0.00	9,061.53
7/4/07 5:45	861.16	340,925.41	254,425.70	74,136.02	6.04	27.47	12.68	278.01	35.30	60.10	0.00	8,799.06
7/4/07 5:46	859.32	354,768.09	256,521.09	73,548.37	6.04	26.84	12.67	277.37	34.70	60.00	0.00	8,912.32
7/4/07 5:47	858.75	358,493.09	261,819.30	73,821.12	6.04	27.76	12.66	277.01	34.70	60.00	0.00	9,070.90
7/4/07 5:48	857.60	371,553.50	262,736.31	74,411.95	5.04	28.13	12.64	277.03	35.10	60.20	0.00	8,999.23
7/4/07 5:49	856.22	350,413.59	254,809.41	73,640.22	6.69	27.86	12.63	276.01	35.50	59.70	0.00	11,846.56
7/4/07 5:50	856.00	340,975.31	256,337.30	73,806.49	3.78	27.78	12.61	276.36	35.30	59.40	0.00	10,531.93
7/4/07 5:51	856.63	367,140.81	255,836.30	73,135.77	2.96	27.88	12.60	276.34	35.50	58.90	0.00	10,473.53
7/4/07 5:52	857.54	365,503.09	263,522.50	74,221.17	4.13	28.70	12.58	277.03	34.90	58.80	0.00	10,462.52
7/4/07 5:53	858.17	360,485.09	260,790.91	73,670.93	5.90	28.77	12.57	277.32	34.10	58.00	0.00	10,511.88
7/4/07 5:54	858.08	361,864.31	265,749.41	74,107.56	5.60	28.13	12.65	277.68	33.50	58.10	0.00	9,110.98
7/4/07 5:55	857.44	384,198.00	261,046.20	74,526.15	6.83	27.84	12.65	277.34	33.50	58.00	0.00	8,201.13
7/4/07 5:56	856.46	355,890.50	260,530.09	74,639.13	6.60	28.75	12.64	277.34	34.90	58.40	0.00	8,950.34
7/4/07 5:57	855.70	357,782.91	260,247.50	73,902.30	4.47	28.25	12.64	277.03	34.10	58.20	0.00	8,861.09
7/4/07 5:58	854.67	342,749.09	258,049.70	73,261.25	4.11	28.00	12.64	277.01	32.80	57.70	0.00	8,582.78
7/4/07 5:59	854.99	361,146.91	261,231.91	73,851.43	4.45	28.53	12.37	276.67	34.10	58.30	0.00	12,733.96
7/4/07 6:00	858.55	360,748.69	262,100.91	73,715.28	4.42	28.75	12.38	276.67	33.40	57.70	0.00	12,765.62
7/4/07 6:01	862.18	365,302.19	268,487.00	74,267.39	5.45	28.91	12.39	276.67	33.40	57.50	0.00	12,521.54
7/4/07 6:02	864.32	352,585.81	260,557.00	73,895.68	6.72	29.00	12.40	276.67	32.70	57.40	0.00	12,621.75
7/4/07 6:03	867.26	362,323.69	263,506.31	73,621.52	3.20	28.88	12.41	277.03	34.10	58.00	0.00	9,745.44
7/4/07 6:04	867.31	361,459.09	264,925.81	74,030.41	4.95	28.78	12.42	277.03	35.10	59.80	0.00	11,348.15
7/4/07 6:05	863.73	368,674.81	264,832.81	73,659.44	4.95	29.00	12.43	277.01	34.60	60.20	0.00	11,348.22
7/4/07 6:06	861.20	368,310.19	264,871.41	74,096.24	4.96	28.63	12.44	276.67	34.80	59.70	0.00	11,864.25
7/4/07 6:07	859.51	371,033.69	265,411.91	74,149.09	4.95	28.91	12.45	276.34	35.00	59.90	0.00	11,672.13
7/4/07 6:08	856.72	362,263.19	262,516.00	73,616.03	6.28	29.09	12.46	276.34	35.10	60.30	0.00	5,763.47
7/4/07 6:09	855.93	350,739.69	265,966.81	74,588.98	4.87	28.91	12.47	276.34	36.20	60.40	0.00	11,414.18
7/4/07 6:10	857.95	364,838.41	266,680.59	73,427.39	5.89	28.68	12.48	276.34	33.60	60.30	0.00	11,211.38
7/4/07 6:11	861.21	374,971.81	270,302.09	75,533.53	3.43	27.91	12.49	276.65	36.10	60.00	0.00	11,256.21
7/4/07 6:12	863.53	367,160.41	266,420.31	73,467.67	7.57	28.16	12.50	277.03	34.60	60.30	0.00	11,049.06
7/4/07 6:13	865.52	373,736.59	273,451.00	74,118.66	4.30	28.81	12.51	277.03	35.00	60.40	0.00	0.00
7/4/07 6:14	865.98	360,762.09	264,033.00	73,832.43	4.67	27.95	12.52	277.70	35.80	60.40	0.00	9,393.57
7/4/07 6:15	863.79	373,193.31	268,086.91	73,583.78	4.88	28.63	12.53	278.01	35.10	60.50	0.00	8,980.57
7/4/07 6:16	861.57	358,052.00	267,719.31	72,800.13	5.19	29.24	12.55	278.32	34.40	60.50	0.00	9,124.12
7/4/07 6:17	859.66	382,291.19	279,384.31	74,541.03	3.00	28.25	12.54	278.32	35.40	60.50	0.00	9,598.86
7/4/07 6:18	857.22	365,352.31	266,292.31	72,949.15	8.47	28.63	12.54	278.32	33.40	60.80	0.00	8,742.64
7/4/07 6:19	857.81	369,554.31	266,470.69	72,621.42	3.68	28.88	12.53	278.32	35.20	60.60	0.00	9,673.93
7/4/07 6:20	859.37	377,088.81	271,018.50	74,155.62	5.52	28.75	12.52	277.72	35.20	60.90	0.00	9,238.68
7/4/07 6:21	861.04	357,576.81	268,371.09	73,684.35	6.44	28.88	12.51	278.01	36.40	60.40	0.00	9,430.39
7/4/07 6:22	862.96	367,827.31	269,815.00	73,395.90	4.86	29.75	12.50	278.01	35.80	59.80	0.00	9,390.50
7/4/07 6:23	865.32	370,550.69	269,730.41	73,980.05	5.43	28.75	12.49	278.01	35.50	60.40	0.00	7,563.33
7/4/07 6:24	865.14	373,502.09	269,547.50	73,790.39	4.86	29.13	12.48	278.32	35.10	59.90	0.00	8,595.03
7/4/07 6:25	862.52	351,256.09	270,091.81	73,678.87	4.85	28.88	12.48	278.01	35.60	60.30	0.00	8,297.04
7/4/07 6:26	860.78	379,289.41	272,579.41	73,171.13	4.86	28.50	12.49	278.32	36.50	60.10	0.00	8,415.63
7/4/07 6:27	858.45	374,882.69	270,036.09	74,152.07	4.85	28.50	12.49	278.70	33.80	60.10	0.00	8,438.98

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/4/07 6:28	857.24	354,135.81	266,686.31	74,483.96	5.38	29.00	12.50	278.68	35.20	60.60	0.00	12,608.04
7/4/07 6:29	859.49	361,292.81	268,893.41	73,293.56	5.28	28.99	12.51	278.70	34.60	59.90	0.00	11,325.42
7/4/07 6:30	863.53	372,889.31	273,361.31	74,415.62	6.00	28.63	12.47	279.01	36.70	60.90	0.00	11,437.41
7/4/07 6:31	867.35	393,638.81	276,829.50	74,729.26	6.39	29.67	12.34	279.65	36.40	61.40	0.00	11,170.20
7/4/07 6:32	869.48	366,697.31	270,657.91	73,164.95	9.37	30.00	12.22	279.68	36.40	62.90	0.00	11,241.45
7/4/07 6:33	871.50	370,796.31	267,756.81	73,427.44	4.68	30.38	12.09	279.35	36.40	62.80	0.00	10,185.69
7/4/07 6:34	869.64	367,324.50	269,440.31	73,978.73	4.93	29.63	11.96	279.35	37.00	62.60	0.00	10,083.51
7/4/07 6:35	866.18	359,913.91	264,392.00	74,171.13	5.44	29.97	11.83	279.35	37.10	63.20	0.00	10,223.75
7/4/07 6:36	862.97	368,316.31	271,940.50	74,515.62	5.17	30.02	11.70	279.35	37.60	64.30	0.00	10,066.12
7/4/07 6:37	859.85	366,460.59	264,723.50	74,091.98	7.32	29.74	11.70	279.37	36.20	64.70	0.00	10,032.35
7/4/07 6:38	858.95	361,614.31	267,560.19	75,996.60	3.33	29.98	11.71	279.35	37.00	65.10	0.00	10,932.26
7/4/07 6:39	860.24	356,445.59	268,831.59	73,697.48	8.41	30.00	11.73	279.68	37.80	65.30	0.00	10,373.23
7/4/07 6:40	861.90	378,606.19	270,156.81	74,076.02	3.99	30.13	11.74	280.01	39.00	65.40	0.00	10,368.24
7/4/07 6:41	863.48	372,954.50	271,299.59	76,310.91	6.28	29.89	11.76	280.01	39.80	66.20	0.00	10,313.33
7/4/07 6:42	865.52	358,064.00	269,049.31	73,966.22	7.81	29.69	11.77	280.01	38.10	65.90	0.00	10,025.42
7/4/07 6:43	867.41	373,450.81	270,033.09	74,681.91	4.60	30.00	11.79	280.73	38.40	65.90	0.00	8,702.08
7/4/07 6:44	865.71	352,750.31	261,272.91	73,922.10	4.66	29.91	11.80	280.70	35.20	59.60	0.00	8,487.08
7/4/07 6:45	862.80	367,212.91	264,699.31	74,163.47	4.66	30.66	11.82	280.37	34.90	59.90	0.00	8,811.04
7/4/07 6:46	860.32	360,076.59	266,014.00	74,618.13	4.66	30.42	11.83	280.04	35.70	60.20	0.00	8,692.77
7/4/07 6:47	858.06	382,815.59	260,386.00	73,720.35	4.66	29.75	11.85	280.70	36.10	59.80	0.00	5,801.69
7/4/07 6:48	857.38	353,732.09	267,455.31	74,591.93	6.49	30.63	11.86	280.35	36.40	60.40	0.00	10,407.62
7/4/07 6:49	859.70	354,805.19	271,099.00	74,318.98	4.83	30.44	11.88	280.01	35.00	60.10	0.00	10,402.19
7/4/07 6:50	862.36	358,691.50	262,018.30	73,015.52	5.55	29.88	11.90	279.65	34.90	60.90	0.00	10,239.33
7/4/07 6:51	865.04	364,034.00	261,469.70	73,833.82	4.88	30.00	11.91	279.35	35.30	60.70	0.00	10,135.87
7/4/07 6:52	867.40	361,409.81	262,167.69	73,487.75	4.74	30.03	11.93	279.65	36.90	61.70	0.00	1,485.55
7/4/07 6:53	868.09	358,628.41	261,441.59	73,529.85	4.73	29.88	11.94	280.01	35.50	62.10	0.00	8,722.01
7/4/07 6:54	865.29	372,078.81	269,501.00	74,567.79	4.38	30.16	11.96	280.35	37.50	62.80	0.00	8,633.34
7/4/07 6:55	862.44	354,193.19	261,484.91	73,806.70	6.98	29.90	11.97	280.35	38.20	64.00	0.00	8,824.07
7/4/07 6:56	858.75	368,224.00	263,304.09	74,023.70	5.07	30.09	11.99	280.04	36.80	64.10	0.00	9,121.07
7/4/07 6:57	855.67	362,655.91	270,303.50	74,677.14	6.94	29.89	12.00	280.70	38.40	64.70	0.00	8,437.50
7/4/07 6:58	855.61	358,288.59	260,941.41	72,757.22	7.20	29.88	12.02	280.73	37.40	65.50	0.00	11,286.15
7/4/07 6:59	856.96	361,399.91	266,806.81	73,291.38	3.89	30.09	12.03	280.35	38.00	65.70	0.00	11,567.39
7/4/07 7:00	858.15	373,762.00	262,694.09	74,095.50	6.84	29.75	12.05	280.35	37.90	66.20	0.00	11,232.05
7/4/07 7:01	859.35	358,174.09	263,846.81	74,068.24	5.27	29.91	12.06	280.01	37.90	66.20	0.00	11,434.97
7/4/07 7:02	860.66	363,270.00	264,403.91	73,529.71	6.17	29.66	12.08	279.65	38.10	65.80	0.00	7,120.27
7/4/07 7:03	862.07	352,011.41	258,751.91	73,864.80	4.23	29.59	12.09	280.04	39.00	66.20	0.00	10,620.76
7/4/07 7:04	862.91	360,243.31	264,921.50	73,760.89	6.18	29.88	12.11	279.37	35.30	59.90	0.00	10,964.75
7/4/07 7:05	863.01	361,293.69	263,442.50	73,998.93	6.18	29.63	12.12	278.99	34.90	60.00	0.00	10,932.50
7/4/07 7:06	864.36	342,594.81	263,560.31	73,439.03	6.18	29.50	12.18	279.01	35.40	60.00	0.00	10,635.99
7/4/07 7:07	865.43	356,102.19	263,277.91	73,445.30	6.18	29.72	12.13	279.65	34.70	60.30	0.00	8,246.51
7/4/07 7:08	863.55	370,844.59	261,221.30	72,385.53	6.83	29.50	12.19	280.04	35.50	60.20	0.00	8,717.53
7/4/07 7:09	859.56	368,078.59	264,414.00	74,782.11	4.61	29.59	12.25	280.35	35.00	60.60	0.00	8,815.53
7/4/07 7:10	856.14	360,768.41	260,860.70	72,821.71	7.03	28.84	12.27	280.35	35.30	61.20	0.00	9,079.88
7/4/07 7:11	852.02	341,409.00	259,299.30	73,756.22	4.49	29.03	12.39	280.35	36.10	62.10	0.00	8,870.35
7/4/07 7:12	849.96	360,859.50	260,953.00	74,096.04	2.46	28.75	12.50	280.37	37.20	62.80	0.00	12,659.27
7/4/07 7:13	850.65	351,907.09	260,566.20	73,815.60	7.29	28.68	12.62	280.35	36.30	62.20	0.00	11,393.96
7/4/07 7:14	852.59	362,928.31	267,000.41	74,612.49	5.16	29.13	12.74	281.04	37.00	63.20	0.00	11,334.91
7/4/07 7:15	854.66	364,231.50	262,874.50	74,026.41	6.36	27.97	12.81	281.04	37.20	63.30	0.00	11,348.37
7/4/07 7:16	856.50	355,621.41	260,793.59	73,738.39	4.88	28.70	12.79	281.04	36.80	63.90	0.00	11,428.14
7/4/07 7:17	857.47	345,263.81	259,464.41	73,486.53	4.85	28.75	12.76	281.04	37.30	64.60	0.00	10,419.69

	3223-TI-015C	3222-FI-002	3221-FI-002	3221-FI-052	3591-FI-011	LS_FLOW	QW_FLOW	3521-TI-005	3561-FI-501A	3561-FI-501B	3561-FI-501C	3241-FI-005
	SH OUTLET	SECONDARY	PRIMARY	DISTRIBUTION		SDA TOTAL	SDA QUENCH		UREA	UREA	UREA	SOOTBLOWER
	FLUE GAS	AIR FLOW	AIR FLOW	AIR FLOW	CEMS STACK	SLURRY	WATER FLOW	SDA OUTLET	INJECTION	INJECTION	INJECTION	STEAM FLOW
	TEMP (DEGF)	(LB/HR)	(LB/HR)	(LB/HR)	FLOW (SCFM)	FLOW (GPM)	(GPM)	TEMP (DEGF)	PUMP 1	PUMP 2	PUMP 3	(LB/HR)
7/4/07 7:18	855.50	352,825.41	261,128.59	73,810.16	4.53	28.99	12.73	280.70	37.00	64.60	0.00	10,404.94
7/4/07 7:19	851.02	353,245.00	258,221.00	73,941.80	4.35	29.07	12.71	281.04	38.40	65.50	0.00	10,377.51
7/4/07 7:20	846.51	352,689.81	260,706.91	74,371.53	4.96	28.78	12.68	281.04	38.80	65.50	0.00	10,132.13
7/4/07 7:21	843.48	351,996.81	259,711.50	74,047.88	4.47	28.88	12.66	281.01	39.20	65.70	0.00	9,971.98
7/4/07 7:22	844.16	354,029.50	264,280.91	75,617.13	4.25	29.09	12.63	281.01	36.60	65.70	0.00	10,785.36
7/4/07 7:23	845.27	347,509.50	257,472.50	73,807.11	8.97	28.78	12.61	280.70	38.00	65.80	0.00	10,404.97
7/4/07 7:24	846.48	367,728.59	260,060.50	73,837.80	5.20	28.84	12.58	280.35	34.90	59.80	0.00	10,394.67
7/4/07 7:25	848.43	358,726.09	260,222.00	74,513.89	5.20	29.00	12.56	280.35	34.60	60.20	0.00	10,373.64
7/4/07 7:26	850.82	355,217.31	262,250.81	74,231.32	5.20	28.89	12.53	280.35	35.20	59.90	0.00	2,151.91
7/4/07 7:27	850.92	367,511.31	257,613.91	73,842.88	5.20	28.88	12.50	280.35	33.70	60.00	0.00	9,539.21
7/4/07 7:28	847.78	351,637.00	258,856.00	73,858.00	4.61	28.75	12.23	280.01	35.80	60.20	0.00	9,423.67
7/4/07 7:29	845.34	354,354.59	262,032.09	75,865.21	3.50	29.03	12.25	279.70	35.10	60.90	0.00	9,029.61
7/4/07 7:30	841.80	350,143.19	260,192.70	73,781.48	7.23	28.44	12.26	279.32	36.30	61.50	0.00	9,451.30
7/4/07 7:31	839.63	353,209.50	258,113.59	73,524.02	5.25	28.84	12.28	279.01	35.20	60.90	0.00	9,383.88
7/4/07 7:32	840.92	375,771.19	261,589.80	74,134.66	3.09	28.86	12.30	278.68	36.00	61.40	0.00	10,759.27
7/4/07 7:33	842.38	351,377.09	257,578.59	72,950.48	6.46	28.69	12.32	278.68	36.60	61.70	0.00	10,811.26
7/4/07 7:34	842.99	354,508.31	259,785.09	73,732.55	3.17	28.88	12.34	278.68	36.00	62.10	0.00	10,920.01
7/4/07 7:35	843.86	360,288.19	259,438.59	73,334.47	5.33	28.75	12.35	278.68	36.30	62.70	0.00	10,940.55
7/4/07 7:36	845.31	358,974.09	261,036.91	73,964.29	5.11	28.59	12.37	277.99	36.90	62.50	0.00	9,317.67
7/4/07 7:37	844.10	355,785.09	258,904.00	73,115.61	6.88	28.69	12.39	278.01	37.50	62.60	0.00	9,486.93
7/4/07 7:38	842.78	358,299.59	261,385.50	73,896.80	3.52	27.78	12.41	277.68	37.10	63.00	0.00	10,081.37
7/4/07 7:39	841.60	364,024.31	263,577.69	74,628.86	4.96	27.88	12.42	277.70	36.50	63.30	0.00	9,521.84
7/4/07 7:40	840.27	350,995.19	259,580.20	73,610.97	6.67	28.09	12.44	278.32	37.10	64.00	0.00	9,701.28
7/4/07 7:41	839.72	351,075.50	261,917.50	73,076.18	5.29	27.88	12.46	278.32	38.20	63.90	0.00	9,714.08
7/4/07 7:42	841.42	354,255.69	261,615.00	72,950.39	5.13	27.65	12.48	278.32	38.20	64.20	0.00	8,708.97
7/4/07 7:43	842.90	381,304.50	264,612.91	72,108.40	4.08	27.94	12.50	278.68	37.90	64.60	0.00	8,465.66
7/4/07 7:44	842.78	360,889.09	262,141.91	73,016.83	8.51	28.00	12.51	278.68	36.10	60.00	0.00	8,650.83
7/4/07 7:45	843.46	331,713.31	260,966.09	73,292.67	8.50	27.97	12.53	278.68	34.60	60.10	0.00	8,580.26
7/4/07 7:46	844.51	360,928.00	260,163.70	72,042.68	8.50	28.01	12.55	278.70	35.80	59.70	0.00	9,015.54
7/4/07 7:47	844.14	349,494.00	262,769.09	73,716.90	8.50	28.06	12.57	279.01	35.80	60.40	0.00	9,022.08
7/4/07 7:48	843.56	373,524.91	268,353.91	73,294.63	6.22	29.81	12.59	279.35	34.90	59.50	0.00	8,948.62
7/4/07 7:49	842.86	358,493.69	264,485.59	73,493.73	7.66	28.94	12.60	280.01	34.00	60.30	0.00	9,541.28
7/4/07 7:50	843.29	374,251.41	262,849.59	73,258.48	6.02	29.16	12.62	280.01	35.80	60.90	0.00	5,125.43
7/4/07 7:51	843.12	355,439.00	262,404.69	72,667.82	7.68	28.75	12.64	279.35	35.20	61.50	0.00	10,613.27
7/4/07 7:52	844.32	365,704.41	264,241.69	73,612.53	4.86	29.00	12.66	279.35	36.20	61.30	0.00	10,529.12
7/4/07 7:53	845.40	358,294.91	263,602.81	73,020.13	6.46	28.75	12.67	279.37	36.40	61.10	0.00	10,330.79
7/4/07 7:54	846.88	357,579.59	263,141.69	73,525.81	5.56	28.59	12.69	279.68	36.60	61.10	0.00	10,379.91
7/4/07 7:55	848.39	363,341.41	264,227.31	74,546.53	6.58	29.00	12.71	279.65	36.00	61.00	0.00	2,110.27
7/4/07 7:56	848.56	358,871.09	261,470.80	72,742.57	6.29	28.72	12.73	280.04	34.60	60.70	0.00	9,807.79
7/4/07 7:57	846.51	360,200.09	262,820.00	73,378.04	4.74	28.25	12.75	279.37	35.00	60.60	0.00	9,466.66
7/4/07 7:58	843.74	371,236.50	264,115.31	74,358.33	6.20	28.34	12.76	279.37	34.30	60.10	0.00	9,553.43

PM-10 TEST DATA FROM THE DCS

Test High Load
Run - 3-1

Date and Time	Leak Detection 1	Leak Detection 2	Leak Detection 3	Leak Detection 4	Leak Detection 5	Leak Detection 6	Leak Detection 7	Leak Detection 8	Baghouse DP
7/3/07 11:42 PM	7.351	6.960	7.838	7.055	7.619	19.407	7.991	7.433	9.439
7/3/07 11:47 PM	6.586	6.513	7.993	6.710	8.312	19.656	7.968	6.518	9.414
7/3/07 11:52 PM	6.075	6.562	6.920	6.525	8.757	18.669	8.049	6.810	9.273
7/3/07 11:57 PM	6.555	8.002	6.360	6.812	8.297	19.012	7.248	7.036	9.353
7/4/07 12:02 AM	5.825	5.691	6.670	6.655	7.888	19.204	7.396	6.942	9.856
7/4/07 12:07 AM	7.416	5.757	8.801	6.607	8.181	15.866	7.724	6.239	9.775
7/4/07 12:12 AM	6.443	6.006	6.775	6.364	8.113	15.007	7.492	6.257	9.742
7/4/07 12:17 AM	5.962	7.001	5.795	6.827	8.363	13.687	7.331	8.394	9.581
7/4/07 12:22 AM	5.944	7.321	6.938	6.507	7.330	11.123	8.283	7.176	9.660
7/4/07 12:27 AM	5.884	5.526	7.008	6.998	7.820	18.488	7.906	7.140	8.917
7/4/07 12:32 AM	6.389	6.698	7.478	6.165	8.311	14.373	7.159	6.308	8.999
7/4/07 12:37 AM	6.248	6.220	6.054	6.467	7.394	12.032	7.411	6.686	8.914
7/4/07 12:42 AM	6.121	7.644	6.370	7.082	7.934	12.608	7.162	7.417	9.311
7/4/07 12:47 AM	6.456	6.472	6.881	6.316	7.787	18.043	7.203	6.655	9.406
7/4/07 12:52 AM	6.281	6.979	7.932	6.897	8.433	19.994	7.305	6.690	9.311
7/4/07 12:57 AM	6.460	7.155	6.480	6.293	8.019	17.922	7.703	6.885	9.034
7/4/07 1:02 AM	5.901	5.895	10.003	5.986	7.288	17.064	7.205	6.983	9.215
7/4/07 1:07 AM	6.513	6.086	6.666	6.758	8.377	20.825	7.815	6.632	9.165
7/4/07 1:12 AM	6.433	5.942	6.792	6.523	8.078	20.821	7.281	6.276	8.965
7/4/07 1:17 AM	6.399	7.041	6.260	7.176	8.335	20.273	7.244	8.573	8.566
7/4/07 1:22 AM	6.177	6.907	6.586	6.239	7.889	20.183	7.481	6.693	8.504
7/4/07 1:27 AM	6.124	5.858	8.716	6.305	7.072	20.122	7.301	7.071	8.478
7/4/07 1:32 AM	6.160	6.372	7.087	6.259	7.859	19.179	7.078	6.424	8.396
7/4/07 1:37 AM	5.886	6.003	6.757	6.444	7.344	18.188	7.546	6.876	8.502
7/4/07 1:42 AM	6.157	7.322	6.252	6.205	7.975	19.073	6.821	7.553	8.609
7/4/07 1:47 AM	6.010	6.939	6.480	6.337	7.404	21.645	7.785	6.734	8.637
7/4/07 1:52 AM	6.065	5.651	7.698	6.026	8.538	18.848	7.539	6.341	8.343
7/4/07 1:57 AM	6.605	7.019	9.515	6.822	8.297	17.708	6.833	6.496	8.580
7/4/07 2:02 AM	5.938	5.640	6.807	6.374	7.597	15.918	7.197	6.669	8.428
7/4/07 2:07 AM	6.832	6.081	8.120	6.266	8.773	14.864	7.634	6.612	8.783
7/4/07 2:12 AM	5.806	5.913	9.112	6.963	8.385	13.485	7.223	6.397	8.100
7/4/07 2:17 AM	6.764	5.784	6.610	6.929	8.562	13.115	7.277	7.694	8.659
7/4/07 2:22 AM	5.977	8.194	6.571	6.634	8.576	13.657	6.993	6.632	8.796
7/4/07 2:27 AM	6.091	5.549	6.229	5.944	7.469	11.759	7.322	6.919	8.531
7/4/07 2:32 AM	6.557	5.617	7.263	6.017	8.876	11.180	7.377	6.303	8.611
7/4/07 2:37 AM	6.483	6.362	6.742	6.349	7.762	10.805	6.918	6.359	8.995
7/4/07 2:42 AM	5.717	7.083	6.641	6.153	8.409	14.200	6.880	7.105	8.953

PM-10 TEST DATA FROM THE DCS

Test High Load
Run - 3-2

Date and Time	Leak Detection 1	Leak Detection 2	Leak Detection 3	Leak Detection 4	Leak Detection 5	Leak Detection 6	Leak Detection 7	Leak Detection 8	Baghouse DP
7/4/07 2:44 AM	6.583	5.828	6.789	5.906	8.961	13.331	7.053	6.755	9.086
7/4/07 2:49 AM	6.321	6.668	7.191	6.093	8.234	13.281	6.941	6.377	8.954
7/4/07 2:54 AM	5.993	7.298	6.389	6.486	8.012	11.329	7.492	7.522	8.860
7/4/07 2:59 AM	5.733	6.725	6.261	6.356	7.646	12.776	9.141	7.283	8.761
7/4/07 3:04 AM	5.850	5.585	6.158	6.655	7.430	13.380	7.119	7.141	8.852
7/4/07 3:09 AM	6.729	5.957	6.813	6.271	8.219	22.011	6.894	6.169	8.714
7/4/07 3:14 AM	6.044	5.767	6.882	6.260	7.792	19.046	7.398	7.074	8.719
7/4/07 3:19 AM	6.822	6.572	8.813	6.486	8.078	17.382	7.522	7.305	8.651
7/4/07 3:24 AM	6.095	6.068	6.654	6.096	8.480	20.586	7.203	6.149	8.879
7/4/07 3:29 AM	7.229	5.997	8.290	6.263	8.493	20.402	7.763	6.653	8.747
7/4/07 3:34 AM	6.262	7.613	6.348	6.029	8.437	20.551	7.285	7.160	8.956
7/4/07 3:39 AM	5.871	5.768	6.573	6.568	7.554	13.901	7.310	6.965	8.678
7/4/07 3:44 AM	7.037	5.945	9.007	6.058	7.921	13.237	7.544	6.228	8.685
7/4/07 3:49 AM	6.406	5.929	6.001	6.097	8.492	11.924	7.264	5.890	8.938
7/4/07 3:54 AM	5.845	6.506	6.497	6.109	8.505	11.946	7.499	8.121	8.799
7/4/07 3:59 AM	5.507	7.429	6.167	6.581	7.295	12.435	8.823	7.090	8.961
7/4/07 4:04 AM	5.989	5.773	6.982	5.886	7.733	12.526	7.556	6.685	8.649
7/4/07 4:09 AM	6.532	6.614	7.312	6.382	8.008	12.260	6.768	6.408	8.814
7/4/07 4:14 AM	5.906	5.545	6.218	6.566	7.494	18.771	7.012	6.571	8.819
7/4/07 4:19 AM	6.008	6.442	6.289	6.634	7.965	7.879	7.241	7.440	8.665
7/4/07 4:24 AM	6.048	6.577	7.198	6.355	8.268	7.451	7.404	6.559	8.756
7/4/07 4:29 AM	5.843	6.860	7.033	6.384	8.501	15.912	7.342	6.559	8.561
7/4/07 4:34 AM	5.936	6.483	6.904	6.200	8.370	13.808	7.297	6.926	9.004
7/4/07 4:39 AM	5.874	5.503	8.778	6.112	7.674	11.412	7.315	7.232	8.723
7/4/07 4:44 AM	6.508	5.574	6.105	6.519	8.282	12.482	7.406	6.620	8.452
7/4/07 4:49 AM	6.356	5.789	7.360	6.065	7.613	16.481	7.359	6.103	8.241
7/4/07 4:54 AM	6.141	7.018	6.257	6.215	8.460	19.010	7.008	8.532	8.218
7/4/07 4:59 AM	5.925	6.878	6.376	6.287	8.091	21.174	8.517	6.453	8.144
7/4/07 5:04 AM	5.866	5.584	7.812	5.895	7.290	16.916	7.499	7.121	8.155
7/4/07 5:09 AM	5.969	6.802	6.318	6.486	8.227	20.327	6.963	6.288	7.954
7/4/07 5:14 AM	6.156	5.830	6.556	6.312	7.120	21.593	7.003	6.724	7.842
7/4/07 5:19 AM	5.939	7.725	6.579	6.248	8.166	21.722	6.861	7.698	7.758
7/4/07 5:24 AM	5.695	6.815	6.600	6.741	8.175	19.846	7.823	7.028	8.520

PM-10 TEST DATA FROM THE DCS

Test High Load
Run - 3-3

Date and Time	Leak Detection 1	Leak Detection 2	Leak Detection 3	Leak Detection 4	Leak Detection 5	Leak Detection 6	Leak Detection 7	Leak Detection 8	Baghouse DP
7/4/07 5:27 AM	6.006	5.573	6.088	5.996	7.231	20.364	7.089	6.673	9.068
7/4/07 5:32 AM	6.764	5.981	9.745	6.419	9.051	20.330	7.407	7.406	9.168
7/4/07 5:37 AM	5.949	5.718	7.360	6.226	8.016	21.216	7.079	6.294	9.177
7/4/07 5:42 AM	6.558	6.106	6.045	6.711	9.209	26.226	7.645	7.806	9.201
7/4/07 5:47 AM	6.347	7.948	6.391	6.634	8.196	24.898	6.903	6.339	8.856
7/4/07 5:52 AM	6.155	5.581	6.785	6.291	7.875	24.042	8.053	7.158	9.197
7/4/07 5:57 AM	6.716	5.680	6.254	6.418	8.080	24.070	7.068	6.284	8.827
7/4/07 6:02 AM	6.334	5.953	7.050	7.025	7.505	22.478	7.086	6.335	9.041
7/4/07 6:07 AM	5.943	6.778	5.357	6.381	8.272	21.708	6.973	7.645	8.927
7/4/07 6:12 AM	6.017	7.283	7.427	6.534	7.822	21.055	7.413	7.308	8.879
7/4/07 6:17 AM	5.852	5.557	7.028	6.488	7.698	19.085	7.271	6.873	8.834
7/4/07 6:22 AM	6.858	6.197	7.406	6.361	8.749	18.262	6.678	6.591	9.082
7/4/07 6:27 AM	6.475	6.008	6.360	6.514	7.632	19.504	6.975	7.276	9.623
7/4/07 6:32 AM	6.642	5.968	5.957	6.090	9.104	19.377	8.033	6.699	9.381
7/4/07 6:37 AM	5.946	6.327	11.698	6.255	7.729	22.222	7.377	5.979	9.573
7/4/07 6:42 AM	7.462	5.957	7.478	6.516	8.720	18.751	7.688	6.103	9.325
7/4/07 6:47 AM	6.025	7.319	6.442	6.343	8.369	19.542	7.442	6.552	9.375
7/4/07 6:52 AM	6.495	5.635	6.658	6.431	7.476	22.174	6.829	7.007	9.378
7/4/07 6:57 AM	6.408	5.794	6.826	6.096	8.268	24.164	7.530	6.119	9.199
7/4/07 7:02 AM	6.057	5.914	6.982	6.074	7.616	25.104	7.196	6.161	8.835
7/4/07 7:07 AM	5.807	7.103	6.940	6.432	8.401	21.307	6.854	7.312	9.164
7/4/07 7:12 AM	5.792	6.922	6.296	6.581	7.352	20.868	8.223	7.289	9.424
7/4/07 7:17 AM	5.993	6.042	6.327	6.076	7.762	21.370	6.734	6.970	9.351
7/4/07 7:22 AM	6.513	5.745	6.595	6.352	7.885	20.240	6.933	6.671	9.216
7/4/07 7:27 AM	6.110	5.631	7.120	6.306	7.775	17.678	7.224	6.945	9.065
7/4/07 7:32 AM	6.943	6.079	8.675	6.521	8.384	17.776	8.197	7.176	8.687
7/4/07 7:37 AM	6.075	6.402	6.751	6.146	8.342	21.224	7.800	6.339	8.848
7/4/07 7:42 AM	7.356	6.259	9.553	6.324	9.031	19.982	7.595	6.194	9.016
7/4/07 7:47 AM	6.475	7.496	6.280	6.346	8.529	18.889	7.196	6.549	9.196
7/4/07 7:52 AM	6.022	5.623	7.316	6.000	7.628	20.187	7.120	7.317	9.192
7/4/07 7:57 AM	7.002	5.949	7.297	6.522	8.689	18.975	7.365	6.221	9.246
7/4/07 8:02 AM	5.974	5.898	7.521	6.320	8.576	15.366	7.537	6.069	8.919

APPENDIX C
CALIBRATION GAS CERTIFICATIONS



CERTIFICATE of ANALYSIS

Interference-Free Multi-Component EPA Protocol Gases

NOTE: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121
Section 2.2 Procedure: G-1

Cylinder Number: CC162006

Customer: Air Hygiene
P.O. Number:
Item Number: SGZCAH094
Notes:

Shipping Order #: 24669211
Transfer #: 24669211
LOT #: LPX218867
Valve: CGA590
Cyl. Pressure:* 1900psig

*Cylinder should not be used when gas pressure is below 150 psig

Assay Date: 26-Mar-07

Expiration Date: 25-Mar-10

Component	Requested Concentration	Assay Concentration
Carbon Dioxide	9 %	8.97 ±0.05 %
Oxygen	12 %	12.0 ±0.1 %
Nitrogen	Balance	Balance

Reference Standard(s) Employed For Analysis:

Std name	Std #	Conc.	Units	Std. Error	Comp.	Balance	Cyl. No.	Exp. Date	Sample No.
GMIS328	GMIS328	14.01	%	0.06	CO2	N2	CC203023	7/24/2008	N.A.
GMIS203	GMIS203	19.0	%	0.2	O2	N2	CC57985	5/12/2007	N.A.

Analysis information:

Component 1: Carbon Dioxide		First Triad Analysis On: 3/26/2007				Second Triad Analysis On:				
Analyzer Information		Trial 1	Trial 2	Trial 3	Units	Trial 1	Trial 2	Trial 3	Units	
Manufacturer:	KVB/Analect									
Model Number:	EN3024	Zero	0.27	0.28	0.28	Zero				
Serial Number:	3024	Reference	14.46	14.49	14.45	Reference				
Analytical Principle:	FTIR	Candidate	9.39	9.36	9.32	Candidate				
MPC Calibrated:	03/01/07	Result	8.99	8.97	8.93	Result				
		Mean Result:			8.97	%	Mean Result:			

Component 2: Oxygen		First Triad Analysis On: 3/26/2007				Second Triad Analysis On:				
Analyzer Information		Trial 1	Trial 2	Trial 3	Units	Trial 1	Trial 2	Trial 3	Units	
Manufacturer:	Servomex									
Model Number:	4605C	Zero	-0.01	-0.01	-0.01	Zero				
Serial Number:	1101	Reference	18.70	18.69	18.70	Reference				
Analytical Principle:	Paramag.	Candidate	11.82	11.82	11.82	Candidate				
MPC Calibrated:	03/14/07	Result	12.02	12.02	12.02	Result				
		Mean Result:			12.02	%	Mean Result:			

Analyst Signature: Warren Pereira Warren Pereira

Calculated by: Warren Pereira Warren Pereira



CERTIFICATE of ANALYSIS

Interference-Free Multi-Component EPA Protocol Gases

NOTE: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121
Section 2.2 Procedure: G-1

Cylinder Number: CC16039

Customer: Air Hygiene
P.O. Number:
Item Number: AH095
Notes:

Shipping Order #: 18651280
Transfer #: 18651280
LOT #: LPX129537
Valve: CGA590
Cyl. Pressure:* 1900psig

*Cylinder should not be used when gas pressure is below 150 psig

Assay Date: 23-Nov-05

Expiration Date: 22-Nov-08

Component	Requested Concentration	Assay Concentration
Carbon Dioxide	19 %	19.0 ±0.2 %
Oxygen	21 %	21.0 ±0.2 %
Nitrogen	Balance	Balance

Reference Standard(s) Employed For Analysis:

Std name	Std #	Conc.	Units	Std. Error	Comp.	Balance	Cyl. No.	Exp. Date	Sample No.
GMIS301	GMIS301	14.0	%	0.1	CO2	N2	CC71493	8/24/2007	N.A.
GMIS204	GMIS204	19.0	%	0.2	O2	N2	CC115413	5/12/2007	N.A.

Analysis Information:

Component 1: Carbon Dioxide		First Triad Analysis On: 11/18/2005				Second Triad Analysis On:			
Analyzer Information		Trial 1	Trial 2	Trial 3	Units	Trial 1	Trial 2	Trial 3	Units
Manufacturer:	KVB/Analect	Zero	0.19	0.29	0.27	Zero			
Model Number:	EN3024	Reference	13.26	13.42	13.39	Reference			
Serial Number:	3024	Candidate	17.99	18.05	18.07	Candidate			
Analytical Principle:	FTIR	Result	18.94	19.01	19.03	Result			
MPC Calibrated:	11/10/05	Mean Result: 19.00			%	Mean Result:			

Component 2: Oxygen		First Triad Analysis On: 11/23/2005				Second Triad Analysis On:			
Analyzer Information		Trial 1	Trial 2	Trial 3	Units	Trial 1	Trial 2	Trial 3	Units
Manufacturer:	Servomex	Zero	0.03	0.03	0.04	Zero			
Model Number:	4605C	Reference	18.61	18.61	18.62	Reference			
Serial Number:	1101	Candidate	20.56	20.57	20.57	Candidate			
Analytical Principle:	Paramag.	Result	20.99	21.00	21.00	Result			
MPC Calibrated:	11/03/05	Mean Result: 21.00			%	Mean Result:			

Analyst Signature:  Warren Pereira

Calculated by:  Warren Pereira



RECERTIFICATION

Interference-Free Multi-Component EPA Protocol Gases

NOTE: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121

Section 2.2

Procedure: G-1

Cyl. Number: CC58443

Customer: AIR HYGIENE
P.O. Number:
Item Number: SGZCAH026
Notes:

Shipping Order #: 23221670
Transfer #: 24017378
LOT #: LPX216414
Valve: CGA660
Cyl. Pressure*: <1900 psig

Assay Date: 15-Feb-07

Expiration Date: 14-Feb-09

*Cylinder should not be used when gas pressure is below 150 psig

Component	Requested Concentration	Assay Concentration
Nitric Oxide	110 ppm	111 ±1 ppm
Total NOX		111 ppm
Nitrogen	Balance	Balance

Reference Standard(s) Employed For Analysis:

Std name	Std #	Conc.	Units	Std. Error	Comp.	Balance	Cyl. No.	Exp. Date	Sample No.
GMIS343	GMIS343	102.0	ppm	0.6	NO	N2	CC60015	11/30/2008	N.A.

Analysis Information:

Component 1: Nitric Oxide		First Triad Analysis On: 2/15/2007				Second Triad Analysis On:					
Analyzer Information		Trial 1	Trial 2	Trial 3	Units	Zero		Trial 1	Trial 2	Trial 3	Units
Manufacturer:	KVB/Analect	0.00	0.38	0.34		Zero					
Model Number:	EN3024	100.08	99.43	99.17		Reference					
Serial Number:	3024	107.00	107.53	109.08		Candidate					
Analytical Principle:	FTIR	109.64	110.19	111.78	ppm	Result					
MPC Calibrated:	2/8/2007	Mean Result: 110.54			ppm	Mean Result:					

Note: The recertification analysis of 111 ±1 ppm of NO has overlapped the original certification number of 111 ±1 ppm. Therefore, the original number has been used on this recertification.

Analyst Signature: Bryan Leger

Calculated by: M. Adnane



CERTIFICATE of ANALYSIS

Interference-Free Multi-Component EPA Protocol Gases

NOTE: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121
Section 2.2 Procedure: G-1

Customer: Air Hygiene
 P.O. Number:
 Item Number: AH021
 Notes:
 Assay Date: 30-Dec-05
 Cyl. Number: CC84458
 Expiration Date: 30-Dec-07
 Shipping Order #: 19040311
 Transfer #: 19040311
 LOT #: LPX130966
 Valve: CGA660
 Cyl. Pressure*: 1900psig
 *Cylinder should not be used when gas pressure is below 150 psig

Component	Requested Concentration	Assay Concentration
Nitric Oxide	250 ppm	253 ±1 ppm
Total NOX		254 ppm
Nitrogen	Balance	Balance

Reference Standard(s) Employed For Analysis:


Std name	Std #	Conc.	Units	Std. Error	Comp.	Balance	Cyl. No.	Exp. Date	Sample No
GMIS299	GMIS299	250.0	ppm	1.0	NO	N2	CC174946	8/11/2007	N.A.

Analysis Information:

Component 1: Nitric Oxide		First Triad Analysis On: 12/23/2005				Second Triad Analysis On: 12/30/2005				
Analyzer Information		Trial 1	Trial 2	Trial 3	Units	Trial 1	Trial 2	Trial 3	Units	
Manufacturer:	KVB/Analect					Zero	0.50	-0.62	0.36	
Model Number:	EN3024	Zero	-0.30	0.16	0.18	Reference	245.71	246.27	245.50	
Serial Number:	3024	Reference	247.30	245.90	246.28	Candidate	249.05	249.73	247.49	
Analytical Principle:	FTIR	Candidate	248.87	249.09	248.04	Result	253.28	253.97	251.70	ppm
MPC Calibrated:	12/15/05	Result	252.41	252.63	251.57					ppm
		Mean Result:	252.21		ppm	Mean Result:	252.98		ppm	

Analyst Signature: Warren Pereira Warren Pereira

Calculated by: Warren Pereira Warren Pereira



CERTIFICATE OF ANALYSIS

Interference-Free Multi-Component EPA Protocol Gases

Note: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121
Section No. 2.2, Procedure . G-1

Customer: AIR HYGIENE TULSA, OK	Cylinder Number: CC233344	Shipping Order Number: 24193970
P.O. Number: AIR HYGIENE CONSIGNMENT		Transfer Number: 24193970
Item Number: SGZCAI032		Lot Number: SFS105098
		Valve: CGA 660
		Cyl. Pressure:* 2000PSIG
Assay Date: 19-Feb-07	Expiration Date: 19-Aug-07	*Cylinder should not be used when gas pressure is below 150 psig

Component	REQUESTED Concentration	ASSAY Concentration
Nitrogen Dioxide	45-50 ppm	47.6 ± 0.8 ppm
Nitrogen	Balance	Balance

Reference Standard Employed For Analysis:

Concentration	Component	Balance	Cyl. No.	SRM or GMIS NTRM No.	Exp. Date	Sample No.	Type
95.2 ± 1.3	ppm Nitrogen Dioxide	Air	CC247654	SFS99692	02/04/09	YO	GMIS

Analysis Information:

Component	Nitrogen Dioxide	First Triad Analysis 02/11/07				Second Triad Analysis 02/19/07			
		Zero	Reference	Candidate	Result	Zero	Reference	Candidate	Result
Manufacturer:	MKS Instruments	-0.006	93.719	47.057	47.80	0.022	94.728	46.966	47.19
Model Number:	2031	0.007	93.776	47.170	47.88	0.020	94.816	47.44	47.51
Serial Number:	10387278	0.015	93.887	47.133	47.78	0.029	94.714	47.279	47.51
MPR Last Calibrated:	02/17/07	VALID	VALID	VALID	VALID	VALID	VALID	VALID	VALID
Analytical Principle:	FTIR	MEAN ANALYTICAL RESULT: 47.82 ppm				MEAN ANALYTICAL RESULT: 47.38 ppm			

Analyst Signature: Aidan Ifland

Approved by: Thuan Tran



015900360

CERTIFICATE of ANALYSIS

Interference-Free Multi-Component EPA Protocol Gases

NOTE: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121

Section 2.2

Procedure: G-1

Cyl. Number: CC17607

Customer: AIR HYGIENE
P.O. Number:
Item Number: SGZCAH045
Notes:

Shipping Order #: 24745990
Transfer #: 24745990
LOT #: LPX219434
Valve: CGA350
Cyl. Pressure:* 1900psig

*Cylinder should not be used when gas pressure is below 150 psig

Assay Date: 17-Apr-07

Expiration Date: 16-Apr-10

Component	Requested Concentration	Assay Concentration
Carbon Monoxide	210 ppm	220 ±2 ppm
Nitrogen	Balance	Balance

Reference Standard(s) Employed For Analysis:

Std name	Std #	Conc.	Units	Std. Error	Comp.	Balance	Cyl. No.	Exp. Date	Sample No.
GMIS339	GMIS339	99.44	ppm	0.48	CO	N2	CC82421	11/14/2008	N.A.

Analysis Information:

Component 1: Carbon Monoxide		First Triad Analysis On: 4/10/2007				Second Triad Analysis On: 4/17/2007					
Analyzer Information		Trial 1	Trial 2	Trial 3	Units	Trial 1	Trial 2	Trial 3	Units		
Manufacturer:	KVB/Analect										
Model Number:	EN3024	Zero	-0.14	-0.01	0.17	Zero	-0.12	-0.05	-0.17		
Serial Number:	3024	Reference	105.21	104.57	103.96	Reference	105.44	105.12	104.85		
Analytical Principle:	FTIR	Candidate	230.54	231.66	231.12	Candidate	231.16	232.51	232.81		
MPC Calibrated:	03/15/07 & 04/12/07	Result	219.22	220.28	219.77	ppm	Result	218.50	219.77	220.06	ppm
		Mean Result:	219.76			ppm	Mean Result:	219.44			ppm

Analyst Signature: Bryan Leger

Calculated by: M. Adnane



AIR LIQUIDE

CERTIFICATE of ANALYSIS

EPA Protocol Gases

Cyl. Number: CC148606	Cyl. Pressure:* 2000 PSIG	Lot Number: SFS75790	COMPONENT	REQUESTED	ASSAY
Assay Date: 01/14/05	Expiration Date: 01/14/08	Document Number: 14680051	Name	Concentration	Concentration
Customer: ALA-CSL-CENTENNIAL CENTENNIAL, CO	P.O. Number: CONSIGNMENT	Item Number:	Carbon Monoxide	450 ppm	457 ± 6 ppm
			Nitrogen	Balance	Balance

*Mixture is valid only to 150 psig

EPA Protocol Section No. 2.2, Procedure . G-1	REFERENCE STANDARD EMPLOYED FOR ANALYSIS			SRM or GMIS				
	Concentration	Component	Balance	Cyl. No.	NTRM No.	Exp. Date	Sample No.	Type
	500 ± 4 ppm	Carbon Monoxide	Nitrogen	CC 150327	SFS48669	04/02/05	LU	GMIS
Analyst: Approved by:	Eric Barron Thuan Tran							

Carbon Monoxide			
GAS ANALYZER EMPLOYED			
Manufacturer:	Varian(A)		
Model Number:	3400		
Serial Number:	2805		
MPR Last Calibrated:	12/22/04		
Analytical Principle:	FID & TCD		

ANALYSIS SUMMARY

	01/07/05	01/07/05	01/07/05	Carbon Monoxide		01/14/05	01/14/05	01/14/05	Carbon Monoxide
	Triad 1	Triad 2	Triad 3	Units		Triad 4	Triad 5	Triad 6	Units
Zero	0	0	0	Area		0	0	0	Area
Reference	20715159	20739129	20771211	Area		21588952	21601768	21615114	Area
Candidate	18925811	18984831	19018555	Area		19769458	19740611	19750175	Area
Result	456.8	457.7	457.8	ppm		457.9	456.9	456.9	ppm
Evaluation	VALID	VALID	VALID			VALID	VALID	VALID	
	MEAN ANALYTICAL RESULT:			457.4 ppm		MEAN ANALYTICAL RESULT:			457.2 ppm

Analyst: 	Approved by:
---------------------	-------------------------



AIR LIQUIDE

CERTIFICATE OF ANALYSIS

Interference-Free Multi-Component EPA Protocol Gases

Note: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121
Section No. 2.2, Procedure . G-1

Cylinder Number: CC171920

Customer: AIR HYGIENE
HUMBLE, TX
P.O. Number: RECERTIFICATION
Item Number: AH043

Shipping Order Number 16169268
Transfer Number:
Lot Number: SFS85767
Valve: CGA 350
Cyl. Pressure*: 1667 PSIG

Assay Date: 25-Jul-05

Expiration Date: 25-Jul-08

*Cylinder should not be used when
gas pressure is below 150 psig

Component	REQUESTED Concentration	ASSAY Concentration
Carbon Monoxide	4000 ppm	4010 ± 60 ppm
Nitrogen	Balance	Balance

Reference Standard Employed For Analysis:

Concentration	Component	Balance	Cyl. No.	SRM or GMIS NTRM No.	Exp. Date	Sample No.	Type
4980 ± 50 ppm	Carbon Monoxide	Nitrogen	AL-1927	12223	06/02/07	BY	GMIS

Analysis Information:

Component	Carbon Monoxide	First Triad Analysis 07/18/05				Second Triad Analysis 07/25/05					
		Zero	Trial 1	Trial 2	Trial 3	Zero	Trial 4	Trial 5	Trial 6	Units	
Manufacturer:	Varian(B)	0	0	0	0	0	0	0	ppm		
Model Number:	3400	Reference	5000	5008	5000	Reference	5004	5010	4994	ppm	
Serial Number:	2806	Candidate	4024	4027	4025	Candidate	4023	4024	4018	ppm	
MPR Last Calibrated:	06/27/05	Result	4008	4004	4009	Result	4004	4000	4007	ppm	
Analytical Principle:	FID & TCD	Evaluation	VALID	VALID	VALID	Evaluation	VALID	VALID	VALID	ppm	
MEAN ANALYTICAL RESULT:					4007	ppm	MEAN ANALYTICAL RESULT: 4003 ppm				

Analyst Signature:  Eric Barron

Approved by:  David Connolly



CERTIFICATE of ANALYSIS

Interference-Free Multi-Component EPA Protocol Gases

NOTE: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121
Section 2.2 Procedure: G-1

Cyl. Number: CC178135

Customer: Air Hygiene
P.O. Number: 5021102
Item Number: AH-042
Notes:

Shipping Order #: 15321147
Transfer #: 15321147
LOT #: LPX114669
Valve: CGA350
Cyl. Pressure:* 1900psig

*Cylinder should not be used when gas pressure is below 150 psig

Assay Date: 8-Mar-05

Expiration Date: 7-Mar-08

Component	Requested Concentration	Assay Concentration
Carbon Monoxide	1800 ppm	1810 ±10 ppm
Nitrogen	Balance	Balance

Reference Standard(s) Employed For Analysis:

Std name	Std #	Conc.	Units	Std. Error	Comp.	Balance	Cyl. No.	Exp. Date	Sample No.
GMIS233	GMIS233	2452.0	ppm	10.0	CO	N2	CC108277	4/17/2005	N.A.

Analysis Information:

Component 1: Carbon Monoxide		First Triad Analysis On: 3/1/2005				Second Triad Analysis On: 3/8/2005					
Analyzer Information		Trial 1	Trial 2	Trial 3	Units	Trial 1	Trial 2	Trial 3	Units		
Manufacturer:	KVB/Analect	Zero	-0.54	0.50	0.17	Zero	-0.02	0.13	0.11		
Model Number:	EN3024	Reference	2359.69	2367.34	2371.32	Reference	2344.65	2347.36	2352.17		
Serial Number:	3024	Candidate	1748.98	1748.03	1741.12	Candidate	1737.56	1730.56	1734.16		
Analytical Principle:	FTIR	Result	1812.45	1811.46	1804.30	Result	1814.45	1807.14	1810.90		
MPC Calibrated:	02/21/05	Mean Result:			1809.40	ppm	Mean Result:			1810.83	ppm

Analyst Signature: Bryan Leger

Calculated by: Yang Qin



CERTIFICATE of ANALYSIS

Interference-Free Multi-Component EPA Protocol Gases

NOTE: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121

Section 2.2

Procedure: G-1

Customer:	AIR HYGIENE	Cyl. Number:	CC13526	Shipping Order #:	16895569
P.O. Number:				Transfer #:	16895569
Item Number:	AH085			LOT #:	LPX121940
Notes:				Valve:	CGA660
				Cyl. Pressure:*	1900psig

*Cylinder should not be used when gas pressure is below 150 psig

Assay Date: 6-Jul-05 Expiration Date: 6-Jul-07

Component	Requested Concentration	Assay Concentration
Sulfur Dioxide	45 ppm	45.9 ±0.6 ppm
Nitrogen	Balance	Balance

Reference Standard(s) Employed For Analysis:

Std name	Std #	Conc.	Units	Std. Error	Comp.	Balance	Cyl. No.	Exp. Date	Sample No.
GMIS263	GMIS263	103.0	ppm	0.4	SO2	N2	CC28420	3/15/2006	N.A.

Analysis Information:

Component 1: Sulfur Dioxide		First Triad Analysis On: 6/29/2005				Second Triad Analysis On: 7/6/2005			
Analyzer Information		Trial 1	Trial 2	Trial 3	Units	Trial 1	Trial 2	Trial 3	Units
Manufacturer:	KVB/Analect	0.02	0.03	0.02		-0.34	-0.27	0.10	
Model Number:	EN3024	100.63	100.63	99.99		100.02	100.17	100.21	
Serial Number:	3024	45.43	45.47	45.00		43.66	43.96	44.50	
Analytical Principle:	FTIR	46.59	46.63	46.14	ppm	45.00	45.31	45.87	ppm
MPC Calibrated:	06/16/05	Mean Result: 46.45			ppm	Mean Result: 45.40			ppm

Analyst Signature: Bryan Leger

Calculated by: M. Adnane



WEST

CERTIFICATE of ANALYSIS

Interference-Free Multi-Component EPA Protocol Gases

NOTE: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121
Section 2.2 Procedure: G-1

Customer: AIR HYGIENE Cyl. Number: CC2463 Shipping Order #: 16910596
 P.O. Number: Transfer #: 16910596
 Item Number: AH086 LOT #: LPX121970
 Notes: Valve: CGA660
 Cyl. Pressure:* 1900psig
 *Cylinder should not be used when gas pressure is below 150 psig

Assay Date: 6-Jul-05 Expiration Date: 6-Jul-07

Component	Requested Concentration	Assay Concentration
Sulfur Dioxide	85 ppm	84.7 ±0.5 ppm
Nitrogen	Balance	Balance

Reference Standard(s) Employed For Analysis:

Std name	Std #	Conc.	Units	Std. Error	Comp.	Balance	Cyl. No.	Exp. Date	Sample No.
GMIS263	GMIS263	103.0	ppm	0.4	SO2	N2	CC28420	3/15/2006	N.A.

Analysis Information:

Component 1: Sulfur Dioxide		First Triad Analysis On: 6/29/2005				Second Triad Analysis On: 7/6/2005			
Analyzer Information		Trial 1	Trial 2	Trial 3	Units	Trial 1	Trial 2	Trial 3	Units
Manufacturer:	KVB/Analect	0.02	0.03	0.02		-0.34	-0.27	0.10	
Model Number:	EN3024	100.63	100.63	99.99		100.02	100.17	100.21	
Serial Number:	3024	82.43	82.41	82.30		82.61	81.89	83.31	
Analytical Principle:	FTIR	84.55	84.53	84.42	ppm	85.01	84.26	85.72	ppm
MPC Calibrated:	06/16/05	Mean Result: 84.50			ppm	Mean Result: 85.00			ppm

Analyst Signature: Bryan Leger

Calculated by: M. Adnane



1290 COMBERMERE STREET, TROY, MI 48083

Phone: 248-589-2950

Fax: 248-589-2134

CERTIFICATE OF ACCURACY: EPA Protocol Gas

Assay Laboratory

SCOTT SPECIALTY GASES
1290 COMBERMERE STREET
TROY, MI 48083

P.O. No.: 55302-71-65000
Project No.: 05-49082-025

Customer

CLEAN AIR ENGINEERING
DON ALLEN
500 W. WOOD STREET
PALATINE IL 60067

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: ALM019950 Certification Date: 01Dec2006 Exp. Date: 30Nov2008
Cylinder Pressure***: 1900 PSIG

COMPONENT

CERTIFIED CONCENTRATION (Moles)

ANALYTICAL

ACCURACY**

TRACEABILITY

SULFUR DIOXIDE *
NITROGEN

197.0 PPM
BALANCE

+/- 1%

Direct NIST and NMI

*** Do not use when cylinder pressure is below 150 psig.

** Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

* This Protocol has been certified using corrected NIST SO2 standard values, per EPA guidance dated 7/24/96 and will not correlate with uncorrected

REFERENCE STANDARD

Table with 5 columns: TYPE/SRMI NO., EXPIRATION DATE, CYLINDER NUMBER, CONCENTRATION, COMPONENT. Row 1: NTRM 1661, 15Aug2009, ALM037811, 506.4 PPM, SULFUR DIOXIDE

INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#

/2030/0928621

DATE LAST CALIBRATED

01Nov2006

ANALYTICAL PRINCIPLE

ANALYZER READINGS

(Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

First Triad Analysis

Second Triad Analysis

Calibration Curve

SULFUR DIOXIDE *

Table with 3 columns: Date, Response, Unit:PPM. Data for 23Nov2006 analysis.

Table with 3 columns: Date, Response, Unit: PPM. Data for 01Dec2006 analysis.

Table with 2 columns: Concentration = A + Bx + Cx2 + Dx3 + Ex4, Constants. r = 0.999999.

Handwritten signature

APPROVED BY: _____



CERTIFICATE of ANALYSIS

Interference-Free Multi-Component EPA Protocol Gases

NOTE: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121
Section 2.2 Procedure: G-1

Customer:	AIR HYGIENE	Cyl. Number:	SC022886B	Shipping Order #:	16895569
P.O. Number:				Transfer #:	16895569
Item Number:	AH087			LOT #:	LPX121941
Notes:				Valve:	CGA660
				Cyl. Pressure:*	1900psig
Assay Date:	6-Jul-05	Expiration Date:	6-Jul-07	*Cylinder should not be used when gas pressure is below 160 psig	

Component	Requested Concentration	Assay Concentration
Sulfur Dioxide	250 ppm	252 ±2 ppm
Nitrogen	Balance	Balance

Reference Standard(s) Employed For Analysis:

Std name	Std #	Conc.	Units	Std. Error	Comp.	Balance	Cyl. No.	Exp. Date	Sample No.
GMIS263	GMIS263	103.0	ppm	0.4	SO2	N2	CC28420	3/15/2006	N.A.

Analysis Information:

Component 1: Sulfur Dioxide		First Triad Analysis On: 6/29/2005			Second Triad Analysis On: 7/6/2005				
Analyzer Information		Trial 1	Trial 2	Trial 3	Units	Trial 1	Trial 2	Trial 3	Units
Manufacturer:	KVB/Analect	Zero	0.02	0.03	0.02	Zero	-0.34	-0.27	0.10
Model Number:	EN3024	Reference	100.63	100.63	99.99	Reference	100.02	100.17	100.21
Serial Number:	3024	Candidate	245.67	248.15	246.50	Candidate	243.44	248.13	243.61
Analytical Principle:	FTIR	Result	252.01	254.56	252.87	Result	250.16	254.98	250.33
MPC Calibrated:	06/16/05	Mean Result:	253.15			Mean Result:	251.82		
					ppm				ppm

Analyst Signature: Bryan Leger

Calculated by: M. Adnane



CERTIFICATE of ANALYSIS

Interference-Free Multi-Component EPA Protocol Gases

NOTE: Analytical uncertainty and NIST traceability are in compliance with EPA-600/R-97/121

Section 2.2

Procedure: G-1

Cyl. Number: CC192242

Customer: AIR HYGIENE
P.O. Number:
Item Number: AH088
Notes:

Shipping Order #: 18651280
Transfer #: 18651280
LOT #: LPX129533
Valve: CGA660
Cyl. Pressure*: 1900psig

Assay Date: 28-Nov-05

Expiration Date: 28-Nov-07

*Cylinder should not be used when gas pressure is below 150 psig

Component	Requested Concentration	Assay Concentration
Sulfur Dioxide	425 ppm	428 ±3 ppm
Nitrogen	Balance	Balance

Reference Standard(s) Employed For Analysis:

Std name	Std #	Conc.	Units	Std. Error	Comp.	Balance	Cyl. No.	Exp. Date	Sample No.
GMIS173	GMIS173	753.0	ppm	4.0	SO2	N2	AL-2738	5/16/2007	N.A.

Analysis Information:

Component 1: Sulfur Dioxide		First Triad Analysis On: 11/17/2005				Second Triad Analysis On: 11/28/2005			
Analyzer Information		Trial 1	Trial 2	Trial 3	Units	Trial 1	Trial 2	Trial 3	Units
Manufacturer:	KVB/Analect	Zero	-0.23	0.16	0.26	Zero	0.11	-0.01	0.22
Model Number:	EN3024	Reference	747.28	742.68	745.53	Reference	746.65	750.96	741.90
Serial Number:	3024	Candidate	423.08	422.60	423.40	Candidate	424.31	424.08	426.21
Analytical Principle:	FTIR	Result	427.50	427.02	427.82	Result	427.96	427.72	429.87
MPC Calibrated:	11/03/05		Mean Result: 427.45				Mean Result: 428.52		
					ppm				ppm

Analyst Signature: Bryan Leger

Calculated by: M. Adnane

APPENDIX D

QUALITY ASSURANCE AND QUALITY CONTROL DATA

QA/QC PROGRAM

Air Hygiene ensures the quality and validity of its emission measurement and reporting procedures through a rigorous quality assurance (QA) program. The program is developed and administered by an internal QA team and encompasses five major areas:

1. QA reviews of reports, laboratory work, and field testing
2. Equipment calibration and maintenance
3. Chain-of-custody
4. Training
5. Knowledge of current test methods

Each of these areas is discussed individually below.

QA Reviews

Air Hygiene's review procedure includes review of each source test report, along with laboratory and fieldwork, by the QA Team. The most important review is the one that takes place before a test program begins. The QA Team works closely with technical division personnel to prepare and review test protocols. Test protocol review includes selection of appropriate test procedures, evaluation of interferences or other restrictions that might preclude use of standard test procedures, and evaluation and/or development of alternate procedures.

Equipment Calibration and Maintenance

The equipment used to conduct the emission measurements is maintained according to the manufacturer's instructions to ensure proper operation. In addition to the maintenance program, calibrations are carried out on each measurement device according to the schedule outlined by the Environmental Protection Agency. Quality control checks are also conducted in the field for each test program.

Chain-of-Custody

Air Hygiene maintains full chain-of-custody documentation on all samples and data sheets. In addition to normal documentation of changes between field sample custodians, laboratory personnel, and field test personnel, Air Hygiene documents every individual who handles any test component in the field (e.g., probe wash, impinger loading and recovery, filter loading and recovery, etc.). Samples are stored in a locked area to which only Air Hygiene personnel have access. Field data sheets are secured at Air Hygiene's offices upon return from the field.

Training

Personnel's training is essential to ensure quality testing. Air Hygiene has formal and informal training programs, which include:

1. Attendance at EPA-sponsored training courses
2. Enrollment in EPA correspondence courses
3. A requirement for all technicians to read and understand Air Hygiene's QA manual
4. In-house training and QA meetings on a regular basis
5. Maintenance of training records

Knowledge of Current Test Methods

With the constant updating of standard test methods and the wide variety of emerging test procedures, it is essential that any qualified source tester keep abreast of new developments. Air Hygiene subscribes to services, which provide updates on EPA reference methods, rules, and regulations. Additionally, source test personnel regularly attend and present papers at testing and emission-related seminars and conferences. Air Hygiene personnel maintain membership in the Air and Waste Management Association and the American Industrial Hygiene Association.

COMBUSTION TESTING QUALITY ASSURANCE ACTIVITIES

A number of quality assurance activities were undertaken before, during, and after this testing project. This section of the report combined with the documentation in Appendix C describe each of those activities.

Each instrument's response was checked and adjusted in the field prior to the collection of data via multi-point calibration. The instrument's linearity was checked by adjusting its zero and span responses to zero nitrogen and an upscale calibration gas in the range of the expected concentrations. The instrument response was then challenged with other calibration gases of known concentration and accepted as being linear if the response of the other calibration gases agreed within \pm two percent of the range of predicted values. NO₂ to NO conversion was checked via direct connect with an EPA Protocol certified concentration of NO₂ in a balance of nitrogen. Conversion was verified to be between 90 and 110 percent.

After each test run, the analyzers were checked for zero and span drift. This allowed each test run to be bracketed by calibrations and documents the precision of the data just collected. The criterion for acceptable data is that the instrument drift is no more than three percent of the full-scale response. The quality assurance worksheets in the following pages summarize all multipoint calibration checks and zero to span checks performed during the tests. These worksheets (as prepared from the data records of Appendix A) show that no drifts in excess of three percent occurred in the zero to span checks following each test run.

The sampling systems were leak checked by demonstrating that a vacuum greater than 10 in Hg could be held for at least one minute with a decline of less than one in. Hg. A leak test was conducted after the sample system was set up and before the system was dismantled. This test was conducted to ensure that ambient air had not diluted the sample. Any leakage detected prior to the tests would be repaired and another leak check conducted before testing commenced. No leaks were found during the pre or post-test leak checks.

The absence of leaks in the sampling system was also verified by a sampling system bias check. The sampling system's integrity was tested by comparing the responses of the analyzers to the calibration gases introduced via two paths. The first path was directly into the analyzer and the second path via the sample system at the sample probe. Any difference in the instrument responses by these two methods was attributed to sampling system bias or leakage. The criterion for acceptance is agreement within five percent of the span of the analyzer.

The control gases used to calibrate the instruments were analyzed and certified by the compressed gas vendors to plus or minus one percent accuracy for all gases. EPA Protocol No. 1 was used, where applicable to assign the concentration values traceable to the National Institute of Standards and Technology (NIST), Standard Reference Materials (SRM's). The gas calibration sheets as prepared by the vendor are contained in Appendix C.

Air Hygiene collected and reported the enclosed test data in accordance with the procedures and quality assurance activities described in this test report. Air Hygiene makes no warranty as to the suitability of the test methods. Air Hygiene also assumes no liability relating to the interpretation and use of the test data.

INSTRUMENTAL ANALYSIS QUALITY ASSURANCE DATA

Date: July 2-4, 2007
Company: Fibrominn, LLC
Location: Benson, Minnesota
Techs: TKG


Sample System Leak Check

Date	Sample System	Leak Rate (l/min)
July 2-4, 2007	1	0
July 2-4, 2007	2	0

Calibration Date: July 2, 2007
 Client: Fibrominn, LLC
 Location: Stack Outlet


NOx Span (ppm) = 254.00

THERMO 42C (NOx Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2%, ≤0.5ppm)
0.00	-0.67	-0.26	0.67	YES (%)
111.00	108.66	-0.92	2.34	YES (%)
254.00	253.55	-0.18	0.45	YES (%)
Linearity = 0.998				




CO Span (ppm) = 457.00

THERMO 48C (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2%, ≤0.5ppm)
0.00	0.43	0.09	0.43	YES (%)
220.00	222.91	0.64	2.91	YES (%)
457.00	458.23	0.27	1.23	YES (%)
Linearity = 0.998				




O2 Span (%) = 21.00

SERVOMEX 1440 (O2 Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass or Fail (±2%, ≤0.5%)
0.00	0.04	0.19	0.04	YES (%)
12.00	12.13	0.62	0.13	YES (%)
21.00	21.03	0.14	0.03	YES (%)
Linearity = 1.000				




CO Span (ppm) = 4010.00

THERMO 48C (CO Analyzer) - High Range				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2%, ≤0.5ppm)
0.00	0.43	0.01	0.43	YES (%)
1810.00	1804.47	-0.14	5.53	YES (%)
4010.00	4000.09	-0.25	9.91	YES (%)
Linearity = 1.003				




CO2 Span (%) = 19.00

SERVOMEX 1440 (CO2 Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass or Fail (±2%, ≤0.5%)
0.00	0.07	0.37	0.07	YES (%)
8.97	9.04	0.37	0.07	YES (%)
19.00	19.07	0.37	0.07	YES (%)
Linearity = 1.000				



SO2 Span (ppm) = 84.70

THERMO 43C (SO2 Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2%, ≤0.5ppm)
0.00	0.04	0.05	0.04	YES (%)
45.90	47.56	1.96	1.66	YES (%)
84.70	85.14	0.52	0.44	YES (%)
Linearity = 0.994				



NOx Converter Efficiency

Date: July 2, 2007

Analyzer: INST-NX-0012

RM 7E, (08-15-06), 8.2.4.1 Introduce a concentration of 40 to 60 ppmv NO₂ to the analyzer in direct calibration mode and record the NOx concentration displayed by the analyzer. ... Calculate the converter efficiency using Equation 7E-7 in Section 12.7. The specification for converter efficiency in Section 13.5 must be met. ... The NO₂ must be prepared according to the EPA Traceability Protocol and have an accuracy within 2.0 percent.

Audit Gas: NO₂ Concentration (C_v), ppmvd **47.60**

Converter Efficiency Calculations:

Analyzer Reading, NO Channel, ppmvd **2.73**
Analyzer Reading, NOx Channel, ppmvd **47.58**
Analyzer Reading, NO₂ Channel (C_{Dir(NO2)}), ppmvd **44.85**
Converter Efficiency, % **94.22**

RM 7E, (08-15-06), 13.5 NO₂ to NO Conversion Efficiency Test (as applicable). The NO₂ to NO conversion efficiency, calculated according to Equation 7E-7 or Equation 7E-9, must be greater than or equal to 90 percent.


$$Eff_{NO_2} = \left(\frac{C_{Dir}}{C_V} \right) \times 100 \quad \text{Eq. 7E-7} = \frac{44.85 \text{ ppmvd}}{47.60 \text{ ppmvd}} \times 100 = 94.22\%$$

Date/Time	Elapsed Time	NOx	NO
mm/dd/yy hh:mm:ss	Seconds	ppmvd	ppmvd
07/02/07 06:36:11	1680	8.88	0.63
07/02/07 06:36:41	1710	41.91	2.49
07/02/07 06:37:11	1740	45.22	2.57
07/02/07 06:37:41	1770	46.54	2.62
07/02/07 06:38:11	1800	47.58	2.73
07/02/07 06:38:41	1830	47.56	2.82
07/02/07 06:39:11	1860	36.48	2.03
07/02/07 06:39:41	1890	10.59	-0.34

Calibration Date: July 2, 2007
 Client: Fibrominn, LLC
 Location: SDA Inlet


CO Span (ppm) = 4010.00

THERMO 48 (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2%, ≤0.5ppm)
0.00	0.00	0.00	0.00	YES (%)
1810.00	1821.47	0.29	11.47	YES (%)
4010.00	4007.25	-0.07	2.75	YES (%)
Linearity = 1.001				




O2 Span (%) = 21.00

M&C PMA 22 (O ₂ Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass or Fail (±2%, ≤0.5%)
0.00	-0.06	-0.29	0.06	YES (%)
12.00	12.06	0.29	0.06	YES (%)
21.00	20.88	-0.57	0.12	YES (%)
Linearity = 1.002				




CO₂ Span (%) = 19.00

FUJI 3300 (CO ₂ Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass or Fail (±2%, ≤0.5%)
0.00	-0.02	-0.11	0.02	YES (%)
8.97	9.01	0.21	0.04	YES (%)
19.00	19.00	0.00	0.00	YES (%)
Linearity = 0.999				



SO₂ Span (ppm) = 428.00


AMETEK 721M (SO ₂ Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2%, ≤0.5ppm)
0.00	0.87	0.20	0.87	YES (%)
252.00	258.28	1.47	6.28	YES (%)
428.00	430.79	0.65	2.79	YES (%)
Linearity = 0.994				



Calibration Date: July 3, 2007
 Client: Fibrominn, LLC
 Location: Stack Outlet


NOx Span (ppm) = 254.00

THERMO 42C (NOx Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2%, ≤0.5ppm)
0.00	-0.48	-0.19	0.48	YES (%)
111.00	109.64	-0.54	1.36	YES (%)
254.00	253.66	-0.13	0.34	YES (%)
Linearity = 0.999				




CO Span (ppm) = 457.00

THERMO 48C (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2%, ≤0.5ppm)
0.00	0.42	0.09	0.42	YES (%)
220.00	221.91	0.42	1.91	YES (%)
457.00	457.22	0.05	0.22	YES (%)
Linearity = 1.001				




O2 Span (%) = 21.00

SERVOMEX 1440 (O ₂ Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass or Fail (±2%, ≤0.5%)
0.00	-0.03	-0.14	0.03	YES (%)
12.00	12.01	0.05	0.01	YES (%)
21.00	20.89	-0.52	0.11	YES (%)
Linearity = 1.003				




CO Span (ppm) = 4010.00

THERMO 48C (CO Analyzer) - High Range				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2%, ≤0.5ppm)
0.00	0.42	0.01	0.42	YES (%)
1810.00	1820.33	0.26	10.33	YES (%)
4010.00	4037.25	0.68	27.25	YES (%)
Linearity = 0.993				




CO2 Span (%) = 19.00

SERVOMEX 1440 (CO ₂ Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass or Fail (±2%, ≤0.5%)
0.00	0.01	0.05	0.01	YES (%)
8.97	8.82	-0.79	0.15	YES (%)
19.00	19.00	0.00	0.00	YES (%)
Linearity = 1.000				



SO2 Span (ppm) = 84.70

THERMO 43C (SO ₂ Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2%, ≤0.5ppm)
0.00	0.35	0.41	0.35	YES (%)
45.90	46.62	0.85	0.72	YES (%)
84.70	85.45	0.89	0.75	YES (%)
Linearity = 0.995				



NOx Converter Efficiency

Date: July 3, 2007

Analyzer: INST-NX-0012

RM 7E, (08-15-06), 8.2.4.1 Introduce a concentration of 40 to 60 ppmv NO₂ to the analyzer in direct calibration mode and record the NOx concentration displayed by the analyzer. ... Calculate the converter efficiency using Equation 7E-7 in Section 12.7. The specification for converter efficiency in Section 13.5 must be met. ... The NO₂ must be prepared according to the EPA Traceability Protocol and have an accuracy within 2.0 percent.

Audit Gas:	NO ₂ Concentration (C _v), ppmvd	47.60
Converter Efficiency Calculations:		
	Analyzer Reading, NO Channel, ppmvd	2.55
	Analyzer Reading, NOx Channel, ppmvd	48.34
	Analyzer Reading, NO ₂ Channel (C _{Dir(NO2)}), ppmvd	45.79
	Converter Efficiency, %	96.20

RM 7E, (08-15-06), 13.5 NO₂ to NO Conversion Efficiency Test (as applicable). The NO₂ to NO conversion efficiency, calculated according to Equation 7E-7 or Equation 7E-9, must be greater than or equal to 90 percent.


$$Eff_{NO_2} = \left(\frac{C_{Dir}}{C_V} \right) \times 100 \quad \text{Eq. 7E-7} = \frac{45.79 \text{ ppmvd}}{47.60 \text{ ppmvd}} \times 100 = 96.2\%$$

Date/Time	Elapsed Time	NOx	NO
mm/dd/yy hh:mm:ss	Seconds	ppmvd	ppmvd
07/03/07 06:24:56	1440	60.87	23.11
07/03/07 06:25:26	1470	45.75	3.55
07/03/07 06:25:56	1500	47.04	2.96
07/03/07 06:26:26	1530	48.20	2.57
07/03/07 06:26:56	1560	48.34	2.55
07/03/07 06:27:26	1590	31.29	2.09
07/03/07 06:27:56	1620	3.06	-0.24
07/03/07 06:28:26	1650	-0.33	-0.15

Calibration Date: July 3, 2007
 Client: Fibrominn, LLC
 Location: SDA Inlet


CO Span (ppm) = 4010.00

THERMO 48 (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2%, ≤0.5ppm)
0.00	-0.24	-0.01	0.24	YES (%)
1810.00	1821.54	0.29	11.54	YES (%)
4010.00	4007.88	-0.05	2.12	YES (%)
Linearity = 1.001				




O2 Span (%) = 21.00

M&C PMA 22 (O ₂ Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass or Fail (±2%, ≤0.5%)
0.00	-0.08	-0.38	0.08	YES (%)
12.00	11.99	-0.05	0.01	YES (%)
21.00	20.98	-0.10	0.02	YES (%)
Linearity = 0.997				




CO₂ Span (%) = 19.00

FUJI 3300 (CO ₂ Analyzer)				
Certified Concentration (%)	Instrument Response (%)	Calibration Error (%)	Absolute Conc. (%)	Pass or Fail (±2%, ≤0.5%)
0.00	0.12	0.63	0.12	YES (%)
8.97	9.02	0.26	0.05	YES (%)
19.00	19.01	0.05	0.01	YES (%)
Linearity = 1.006				



SO₂ Span (ppm) = 428.00

AMETEK 721M (SO ₂ Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail (±2%, ≤0.5ppm)
0.00	-0.89	-0.21	0.89	YES (%)
252.00	255.25	0.76	3.25	YES (%)
428.00	427.85	-0.04	0.15	YES (%)
Linearity = 0.997				



DRIFT AND BIAS CHECK			
Strat Test Pre and Post QA/QC Check	O2	NOx	CO
Initial Zero	0.22	-0.64	0.45
Final Zero	0.01	-0.21	0.67
Avg. Zero	0.12	-0.43	0.56
Initial UpScale	12.14	105.86	220.13
Final UpScale	12.04	108.07	221.77
Avg. UpScale	12.09	106.97	220.95
Sys Resp (Zero)	0.04	-0.67	0.43
Sys Resp (Upscale)	12.13	108.66	222.91
Upscale Cal Gas	12.00	111.00	220.00
Initial Zero Bias	0.86%	0.01%	0.00%
Final Zero Bias	-0.14%	0.18%	0.05%
Zero Drift	1.00%	0.17%	0.05%
Initial Upscale Bias	0.05%	-1.10%	-0.61%
Final Upscale Bias	-0.43%	-0.23%	-0.25%
Upscale Drift	0.48%	0.87%	0.36%
Initial Zero	0.18	0.03	0.02
Final Zero	0.03	0.46	0.24
Initial Upscale	0.01	2.80	2.78
Final Upscale	0.09	0.59	1.14
Calibration Span	21.00	254.00	457.00
3% of Range (drift)	0.63	7.62	13.71
5% of Range (bias)	1.05	12.70	22.85

Response Time (min)	0.3	0.8	0.7
Sys. Response (min)	0.8		

Date/Time mm/dd/yy hh:mm:ss	O2-10 %	NOx-10 ppm	CO-10 ppm
07/02/07 06:48:11	20.89	-0.46	2.30
07/02/07 06:48:21	17.13	-0.46	14.50
07/02/07 06:48:31	12.54	-0.40	54.63
07/02/07 06:48:41	12.20	-0.35	54.58
07/02/07 06:48:51	12.17	-0.49	36.40
07/02/07 06:49:01	12.16	-0.26	13.62
07/02/07 06:49:11	12.14	-0.35	4.00
07/02/07 06:49:21	12.15	-0.65	1.53
07/02/07 06:49:31	12.14	-0.62	1.22
07/02/07 06:49:41	12.15	-0.68	0.54
07/02/07 06:49:51	12.13	-0.70	0.45
07/02/07 06:50:01	12.15	-0.65	0.62
07/02/07 06:50:11	12.15	-0.48	0.76
07/02/07 06:50:21	12.13	-0.32	0.81
07/02/07 06:50:31	12.13	-0.29	0.73
07/02/07 06:50:41	12.12	-0.35	0.62
07/02/07 06:50:51	12.13	-0.40	0.59
07/02/07 06:51:01	12.14	-0.57	0.54
07/02/07 06:51:11	13.00	-0.48	0.70
07/02/07 06:51:21	11.72	-0.40	0.64
07/02/07 06:51:31	1.20	-1.01	0.45
07/02/07 06:51:41	0.33	-0.51	0.48
07/02/07 06:51:51	0.28	49.84	0.78
07/02/07 06:52:01	0.25	98.84	1.58
07/02/07 06:52:11	0.26	101.81	1.42
07/02/07 06:52:21	0.24	104.52	1.42
07/02/07 06:52:31	0.26	105.68	1.50
07/02/07 06:52:41	0.24	105.46	1.28
07/02/07 06:52:51	0.25	105.43	1.31
07/02/07 06:53:01	0.24	105.57	1.53
07/02/07 06:53:11	0.23	105.40	1.31
07/02/07 06:53:21	0.24	105.84	1.80
07/02/07 06:53:31	0.22	105.86	1.80
07/02/07 06:53:41	0.23	105.78	1.72
07/02/07 06:53:51	0.23	105.95	1.83
07/02/07 06:54:01	0.25	105.86	1.64
07/02/07 06:54:11	6.04	106.17	2.05
07/02/07 06:54:21	0.79	103.58	11.22
07/02/07 06:54:31	0.26	83.08	60.47
07/02/07 06:54:41	0.23	61.38	135.78
07/02/07 06:54:51	0.24	28.96	192.85
07/02/07 06:55:01	0.21	1.55	214.64
07/02/07 06:55:11	0.22	0.75	218.82
07/02/07 06:55:21	0.22	0.40	219.05
07/02/07 06:55:31	0.20	0.23	220.38

DRIFT AND BIAS CHECK		
Strat Test Pre and Post QA/QC Check	O2	SO2
Initial Zero	-0.02	2.16
Final Zero	-0.06	1.07
Avg. Zero	-0.04	1.62
Initial UpScale	11.99	250.61
Final UpScale	11.92	248.41
Avg. UpScale	11.96	249.51
Sys Resp (Zero)	-0.06	0.87
Sys Resp (Upscale)	12.06	258.28
Upscale Cal Gas	12.00	252.00
Initial Zero Bias	0.19%	0.30%
Final Zero Bias	0.00%	0.05%
Zero Drift	0.19%	0.25%
Initial Upscale Bias	-0.33%	-1.79%
Final Upscale Bias	-0.67%	-2.31%
Upscale Drift	0.33%	0.51%
Initial Zero	0.04	1.29
Final Zero	0.00	0.20
Initial Upscale	0.07	7.67
Final Upscale	0.14	9.87
Calibration Span	21.00	428.00
3% of Range (drift)	0.63	12.84
5% of Range (bias)	1.05	21.40

Response Time (min)	0.5	1.3
Sys. Response (min)	1.3	

Date/Time	O2IN-10	SO2IN-10
mm/dd/yy hh:mm:ss	%	ppm
07/02/07 06:46:11	20.87	1.59
07/02/07 06:46:21	16.50	1.56
07/02/07 06:46:31	12.39	2.20
07/02/07 06:46:41	11.99	2.36
07/02/07 06:46:51	11.97	2.39
07/02/07 06:47:01	11.97	2.17
07/02/07 06:47:11	11.98	2.17
07/02/07 06:47:21	11.99	1.67
07/02/07 06:47:31	11.99	1.84
07/02/07 06:47:41	11.99	1.34
07/02/07 06:47:51	11.99	1.51
07/02/07 06:48:01	12.00	1.40
07/02/07 06:48:11	8.44	11.31
07/02/07 06:48:21	0.10	150.10
07/02/07 06:48:31	-0.05	202.36
07/02/07 06:48:41	-0.20	219.02
07/02/07 06:48:51	-0.14	228.87
07/02/07 06:49:01	-0.08	234.89
07/02/07 06:49:11	-0.27	236.13
07/02/07 06:49:21	-0.02	240.95
07/02/07 06:49:31	-0.02	243.02
07/02/07 06:49:41	-0.02	244.43
07/02/07 06:49:51	-0.04	245.78
07/02/07 06:50:01	-0.04	246.75
07/02/07 06:50:11	-0.03	247.16
07/02/07 06:50:21	-0.03	249.04
07/02/07 06:50:31	-0.02	248.85
07/02/07 06:50:41	-0.02	249.76
07/02/07 06:50:51	-0.02	250.61
07/02/07 06:51:01	3.09	248.96
07/02/07 06:51:11	19.74	171.83

DRIFT AND BIAS CHECK						
High Load, Run - Out-1	O2	NOx	CO	CO2	SO2	
Raw Average	5.30	86.21	230.77	14.09	64.96	
Corrected Average	5.35	90.31	229.25	14.46	64.35	
Initial Zero	0.02	-0.49	0.59	0.08	0.91	
Final Zero	-0.02	0.53	1.51	0.05	0.83	
Avg. Zero	0.00	0.02	1.05	0.07	0.87	
Initial UpScale	11.94	106.88	221.78	8.75	47.44	
Final UpScale	11.85	105.04	221.23	8.79	45.74	
Avg. UpScale	11.90	105.96	221.51	8.77	46.59	
Sys Resp (Zero)	-0.03	-0.48	0.42	0.01	0.35	
Sys Resp (Upscale)	12.01	109.64	221.91	8.82	46.62	
Upscale Cal Gas	12.00	111.00	220.00	8.97	45.90	
Initial Zero Bias	0.24%	0.00%	0.04%	0.37%	0.66%	
Final Zero Bias	0.05%	0.40%	0.24%	0.21%	0.57%	
Zero Drift	0.19%	0.40%	0.20%	0.16%	0.09%	
Initial Upscale Bias	-0.33%	-1.09%	-0.03%	-0.37%	0.97%	
Final Upscale Bias	-0.76%	-1.81%	-0.15%	-0.16%	-1.04%	
Upscale Drift	0.43%	0.72%	0.12%	0.21%	2.01%	
Alternative Specification Abs Diff	Initial Zero	0.05	0.01	0.17	0.07	0.56
	Final Zero	0.01	1.01	1.09	0.04	0.48
	Initial Upscale	0.07	2.76	0.13	0.07	0.82
	Final Upscale	0.16	4.60	0.68	0.03	0.88
Calibration Span	21.00	254.00	457.00	19.00	84.70	
3% of Range (drift)	0.63	7.62	13.71	0.57	2.54	
5% of Range (bias)	1.05	12.70	22.85	0.95	4.24	

DRIFT AND BIAS CHECK						
High Load, Run - Out-2	O2	NOx	CO	CO2	SO2	
Raw Average	4.81	73.92	261.72	14.52	64.60	
Corrected Average	4.88	77.80	260.13	14.86	65.95	
Initial Zero	-0.02	0.53	1.51	0.05	0.83	
Final Zero	-0.02	1.00	0.91	0.12	0.24	
Avg. Zero	-0.02	0.77	1.21	0.09	0.54	
Initial UpScale	11.85	105.04	221.23	8.79	45.74	
Final UpScale	11.86	105.25	221.82	8.81	44.51	
Avg. UpScale	11.86	105.15	221.53	8.80	45.13	
Sys Resp (Zero)	-0.03	-0.48	0.42	0.01	0.35	
Sys Resp (Upscale)	12.01	109.64	221.91	8.82	46.62	
Upscale Cal Gas	12.00	111.00	220.00	8.97	45.90	
Initial Zero Bias	0.05%	0.40%	0.24%	0.21%	0.57%	
Final Zero Bias	0.05%	0.58%	0.11%	0.58%	-0.13%	
Zero Drift	0.00%	0.19%	0.13%	0.37%	0.70%	
Initial Upscale Bias	-0.76%	-1.81%	-0.15%	-0.16%	-1.04%	
Final Upscale Bias	-0.71%	-1.73%	-0.02%	-0.05%	-2.49%	
Upscale Drift	0.05%	0.08%	0.13%	0.11%	1.45%	
Alternative Specification Abs Diff	Initial Zero	0.01	1.01	1.09	0.04	0.48
	Final Zero	0.01	1.48	0.49	0.11	0.11
	Initial Upscale	0.16	4.60	0.68	0.03	0.88
	Final Upscale	0.15	4.39	0.09	0.01	2.11
Calibration Span	21.00	254.00	457.00	19.00	84.70	
3% of Range (drift)	0.63	7.62	13.71	0.57	2.54	
5% of Range (bias)	1.05	12.70	22.85	0.95	4.24	

DRIFT AND BIAS CHECK					
High Load, Run - Out-3	O2	NOx	CO	CO2	SO2
Raw Average	5.43	95.74	166.75	13.94	65.88
Corrected Average	5.50	101.11	165.12	14.27	66.90
Initial Zero	-0.02	1.00	0.91	0.12	0.24
Final Zero	-0.01	0.67	1.52	0.13	0.87
Avg. Zero	-0.02	0.84	1.22	0.13	0.56
Initial UpScale	11.86	105.25	221.82	8.81	44.51
Final UpScale	11.87	104.79	221.71	8.81	46.23
Avg. UpScale	11.87	105.02	221.77	8.81	45.37
Sys Resp (Zero)	-0.03	-0.48	0.42	0.01	0.35
Sys Resp (Upscale)	12.01	109.64	221.91	8.82	46.62
Upscale Cal Gas	12.00	111.00	220.00	8.97	45.90
Initial Zero Bias	0.05%	0.58%	0.11%	0.58%	-0.13%
Final Zero Bias	0.10%	0.45%	0.24%	0.63%	0.61%
Zero Drift	0.05%	0.13%	0.13%	0.05%	0.74%
Initial Upscale Bias	-0.71%	-1.73%	-0.02%	-0.05%	-2.49%
Final Upscale Bias	-0.67%	-1.91%	-0.04%	-0.05%	-0.46%
Upscale Drift	0.05%	0.18%	0.02%	0.00%	2.03%
Alternative Specification Abs Diff	Initial Zero	0.01	1.48	0.49	0.11
	Final Zero	0.02	1.15	1.10	0.12
	Initial Upscale	0.15	4.39	0.09	0.01
	Final Upscale	0.14	4.85	0.20	0.01
Calibration Span	21.00	254.00	457.00	19.00	84.70
3% of Range (drift)	0.63	7.62	13.71	0.57	2.54
5% of Range (bias)	1.05	12.70	22.85	0.95	4.24

DRIFT AND BIAS CHECK		
High Load, Run - In-1	O2	SO2
Raw Average	5.16	329.82
Corrected Average	5.24	337.80
Initial Zero	-0.09	3.08
Final Zero	-0.01	4.87
Avg. Zero	-0.05	3.98
Initial UpScale	11.94	249.73
Final UpScale	11.82	244.39
Avg. UpScale	11.88	247.06
Sys Resp (Zero)	-0.08	-0.89
Sys Resp (Upscale)	11.99	255.25
Upscale Cal Gas	12.00	252.00
Initial Zero Bias	-0.05%	0.93%
Final Zero Bias	0.33%	1.35%
Zero Drift	0.38%	0.42%
Initial Upscale Bias	-0.24%	-1.29%
Final Upscale Bias	-0.81%	-2.54%
Upscale Drift	0.57%	1.25%
Alternative Specification Abs Diff	Initial Zero	0.01
	Final Zero	0.07
	Initial Upscale	0.05
	Final Upscale	0.17
Calibration Span	21.00	428.00
3% of Range (drift)	0.63	12.84
5% of Range (bias)	1.05	21.40

DRIFT AND BIAS CHECK		
High Load, Run - In-2	O2	SO2
Raw Average	5.13	331.41
Corrected Average	5.22	337.81
Initial Zero	-0.01	4.87
Final Zero	-0.01	5.26
Avg. Zero	-0.01	5.07
Initial UpScale	11.82	244.39
Final UpScale	11.82	252.63
Avg. UpScale	11.82	248.51
Sys Resp (Zero)	-0.08	-0.89
Sys Resp (Upscale)	11.99	255.25
Upscale Cal Gas	12.00	252.00
Initial Zero Bias	0.33%	1.35%
Final Zero Bias	0.33%	1.44%
Zero Drift	0.00%	0.09%
Initial Upscale Bias	-0.81%	-2.54%
Final Upscale Bias	-0.81%	-0.61%
Upscale Drift	0.00%	1.93%
Alternative Specification Abs Diff	Initial Zero	0.07
	Final Zero	0.07
	Initial Upscale	0.17
	Final Upscale	0.17
Calibration Span	21.00	428.00
3% of Range (drift)	0.63	12.84
5% of Range (bias)	1.05	21.40

DRIFT AND BIAS CHECK		
High Load, Run - In-3	O2	SO2
Raw Average	4.80	338.12
Corrected Average	4.89	334.51
Initial Zero	-0.01	5.26
Final Zero	-0.03	5.83
Avg. Zero	-0.02	5.55
Initial UpScale	11.82	252.63
Final UpScale	11.82	259.55
Avg. UpScale	11.82	256.09
Sys Resp (Zero)	-0.08	-0.89
Sys Resp (Upscale)	11.99	255.25
Upscale Cal Gas	12.00	252.00
Initial Zero Bias	0.33%	1.44%
Final Zero Bias	0.24%	1.57%
Zero Drift	0.10%	0.13%
Initial Upscale Bias	-0.81%	-0.61%
Final Upscale Bias	-0.81%	1.00%
Upscale Drift	0.00%	1.62%
Alternative Specification Abs Diff	Initial Zero	0.07
	Final Zero	0.05
	Initial Upscale	0.17
	Final Upscale	0.17
Calibration Span	21.00	428.00
3% of Range (drift)	0.63	12.84
5% of Range (bias)	1.05	21.40

SAMPLE DESCRIPTION AND CHAIN OF CUSTODY RECORD



Air Hygiene International, Inc.
 5634 S. 122nd East Ave, Suite F
 Tulsa, Oklahoma 74146
 (888) 461-8778
 www.airhygiene.com

Project Number:	snc-07-benson.mn-comp#1	Laboratory Analysis Requested:	
-----------------	-------------------------	--------------------------------	--

Person Taking Samples:	TP	RM 26a and Volume
------------------------	----	-------------------

Sample Number	Location	Date	Volume	Analysis Method			
				RM 26a	Volume		
IN-HCI-1	Inlet, HCl, Run 1	7/3/2007	As Marked	X	455		
IN-HCI-2	Inlet, HCl, Run 2	7/3/2007	As Marked	X	430		
IN-HCI-3	Inlet, HCl, Run 3	7/3/2007	As Marked	X	390		
Blank	HCl Blank	7/3/2007	As Marked	X	100		

<u>Sidd Kshirsagar</u> Relinquished by: (Signature)	07/03/07 Date:	18:58 Time:	 Received by: (Signature)	07/03/07 Date:	18:58 Time:
_____	_____	_____	_____	_____	_____
Relinquished by: (Signature)	Date:	Time:	Received by: (Signature)	Date:	Time:



Air Hygiene International, Inc.
 5634 S. 122nd East Ave, Suite F
 Tulsa, Oklahoma 74146
 (888) 461-8778
 www.airhygiene.com

SAMPLE DESCRIPTION AND CHAIN OF CUSTODY RECORD

Project Number: snc-07-benson.mn-comp#1 Laboratory Analysis Requested:

Person Taking Samples: TKG METHOD 5 (FRONTHALF) AND 202 (BACKHALF)

Sample Number	Location	Date	Volume	Analysis Method			
				RM 5	RM 202		
OUT-PM-1-F	Stack Outlet, Run 1 Filter	7/3/2007	N/A	X			
OUT-PM-2-F	Stack Outlet, Run 2 Filter	7/4/2007	N/A	X			
OUT-PM-3-F	Stack Outlet, Run 3 Filter	7/4/2007	N/A	X			
OUT-PM-1-PW	Stack Outlet, Run 1 Probe Wash	7/3/2007	as marked	X			
OUT-PM-2-PW	Stack Outlet, Run 2 Probe Wash	7/4/2007	as marked	X			
OUT-PM-3-PW	Stack Outlet, Run 3 Probe Wash	7/4/2007	as marked	X			
OUT-PM-1-BH	Stack Outlet, Run 1 Back Half	7/3/2007	as marked		X		
OUT-PM-2-BH	Stack Outlet, Run 2 Back Half	7/4/2007	as marked		X		
OUT-PM-3-BH	Stack Outlet, Run 3 Back Half	7/4/2007	as marked		X		
OUT-PM-1-MC	Stack Outlet, Run 1 MeCl Rinse	7/3/2007	as marked		X		
OUT-PM-2-MC	Stack Outlet, Run 2 MeCl Rinse	7/4/2007	as marked		X		
OUT-PM-3-MC	Stack Outlet, Run 3 MeCl Rinse	7/4/2007	as marked		X		
AC-B	Stack Outlet, Acetone Blank	7/3/2007	as marked	X			
MC-B	Stack Outlet, MeCl Blank	7/3/2007	as marked		X		
DI-B	Stack Outlet, DI Water Blank	7/3/2007	as marked		X		

 Relinquished by: (Signature)	07/05/07 Date:	19:00 Time:	 Received by: (Signature)	07/05/07 Date:	19:00 Time:
_____	Date: _____	Time: _____	_____	Date: _____	Time: _____

VISIBLE EMISSIONS EVALUATOR

This is to certify that

Rob White

met the specifications of Federal Reference Method 9 and qualified as a visible emissions evaluator. Maximum deviation on white and black smoke did not exceed 7.5% opacity and no single error exceeding 15% opacity was incurred during the certification test conducted by Eastern Technical Associates of Raleigh, North Carolina. This certificate is valid for six months from date of issue.

349751

Certificate Number

Oklahoma City, Oklahoma

Location

March 28, 2007

Date of Issue

Thomas Hore

President

Michael W. Junford

Director of Training

METERING SYSTEM CALIBRATION SHEET

EPA Reference Method 5

Metering System Pre-Test Calibration

Air Hygiene Asset ID: samp-cp-0016

Filename: Z:\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.0\Current[SAMP-CP-0016 Calibration 06-06-07.xls]Original (5 point)

Make: Apex
Model #: XC-522
Serial #: 0705008

Date: 06/07/07
Barometric Pressure: 28.82 (in. Hg)
Theoretical Critical Vacuum: 13.59 (in. Hg)

DRY GAS METER READINGS

ΔH (in H2O)	Time (min)	Volume			Initial Temps.	
		Initial (cu ft)	Final (cu ft)	Total (cu ft)	Inlet (deg F)	Outlet (deg F)
0.30	17.00	205.030	210.240	5.210	81.0	81.0
0.65	12.00	210.240	215.790	5.550	82.0	82.0
1.10	10.00	215.790	221.730	5.940	82.0	82.0
1.80	10.00	221.730	229.400	7.670	83.0	83.0
3.30	10.00	229.400	239.860	10.460	83.0	83.0

Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	Ambient Temperature		
Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
81.0	81.0	40	0.2354	16.0	82.0	82.0	82.0
82.0	82.0	48	0.3491	16.0	82.0	82.0	82.0
83.0	83.0	55	0.4530	16.0	82.0	82.0	82.0
83.0	83.0	63	0.5840	16.0	82.0	82.0	82.0
84.0	84.0	73	0.7945	16.0	82.0	83.0	82.5

RESULTS

DRY GAS METER		ORIFICE		
VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL
Vm(std) (cu ft)	Vm(std) (liters)	Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)
4.900	138.76	4.954	140.3	5.281
5.214	147.67	5.186	146.9	5.529
5.582	158.08	5.608	158.8	5.979
7.214	204.30	7.229	204.7	7.708
9.867	279.42	9.831	278.4	10.490

DRY GAS METER CALIBRATION FACTOR Y		ORIFICE CALIBRATION FACTOR ΔH@		
Variation (number)	Value (number)	Value (in H2O)	Value (mm H2O)	Variation (in H2O)
0.009	1.011	1.868	47.45	0.036
-0.007	0.995	1.837	46.66	0.005
0.003	1.005	1.845	46.85	0.012
0.000	1.002	1.814	46.09	-0.018
-0.005	0.996	1.797	45.65	-0.035
AVERAGE:	1.002	1.832	46.54	PASSED

Notes: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/- 0.02. For Orifice Calibration Factor ΔH@, the orifice differential pressure in inches of H₂O that equates to 0.75 cfm of air at 68 °F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/- 0.2. For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above. The Critical Orifice Coefficient, K', must be entered in English units, (ft)³*(deg R)^{0.5}/((in.Hg)*(min)).

SIGNATURE: Craig McCarty

DATE: 06/07/07 06/07/07

METERING SYSTEM CALIBRATION SHEET

EPA Reference Method 5

Metering System Pre-Test Calibration

Air Hygiene Assett ID: samp-cp-0017

Filename: Z:\Shared\QAQC\Calibrations\PM-Equipment\M-5 Consoles\Calibration Sheet v4.0\Current[SAMP-CP-0017 Calibration 06-06-07.xls]Original (5 point)

Make: Apex
Model #: XC-522
Serial #: 0705009

Date: 06/06/07
Barometric Pressure: 28.85 (in. Hg)
Theoretical Critical Vacuum: 13.61 (in. Hg)

DRY GAS METER READINGS

ΔH (in H2O)	Time (min)	Volume			Initial Temps.	
		Initial (cu ft)	Final (cu ft)	Total (cu ft)	Inlet (deg F)	Outlet (deg F)
0.30	17.00	222.500	227.910	5.410	97.0	97.0
0.65	12.00	227.910	233.430	5.520	94.0	94.0
1.10	10.00	233.430	239.410	5.980	93.0	93.0
1.80	10.00	239.410	247.160	7.750	93.0	93.0
3.30	10.00	247.160	257.700	10.540	93.0	93.0

Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	Ambient Temperature		
Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
95.0	95.0	40	0.2354	16.0	87.0	88.0	87.5
94.0	94.0	48	0.3491	16.0	88.0	89.0	88.5
93.0	93.0	55	0.4530	16.0	89.0	89.0	89.0
93.0	93.0	63	0.5840	16.0	89.0	89.0	89.0
94.0	94.0	73	0.7945	16.0	89.0	89.0	89.0

RESULTS

DRY GAS METER		ORIFICE		
VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL
Vm(std) (cu ft)	Vm(std) (liters)	Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)
4.956	140.34	4.934	139.7	5.308
5.079	143.84	5.160	146.1	5.562
5.519	156.29	5.578	158.0	6.017
7.165	202.91	7.191	203.6	7.757
9.772	276.76	9.783	277.0	10.553

DRY GAS METER CALIBRATION FACTOR Y		ORIFICE CALIBRATION FACTOR ΔH@		
Variation (number)	Value (number)	Value (in H2O)	Value (mm H2O)	Variation (in H2O)
-0.010	0.996	1.834	46.59	0.020
0.011	1.016	1.817	46.15	0.003
0.005	1.011	1.831	46.51	0.017
-0.002	1.004	1.803	45.79	-0.011
-0.004	1.001	1.784	45.32	-0.030
AVERAGE:	1.005	1.814	46.07	PASSED

Notes: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/- 0.02. For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H₂O that equates to 0.75 cfm of air at 68 °F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/- 0.2. For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above. The Critical Orifice Coefficient, K', must be entered in English units, (ft)³*(deg R)^{0.5}/((in.Hg)*(min)).

SIGNATURE: Craig McCarty

DATE: 06/06/07 06/06/07

APPENDIX E
STRATIFICATION TEST DATA

STRATIFICATION TEST DATA

SDA Inlet Test Data

Source Information	
Company	Fibrominn, LLC
Plant Name	Fibrominn Biomass Power Plant
Equipment	Biomass Boiler, SDA Inlet
Location	Benson, Minnesota

Test Information	
Date	07/02/07
Project #	snc-07-benson.mn-comp#1
Unit Number	1
Load	high
Number of Ports Available	2
Number of Ports Used	2

Stack and Test Type	
<input type="radio"/> Isokinetic Traverse (Wet Chemistry Testing) <input type="radio"/> Velocity Traverse (Flow and Flow RATA Test) <input checked="" type="radio"/> Stratification Traverse (Compliance Test) <input type="checkbox"/> RM 20 <input type="radio"/> Stratification Traverse (RATA) <input type="checkbox"/> Part 60 <input type="checkbox"/> Part 75	Circular Stack

METHOD 1 - STRATIFICATION TEST FOR A CIRCULAR SOURCE

Company	Fibrominn, LLC	Date	07/02/07
Plant Name	Fibrominn Biomass Power Plant	Project #	snc-07-benson.mn-comp#1
Equipment	Biomass Boiler, SDA Inlet	# of Ports Available	2
Location	Benson, Minnesota	# of Ports Used	2



Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L _{fw})	136.00	in.
Distance to Near Wall of Stack	(L _{nw})	7.00	in.
Diameter of Stack	(D)	129.00	in.
Area of Stack	(A _s)	90.76	ft ²

Distance from Disturbances to Port			
Distance Upstream	(A)	350.00	in.
Diameters Upstream	(A _D)	2.71	diameters
Distance Downstream	(B)	1222.00	in.
Diameters Downstream	(B _D)	9.47	diameters

Number of Traverse Points Required					
Diameters to Flow Disturbance		Minimum Number of ¹ Traverse Points		Minimum Number of Traverse Points	
Down (B _D)	Up (A _D)	Particulate	Velocity	Criteria	Points
2.00-4.99	0.50-1.24	24	16	<input type="checkbox"/> RM 7E 8.1.2	12 RM1 pts
5.00-5.99	1.25-1.49	20	16	<input type="checkbox"/> Alt 7E 8.1.2	3 points
6.00-6.99	1.50-1.74	16	12	12 points	
7.00-7.99	1.75-1.99	12	12	12 points	
>= 8.00	>=2.00	8 or 12 ²	8 or 12 ²	Minimum Number of	
Upstream Spec		12	12	Traverse Points	
Downstream Spec		12	12	RATA Stratification	
Traverse Pts Required		12	12	Criteria	Points
¹ Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.				<input type="checkbox"/> Part75/60	12 RM1 pts
				<input type="checkbox"/> 75 abrv (a)	3 points
				<input type="checkbox"/> 75 abrv (b)	6 points
² 8 for Circular Stacks 12 to 24 inches 12 for Circular Stacks over 24 inches				12 points	

Number of Traverse Points Used				
2	Ports by	6	Pts / port	Stratification Traverse
12	Pts Used	12	Required	(Compliance Test)

Traverse Point Locations			
Traverse Point Number	Percent of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
	%	in.	in.
1	4.4%	5 5/8	12 5/8
2	14.6%	18 7/8	25 7/8
3	29.6%	38 1/8	45 1/8
4	70.4%	90 7/8	97 7/8
5	85.4%	110 1/8	117 1/8
6	95.6%	123 3/8	130 3/8
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			



STRAT TEST DETERMINED SAMPLE POINTS FOR CIRCULAR STACK

Company	Fibrominn, LLC	Date	07/02/07
Plant Name	Fibrominn Biomass Power Plant	Project #	snc-07-benson.mn-comp#1
Equipment	Biomass Boiler, SDA Inlet	# of Ports Available	2
Location	Benson, Minnesota	# of Ports Used	2

Stack Dimensions				Traverse Data			
Diameter or Length of Stack	(D)	129.00	in.	2	Ports by	6	Pts / port
Width of Stack	(W)		in.	12	Pts Used	12	Required
Area of Stack	(A _s)	90.76	ft ²	Run Start	7:10:41	Run End	7:49:41

40 CFR 60, Appendix A, Method 7E Criteria


Stratification Results	
Maximum Percent Difference	38.29 % for O ₂
Maximum Conc. Difference	59.73 ppm for SO ₂
Stack Diameter	129.00 in.

Stratification Conclusions	
Maximum % Diff.	Percent Diff. >10% Failed Stratification Test
Maximum Conc. Diff.	Conc. Diff. > 0.5%
Stack Diameter	D > 93.6 in.

Use RM 1 Measurement Points and Sample Full Stack

Traverse Point Number	Percent of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
	%	in.	in.
1			
2			
3			

Test Type	<input type="checkbox"/> Moisture, for MW	<input type="checkbox"/>
	<input type="checkbox"/> Moisture, for wet-to-dry	<input type="checkbox"/> 6.5.6(b)(2) alt. points do not apply
	<input checked="" type="checkbox"/> Gas	



STRATIFICATION TEST DATA

Stack Exhaust Data

Source Information	
Company	Fibrominn, LLC
Plant Name	Fibrominn Biomass Power Plant
Equipment	Biomass Boiler, Stack Exhaust
Location	Benson, Minnesota

Test Information	
Date	07/02/07
Project #	snc-07-benson.mn-comp#1
Unit Number	1
Load	high
Number of Ports Available	4
Number of Ports Used	2

Stack and Test Type	
<input type="radio"/> Isokinetic Traverse (Wet Chemistry Testing) <input type="radio"/> Velocity Traverse (Flow and Flow RATA Test) <input checked="" type="radio"/> Stratification Traverse (Compliance Test) <input type="checkbox"/> RM 20 <input type="radio"/> Stratification Traverse (RATA) <input type="checkbox"/> Part 60 <input type="checkbox"/> Part 75	Circular Stack

METHOD 1 - STRATIFICATION TEST FOR A CIRCULAR SOURCE

Company	Fibrominn, LLC	Date	07/02/07
Plant Name	Fibrominn Biomass Power Plant	Project #	snc-07-benson.mn-comp#1
Equipment	Biomass Boiler, Stack Exhaust	# of Ports Available	4
Location	Benson, Minnesota	# of Ports Used	2



Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L _{fw})	129.00	in.
Distance to Near Wall of Stack	(L _{nw})	21.00	in.
Diameter of Stack	(D)	108.00	in.
Area of Stack	(A _s)	63.62	ft ²

Distance from Disturbances to Port			
Distance Upstream	(A)	2358.00	in.
Diameters Upstream	(A _D)	21.83	diameters
Distance Downstream	(B)	910.00	in.
Diameters Downstream	(B _D)	8.43	diameters

Number of Traverse Points Required					
Diameters to Flow Disturbance		Minimum Number of ¹ Traverse Points		Minimum Number of Traverse Points	
Down (B _D)	Up (A _D)	Particulate	Velocity	Criteria	Points
2.00-4.99	0.50-1.24	24	16	<input type="checkbox"/> RM 7E 8.1.2	12 RM1 pts
5.00-5.99	1.25-1.49	20	16	<input type="checkbox"/> Alt 7E 8.1.2	3 points
6.00-6.99	1.50-1.74	16	12	12 points	
7.00-7.99	1.75-1.99	12	12	12 points	
>= 8.00	>=2.00	8 or 12 ²	8 or 12 ²	Minimum Number of	
Upstream Spec		12	12	Traverse Points	
Downstream Spec		12	12	RATA Stratification	
Traverse Pts Required		12	12	Criteria	Points
¹ Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.				<input type="checkbox"/> Part75/60	12 RM1 pts
				<input type="checkbox"/> 75 abrv (a)	3 points
				<input type="checkbox"/> 75 abrv (b)	6 points
² 8 for Circular Stacks 12 to 24 inches 12 for Circular Stacks over 24 inches				12 points	

Number of Traverse Points Used				
2	Ports by	6	Pts / port	Stratification Traverse
12	Pts Used	12	Required	(Compliance Test)

Traverse Point Locations			
Traverse Point Number	Percent of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
	%	in.	in.
1	4.4%	4 6/8	25 6/8
2	14.6%	15 6/8	36 6/8
3	29.6%	32	53
4	70.4%	76	97
5	85.4%	92 2/8	113 2/8
6	95.6%	103 2/8	124 2/8
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			



STRAT TEST DETERMINED SAMPLE POINTS FOR CIRCULAR STACK

Company	Fibrominn, LLC	Date	07/02/07
Plant Name	Fibrominn Biomass Power Plant	Project #	snc-07-benson.mn-comp#1
Equipment	Biomass Boiler, Stack Exhaust	# of Ports Available	4
Location	Benson, Minnesota	# of Ports Used	2

Stack Dimensions				Traverse Data			
Diameter or Length of Stack	(D)	108.00	in.	2	Ports by	6	Pts / port
Width of Stack	(W)		in.	12	Pts Used	12	Required
Area of Stack	(A _s)	63.62	ft ²	Run Start	7:10:41	Run End	7:49:41

40 CFR 60, Appendix A, Method 7E Criteria


Stratification Results	
Maximum Percent Difference	736.24 % for CO
Maximum Conc. Difference	881.20 ppm for CO
Stack Diameter	108.00 in.

Stratification Conclusions	
Maximum % Diff.	Percent Diff. >10% Failed Stratification Test
Maximum Conc. Diff.	Conc. Diff. > 0.5%
Stack Diameter	D > 93.6 in.

Use RM 1 Measurement Points and Sample Full Stack

Traverse Point Number	Percent of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
	%	in.	in.
1			
2			
3			

Test Type	<input type="checkbox"/> Moisture, for MW	<input type="checkbox"/>
	<input type="checkbox"/> Moisture, for wet-to-dry	<input type="checkbox"/> 6.5.6(b)(2) alt. points do not apply
	<input checked="" type="checkbox"/> Gas	



APPENDIX F
FUEL ANALYSIS

Client: Fibrominn, LLC

Location: Fibrominn Biomass Power Plant

Date: July 3, 2007

Project #: snc-07-benson.mn-comp#1

Biomass - Fuel Analysis

Characteristics of Fuel Gas		
Btu per lb. of biomass =	4,372	gross (HHV)
Btu per lb. of biomass =	4,415	gross (HHV)
Btu per lb. of biomass =	4,203	gross (HHV)
Btu per lb. of biomass =	4,346	gross (HHV)
Btu per lb. of biomass =	4,334	gross (HHV)

Component	Wt%	Sample
carbon	25.65	LOT 10
carbon	25.50	LOT 11
carbon	25.34	LOT 12
carbon	25.60	LOT 13
carbon	25.52	AVERAGE

F_c -Factor (SCF dry exhaust per MMBtu [HHV]) =	1,883.27	LOT 10
F_c -Factor (SCF dry exhaust per MMBtu [HHV]) =	1,854.02	LOT 11
F_c -Factor (SCF dry exhaust per MMBtu [HHV]) =	1,935.32	LOT 12
F_c -Factor (SCF dry exhaust per MMBtu [HHV]) =	1,890.84	LOT 13
F_c-Factor (SCF dry exhaust per MMBtu [HHV]) =	1,890.34	AVERAGE
(Based on EPA RM-19) at 68 deg F and 14.696 psia		



Hazen Research, Inc.
 4601 Indiana Street
 Golden, CO 80403 USA
 Tel: (303) 279-4501
 Fax: (303) 278-1528

Date July 11 2007
 HRI Project 002-UD9
 HRI Series No. G30/07-1
 Date Rec'd. 07/06/07
 Cust. P.O.#

McHale & Associates, Inc.
 Gary Anderson
 1635 235th Ave SE
 Sammamish, WA 98075

Sample Identification
 Turkey Litter Sample 10

Reporting Basis > As Rec'd Dry Air Dry

Proximate (%)

Moisture	37.60	0.00	5.26
Ash	12.51	20.05	19.00
Volatile			
Fixed C			
Total			
Sulfur	0.31	0.50	0.47
Btu/lb (HHV)	4372	7007	6639
MMF Btu/lb	5048	8944	
MAF Btu/lb		8765	
Air Dry Loss (%)		34.14	

Ultimate (%)

Moisture	37.60	0.00	5.26
Carbon	25.65	41.10	38.94
Hydrogen	3.26	5.23	4.95
Nitrogen	2.66	4.26	4.04
Sulfur	0.31	0.50	0.47
Ash	12.51	20.05	19.00
Oxygen*	18.01	28.86	27.34
Total	100.00	100.00	100.00
Chlorine**	0.450	0.721	0.683

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
Total	0.31	0.50

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu= 28.62
 Lb. SO2/MM Btu= 1.42
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=
 F-Factor(dry).DSCF/MM BTU= 9,920

Water Soluble Alkalies (%)

Na2O
 K2O

Report Prepared By:
Vickie Buster for
 Gerard H. Cunningham
 Fuels Laboratory Supervisor

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.
 4601 Indiana Street
 Golden, CO 80403 USA
 Tel: (303) 279-4501
 Fax: (303) 278-1528

Date July 11 2007
 HRI Project 002-UD9
 HRI Series No. G30/07-2
 Date Rec'd. 07/06/07
 Cust. P.O.#

McHale & Associates, Inc.
 Gary Anderson
 1635 235th Ave SE
 Sammamish, WA 98075

Sample Identification
 Turkey Litter Sample 11

Reporting Basis >	As Rec'd	Dry	Air Dry
Proximate (%)			
Moisture	34.00	0.00	0.64
Ash	14.35	21.74	21.60
Volatile			
Fixed C			
Total			
Sulfur	0.30	0.45	0.45
Btu/lb (HHV)	4415	6689	6646
MMF Btu/lb	5217	8740	
MAF Btu/lb		8547	
Air Dry Loss (%)		33.57	
Ultimate (%)			
Moisture	34.00	0.00	0.64
Carbon	25.50	38.64	38.39
Hydrogen	3.45	5.22	5.19
Nitrogen	2.76	4.18	4.15
Sulfur	0.30	0.45	0.45
Ash	14.35	21.74	21.60
Oxygen*	19.64	29.77	29.58
Total	100.00	100.00	100.00
Chlorine**	0.428	0.648	0.644

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
Total	0.30	0.45

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu= 32.50
 Lb. SO₂/MM Btu= 1.35
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=
 F-Factor(dry), DSCF/MM BTU= 9,758

Water Soluble Alkalies (%)

Na₂O
 K₂O

Report Prepared By:

Vickie Buster for
 Gerard H. Cunningham
 Fuels Laboratory Supervisor

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.

4601 Indiana Street
Golden, CO 80403 USA
Tel: (303) 279-4501
Fax: (303) 278-1528

Date July 11 2007
HRI Project 002-UD9
HRI Series No. G30/07-3
Date Rec'd. 07/06/07
Cust. P.O.#

McHale & Associates, Inc.
Gary Anderson
1635 235th Ave SE
Sammamish, WA 98075

Sample Identification
Turkey Litter Sample 12

Reporting Basis > As Rec'd Dry Air Dry

Proximate (%)

Moisture	33.32	0.00	2.86
Ash	15.51	23.27	22.60
Volatile			
Fixed C			
Total			
Sulfur	0.34	0.51	0.50
Btu/lb (HHV)	4203	6303	6123
MMF Btu/lb	5040	8416	
MAF Btu/lb		8215	
Air Dry Loss (%)		31.36	

Ultimate (%)

Moisture	33.32	0.00	2.86
Carbon	25.34	38.01	36.92
Hydrogen	3.51	5.26	5.11
Nitrogen	2.92	4.38	4.25
Sulfur	0.34	0.51	0.50
Ash	15.51	23.27	22.60
Oxygen*	19.06	28.57	27.76
Total	100.00	100.00	100.00
Chlorine**	0.499	0.748	0.727

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic		
Total	0.34	0.51

Lb. Alkali/MM Btu=
Lb. Ash/MM Btu= 36.91
Lb. SO2/MM Btu= 1.63
HGI= @ % Moisture
As Rec'd. Sp.Gr.=
Free Swelling Index=
F-Factor(dry), DSCF/MM BTU= 10,321

Water Soluble Alkalies (%)

Na2O
K2O

Report Prepared By:
Vickie Buster for
Gerard H. Cunningham
Fuels Laboratory Supervisor

* Oxygen by Difference.

** Not usually reported as part of the ultimate analysis.



Hazen Research, Inc.
 4601 Indiana Street
 Golden, CO 80403 USA
 Tel: (303) 279-4501
 Fax: (303) 278-1528

Date July 11 2007
 HRI Project 002-UD9
 HRI Series No. G30/07-4
 Date Rec'd. 07/06/07
 Cust. P.O.#

McHale & Associates, Inc.
 Gary Anderson
 1635 235th Ave SE
 Sammamish, WA 98075

Sample Identification
 Turkey Litter Sample 13

Reporting Basis > As Rec'd Dry Air Dry

Proximate (%)

Moisture	34.95	0.00	3.59
Ash	13.15	20.22	19.49
Volatile			
Fixed C			
Total	_____	_____	_____
Sulfur	0.36	0.55	0.53
Btu/lb (HHV)	4346	6681	6441
MMF Btu/lb	5056	8545	
MAF Btu/lb		8374	
Air Dry Loss (%)		32.53	

Ultimate (%)

Moisture	34.95	0.00	3.59
Carbon	25.60	39.35	37.94
Hydrogen	3.57	5.49	5.29
Nitrogen	3.22	4.95	4.77
Sulfur	0.36	0.55	0.53
Ash	13.15	20.22	19.49
Oxygen*	19.15	29.44	28.39
Total	100.00	100.00	100.00
Chlorine**	0.462	0.711	0.685

Forms of Sulfur (as S,%)

Sulfate		
Pyritic		
Organic	_____	_____
Total	0.36	0.55

Lb. Alkali/MM Btu=
 Lb. Ash/MM Btu= 30.26
 Lb. SO2/MM Btu= 1.65
 HGI= @ % Moisture
 As Rec'd. Sp.Gr.=
 Free Swelling Index=
 F-Factor(dry), DSCF/MM BTU= 10,123

Water Soluble Alkalies (%)

Na2O
 K2O

Report Prepared By:
Viccie Buster for
 Gerard H. Cunningham
 Fuels Laboratory Supervisor

* Oxygen by Difference.
 ** Not usually reported as part of the ultimate analysis.

APPENDIX G
TEST PROTOCOL



**COMPLIANCE TEST
PROTOCOL**

**FOR
ONE BIOMASS BOILER
(SPRAY DRYER ABSORBER
INLET AND STACK OUTLET)**

**PREPARED FOR
SNC – LAVALIN, POWERMINN 9090
LLC, AND FIBROMINN LLC**

**AT THE
FIBROMINN BIOMASS
POWER PLANT
BENSON, MINNESOTA**

**Minnesota Pollution
Control Agency
Permit No: 15100038-004**

April 25, 2007





**COMPLIANCE TEST
PROTOCOL**

**FOR
ONE BIOMASS BOILER
(SPRAY DRYER ABSORBER
INLET AND STACK OUTLET)**

**PREPARED FOR
SNC – LAVALIN, POWERMINN 9090
LLC, AND FIBROMINN LLC**

**AT THE
FIBROMINN BIOMASS
POWER PLANT
BENSON, MINNESOTA**

**Minnesota Pollution
Control Agency
Permit No: 15100038-004**

April 25, 2007

Prepared By:

Thomas K. Graham, PE, Director of Operations

rev - 0



Table of Contents

1.0	<u>INTRODUCTION</u>	1
1.1	General Facility Description	1
1.2	Reason for Testing	1
2.0	<u>SUMMARY</u>	1
2.1	Owner Information.....	1
2.2	Operator Information	2
2.3	Site Information.....	2
2.4	Engineering Consultant Information	2
2.5	Test Contractor Information	2
2.6	Expected Test Start Date	2
2.7	Testing Schedule	3
2.8	Test Report Content.....	5
2.9	Equipment and Procedures	5
2.10	Proposed Variations	5
2.11	Compliance Sampling Strategy	6

Appendix A QA/QC PROGRAM

Appendix B TEST EQUIPMENT CONFIGURATION and DESCRIPTION

Figure 1 – Emissions Testing Setup

Figure 2 – Wet Chemistry Setup

Table 1 – Testing Matrix

Table 2 – Analytical Instrumentation

Table 2 – Analytical Instrumentation Testing Configuration

Appendix C STACK DRAWINGS

Appendix D EXAMPLE TEMPLATES AND CALCULATIONS

Appendix E AIR HYGIENE STATEMENT OF QUALIFICATIONS

1.0 INTRODUCTION

1.1 General Facility Description

PowerMinn 9090, LLC (PowerMinn) owns and Fibrominn, LLC (Fibrominn) operates the Fibrominn Biomass Power Plant (FBPP) in Swift County, Benson, Minnesota. FBPP comprises one boiler, fueled principally with poultry litter. Vegetative biomass may also be burned. The facility generates an average of 50 megawatts (MW) of electricity for export and has a peak electrical export capacity of 55 MW.

Emissions from the boiler are controlled by a baghouse spray dryer to control particulate matter and particulate matter less than 10 micron in diameter (PM/PM₁₀), sulfur dioxide (SO₂), sulfuric acid mist (H₂SO₄), and hydrochloric acid (HCl). Selective non-catalytic reduction (SNCR) is used to control nitrogen oxides (NO_x). Good combustion practices are used to control carbon monoxide (CO) and volatile organic compounds (VOCs).

Air emissions testing on the unit will occur at the spray dryer absorber (SDA) inlet and the stack outlet. The SDA inlet duct is circular and measures 10.8 feet (ft) (129 inches) in diameter at the test ports which are approximately 120 ft above grade level. The test ports are located approximately 101.8 ft (1,222 inches) downstream and approximately 29.2 ft (350 inches) upstream from the nearest disturbances.

The stack exhaust is circular and measures 9 feet (ft) (108 inches) in diameter at the test ports which are approximately 104 ft above grade level with an exit elevation of approximately 300 ft above grade level. The test ports are located approximately 75.8 ft (910 inches) downstream and approximately 196.5 ft (2,358 inches) upstream from the nearest disturbances.

1.2 Reason for Testing

FBPP is required to perform air emissions testing in conjunction with the requirements of the Minnesota Pollution Control Agency (MPCA) air emissions permit (Permit No. 15100038-004) and the requirements of the United States Environmental Protection Agency (EPA); to determine the concentrations, rates, and reductions of certain pollutants. Pollutants measured at the stack exhaust will include HCl, mercury (Hg), PM/PM₁₀, dioxins/furans (PCDD/PCDF), SO₂, NO_x, CO, opacity, carbon dioxide (CO₂), and oxygen (O₂). A reduced number of pollutants will be measured at the SDA inlet (SO₂, HCl, and Hg) to calculate capture efficiencies. All common stack exhaust and SDA pollutant tests will be performed simultaneously.

This protocol will be submitted to the MPCA at least 30 days before the first test.

2.0 SUMMARY

2.1 Owner Information

Company:	PowerMinn 9090, LLC
Mailing address:	2295 Corporate Boulevard, Suite 222 Boca Raton, Florida 33431

2.2 Operator Information

Company: Fibrominn, LLC
Contact Person: Chuck Wagoner, Owners Site Construction Rep.
Mailing address: 900 Industrial Drive
PO Box 265
Benson, Minnesota 56215
Office: (320) 843-9013
Fax: (320) 843-9014
Email: chuck.wagoner@fibrowattusa.com

2.3 Site Information

Site Name: Fibrominn Biomass Power Plant
Contact Person: Victor Myers, Commissioning Manager
Location: 900 Industry Drive Benson
Swift County, Minnesota 56215
Office: (320) 843-5170
Cell: (425) 922-9018
Fax: (320) 843-4193
Email: victor.myers@slthermal.com

2.4 Engineering Consultant Information

Company: SNC – Lavalin (SNC)
Contact Person: Robert Dolesky, Project Engineer
Mailing Address: 1200-1075 West Georgia St
Vancouver, British Columbia
Canada V6E 3C9
Office: (604) 605-4927
Fax: (604) 683-1672
E-mail: robert.dolesky@snclavalin.com

2.5 Test Contractor Information

Company: Air Hygiene International, Inc.
Contact Person: Thomas K. Graham, PE, Director of Operations
Mailing Address: 5634 South 122nd East Ave., Suite F
Tulsa, Oklahoma 74146
Office: (918) 307-8865
Cell: (918) 407-5168
Fax: (918) 307-9131
E-mail: tom@airhygiene.com
Website: www.airhygiene.com

2.6 Expected Test Start Date

Thursday, June 14, 2007

2.7 Testing Schedule

The following schedule indicates specific activities required to be done each day; however, the schedule may require flexibility and will be extended as necessary. If there are no operational delays, this schedule can be completed as detailed by the testing crew on the two sources (stack outlet and SDA inlet). The details below describe the activities to be conducted on each source.

Pre-test Activities

1. Conduct site inspection
2. Prepare draft test protocol (Air Hygiene)
3. Submit final approved test plan to SNC (Air Hygiene)
4. Pre-test meeting with SNC, MPCA, etc.
5. Receive site safety training

Due Date

per SNC and Air Hygiene
prior to testing
3 days after comments on draft
Prior to testing
Day of arrival for setup

On-Site Pre-testing Schedule

Day 0 – Initial Site Mobilization and Setup

- | | <u>Time</u> |
|--------------------------------|---------------|
| • Arrive at site | 09:00 |
| • Attend safety training class | 09:00 – 10:00 |
| • Setup on inlet and outlet | 10:00 – 18:00 |

Activities below will be conducted at the SDA inlet and stack exhaust outlet. Testing will be conducted as appropriate run conditions are available and the testing schedule may move up each day if conditions permit. The schedule assumes 12 hour days with no overtime.

All tests will be conducted under representative operation conditions with the biomass fired boiler steam load between 90 and 100 percent of the nominal rating (490,000 lb/hr). Operation during periods of boiler and air pollution control system malfunctions or upset conditions will not be considered representative conditions and will be reason for delaying, interrupting, aborting, or invalidating a test run. The following are typical malfunctions or upset conditions that will be reason for delaying, interrupting, or invalidating a test run.

1. Crane outage
2. Fan outage
3. Spray dryer absorber or lime slaker problem
4. Carbon system malfunction
5. Broken or frozen grate bar
6. Plugged feed chute
7. Plugged ash discharge
8. Plugged ash conveyor system
9. Turbine trip
10. Hydraulic failure of system
11. Fabric filter malfunction
12. Steam flow not within 10 percent of steam flow set point
13. Boiler tube leak or rupture
14. Plug or bridge in refuse feed hopper

When the malfunction or upset condition has been cleared, testing will resume from that point at which it was stopped. If the malfunction or upset condition results in an extended test delay, then the affected test run(s) may be aborted and a new run(s) conducted when the malfunction has been corrected or process upset cleared. The above list represents but not entirely encompasses the most typical malfunctions or process upsets potentially encountered.

On-site Testing Activities

Time

Day 1 – Compliance / Performance Testing

- Daily setup and calibrations 06:00 – 07:00
- Conduct stratification test 07:00 – 09:00
 - Collect outlet data for NO_x and O₂ to determine sample collection location(s)
- Conduct preliminary cyclonic testing and flow measurements 07:00 – 09:00
 - Collect inlet and outlet data for differential pressures, temperatures, and null angles
- Conduct testing for NO_x, CO, SO₂, CO₂, and O₂ 09:00 – 13:00
 - Collect outlet data for NO_x, CO, SO₂, CO₂, and O₂ (3, 60-minute runs)
 - Collect simultaneous inlet data for SO₂ and O₂ (3, 60-minute runs)
- Conduct testing for opacity 09:00 – 13:00
 - Collect outlet data for opacity (3, 60-minute runs)
- Conduct simultaneous testing for HCl 09:00 – 14:00
 - Collect inlet data for HCl (3, 60-minute runs with setup)
 - O₂, CO₂, and CO data will be monitored by periodic Tedlar bag collection
 - Collect outlet data for HCl (3, 60-minute runs with setup)
 - O₂, CO₂, and CO data will be monitored by the RM analyzers



Day 2 – Compliance / Performance Testing

- Daily setup and calibrations 06:00 – 07:00
- Conduct simultaneous testing for Hg 07:00 – 16:00
 - Collect inlet data for Hg (3, 120-minute runs with setup)
 - O₂, CO₂, and CO data will be monitored by periodic Tedlar bag collection
 - Collect outlet data for Hg (3, 120-minute runs with setup)
 - O₂, CO₂, and CO data will be monitored by the RM analyzers

Day 3 – Compliance / Performance Testing

- Daily setup and calibrations 06:00 – 07:00
- Conduct testing for PCDD/PCDF (Runs 1 and 2) 07:00 – 18:00
 - Collect outlet data for PCDD/PCDF (2, 240-min runs with setup)
 - O₂, CO₂, and CO data will be monitored by the RM analyzers

Day 4 – Compliance / Performance Testing

- Daily setup and calibrations 06:00 – 07:00
- Conduct testing for PCDD/PCDF (Run 3) 07:00 – 13:00
 - Collect outlet data for PCDD/PCDF (1, 240-min run with setup)
 - O₂, CO₂, and CO data will be monitored by the RM analyzers

Day 5 – Compliance / Performance Testing

- Daily setup and calibrations 06:00 – 07:00
- Conduct testing for PM/PM₁₀ 07:00 – 18:00
 - Collect outlet data for PM/PM₁₀ (3, approx. 150-min, min. 100dscf runs with setup)
 - O₂, CO₂, and CO data will be monitored by the RM analyzers

Activities after Testing

- Demobilization of Testing Crew (Air Hygiene) Day 5
- Preparation of draft test report (Air Hygiene) Days 6 – 14*
- Submit for review to SNC (Air Hygiene) Day 15
- Review and comment on draft (SNC) Days 16 – 17
- Prepare final hard copy test reports (Air Hygiene) Days 17 – 18
- Final reports delivered to SNC (Air Hygiene) Day 19

* Draft report timeline may depend on out-sourced laboratory analysis timeline. PCDD/PCDF analysis in particular typically takes from 17 to 21 days to complete a full analysis.

2.8 Test Report Content

The test report methods and content will meet the requirements of the MPCA and the EPA for compliance and certification testing. The reports will include discussion of the following:

- Introduction
- Plant and Sampling Location Description
- Summary and Discussion of Test Results Relative to Acceptance Criteria
- Sampling and Analytical Procedures
- QA/QC Activities
- Test Results and Related Calculations
- Stack and Testing Equipment Drawings
- Raw Field Data and Calibration Data Sheets
- Sampling Log and Chain-of-Custody Records
- Audit Data Sheets

2.9 Equipment and Procedures

Test Methods and Parameters to Satisfy 40 CFR Part 60

- EPA Method 1 for sample location [inlet and outlet]
- EPA Method 2 for exhaust flow [inlet and outlet]
- EPA Method 3a for oxygen (O₂) [inlet and outlet]
- EPA Method 3a for carbon dioxide (CO₂) [inlet and outlet]
- EPA Method 4 for exhaust gas moisture [inlet and outlet]
- EPA Method 5 for particulate matter (PM – front half filterable) [outlet]
- EPA Method 6c for sulfur dioxide (SO₂) [inlet and outlet, simultaneous]
- EPA Method 7e for nitrogen oxides (NO_x) [outlet]
- EPA Method 9 for opacity [outlet]
- EPA Method 10 for carbon monoxide (CO) [outlet]
- EPA Method 23 for dioxins and furans (PCDD/PCDF) [outlet]
- EPA Method 26a for hydrogen chloride (HCl) [inlet and outlet, simultaneous]
- EPA Method 202 for particulate matter (PM₁₀ – back half condensable) [outlet]
- Ontario Hydro Method for mercury (Hg) [inlet and outlet, simultaneous]

2.10 Proposed Variations

- Stainless steel nozzles and inconel liners will be used instead of borosilicate glass (to prevent breakage) in the Method 5/202 sampling assembly.

- Due to test matrix restrictions, schedule, and operations availability; wet chemistry (isokinetic) runs may be stopped before a run is complete. In this case a delay of more than two hours will constitute cooling and capping off the impinger train. Also, wet chemistry test runs may not be run consecutively.
- Method 26a testing will be from a single point.

2.11 Compliance Sampling Strategy

All compliance testing will be performed while the unit is operating between 90 and 100 percent of the nominal throughput. During the dioxin/furan testing, the temperature (°F) at the inlet to the baghouse spray dryer will be recorded by the plant. In addition to this parameter, for all testing, plant personnel will also track boiler measurements including: turbine output (MW), steam flow (lb/hr), feed water flow (gpm), ambient temperature (°F), ambient relative humidity (%), barometric pressure (in. Hg), fuel flow (tph), feed water temperature (°F), super heater outlet steam temperature (°F), super heater outlet steam pressure (psig), super heater outlet flue gas temperature (°F), total over fire and under fire combustion air flow (Kacfm); and spray dryer absorber measurements including: total slurry feed (gpm), dilution water feed (gpm), inlet and outlet flue gas temperature (°F), slurry concentration (%).

- A. Gases (NO_x, SO₂, CO, CO₂, and O₂) – EPA Methods 7e, 6c, 10, and 3a
 NO_x, SO₂, CO, CO₂, and O₂ testing will be conducted on the stack outlet. Each test run will be 60 minutes in duration. Simultaneously, SO₂ and O₂ testing will be conducted on the SDA inlet to calculate control efficiency.
- B. PM/PM₁₀ Testing – EPA Methods 5/202
 Total Particulate matter (PM) and particulate matter less than 10 microns in diameter (PM₁₀) testing will be conducted on the stack outlet. Each test run will be approximately 150 minutes in duration pulling at least 100 dry standard cubic feet (dscf) of sample volume. An S-type pitot tube will be used to measure cyclonic flow and velocity pressure in accordance with EPA Method 2. This data will be correlated with meter coefficients, temperatures, barometric pressure, and stack gas moisture (EPA Method 4) to determine the stack gas dry exhaust flow rate. PM/PM₁₀ samples will be collected following EPA Method 5 (front half filterables) and EPA Method 202 (back half condensables) with an isokinetic sampling train utilizing a stainless steel nozzle and inconel probe liner. A scale will be used to measure net weight gain from each impinger to determine moisture gain. Gravimetric analysis by Air Hygiene's in-house laboratory will provide PM/PM₁₀ results.

The exit of the filter holder is connected to a series of four full size impingers. The first three impingers each contain 100 milliliters of de-ionized water. The fourth contains a tared quantity of silica gel. The impingers are maintained at a temperature below 68 °F for the duration of each test. In accordance with EPA Method 202 requirements, all glassware is cleaned prior to testing with soap and water, rinsed with de-ionized water, acetone and finally methylene chloride.

Procedures for selecting sampling locations and for operation of the apparatus are derived from EPA Method 5/202 and associated EPA Methods 1 through 4. The sampling apparatus is leak-checked before and after each test run. Sampling is performed at an isokinetic rate greater than 90 percent and less than 110 percent.

At the conclusion of each test run, the filter is removed from the filter holder and placed in a labeled Petri dish (container No. 1). Any particles adhering to the filter holder gasket are also transferred to the dish. The probe liner, nozzle, probe fittings and front half of the filter holder are washed three times with acetone to remove any particulate matter or condensate. These rinses are saved in a pre-cleaned glass sample jar (container No. 2).

As soon as possible after the post-test leak check the probe and filter will be detached from the impinger train and the nitrogen (N₂) purge will begin. During the purge, N₂ will flow through the back half of the sample train at 20 liters per min for one hour. The purge will effectively remove any SO₂ in the sample train which may solidify and cause the laboratory to over-report the amount of particulate matter.

The first three impinger catches are measured, their weights recorded, and the catches transferred to container No. 3. The weight gain is added to the silica gel weight gain of the fourth impinger to determine the stack gas moisture content. The impingers and all connecting glassware are then rinsed twice with de-ionized water. These rinses are added to container No. 3. A final rinse, of the above components, with methylene chloride is saved in glass sample container No. 4.

Sample bottles are sealed, shaken and labeled, and the liquid level is marked. At that time, approximately 200-ml each of de-ionized water, acetone and methylene chloride are prepared for analysis as reagent blanks.

Particulate samples collected on the glass fiber filters are analyzed gravimetrically to a constant weight. The front half wastes are transferred to tared beakers, evaporated to dryness, and brought to constant weights.

The impinger water is extracted by adding the contents of the methylene chloride rinse to the impinger water, and separating the layers in a separatory funnel. Two additional 75 milliliter portions of methylene chloride are added to the funnel to complete the extraction. The organic extract fraction is then placed into a tared beaker and evaporated at room temperature to dryness. It is then desiccated for 24 hours and brought to a constant weight. The aqueous inorganic fraction is taken to dryness at a slightly elevated temperature and allowed to air dry at room temperature. The residue is then desiccated for 24 hours and brought to a constant weight. The weight differentials for the organic and inorganic fractions are combined to determine the total condensable particulate matter.

The particulate analysis is performed by Air Hygiene's in house laboratory.

C. Mercury Testing – Ontario Hydro Method

Mercury (Hg) testing will be conducted simultaneously on the SDA inlet and stack outlet. Each test run will be 120 minutes in duration. An S-type pitot tube will be used to measure cyclonic flow and velocity pressure in accordance with EPA Method 2. This data will be correlated with meter coefficients, temperatures, barometric pressure, and stack gas moisture (EPA Method 4) to determine the stack gas dry exhaust flow rate. Mercury samples will be collected following the Ontario Hydro Method (ASTM D6784-02) with an isokinetic sampling train utilizing a glass nozzle and probe liner.

The exit of the filter holder is connected to a series of eight full size impingers. The first three impingers each contain 100 mL of 1.0 N potassium chloride (KCl). The fourth impinger contains 100 mL of 5% nitric acid (HNO₃) / 10% hydrogen peroxide (H₂O₂). The fifth, sixth, and seventh impinger contain 100 mL of 10% sulfuric acid (H₂SO₄) / 4% potassium permanganate (KMnO₄). The eighth contains a tared quantity of silica gel. The impingers are maintained at a temperature below 68 °F for the duration of each test.

Procedures for selecting sampling locations and for operation of the apparatus are derived from Ontario Hydro Method and associated EPA RMs 1 through 4. The sampling apparatus is leak-checked before and after each test run. Sampling is performed at an isokinetic rate greater than 90 percent and less than 110 percent.

At the conclusion of each test run, the probe and nozzle will be rinsed and brushed with 0.1 normal nitric acid to remove any particulate matter. These rinses will be collected into polyethylene sample containers. The quartz fiber filter will be recovered and placed into a polyethylene sample container. The volume of liquid collected in each of the impingers will be quantified.

The liquid from the first three impingers will be transferred to a leak-free polyethylene storage container. The first three impingers and all connecting glassware will be rinsed with 0.1 normal nitric acid which will be added to the storage container. The liquid from the fourth impinger will be transferred to a separate polyethylene container, and the impinger will be rinsed into the container with 0.1 normal nitric acid. The contents of impingers 5, 6, and 7 will be collected into an amber glass container. All impingers 5, 6, and 7 and the connecting glassware will then be rinsed with 0.1 normal nitric acid and 8.0 normal hydrochloric acid. These rinses will also be collected in the glass container.

All containers will be sealed, labeled and liquid levels marked prior to transport to the laboratory. The silica gel weight and the volume of condensate collected in the impingers will be used to determine moisture content of the stack gas. A scale will be used to measure net weight gain from each impinger to determine moisture gain. An out-sourced laboratory will be used to provide mercury results.

D. Dioxin/Furan Testing – EPA Method 23

Dioxin/Furan (PCDD/PCDF) testing will be conducted on the stack outlet. Each test run will be 240 minutes in duration. An S-type pitot tube will be used to measure cyclonic flow and velocity pressure in accordance with EPA Method 2. This data will be correlated with meter coefficients, temperatures, barometric pressure, and stack gas moisture (EPA Method 4) to determine the stack gas dry exhaust flow rate. Dioxin/Furan samples will be collected following EPA Method 23 with an isokinetic sampling train utilizing a glass nozzle and probe liner. Particulate will be collected on a filter and a sorbent cartridge will retain vaporous emissions. Following sampling, the appropriate components of the train will be recovered and transferred to the laboratory for analysis. The components will be extracted and the extracts will be cleaned to remove excessive levels of potential interference. A scale will be used to measure net weight gain from each impinger to determine moisture gain. An out-sourced laboratory will be used to provide dioxin/furan results.

All sampling train components that contact the recovered sample will be composed of borosilicate glass, polytetrafluoroethylene (PTFE) or similar materials to avoid potential sample contamination or reactions with PCDDs and PCDFs.

The exit of the filter holder will be connected to a water jacketed glass coil condenser and adsorbent trap unit, configured such that the flue gas and condensed moisture will flow down through the resin in the cartridge. The adsorbent trap will contain an XAD resin cartridge to adsorb the PCDDs and PCDFs present in the vapor and condensed portion of the sample. The resin cartridges will be pre-cleaned and spiked with isotopically labeled surrogates by an outsourced laboratory prior to use in the field. During operation, a leak-free submersible pump will be used to re-circulate cooling water through the coil condenser to ensure proper cooling of the condenser and resin cartridge unit.

Immediately following the adsorbent cartridge will be a series of four full size leak-free glass impingers. All impingers will be of the Greenburg-Smith design, with the first impinger being further modified to have a short stem, to prevent the sample gas from bubbling through the collected condensate. The first impinger will be empty, the second and third impingers each contained 100 milliliters of HPLC-grade distilled water, the fourth empty and the fifth will be charged with silica gel. The impingers will be immersed in an ice bath for the duration of the test.

All train components will be cleaned before use to avoid organic contamination. This cleaning will include a hot soapy wash, three deionized water rinses, two hours of heating at 450 °F, three acetone rinses, and three methylene chloride rinses. All glassware components are then covered with hexane rinsed aluminum foil until assembled at the site.

The impingers will be connected to the metering system via an umbilical. The metering system includes a vacuum gauge, a leak-free pump, thermometers accurate to within ± 5.4 °F, and a dry gas meter accurate to within two percent.

Procedures for selecting sampling locations and for operation of the train will be derived from EPA Method 23 and associated Methods 1 through 5. The flue gas sample will be collected by operating the train according to the Method 5 specifications, including leak-checking, isokinetic sampling rates, and stack traversing. Sampling will be performed isokinetically (within plus or minus 10 percent).

At the conclusion of each test run, the probe and umbilical will be carefully removed from the sampling train. The inlet to the sampling train will be removed to a clean field laboratory for sample recovery. The sample from the probe nozzle and probe liner will be recovered at the sampling location. The recovered sample will consist of the following components:

- ◆ Glass fiber filter and particulate catch;
- ◆ Adsorbent trap containing the XAD-2 resin;
- ◆ Acetone/Methylene chloride rinse: Probe liner and nozzle rinsed and brushed three times with acetone and rinsed three times with methylene chloride combined with three rinses of the filter holder, coil condenser and all interconnecting glassware, with three soaks of the condenser with acetone and methylene chloride each;

- ◆ Toluene rinse: Probe liner and nozzle rinsed three times combined with three rinses of the filter holder, coil condenser and all interconnecting glassware with three soaks of the condenser with toluene;
- ◆ The volume of water collected in the impinger train will be measured gravimetrically.

One field train blank will be assembled, recovered and analyzed in the same manner as a sample train.

The samples will be analyzed for PCDDs and PCDFs in accordance with EPA Method 23 protocol using high resolution gas chromatography and high resolution mass spectrometry (GC/MS). All Method 23 samples will be analyzed with the DB-5S column with modified calibration and additional quality assurance procedures as a direct substitute for the DB-5 and DB-225 columns. Confirmation of the 2,3,7,8 TCDF and 2,3,7,8 isomers will be performed on the DB-5S column and modified calibration procedures meets the column separation requirement and can be used as a direct substitute for the DB-5 and DB-225 columns in accordance with Method 23 as approved by the USEPA.

All of the organic analytical work will be performed by an outsourced laboratory. All components of the recovered sampling train, including the toluene rinse, will be pooled and extracted for one analysis.

E. Hydrogen Chloride Testing – EPA Method 26/26a

Hydrogen chloride (HCl) testing will be conducted simultaneously on the SDA inlet and stack outlet. Each test run will be 60 minutes in duration. Each test will be conducted from a single point in the stack. This data will be correlated with meter coefficients, temperatures, barometric pressure, and stack gas moisture (EPA Method 4) to determine the stack gas dry exhaust flow rate. HCl samples will be collected following EPA Method 26a with an isokinetic sampling train utilizing a glass nozzle and probe liner. A scale will be used to measure net weight gain from each impinger to determine moisture gain. An out-sourced laboratory will be used to provide HCl results.

The train components will include a glass nozzle, heated glass lined probe, heated quartz fiber filter, and four full size impingers. The first impinger will have 50 milliliters of 0.1 N sulfuric acid solution and a short stem. The second and third impingers will each have 100 milliliters of 0.1 N sulfuric acid solution. The fourth impinger will be empty and the fifth will contain silica gel. The sodium hydroxide impingers will not be used as chlorine (Cl₂), does not need to be determined.

An integrated sample of at least 30 dry standard cubic feet will be extracted from the gas stream and passed through the dilute sulfuric acid. In the dilute acid, the HCl gas dissolves and forms chloride (Cl⁻) ions. The train will be leak checked as described in Method 5 from the end of the glass probe liner after testing. After the one hour test the first four impingers, all connecting glassware and back half of the filter housing will be rinsed into one polyethylene container. The probe liner, filter and filter housing will not be recovered. The liquid level of the one sample container will be marked. The Cl⁻ concentration will be determined by ion chromatography.

As part of the quality assurance program, one duplicate analysis will be performed as specified in Method 26a. In addition, a spike analysis will be performed on one of the

samples. Three runs will be performed for each unit. The hydrogen chloride removal efficiency will be calculated using the ppm_{dv} @ 7% O₂ concentration at the SDA inlet and stack outlet.

F. Opacity – EPA Method 9

Visual opacity from the stack outlet will be determined using EPA Method 9. This method determines the level of any visible emissions that occur during the observation period. It requires that the opacity of emission be determined by a trained and certified individual. Three one hour runs will be observed from the proper location(s) on the stack outlet. The opacity level is recorded every 15 seconds.

**APPENDIX A
QA/QC PROGRAM**

QA/QC PROGRAM

AIR HYGIENE ensures the quality and validity of its emission measurement and reporting procedures through a rigorous quality assurance (QA) program. The program is developed and administered by an internal QA team and encompasses five major areas:

1. QA reviews of reports, laboratory work, and field testing;
2. Equipment calibration and maintenance;
3. Chain-of-custody;
4. Training; and
5. Knowledge of current test methods.

QA Reviews

AIR HYGIENE's review procedure includes a review of each source test report, along with laboratory and fieldwork by the QA Team.

The most important review is the one that takes place before a test program begins. The QA Team works closely with technical division personnel to prepare and review test protocols. Test protocol review includes selection of appropriate test procedures, evaluation of interferences or other restrictions that might preclude use of standard test procedures, and evaluation and/or development of alternate procedures.

Equipment Calibration and Maintenance

The equipment used to conduct the emission measurements is maintained according to the manufacturer's instructions to ensure proper operation. In addition to the maintenance program, calibrations are carried out on each measurement device according to the schedule outlined by the Environmental Protection Agency. Quality control checks are also conducted in the field for each test program.

Chain-of-Custody

AIR HYGIENE maintains full chain-of-custody documentation on all samples and data sheets. In addition to normal documentation of changes between field sample custodians, laboratory personnel, and field test personnel, AIR HYGIENE documents every individual who handles any test component in the field (e.g., probe wash, impinger loading and recovery, filter loading and recovery, etc.). Samples are stored in a locked area to which only AIR HYGIENE personnel have access. Field data sheets are secured at AIR HYGIENE's offices upon return from the field.

Training

Personnel training is essential to ensure quality testing. AIR HYGIENE has formal and informal training programs, which include:

1. Attendance at EPA-sponsored training courses;
2. Enrollment in EPA correspondence courses;
3. A requirement for all technicians to read and understand Air Hygiene Incorporated's QA manual;
4. In-house training and QA meetings on a regular basis; and
5. Maintenance of training records.

Knowledge of Current Test Methods

With the constant updating of standard test methods and the wide variety of emerging test procedures, it is essential that any qualified source tester keep abreast of new developments. AIR HYGIENE subscribes to services, which provide updates on EPA reference methods, rules, and regulations. Additionally, source test personnel regularly attend and present papers at testing and emission-related seminars and conferences.

COMBUSTION TESTING QUALITY ASSURANCE ACTIVITIES

A number of quality assurance activities are undertaken before, during, and after each testing project. The following paragraphs detail the quality control techniques, which are rigorously followed during testing projects.

Each instrument's response is checked and adjusted in the field prior to the collection of data via multi-point calibration. The instrument's linearity is checked by first adjusting its zero and span responses to zero nitrogen and an upscale calibration gas in the range of the expected concentrations. The instrument response is then challenged with other calibration gases of known concentration and accepted as being linear if the response of the other calibration gases agreed within ± 2 percent of range of the predicted values.

After each test run, the analyzers are checked for zero and span drift. This allowed each test run to be bracketed by calibrations and documents the precision of the data just collected. The criteria for acceptable data are that the instrument drift is no more than 3 percent of the full-scale response. Quality assurance worksheets are prepared to document the multipoint calibration checks and zero to span checks performed during the tests.

The sampling systems are leak checked by demonstrating that a vacuum greater than 10 in Hg could be held for at least 1 minute with a decline of less than 1 in. Hg. A leak test is conducted after the sample system is set up and before the system is dismantled. This test was conducted to ensure that ambient air had not diluted the sample. Any leakage detected prior to the tests would be repaired and another leak check conducted before testing commenced.

The absence of leaks in the sampling system is also verified by a sampling system bias check. The sampling system's integrity is tested by comparing the responses of the analyzers to the calibration gases introduced via two paths. The first path was directly into the analyzer and the second path via the sample system at the sample probe. Any difference in the instrument responses by these two methods is attributed to sampling system bias or leakage. The criteria for acceptance are agreement within 5% of the span of the analyzer.

The control gases used to calibrate the instruments are analyzed and certified by the compressed gas vendors to $\pm 1\%$ accuracy for all gases. EPA Protocol No. 1 was used where applicable to assign the concentration values traceable to the National Institute of Standards and Technology (NIST), Standard Reference Materials.

AIR HYGIENE maintains a large variety of calibration gases to allow the flexibility to accurately test emissions over a wide range of concentrations.

APPENDIX B
TEST EQUIPMENT CONFIGURATION and DESCRIPTION

INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS

The sampling and analysis procedures to be used conform in principle with the methods outlined in the Code of Federal Regulations, Title 40, Part 60, Appendix A, Methods 1, 2, 3a, 4, 5, 6c, 7e, 9, 10, 23, 26a; 40 CFR 51, Appendix M, Method 202; and the Ontario Hydro Method.

The sample system to be used for the NO_x, SO₂, CO₂, CO, and O₂ tests is configured per the following description. A stainless steel probe will be inserted into the sample port of the stack. The gas sample will be continuously pulled through the probe and transported via 3/8 inch heat-traced Teflon® tubing to a stainless steel, minimum-contact condenser designed to dry the sample and then through Teflon® tubing via a stainless steel/Teflon® diaphragm pump and into the sample manifold within the mobile laboratory. From the manifold, the sample is partitioned to the NO_x, SO₂, CO₂, CO, and O₂ analyzers through rotameters that control the flow rate of the sample.

The schematic (Figure 1) shows that the sample system is also equipped with a separate path through which a calibration gas could be delivered to the probe and back through the entire sampling system. This allows for convenient performance of system bias checks as required by the testing methods.

All instruments are housed in an air-conditioned, trailer-mounted mobile laboratory. Gaseous calibration standards are provided in aluminum cylinders with the concentrations certified by the vendor according to EPA Protocol No. 1.

This general schematic also illustrates the analyzers to be used for the tests (i.e., O₂, CO). All data from the Reference Method continuous monitoring instruments are recorded on a Logic Beach Hyperlogger. The Hyperlogger retrieves calibrated emissions data from each instrument every second. An average value is recorded every 30 seconds.

The stack gas analysis for O₂ and CO₂ concentrations will be performed in accordance with procedures set forth in EPA Method 3a. The O₂ analyzer uses a paramagnetic cell detector. The CO₂ analyzer uses a continuous nondispersive infrared (NDIR) analyzer.

EPA Method 6c will be used to determine the concentrations of SO₂. An ultraviolet analyzer will be used to determine the sulfur dioxide concentrations in the gas stream.

EPA Method 7e will be used to determine concentrations of NO_x. A chemiluminescence analyzer will be used to determine the nitrogen oxides concentration in the gas stream. A NO₂ in nitrogen certified gas cylinder will be used to verify at least a 90 percent NO₂ conversion on the day of the test.

CO emission concentrations will be quantified in accordance with procedures set forth in EPA Method 10. A continuous nondispersive infrared (NDIR) analyzer was used for this purpose.

Figure 2 represents the sample train setup for all of the wet chemistry (isokinetic) sampling. An S-type pitot tube will be used to measure cyclonic flow and velocity pressure in accordance with EPA Method 2. This data will be correlated with meter coefficients, temperatures, barometric pressure, and stack gas moisture (EPA Method 4) to determine the stack gas dry exhaust flow rate. Samples will be collected following EPA Methods with an isokinetic sampling train utilizing a stainless steel or glass nozzles and inconel or glass probe liners as appropriate. A scale will be used to measure net weight gain from each impinger to determine moisture gain.





Figure 1
EMISSIONS TESTING LAB
5634 S. 122nd East Ave, Suite F
Tulsa, Oklahoma 74146
www.airhygiene.com
(888) 461-8778



Wet Chemistry Assembly (photo)




Figure 2
WET CHEMISTRY ASSEMBLY
 5634 S. 122nd East Ave, Suite F
 Tulsa, Oklahoma 74146
 www.airhygiene.com
 (888) 461-8778

TABLE #1: TESTING MATRIX

Target Emission	EPA Test Method	Location	Test Length
O ₂	3a	Inlet / Outlet	3, 60 minute runs [inlet] 3, 60 minute runs [outlet]
SO ₂	6c	Inlet / Outlet	3, 60 minute runs [inlet] 3, 60 minute runs [outlet]
NO _x	7e	Outlet	3, 60 minute runs
CO	10	Inlet / Outlet	3, 60 minute runs [inlet] 3, 60 minute runs [outlet]
CO ₂	3a	Inlet / Outlet	3, 60 minute runs [inlet] 3, 60 minute runs [outlet]
PM (front half filterable)	5	Outlet	3, 150-minute runs
PM ₁₀ (back half condensable)	202	Outlet	3, 150-minute runs
Opacity	9	Outlet	3, 60-minute runs
Hg	Ontario Hydro	Outlet	3, 120-minute runs
HCl	26/26a	Inlet / Outlet	3, 60 minute runs [inlet] 3, 60 minute runs [outlet]
Dioxins/Furans	23	Outlet	3, 240-minute runs

TABLE #2: ANALYTICAL INSTRUMENTATION

Parameter	Model and Manufacturer	Common Use Ranges	Sensitivity	Detection Principle
NO _x	API 200AH or equivalent	User may select up to 5,000 ppm	0.1 ppm	Thermal reduction of NO ₂ to NO Chemilumines-cence of reaction of NO with O ₃ . Detection by PMT. Inherently linear for listed ranges.
SO ₂	Ametek 721M or equivalent	User may select up to 10,000 ppm	0.1 ppm	Ultraviolet
CO	TECO 48C or equivalent	0-10,000 ppm	0.1 ppm	Infrared absorption, gas filter correlation detector, microprocessor based linearization.
CO ₂	Servomex or equivalent	0-20%	0.1%	Nondispersive infrared
O ₂	Servomex or equivalent	0-25%	0.1%	Oxygen - Paramagnetic cell

TABLE #3: ANALYTICAL INSTRUMENTATION TESTING CONFIGURATION

Parameter	Sample Methodology	Example Range	Sensitivity	Calibration Gases (based on example range)
NO _x	7e	0-500 ppm	0.1 ppm	Zero = 0 ppm nitrogen Mid = 200 – 300 ppm High = 500 ppm
SO ₂	6c	0-200 ppm	0.1 ppm	Zero = 0 ppm nitrogen Mid = 80 – 120 ppm High = 200 ppm
CO	10	0-200 ppm	0.1 ppm	Zero = 0 ppm nitrogen Mid = 80 – 120 ppm High = 200 ppm
CO ₂	3a	0-20%	0.1%	Zero = 0 ppm nitrogen Mid = 8 – 12% High = 20%
O ₂	3a	0-21%	0.1%	Zero = 0 ppm nitrogen Mid = 8.4 – 12.6% High = 21%

**APPENDIX C
STACK DRAWINGS**

METHOD 1 - ISOKINETIC TRAVERSE FOR A CIRCULAR SOURCE

Company	SNC - Lavalin	Date	2007
Plant Name	Fibrominn Biomass Power Plant	Project #	snc-07-benson.mn-comp#1
Equipment	Biomass Boiler, SDA Inlet	# of Ports Available	4
Location	Benson, Minnesota	# of Ports Used	4

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L _{fw})	141.00	in.
Distance to Near Wall of Stack	(L _{nw})	12.00	in.*
Diameter of Stack	(D)	129.00	in.
Area of Stack	(A _s)	90.76	ft ²




*assume 12 in. reference

Distance from Disturbances to Port			
Distance Upstream	(A)	350.00	in.
Diameters Upstream	(A _D)	2.71	diameters
Distance Downstream	(B)	1222.00	in.
Diameters Downstream	(B _D)	9.47	diameters

Number of Traverse Points Required					
Diameters to Flow Disturbance		Minimum Number of ¹ Traverse Points		Minimum Number of Traverse Points	
Down (B _D)	Up (A _D)	Particulate	Velocity	Criteria	Points
2.00-4.99	0.50-1.24	24	16	<input type="checkbox"/> RM 7E 8.1.2	12 RM1 pts
5.00-5.99	1.25-1.49	20	16	<input type="checkbox"/> Alt 7E 8.1.2	3 points
6.00-6.99	1.50-1.74	16	12	12 points	
7.00-7.99	1.75-1.99	12	12	12 points	
>= 8.00	>=2.00	8 or 12 ²	8 or 12 ²	Minimum Number of	
Upstream Spec		12	12	Traverse Points	
Downstream Spec		12	12	RATA Stratification	
Traverse Pts Required		12	12	Criteria	Points
¹ Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.				<input type="checkbox"/> Part75/60	12 RM1 pts
² 8 for Circular Stacks 12 to 24 inches				<input type="checkbox"/> 75 abrv (a)	3 points
12 for Circular Stacks over 24 inches				<input type="checkbox"/> 75 abrv (b)	6 points
				12 points	

Number of Traverse Points Used				
4	Ports by	3	Pts / port	Isokinetic Traverse
12	Pts Used	12	Required	(Wet Chemistry)

Traverse Point Locations			
Traverse Point Number	Percent of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
	%	in.	in.
1	4.4%	5 5/8	17 5/8
2	14.6%	18 7/8	30 7/8
3	29.6%	38 1/8	50 1/8
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			



METHOD 1 - ISOKINETIC TRAVERSE FOR A CIRCULAR SOURCE

Company	SNC - Lavalin	Date	2007
Plant Name	Fibrominn Biomass Power Plant	Project #	snc-07-benson.mn-comp#1
Equipment	Biomass Boiler, Stack Exhaust	# of Ports Available	4
Location	Benson, Minnesota	# of Ports Used	4

Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L _{fw})	120.00	in.
Distance to Near Wall of Stack	(L _{nw})	12.00	in.*
Diameter of Stack	(D)	108.00	in.
Area of Stack	(A _s)	63.62	ft ²

*assume 12 in. reference




Distance from Disturbances to Port			
Distance Upstream	(A)	2358.00	in.
Diameters Upstream	(A _D)	21.83	diameters
Distance Downstream	(B)	910.00	in.
Diameters Downstream	(B _D)	8.43	diameters

Number of Traverse Points Required					
Diameters to Flow Disturbance		Minimum Number of ¹ Traverse Points		Minimum Number of Traverse Points	
Down (B _D)	Up (A _D)	Particulate	Velocity	Criteria	Points
2.00-4.99	0.50-1.24	24	16	<input type="checkbox"/> RM 7E 8.1.2	12 RM1 pts
5.00-5.99	1.25-1.49	20	16	<input type="checkbox"/> Alt 7E 8.1.2	3 points
6.00-6.99	1.50-1.74	16	12	12 points	
7.00-7.99	1.75-1.99	12	12		
>= 8.00	>=2.00	8 or 12 ²	8 or 12 ²	Minimum Number of Traverse Points	
Upstream Spec		12	12	Criteria	
Downstream Spec		12	12	Points	
Traverse Pts Required		12	12	<input type="checkbox"/> Part75/60	12 RM1 pts
				<input type="checkbox"/> 75 abrv (a)	3 points
				<input type="checkbox"/> 75 abrv (b)	6 points
					12 points

¹ Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.
² 8 for Circular Stacks 12 to 24 inches
 12 for Circular Stacks over 24 inches

Number of Traverse Points Used				
4	Ports by	3	Pts / port	Isokinetic Traverse
12	Pts Used	12	Required	(Wet Chemistry)

Traverse Point Locations			
Traverse Point Number	Percent of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
	%	in.	in.
1	4.4%	4 6/8	16 6/8
2	14.6%	15 6/8	27 6/8
3	29.6%	32	44
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			



APPENDIX D
EXAMPLE TEMPLATES AND CALCULATIONS

SINGLE LOAD TEST - FIELD DATA SHEET

AIR HYGIENE



Company:	
Location:	
Date:	
Unit Make and Model:	
Unit Number:	
Serial Number:	
Data Recorded By:	
Tested With AHI Unit(s):	Truck(s): Trailer(s):
LDEQ Warmup/Cal Req:	On (Day/Time): Cal (Day/Time):

CYLINDER SERIAL NUMBERS		O ₂	NOx	CO
	Low			
	Mid			
	High			

CYLINDER SERIAL NUMBERS		THC	CO ₂	SO ₂
	Low			
	Mid			
	High			

RUN INFORMATION	Load		
	% #1	% #2	% #3
Time Start (hh:mm:ss)			
Time Stop (hh:mm:ss)			
Rated Power (MW or hp)			
Actual Power (MW or hp)			
Barometric Pressure (in. Hg)			
Ambient Temperature (°F)			
Relative Humidity (%)			
Fuel Flow (lb/min)			
Fuel Flow (SCF/hr)=(lb/min)*21.7			
Specific Humidity (gr/lb)			
Spec. Hum. (lb H ₂ O/lb air)=(gr/lb)/7000			
PCD (psi)			
PCD (mm Hg)=(psi+14.24)*51.71493			
NOx Water Injection (gpm)			

NO ₂ CONVERSION	
NO ₂ Gas (ppm)	
NO Reading (ppm)	
NOx Reading (ppm)	
Cylinder Num	

REPORT INFORMATION		
	INSTRUMENT	SERIAL #
O ₂		
NOx		
CO		
THC		
CO ₂		
SO ₂		

RESPONSE TIME		
	TIME (hh:mm)	RESP (min)
1 st Gas Inject		
1 st Inst. @ 95%		
2 nd Inst. @ 95%		
3 rd Inst. @ 95%		
2 nd Gas Inject		
1 st Inst. @ 95%		
2 nd Inst. @ 95%		
3 rd Inst. @ 95%		
3 rd Gas Inject		
1 st Inst. @ 95%		
2 nd Inst. @ 95%		
3 rd Inst. @ 95%		

CALIBRATION	O ₂		NOx		CO		THC		CO ₂		SO ₂	
	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual	Conc.	Actual
Zero Gas												
Low Gas												
Mid Gas												
High Gas												

BIAS	O ₂		NOx		CO		THC		CO ₂		SO ₂	
	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid	Zero	Mid
Initial Run #1												
Run #1 / Run #2												
Run #2 / Run #3												
Run #3 / Final												

Bias Gas Actual Conc. _____

Method Used (Circle One)
 Method 9 203A 203B Other: _____

Company Name _____
 Facility Name _____
 Street Address _____
 City _____ State _____ Zip _____

Process _____ Unit # _____ Operating Mode _____
 Control Equipment _____ Operating Mode _____

Describe Emissions Point _____
 Height of Emiss. Pt. _____ Height of Emiss. Pt. Rel. to Observer _____
 Start _____ End _____ Start _____ End _____
 Distance to Emiss. Pt. _____ Direction to Emiss. Pt. (Degrees) _____
 Start _____ End _____ Start _____ End _____

Vertical Angle to Obs. Pt. _____ Direction to Obs. Pt. (Degrees) _____
 Start _____ End _____ Start _____ End _____
 Distance and Direction to Observation Point from Emission Point _____
 Start _____ End _____

Describe Emissions _____
 Start _____ End _____
 Emission Color _____ Water Droplet Plume _____
 Start _____ End _____ Start _____ End _____

Describe Plume Background _____
 Start _____ End _____
 Background Color _____ Sky Conditions _____
 Start _____ End _____ Start _____ End _____
 Wind Speed _____ Wind Direction _____
 Start _____ End _____ Start _____ End _____
 Ambient Temp. _____ Wet Bulb Temp. _____ RH Percent _____
 Start _____ End _____

Source Layout Sketch

Latitude _____ Longitude _____ Declination _____

Additional Information _____

VISUAL EMISSIONS OBSERVATION FORM

Form Number		Page		of			
Continued on Form Number _____							
Observation Date		Time Zone		Start Time		End Time	
Min.	Sec.	0	15	30	45	Comments	
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							

Observer's Name (Print) _____
 Observer's Signature _____ Date _____
 Organization _____
 Certified By _____ Date _____


Air Permit # :	
Plant Name or Location:	
Date:	
Project Number:	
Manufacturer & Equipment:	
Model:	
Serial Number:	
Unit Number:	
Test Load:	
Tester(s) / Test Unit(s):	

		RUN																	
	UNITS	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18
Start Time	hh:mm:ss																		
End Time	hh:mm:ss																		
Bar. Pressure	in. Hg																		
Amb. Temp.	°F																		
Rel. Humidity	%																		
Spec. Humidity	lb water / lb air																		
Comb. Inlet Pres.	psig																		
NOx Water Inj.	gpm																		
Total Fuel Flow	SCFH																		
Heat Input	MMBtu/hr																		
Power Output	megawatts																		
Steam Rate	lb/hr																		

Calibration Date:
Client:


NOx Span (ppm) =

THERMO 42H (NOx Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail ($\pm 2\%$, $\leq 0.5\text{ppm}$)
Linearity =				




CO Span (ppm) =

API 300 (CO Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail ($\pm 2\%$, $\leq 0.5\text{ppm}$)
Linearity =				



O2 Span (%) =


SERVOMEX 1400 (O2 Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail ($\pm 2\%$, $\leq 0.5\%$)
Linearity =				



THC Range (ppm) =


THERMO 51 (THC Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Estimated Point (ppm)	Pass or Fail ($\pm 2.5\%$ ¹)
Linearity =				

¹-zero/high based on 2% of span/low based on 5% of concentration




CO2 Span (%) =

FUJI 3300 (CO2 Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail ($\pm 2\%$, $\leq 0.5\%$)
Linearity =				



SO2 Span (ppm) =

Ametek 721M (SO2 Analyzer)				
Certified Concentration (ppm)	Instrument Response (ppm)	Calibration Error (%)	Absolute Conc. (ppm)	Pass or Fail ($\pm 2\%$, $\leq 0.5\text{ppm}$)
Linearity =				



NOx Converter Efficiency

Date:

Analyzer:

RM 7E, (08-15-06), 8.2.4.1 Introduce a concentration of 40 to 60 ppmv NO_x to the analyzer in direct calibration mode and record the NO_x concentration displayed by the analyzer. ... Calculate the converter efficiency using Equation 7E-7 in Section 12.7. The specification for converter efficiency in Section 13.5 must be met. ... The NQ must be prepared according to the EPA Traceability Protocol and have an accuracy within 2.0 percent.

Audit Gas: NO₂ Concentration (C_v), ppmvd

Converter Efficiency Calculations:

Analyzer Reading, NO Channel, ppmvd

Analyzer Reading, NO_x Channel, ppmvd

Analyzer Reading, NO₂ Channel (C_{Dir(NO2)}), ppmvd

Converter Efficiency, %

RM 7E, (08-15-06), 13.5 NO₂ to NO Conversion Efficiency Test (as applicable). The NO₂ to NO conversion efficiency, calculated according to Equation 7E-7 or Equation 7E-9, must be greater than or equal to 90 percent.

$$Eff_{NO_2} = \left(\frac{C_{Dir}}{C_v} \right) \times 100 \quad \text{Eq. 7E-7} = \frac{\text{ppmvd}}{\text{ppmvd}} \times 100 =$$

Date/Time	Elapsed Time	NOx	NO
mm/dd/yy hh:mm:ss	Seconds	ppmvd	ppmvd

Fuel Data

Fuel F ₂ factor		SCF/MMBtu
Fuel Heating Value (HHV)		Btu/SCF

Weather Data

Barometric Pressure		in. Hg
Relative Humidity		%
Ambient Temperature		°F
Specific Humidity		lb H ₂ O / lb air

Unit Data

Unit Load		megawatts
Heat Input		lb/MMBtu
Steam Rate		Steam lb/hr
Combustor Inlet Pres.		psig
NOx Control Water Injection		gpm
Est. Stack Moisture		%
Stack Exhaust Flow (M2)		SCFH
Stack Exhaust Flow (M19)		SCFH

Run - 1

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)
----------------------------------	---------------------------	-----------------------	----------------	---------------

RAW AVERAGE

	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)
Serial Number:			
Initial Zero			
Final Zero			
Avg. Zero			
Initial UpScale			
Final UpScale			
Avg. UpScale			

Upscale Cal Gas

EMISSIONS DATA	O ₂	NOx	CO
Corrected Raw Average (ppm/% dry basis)			
Corrected Raw Average (ppm/% wet basis)			
Concentration (ppm@ %O ₂)			
Concentration (ppm@ %O ₂ &ISO)			
Emission Rate (lb/hr)			
Emission Rate (tons/day) at 24 hr/day			
Emission Rate (tons/year) at 8760 hr/yr			
Emission Rate (lb/MMBtu)			
Emission Rate (g/hp ³ hr)			

DRIFT AND BIAS CHECK			
Run - 1	O2	NOx	CO
Raw Average			
Corrected Average			
Initial Zero			
Final Zero			
Avg. Zero			
Initial UpScale			
Final UpScale			
Avg. UpScale			
Sys Resp (Zero)			
Sys Resp (Upscale)			
Upscale Cal Gas			
Initial Zero Bias			
Final Zero Bias			
Zero Drift			
Initial Upscale Bias			
Final Upscale Bias			
Upscale Drift			
Alternative Specification Abs Diff	Initial Zero		
	Final Zero		
	Initial Upscale		
	Final Upscale		
Calibration Span			
3% of Range (drift)			
5% of Range (bias)			

DRIFT AND BIAS CHECK			
Run - 2	O2	NOx	CO
Raw Average			
Corrected Average			
Initial Zero			
Final Zero			
Avg. Zero			
Initial UpScale			
Final UpScale			
Avg. UpScale			
Sys Resp (Zero)			
Sys Resp (Upscale)			
Upscale Cal Gas			
Initial Zero Bias			
Final Zero Bias			
Zero Drift			
Initial Upscale Bias			
Final Upscale Bias			
Upscale Drift			
Alternative Specification Abs Diff	Initial Zero		
	Final Zero		
	Initial Upscale		
	Final Upscale		
Calibration Span			
3% of Range (drift)			
5% of Range (bias)			

**TABLE A.2
LOAD 1 DATA SUMMARY**

Parameter	Run - 1	Run - 2	Run - 3	Average
Start Time (hh:mm:ss)				
End Time (hh:mm:ss)				
Run Duration (min)				
Bar. Pressure (in. Hg)				
Amb. Temp. (°F)				
Rel. Humidity (%)				
Spec. Humidity (lb water / lb air)				
Turbine Fuel Flow (SCFH)				
Stack Flow (RM19) (SCFH)				
Power Output (megawatts)				
NOx (ppmvd)				
NOx (lb/hr)				
NOx (lb/MMBtu)				
NOx (g/hp*hr)				
CO (ppmvd)				
CO (lb/hr)				
CO (lb/MMBtu)				
CO (g/hp*hr)				
O ₂ (%)				

**TABLE A.3
LOAD 2 DATA SUMMARY**

Parameter	Run - 4	Run - 5	Run - 6	Average
Start Time (hh:mm:ss)				
End Time (hh:mm:ss)				
Run Duration (min)				
Bar. Pressure (in. Hg)				
Amb. Temp. (°F)				
Rel. Humidity (%)				
Spec. Humidity (lb water / lb air)				
Turbine Fuel Flow (SCFH)				
Stack Flow (RM19) (SCFH)				
Power Output (megawatts)				
NOx (ppmvd)				
NOx (lb/hr)				
NOx (lb/MMBtu)				
NOx (g/hp*hr)				
CO (ppmvd)				
CO (lb/hr)				
CO (lb/MMBtu)				
CO (g/hp*hr)				
O ₂ (%)				

EXAMPLE CALCULATIONS (INFORMATION)

Specific Humidity (RH_{sp})

Note: RH_{sp} (gr/lb) calculated using temperature, relative humidity, and barometric pressure with psychrometric chart, psychrometric calculator, or built in psychrometric algorithm.

$$RH_{sp} \text{ (lb / lb)} = \left[\left(\frac{gr}{lb} \right) \times \frac{lb}{7000 gr} \right] \quad RH_{sp} = \frac{gr}{lb} \times \frac{1 lb}{7000 gr} = \frac{lb H_2O}{lb Air}$$

Fuel Flow Conversion (Q_f)

Note: Q_f(lb/min) is a value uptained from the source operator.

$$Q_f = \left[Q_f \times G \times \left(\frac{1}{MW_{Fuel}} \right) \right] \quad Q_f = \frac{lb}{min} \times \frac{60 min}{hr} \times \frac{ft^3}{lb-mol} \times \frac{lb-mol}{lb} = \text{SCFH}$$

Combustor Inlet Pressure / Compressor Discharge Pressure (CIP / CDP)

(corrected from gauge to atmospheric pres. and conv. to mm Hg.)

Note: CIP / CDP (psig) is a value obtained from the source operator.

$$CIP / CDP = \left[(psig + P) \times \frac{51.71493 mmHg}{1 psi} \right] \quad CIP / CDP = \left[\text{psig} + \right] \times \frac{51.71493 mmHg}{1 psia} = \text{mmHg (abs)}$$

Heat Rate (MMBtu/hr)

$$HR = \frac{HHV_{DRY} \times Q_f}{1,000,000} \quad \text{Heat Rate} = \frac{Btu}{SCF} \times \frac{SCF}{hr} \times \frac{MMBtu}{10^6 Btu} = \frac{MMBtu}{hr}$$

Estimated Stack Gas Moisture Content (B_{ws})

$$B_{ws} (\%) = \frac{2 \times Q_f}{Q_s} \times 100 \quad B_{ws} = 2 \times \frac{SCF}{hr} \times \frac{hr}{SCF} \times 100 = \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (CALIBRATION)

Analyzer Calibration Error

RM 7E, (08-15-06), 12.2 Analyzer Calibration Error. For non-dilution systems, use Equation 7E-1 to calculate the analyzer calibration error for the low-, mid-, and high-level calibration gases. (calc for analyzer mid gas, if applicable)

$$ACE = \left(\frac{C_{Dir} - C_V}{CS} \right) \times 100 \quad \text{Eq. 7E-1} \quad ACE = \frac{\text{ppm} - \text{ppm}}{\text{ppm}} \times 100 = \%$$

Calibration Error and Estimated Point, RM 25A, THC Analyzer

RM 25A, (07-19-06), 8.4 Calibration Error Test. Immediately prior to the test series (within 2 hours of the start of the test), introduce zero gas and high-level calibration gas at the calibration valve assembly. Adjust the analyzer output to the appropriate levels, if necessary. Calculate the predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level response. Then introduce low-level and mid-level calibration gases successively to the measurement system. ... These differences must be less than 5 percent of the respective calibration gas value. (calc for THC analyzer mid gas, if applicable)

$$E_p = \frac{C_{Dir(H)} - C_{Dir(Z)}}{C_{V(H)} - C_{V(Z)}} \times C_{Dir(M)} + C_{Dir(Z)} \quad \text{Eq. of a line } y=mx+b \quad E_p = \frac{\text{ppm} - \text{ppm}}{\text{ppm} - \text{ppm}} \times \text{ppm} + \text{ppm} = \text{ppm}$$

$$ACE = \left(\frac{C_{Dir} - C_V}{CS} \right) \times 100 \quad \text{Eq. 7E-1} \quad ACE_{THC} = \frac{\text{ppm} - \text{ppm}}{\text{ppm}} \times 100 = \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (BIAS, DRIFT, AND CORRECTED RAW AVERAGE)

System Bias

RM 7E, (08-15-06), 12.3 System Bias. For non-dilution systems, use Equation 7E-2 to calculate the system bias separately for the low-level and upscale calibration gases. (calc for analyzer upscale gas, Run 1 initial bias, if applicable)

$$SB = \left(\frac{C_S - C_{Dir}}{C_S} \right) \times 100 \quad \text{Eq. 7E-2} \quad SB = \frac{\text{ppm} - \text{ppm}}{\text{ppm}} \times 100 = \%$$

Drift Assessment

RM 7E, (08-15-06), 12.5 Drift Assessment. Use Equation 7E-4 to separately calculate the low-level and upscale drift over each test run. (calc for analyzer upscale drift, Run 1, if applicable)

$$D = |SB_{final} - SB_i| \quad \text{Eq. 7E-4} \quad D = | \quad \% - \quad \% | = \%$$

Alternative Drift and Bias

RM 7E, (08-15-06), 13.2 / 13.3 System Bias and Drift. Alternatively, the results are acceptable if |Cs - Cdir| is ≤ 0.5 ppmv or if |Cs - Cv| is ≤ 0.5 ppmv (as applicable). (calc for analyzer initial upscale, Run 1, if applicable)

$$SB / D_{Air} = |C_S - C_{Dir}| \quad \text{Eq. Section 13.2 and 13.3} \quad SB / D_{Air} = | \quad \text{ppm} - \quad \text{ppm} | = \text{ppm}$$

Bias Adjusted Average

RM 7E, (08-15-06), 12.6 Effluent Gas Concentration. For each test run, calculate Cavg, the arithmetic average of all valid concentration values (e.g., 1-minute averages). Then adjust the value of Cavg for bias, using Equation 7E-5. (calc for analyzer, Run 1, if applicable)

$$C_{Gas} = (C_{Avg} - C_O) \times \left(\frac{C_{MA}}{C_M - C_O} \right) \quad \text{Eq. 7E-5} \quad C_{Gas} = \left(\text{ppm} - \text{ppm} \right) \times \left(\frac{\text{ppm}}{\text{ppm} - \text{ppm}} \right) = \text{ppm}$$

EXAMPLE CALCULATIONS (BSFC)

Using LHV with Q_f (Btu/hp*hr)

$$BSFC (Btu / hp \cdot hr) = Q_f$$

$$BSFC = \frac{\text{Btu}}{\text{hp} \cdot \text{hr}} = \frac{\text{Btu}}{\text{hp} \cdot \text{hr}}$$

Using HHV with Q_f (SCFH)

$$BSFC (Btu / hp \cdot hr) = \frac{HHV \times Q_f}{bhp}$$

$$BSFC = \frac{\text{Btu}}{\text{SCF}} \times \frac{\text{SCF}}{\text{hr}} \times \frac{1}{\text{hp}} = \frac{\text{Btu}}{\text{hp} \cdot \text{hr}}$$

Using LHV with Q_f (SCFH)

$$BSFC (Btu / hp \cdot hr) = \frac{LHV \times Q_f}{bhp}$$

$$BSFC = \frac{\text{Btu}}{\text{SCF}} \times \frac{\text{SCF}}{\text{hr}} \times \frac{1}{\text{hp}} = \frac{\text{Btu}}{\text{hp} \cdot \text{hr}}$$

Using HHV with Q_f (Btu/hp*hr)

$$BSFC (Btu / hp \cdot hr) = \frac{Q_f \times HHV}{LHV}$$

$$BSFC = \frac{\text{N/A Btu}}{\text{hp} \cdot \text{hr}} \times \frac{\text{Btu}}{\text{SCF}} \times \frac{\text{scf}}{\text{Btu}} = \frac{\text{Btu}}{\text{hp} \cdot \text{hr}}$$

EXAMPLE CALCULATIONS (Emissions based on Table 29 values)

Emission Rate (lb/hr)

Q_f (Btu/hp*hr)

$$E (lb / hr) = \frac{E_{g / hp \cdot hr} \times bhp}{453.6}$$

$$E (lb/hr) = \frac{\text{g}}{\text{hp} \cdot \text{hr}} \times \frac{\text{lb}}{453.6 \text{ g}} \times \text{hp} = \frac{\text{lb}}{\text{hr}}$$

Emission Rate (g/hp-hr)

Q_f (Btu/hp*hr)

$$E (g / hp \cdot hr) = CRA \times Q_f \times FFactor \times MW \times \frac{1}{10^6} \times \frac{1}{10^6} \times \frac{453.6}{G} \times \frac{20.9\%}{20.9\% - CRA_{O_2}}$$

$$E (g/hp-hr) = \text{ppm} \times \frac{\text{Btu}}{\text{hp} \cdot \text{hr}} \times \frac{\text{SCF}}{\text{MMBtu}} \times \frac{\text{lb}}{\text{lb-mol}} \times \frac{1 \text{ parts}}{10^6 \text{ ppm}} \times \frac{1 \text{ MMBtu}}{10^6 \text{ Btu}} \times \frac{453.6 \text{ g}}{\text{lb}} \times \frac{\text{lb-mol}}{\text{SCF}} \times \frac{20.9\%}{20.9\% - \%} = \frac{\text{g}}{\text{hp} \cdot \text{hr}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (RUNS)

Stack Exhaust Flow (Q_s) - RM19

$$Q_s = \left(\frac{FFactor \times Q_f \times HHV}{1,000,000} \right) \times \left(\frac{20.9\%}{20.9\% - C_{Gas(O_2)}} \right)$$

$$Q_s = \frac{SCF}{MMBtu} \times \frac{SCF}{hr} \times \frac{Btu}{SCF}$$

$$\times \frac{MMBtu}{10^6 \text{ Btu}} \times \left(\frac{20.90\%}{20.9\% - \%} \right) = \text{SCFH}$$

NO₂ Conversion Efficiency Correction

RM 7E, (08-15-06), 12.8 NO₂ - NO Conversion Efficiency Correction. If desired, calculate the total NOx concentration with a correction for converter efficiency using Equations 7E-8. (calc for non-bias corrected (raw) NOx gas, Run 1, if applicable)

$$NOx_{Corr} = NO + \frac{NOx - NO}{Eff_{NO_2}} \times 100 \quad \text{Eq. 7E-8}$$

$$NOx_{Corr} = \text{ppm} + \frac{\text{ppm} - \text{ppm}}{\%} \times 100 = \text{ppm}$$

Moisture Correction

RM 7E, (08-15-06), RM7E, (08-15-06), 12.10 Moisture Correction. Use Equation 7E-10 if your measurements need to be corrected to a dry basis. (calc for THC analyzer, Run 1, if applicable) Note: Calculations may not match as Run 1 results are typically also bias adjusted

$$C_D = \frac{C_w}{1 - B_{WS}} \quad \text{Eq. 7E-10}$$

$$C_D = \frac{\text{ppm}_{vw}}{1 - \%} = \text{ppm}_{vd}$$

Diluent-Corrected Polutant Concentration, O₂ Based

RM 20, (11-26-02), 7.3.1 Correction of Pollutant Concentration Using O₂ Concentration. Calculate the O₂ corrected pollutant concentration, as follows: (calc for gas, Run 1, if applicable)

$$C_{adj} = C_{Gas(T arg et)} \times \left(\frac{20.9\% - AdjFactor}{20.9\% - C_{Gas(O_2)}} \right) \quad \text{Eq. 20-4}$$

$$C_{adj} = \text{ppm} \times \left(\frac{20.9\% - \%}{20.9\% - \%} \right) = \text{ppm}@ \%O_2$$

Diluent-Corrected Polutant Concentration, CO₂ Based

RM 20, (11-26-02), 7.3.2 Correction of Pollutant Concentration Using CO₂ Concentration. Calculate the CO₂ corrected pollutant concentration, as follows: (calc for gas, Run 1, if applicable)

$$C_{adj} = C_{Gas(T arg et)} \times \frac{X_{CO_2}}{C_{Gas(CO_2)}} \quad \text{Eq. 20-5}$$

$$C_{adj} = \text{ppm} \times \frac{\%}{\%} =$$

7.2 CO₂ Correction Factor. If pollutant concentrations are to be corrected to percent O₂ and CO₂ concentration is measured in lieu of O₂ concentration measurement, a CO₂ correction factor is needed. Calculate the CO₂ correction factor as follows: 7.2.1 Calculate the fuel specific F₀, as follows:

$$F_0 = \frac{0.209 F_d}{F_c} \quad \text{Eq. 20-2}$$

$$F_0 = \frac{0.209 \times \text{SCF/MMBtu}}{\text{SCF/MMBtu}} =$$

7.2.2. Calculate the CO₂ correction factor for correcting measurement data to percent oxygen, as follows:

$$X_{CO_2} = \frac{20.9\% - AdjFactor}{F_0} \quad \text{Eq. 20-3}$$

$$X_{CO_2} = \frac{20.9\% - \%}{\%} = \%$$

Diluent-Corrected Polutant Concentration Corrected to ISO Conditions

40CFR60.335(b)(1), Conversion for conc. at ISO Conditions (68°F, 1 atm). Calculate, as follows: (calc for @% with Run 1 data, if applicable)

$$C_{ISO} = C_{Adj} \times \sqrt{\frac{P_r}{P_o}} \times e^{(19 \times (H_a - 0.00633))} \times \left(\frac{288}{T_a} \right)^{1.53}$$

$$C_{ISO} = \text{ppm}@ \%O_2 \times \left(\frac{\text{psig} + 14.69232 \text{ psi}}{0.01933677 \text{ psi/mm Hg.}} \right)^{(19 \times (\text{lb/lb} - 0.00633))} \times \left(\frac{288 \text{ K}}{\text{K}} \right)^{1.53} \times 2.718 = \text{ppm}@ \% \text{ and ISO}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (RUNS)

Emissions Rate (lb/hr)

Calculation for pound per hour emission rate. Calculate, as follows: (calc for gas Run 1, if applicable)

$$E_{lb/hr} = \frac{C_{Gas}}{10^6} \times \frac{Q_S \times MW}{G} \qquad E_{lb/hr} = \frac{\text{ppm}}{10^6 \text{ ppm/part}} \times \frac{\text{SCFH} \times \text{lb/lb-mol}}{\text{SCF/lb-mol}} = \frac{\text{lb}}{\text{hr}}$$

Emissions Rate (ton/year)

Calculation for tons per year emission rate based on 8760 hours per year. Calculate, as follows: (calc for gas Run 1, if applicable)

$$E_{ton/yr} = \frac{E_{lb/hr} \times \text{hr}_{year}}{2000} \qquad E_{ton/yr} = \frac{\text{lb}}{\text{hr}} \times \frac{\text{hr}}{\text{year}} \times \frac{\text{ton}}{2000 \text{ lb}} = \frac{\text{ton}}{\text{year}}$$

Emissions Rate (lb/MMBtu)

RM 19, (07-19-06), 12.2 Emission Rates of PM, SO₂, and NO_x. Select from the following sections the applicable procedure to compute the PM, SO₂, or NO_x emission rate (E) in ng/J (lb/million Btu). (calc for gas Run 1, if applicable)

Oxygen Based

12.2.1 Oxygen-Based F Factor, Dry Basis. When measurements are on a dry basis for both O₂ (%O₂d) and pollutant (Cd) concentrations, use the following equation:

$$E_{lb/MMBtu} = \frac{C_{Gas} \times F_d \text{ Factor} \times \text{Conv}_c \times 20.9\%}{20.9\% - C_{Gas(O_2)}} \qquad \text{Eq. 19-1}$$

$$E_{lb/MMBtu} = \frac{\text{ppm} \times \text{SCF/MMBtu} \times \text{lb/ppm} \cdot \text{ft}^3 \times 20.9\%}{20.9\% - \%} = \frac{\text{lb}}{\text{MMBtu}}$$

Carbon Dioxide Based

12.2.4 Carbon Dioxide-Based F Factor, Dry Basis. When measurements are on a dry basis for both CO₂ (%CO₂d) and pollutant (Cd) concentrations, use the following equation:

$$E_{lb/MMBtu} = \frac{C_{Gas} \times F_d \text{ Factor} \times \text{Conv}_c \times 100\%}{C_{Gas(CO_2)}} \qquad \text{Eq. 19-6}$$

$$E_{lb/MMBtu} = \frac{\text{ppm} \times \text{SCF/MMBtu} \times \text{lb/ppm} \cdot \text{ft}^3 \times 100\%}{\%} = \frac{\text{lb}}{\text{MMBtu}}$$

Conversion Constant

Conv_c for

$$\text{Conv}_c (\text{lb} / \text{ppm} \cdot \text{ft}^3) = \frac{MW}{10^6} \qquad \text{Conv}_c = \frac{\text{lb}}{\text{lb} \cdot \text{mole}} \times \frac{\text{lb} \cdot \text{mole}}{\text{SCF}} = \frac{\text{lb}}{\text{ppm} \cdot \text{ft}^3}$$

Sulfur Dioxide Rate (lb/MMBtu), 40CFR60, App. A, RM 19, Eq. 19-25 (11/20/03)

$$SO_2 (\text{lb} / \text{MMBtu}) = 0.97 \times K \times \frac{S(\text{wt}\%)}{GCV} \qquad SO_2 = 0.97 \times \frac{2 \times 10^4 \text{ Btu}}{\text{wt}\% \cdot \text{MMBtu}} \times \frac{\text{wt}\%}{\text{Btu/lb}} = \frac{\text{lb}}{\text{MMBtu}}$$

Emissions Rate (g/hp-hr)

Calculation for grams per horsepower-hour. Calculate, as follows: (calc for gas Run 1, if applicable)

$$E_{g/hp-hr} = \frac{E_{lb/hr} \times 453.6}{\text{mw} \times 1314.022} \text{ or } \frac{E_{lb/hr} \times 453.6}{hp} \qquad E_{g/hp-hr} = \frac{\text{lb}}{\text{hr}} \times \frac{453.6 \text{ g}}{\text{lb}} \times \frac{1}{\text{mw}} \times \frac{\text{mw}}{1314.022 \text{ hp}} = \frac{\text{g}}{\text{hp} \cdot \text{hr}}$$

$$E_{g/hp-hr} = \frac{\text{lb}}{\text{hr}} \times \frac{453.6 \text{ g}}{\text{lb}} \times \frac{1}{\text{hp}} = \frac{\text{g}}{\text{hp} \cdot \text{hr}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

RM 7E, (08-15-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

ACE = Analyzer calibration error, percent of calibration span.
B_{WS} = Moisture content of sample gas as measured by Method 4 or other approved method, percent/100.
C_{Avg} = Average unadjusted gas concentration indicated by data recorder for the test run.
C_D = Pollutant concentration adjusted to dry conditions.
C_{Dir} = Measured concentration of a calibration gas (low, mid, or high) when introduced in direct calibration mode.
C_{Gas} = Average effluent gas concentration adjusted for bias.
C_M = Average of initial and final system calibration bias (or 2-point system calibration error) check responses for the upscale calibration gas.
C_{MA} = Actual concentration of the upscale calibration gas, ppmv.
C_O = Average of the initial and final system calibration bias (or 2-point system calibration error) check responses from the low-level (or zero) calibration gas.
C_S = Measured concentration of a calibration gas (low, mid, or high) when introduced in system calibration mode.
C_{SS} = Concentration of NO_x measured in the spiked sample.
C_{Spike} = Concentration of NO_x in the undiluted spike gas.
C_{Calc} = Calculated concentration of NO_x in the spike gas diluted in the sample.
C_V = Manufacturer certified concentration of a calibration gas (low, mid, or high).
C_W = Pollutant concentration measured under moist sample conditions, wet basis.
CS = Calibration span.
D = Drift assessment, percent of calibration span.
E_p = The predicted response for the low-level and mid-level gases based on a linear response line between the zero and high-level response.
Eff_{NO₂} = NO₂ to NO converter efficiency, percent.
H = High calibration gas, designator.
L = Low calibration gas, designator.
M = Mid calibration gas, designator.
NO_{Final} = The average NO concentration observed with the analyzer in the NO mode during the converter efficiency test in Section 16.2.2.
NO_xCorr = The NO_x concentration corrected for the converter efficiency.
NO_xFinal = The final NO_x concentration observed during the converter efficiency test in Section 16.2.2.
NO_xPeak = The highest NO_x concentration observed during the converter efficiency test in Section 16.2.2.
Q_{Spike} = Flow rate of spike gas introduced in system calibration mode, L/min.
Q_{Total} = Total sample flow rate during the spike test, L/min.
R = Spike recovery, percent.
SB = System bias, percent of calibration span.
SB_i = Pre-run system bias, percent of calibration span.
SB_f = Post-run system bias, percent of calibration span.
SB / D_{Air} = Alternative absolute difference criteria to pass bias and/or drift checks.
SCE = System calibration error, percent of calibration span.
SCE_i = Pre-run system calibration error, percent of calibration span.
SCE_{final} = Post-run system calibration error, percent of calibration span.
Z = Zero calibration gas, designator.

40CFR60.355(b)(1), (09-20-06), Nomenclature. The terms used in the equations are defined as follows:

P_r = reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg
P_o = observed combustor inlet absolute pressure at test, mm Hg
H_o = observed humidity of ambient air, g H₂O/g air
e = transcendental constant, 2.718
T_a = ambient temperature, K

Small Engine and FTIR Nomenclature. The terms used in the equations are defined as follows:

bhp = brake horsepower
hp = horsepower
Q_{sys} = system flow (lpm)
Q_m = matrix spike flow (lpm)

RM 19, (07-29-06), 12.1 Nomenclature. The terms used in the equations are defined as follows:

AdjFactor = percent oxygen or carbon dioxide adjustment applied to a target pollutant
 B_{wa} = Moisture fraction of ambient air, percent.
 Btu = British thermal unit
 $\%_C$ = Concentration of carbon from an ultimate analysis of fuel, weight percent.
 $\%_{CO2d}, \%_{CO2w}$ = Concentration of carbon dioxide on a dry and wet basis, respectively, percent.
 CIP / CDP = Combustor inlet pressure / compressor discharge pressure (mm Hg); note, some manufactures reference as PCD.
 E = Pollutant emission rate, ng/J (lb/million Btu).
 E_a = Average pollutant rate for the specified performance test period, ng/J (lb/million Btu).
 E_{a0}, E_{a1} = Average pollutant rate of the control device, outlet and inlet, respectively, for the performance test period, ng/J (lb/million Btu).
 E_{bi} = Pollutant rate from the steam generating unit, ng/J (lb/million Btu).
 E_{bo} = Pollutant emission rate from the steam generating unit, ng/J (lb/million Btu).
 E_{ci} = Pollutant rate in combined effluent, ng/J (lb/million Btu).
 E_{co} = Pollutant emission rate in combined effluent, ng/J (lb/million Btu).
 E_d = Average pollutant rate for each sampling period (e.g., 24-hr Method 6B sample or 24-hr fuel sample) or for each fuel lot (e.g., amount of fuel bunkered), ng/J (lb/million Btu).
 E_{di} = Average inlet SO₂ rate for each sampling period d, ng/J (lb/million Btu).
 E_g = Pollutant rate from gas turbine, ng/J (lb/million Btu).
 E_{ga} = Daily geometric average pollutant rate, ng/J (lbs/million Btu) or ppm corrected to 7 percent O₂.
 E_{oi}, E_{ji} = Matched pair hourly arithmetic average pollutant rate, outlet and inlet, respectively, ng/J (lb/million Btu) or ppm corrected to 7 percent O₂.
 E_{hj} = Hourly arithmetic average pollutant rate for hour "j," ng/J (lb/million Btu) or ppm corrected to 7 percent O₂.
 EXP = Natural logarithmic base (2.718) raised to the value enclosed by brackets.
 F_c = Ratio of the volume of carbon dioxide produced to the gross calorific value of the fuel from Method 19
 F_d, F_w, F_c = Volumes of combustion components per unit of heat content, scm/J (scf/million Btu).
 ft^3 = cubic feet
 G = ideal gas conversion factor
 (385.23 SCF/lb-mol at 68 deg F & 14.696 psia)
 GCM = gross Btu per SCF (constant, compound based)
 GCV = Gross calorific value of the fuel consistent with the ultimate analysis, kJ/kg (Btu/lb).
 GCV_p, GCV_r = Gross calorific value for the product and raw fuel lots, respectively, dry basis, kJ/kg (Btu/lb).
 $\%_H$ = Concentration of hydrogen from an ultimate analysis of fuel, weight percent.
 H_b = Heat input rate to the steam generating unit from fuels fired in the steam generating unit, J/hr (million Btu/hr).
 H_g = Heat input rate to gas turbine from all fuels fired in the gas turbine, J/hr (million Btu/hr).
 $\%_{H2O}$ = Concentration of water from an ultimate analysis of fuel, weight percent.
 H_t = Total numbers of hours in the performance test period (e.g., 720 hours for 30-day performance test period).
 K = volume of combustion component per pound of component (constant)
 K = Conversion factor, 10^{-5} (kJ/J)/(%) [10^6 Btu/million Btu].
 $K_c = (9.57 \text{ scm/kg})/\% [(1.53 \text{ scf/lb})/\%]$.
 $K_{cc} = (2.0 \text{ scm/kg})/\% [(0.321 \text{ scf/lb})/\%]$.
 $K_{hd} = (22.7 \text{ scm/kg})/\% [(3.64 \text{ scf/lb})/\%]$.
 $K_{hw} = (34.74 \text{ scm/kg})/\% [(5.57 \text{ scf/lb})/\%]$.
 $K_n = (0.86 \text{ scm/kg})/\% [(0.14 \text{ scf/lb})/\%]$.
 $K_o = (2.85 \text{ scm/kg})/\% [(0.46 \text{ scf/lb})/\%]$.
 $K_s = (3.54 \text{ scm/kg})/\% [(0.57 \text{ scf/lb})/\%]$.
 $K_{sulfur} = 2 \times 10^4 \text{ Btu/wt}\% \text{-MMBtu}$
 $K_w = (1.30 \text{ scm/kg})/\% [(0.21 \text{ scf/lb})/\%]$.
 lb = pound
 \ln = Natural log of indicated value.
 L_p, L_r = Weight of the product and raw fuel lots, respectively, metric ton (ton).
 $\%_N$ = Concentration of nitrogen from an ultimate analysis of fuel, weight percent.
 $M\%$ = mole percent
 mol = mole
 MW = molecular weight (lb/lb-mol)
 MW_{AIR} = molecular weight of air (28.9625 lb/lb-mole)¹
 NCM = net Btu per SCF (constant based on compound)
 $\%_O$ = Concentration of oxygen from an ultimate analysis of fuel, weight percent.
 $\%_{O2d}, \%_{O2w}$ = Concentration of oxygen on a dry and wet basis, respectively, percent.
 P_B = barometric pressure, in Hg
 P_s = Potential SO₂ emissions, percent.
 $\%_S$ = Sulfur content of as-fired fuel lot, dry basis, weight percent.
 S_e = Standard deviation of the hourly average pollutant rates for each performance test period, ng/J (lb/million Btu).
 $\%_{SF}$ = Concentration of sulfur from an ultimate analysis of fuel, weight percent.
 $S(wt\%)$ = weight percent of sulfur, per lab analysis by appropriate ASTM standard
 S_d = Standard deviation of the hourly average inlet pollutant rates for each performance test period, ng/J (lb/million Btu).
 S_o = Standard deviation of the hourly average emission rates for each performance test period, ng/J (lb/million Btu).
 $\%S_p, \%S_r$ = Sulfur content of the product and raw fuel lots respectively, dry basis, weight percent.
 SCF = standard cubic feet
 SH = specific humidity, pounds of water per pound of air
 $t_{0.95}$ = Values shown in Table 19-3 for the indicated number of data points n.
 T_{amb} = ambient temperature, °F
 W/D Factor = 1.0236 = conv. at 14.696 psia and
 68 deg F (ref. Civil Eng. Ref. Manual, 7th Ed.)
 X_{CO2} = CO₂ Correction factor, percent.
 X_k = Fraction of total heat input from each type of fuel k.

ALARMS EXIST !!! - Check Alarm Sheet

ALARMS EXIST !!! - Check Alarm Sheet

<input type="checkbox"/>	English Units	<input type="radio"/> <input checked="" type="radio"/>	Cells Unprotected
--------------------------	---------------	--	-------------------

Source Information			
Plant Name			
Sampling Location			
Fuel or Source Type	Gas, Natural		
Fuel F-Factor			

Test Information			
Starting Test Date			
Project #			
Operator			
Standard Temperature		68	oF
Standard Pressure		29.92	in Hg
Minimum Required Sample Vol.	indust. spec.	100	scf
Run Duration	chk Subpart	180	minutes
Unit Number			
Load	% or w/DB		
Base Run Number			
Number of Ports Available			
Number of Ports Used			
Port Inside Diameter			in
Circular Stack		<input type="checkbox"/>	

Test Equipment Information					
Run		1	2	3	
Meter Box Number	from ACS				
Meter Calibration Factor	(Y)				
Orifice Meter Coefficient	(ΔH_{θ})				in H ₂ O
Pitot Identification	from ACS				
Pitot Tube Coefficient	(C _p)	0.840	0.840	0.840	
Orsat Identification	from ACS				
Nozzle Number	from ACS				
Nozzle Diameter	(D _n)				in
Probe Number	from ACS				
Probe Length					in
(SS, Glass) Liner Material	from list	inconel	inconel	inconel	
Sample Case / Oven Number	from ACS				
Impinger Case Number	from ACS				
Acetone Lot Number	from bottle				

Testing Company Information	
Company Name	Air Hygiene International, Inc. (Tulsa, Oklahoma)
Address	5634 S. 122nd East Ave., Suite F
City, State Country Zip	Tulsa, Oklahoma 74146
Project Manager	
Phone Number	(918) 307-8865
Fax Number	(918) 307-9131

METHOD 1 - SAMPLE AND VELOCITY TRAVERSES FOR CIRCULAR SOURCES

Plant Name		Date	
Sampling Location		Project #	
Operator		# of Ports Available	
Stack Type	Circular	# of Ports Used	
Stack Size		Port Inside Diameter	


Circular Stack or Duct Diameter			
Distance to Far Wall of Stack	(L_{fw})		in
Distance to Near Wall of Stack	(L_{nw})		in
Diameter of Stack	(D)		in
Area of Stack	(A_s)		ft ²

Distance from Port to Disturbances			
Distance Downstream	(B)		in
Diameters Downstream	(B_D)		diameters
Distance Upstream	(A)		in
Diameters Upstream	(A_D)		diameters

Number of Traverse Points Required			
Diameters to Flow Disturbance		Minimum Number of Traverse Points ^a	
Down Stream	Up Stream	Particulate Points	Velocity Points
2.00-4.99	0.50-1.24	24	16
5.00-5.99	1.25-1.49	20	16
6.00-6.99	1.50-1.74	16	12
7.00-7.99	1.75-1.99	12	12
≥ 8.00	≥ 2.00	8 or 12 ²	8 or 12 ²
Upstream Spec			
Downstream Spec			
Traverse Pts Required			

¹ Check Minimum Number of Points for the Upstream and Downstream conditions, then use the largest.
² 8 for Circular Stacks 12 to 24 inches
 12 for Circular Stacks over 24 inches

Location of Traverse Points in Circular Stacks									
Traverse Point	(Fraction of Stack Dimension from Inside Wall to Traverse Point)								
Number	Number of Traverse Points Across the Stack								
	2	4	6	8	10	12	14	16	18
1	.146	.067	.044	.032	.026	.021	.018	.016	.014
2	.854	.250	.146	.105	.082	.067	.057	.049	.044
3		.750	.296	.194	.146	.118	.099	.085	.075
4		.933	.704	.323	.226	.177	.146	.125	.109
5			.854	.677	.342	.250	.201	.169	.146
6			.956	.806	.658	.356	.269	.220	.188
7				.895	.774	.644	.366	.283	.236
8				.968	.854	.750	.634	.375	.296
9					.918	.823	.731	.625	.382
10					.974	.882	.799	.717	.618
11						.933	.854	.780	.704
12						.979	.901	.831	.764



Number of Traverse Points Used			
	Ports by		Across
	Pts Used		Required
			Particulate Traverse

Traverse Point Locations			
Traverse Point Number	Fraction of Stack Diameter	Distance from Inside Wall	Distance Including Reference Length
		in	in
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			

METHOD 3a - DETERMINATION OF DRY MOLECULAR WEIGHT BY ANALYZER

Plant Name					Date		
Sampling Location					Project #		
Operator					# of Ports Used		
Fuel Type	N/A	Minimum Fuel Factor	1.600	Maximum Fuel Factor	1.836		
Orsat Leak Check	<input type="checkbox"/>	PreTest	<input type="checkbox"/>	PostTest	Orsat Identification		

Gas Analysis Data										
Run Number		1				Run Start Time		Run Stop Time		
Sample Analysis Time	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N ₂)	Dry Molecular Weight (M _d)	Molecular Weight Deviation (ΔM _d)	
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole	
Results			Averages							
Average Calculated Fuel Factor			(F _o) _{avg}			Molecular Wt Deviation < 0.3?			<input type="checkbox"/>	
Average Excess Air			(%EA) _{avg}			percent	Fuel Factor in Handbook Range?		<input type="checkbox"/>	

Gas Analysis Data										
Run Number		2				Run Start Time		Run Stop Time		
Sample Analysis Time	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N ₂)	Dry Molecular Weight (M _d)	Molecular Weight Deviation (ΔM _d)	
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole	
Results			Averages							
Average Calculated Fuel Factor			(F _o) _{avg}			Molecular Wt Deviation < 0.3?			<input type="checkbox"/>	
Average Excess Air			(%EA) _{avg}			percent	Fuel Factor in Handbook Range?		<input type="checkbox"/>	

Gas Analysis Data										
Run Number		3				Run Start Time		Run Stop Time		
Sample Analysis Time	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (ppmCO)	Carbon Dioxide Conc. (%CO ₂)	Oxygen Conc. (%O ₂)	Carbon Monoxide Conc. (%CO)	Nitrogen Conc. (%N ₂)	Dry Molecular Weight (M _d)	Molecular Weight Deviation (ΔM _d)	
hh:mm	percent	percent	ppm	percent	percent	percent	percent	lb/lb-mole	lb/lb-mole	
Results			Averages							
Average Calculated Fuel Factor			(F _o) _{avg}			Molecular Wt Deviation < 0.3?			<input type="checkbox"/>	
Average Excess Air			(%EA) _{avg}			percent	Fuel Factor in Handbook Range?		<input type="checkbox"/>	

Fuel Factor Fo		
Fuel Type	Minimum	Maximum
Coal, Anthracite	1.016	1.130
Coal, Lignite	1.016	1.130
Coal, Bituminous	1.083	1.230
Oil, Distillate	1.260	1.413
Oil, Residual	1.210	1.370
Gas, Natural	1.600	1.836
Gas, Propane	1.434	1.586
Gas, Butane	1.405	1.553
Wood	1.000	1.120
Wood Bark	1.003	1.130

METHOD 4 - DETERMINATION OF MOISTURE CONTENT IN STACK GASES

Plant Name					Date	
Sampling Location					Project #	
Operator					# of Ports Used	
Stack Type	Circular				Meter Box Number	
Train Leak Check	<input type="checkbox"/>	PreTest	<input type="checkbox"/>	PostTest	Meter Cal Factor (Y)	

Moisture Content Data								
Run Number	1		Run Start Time		Run Stop Time			
Total Meter Volume	(V_m)		dcf	Barometric Press.	(P_b)		in Hg	
Avg Meter Temp	$(t_m)_{avg}$		oF	Stack Static Press.	(P_{static})		in H2O	
Avg Stack Temp	$(t_s)_{avg}$		oF	Avg Orifice Press.	$(\Delta H)_{avg}$		in H2O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8
	g	g	g	g	g	g	g	g
Contents	DI	DI	DI	Sil Gel				
Final Value	$(V_f), (W_f)$							
Initial Value	$(V_i), (W_i)$							
Net Value	$(V_n), (W_n)$							
Results								
Total Weight	(W_t)		g	Water Vol Weighed	$(V_{wsg(std)})$		scf	
Std Meter Volume	$(V_{m(std)})$		dscf	Sat. Moisture Content	$(B_{ws(svp)})$		%	
Calc Moisture Content	$(B_{ws(calc)})$		%	Final Moisture Content	(B_{ws})		%	

Moisture Content Data								
Run Number	2		Run Start Time		Run Stop Time			
Total Meter Volume	(V_m)		dcf	Barometric Press.	(P_b)		in Hg	
Avg Meter Temp	$(t_m)_{avg}$		oF	Stack Static Press.	(P_{static})		in H2O	
Avg Stack Temp	$(t_s)_{avg}$		oF	Avg Orifice Press.	$(\Delta H)_{avg}$		in H2O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8
	g	g	g	g	g	g	g	g
Contents	DI	DI	DI	Sil Gel				
Final Value	$(V_f), (W_f)$							
Initial Value	$(V_i), (W_i)$							
Net Value	$(V_n), (W_n)$							
Results								
Total Weight	(W_t)		g	Water Vol Weighed	$(V_{wsg(std)})$		scf	
Std Meter Volume	$(V_{m(std)})$		dscf	Sat. Moisture Content	$(B_{ws(svp)})$		%	
Calc Moisture Content	(B_{ws})		%	Final Moisture Content	(B_{ws})		%	

Moisture Content Data								
Run Number	3		Run Start Time		Run Stop Time			
Total Meter Volume	(V_m)		dcf	Barometric Press.	(P_b)		in Hg	
Avg Meter Temp	$(t_m)_{avg}$		oF	Stack Static Press.	(P_{static})		in H2O	
Avg Stack Temp	$(t_s)_{avg}$		oF	Avg Orifice Press.	$(\Delta H)_{avg}$		in H2O	
	Impinger 1	Impinger 2	Impinger 3	Impinger 4	Impinger 5	Impinger 6	Impinger 7	Impinger 8
	g	g	g	g	g	g	g	g
Contents	DI	DI	DI	Sil Gel				
Final Value	$(V_f), (W_f)$							
Initial Value	$(V_i), (W_i)$							
Net Value	$(V_n), (W_n)$							
Results								
Total Weight	(W_t)		g	Water Vol Weighed	$(V_{wsg(std)})$		scf	
Std Meter Volume	$(V_{m(std)})$		dscf	Sat. Moisture Content	$(B_{ws(svp)})$		%	
Calc Moisture Content	(B_{ws})		%	Final Moisture Content	(B_{ws})		%	

- SAMPLE RECOVERY AND INTEGRITY DATA SHEET

Plant Name		Date	
Sampling Location		Project #	
Operator		Acetone Lot Number	

Run History Data				
Run Number	1	2	3	
Run Start Time				(hh:mm)
Run Stop Time				(hh:mm)
Train Prepared By				
Train Recovered By				
Recovery Date				(mm/dd/yy)
Relinquished By				
Received By				
Relinquished Date				(mm/dd/yy)
Relinquished Time				(hh:mm)

Equipment Identification Numbers			
Filter			
Acetone Wash			
Silica Gel			
Impinger Case			
Sample Box			
Oven			

Alarms Exist - Enter Filter Numbers!!!

Sample Blank Taken NO

Alarms Exist - Collect Sample Blanks of at least 75ml each!!!

Moisture Content Data					
Impingers 1, 2, and 3 - Liquid Volume					
Final Volume	(V _f)				ml
Initial Volume	(V _i)				ml
Net Volume	(V _n)				ml
Comments					
Impinger 4 - Silica Gel Weight					
Final Weight	(W _f)				g
Initial Weight	(W _i)				g
Net Weight	(W _n)				g
Comments					
Total Water Collected					
Total Volume	(V _{ic})				ml

METHOD 5 (FRONTHALF) AND 202 (BACKHALF) - SAMPLE ANALYTICAL DATA SHEET

Plant Name		Date	
Sampling Location		Project #	
Operator		Acetone Lot Number	

Analytical Data						
Placed in Desiccator				Run	1	Start Time
	Number	Date	Time	Leakage Evident?	<input type="checkbox"/>	
Filter				Estimated Volume	0.00	
Probe Wash Beaker #						
Water Beaker #						
MeCl (org) Beaker #						

Weight Data							
Filter and Beaker Weight		Filter	Date	Time	Humidity	Temp	Cal Audit
		g	mm/dd/yy	hh:mm	%RH	oF	g
Measurement 1	(m _{1f})						
Measurement 2	(m _{2f})						
Measurement 3	(m _{3f})						
Measurement 4	(m _{4f})						
Probe Wash and Beaker Weight		Acetone	Date	Time	Humidity	Temp	Cal Audit
		g	mm/dd/yy	hh:mm	%RH	oF	g
Measurement 1	(m _{1a})						
Measurement 2	(m _{2a})						
Measurement 3	(m _{3a})						
Measurement 4	(m _{4a})						
Imp Content and Beaker Weight		Imp Water	Date	Time	Humidity	Temp	Cal Audit
		g	mm/dd/yy	hh:mm	%RH	oF	g
Measurement 1	(m _{1ino})						
Measurement 2	(m _{2ino})						
Measurement 3	(m _{3ino})						
Measurement 4	(m _{4ino})						
Organics and Beaker Weight		MeCl Org	Date	Time	Humidity	Temp	Cal Audit
		g	mm/dd/yy	hh:mm	%RH	oF	g
Measurement 1	(m _{1org})						
Measurement 2	(m _{2org})						
Measurement 3	(m _{3org})						
Measurement 4	(m _{4org})						

METHOD 5 (FRONTHALF) AND 202 (BACKHALF) - SAMPLE ANALYTICAL DATA SHEET

Plant Name		Date	
Sampling Location		Project #	
Operator		Acetone Lot Number	

Tare (Pre-Particulate) Weights					
Tare	Filter	Filter Beaker	Acetone Beaker	Imp Content Beaker	
					g
Tare	Organics Beaker	PM₁₀ Beaker			
			g	Run	1

Sample Volume and Blank Concentrations			
Probe Wash Volume	(V _a)		ml
Impinger Content Volume	(V _{ino})		ml
Organics Wash Volume	(V _{org})		ml
Net Wash Volume	(V _n)		ml
Acetone Blank Weight of Solids	(W _{ab})		g
Imp Cont Blank Weight of Solids	(W _{inob})		g
MeCl Blank Weight of Solids	(W _{orgb})		g
Acetone Blank Volume	(V _{ab})		ml
Imp Content Blank Volume	(V _{inob})		ml
MeCl Blank Volume	(V _{orgb})		ml
Acetone Blank Concentration	(C _a)		mg/ml
Imp Content Blank Concentration	(C _{ino})		mg/ml
MeCl Blank Concentration	(C _{org})		mg/ml

Results							
		Filter_f	PM10_{a1'}	Probe_{a'}	Imp Cont_{ino'}	Organics_{org'}	
Final Weight	(m _{fx})						g
Tare Weight	(m _{tx})						g
Weight Gain	(m _x)						mg
Blank Adjustment	(W _x)						mg
Total Particulates	(M _n)						mg

METHOD 5 (FRONTHALF) AND 202 (BACKHALF) - RESULTS

Plant Name		Date	
Sampling Location		Project #	
Operator		Stack Type	Circular

Historical Data						
Run Number		1	2	3	Average	
Run Start Time						hh:mm
Run Stop Time						hh:mm
Meter Calibration Factor	(Y)					
Pitot Tube Coefficient	(C _p)	0.840	0.840	0.840		
Average Nozzle Diameter	(D _{na})		#DIV/0!	#DIV/0!		in
Stack Test Data						
Initial Meter Volume	(V _{m,i})					ft3
Final Meter Volume	(V _{m,f})					ft3
Total Meter Volume	(V _m)					ft3
Total Sampling Time	(t)	0.0	0.0	0.0	0.0	min
Average Meter Temperature	(t _m) _{avg}					oF
Average Stack Temperature	(t _s) _{avg}					oF
Barometric Pressure	(P _b)					in Hg
Stack Static Pressure	(P _{static})					in H2O
Absolute Stack Pressure	(P _s)					in Hg
Average Orifice Pressure Drop	(ΔH) _{avg}					in H2O
Absolute Meter Pressure	(P _m)					in Hg
Avg Square Root Pitot Pressure	(ΔP ^{1/2}) _{avg}					(in H2O) ^{1/2}
Moisture Content Data						
Impingers 1-3 Water Volume Gain	(V _w)					ml
Impinger 4 Silica Gel Weight Gain	(W _n)					g
Total Water Volume Collected	(V _{wc})					ml
Standard Water Vapor Volume	(V _w) _{std}					scf
Standard Meter Volume	(V _m) _{std}					dscf
Calculated Stack Moisture	(B _{ws(calc)})					%
Saturated Stack Moisture	(B _{ws(svp)})					%
Reported Stack Moisture Content	(B _{ws})					%
Gas Analysis Data						
Carbon Dioxide Percentage	(%CO ₂)					%
Oxygen Percentage	(%O ₂)					%
Carbon Monoxide Percentage	(%CO)					%
Nitrogen Percentage	(%N ₂)					%
Dry Gas Molecular Weight	(M _d)					lb/lb-mole
Wet Stack Gas Molecular Weight	(M _w)					lb/lb-mole
Calculated Fuel Factor	(F _d)					
Fuel F-Factor	(F _d)					dscf/MMBtu
Percent Excess Air	(%EA)					%
Volumetric Flow Rate Data						
Average Stack Gas Velocity	(V _s)					ft/sec
Stack Cross-Sectional Area	(A _s)					ft2
Actual Stack Flow Rate	(Q _{aw})					acfm
Wet Standard Stack Flow Rate	(Q _{sw})					wkscfh
Dry Standard Stack Flow Rate	(Q _{sd})					dscfm
Percent of Isokinetic Rate	(I)					%
Emission Rate Data						
Mass of Particulate on Filter	(M _f)					mg
Mass of Particulate in Acetone	(M _a)					mg
Mass of Particulate in Imp Content	(M _{ino})					mg
Mass of Particulate in Org Rinse	(M _{org})					mg
Total Mass of Particulates	(M _t)					mg
Stack Particulate Concentration	(C _s)					g/dscf
	(C _s)					gr/dscf
Particulate Emission Rate	(E)					kg/hr
	(E)					lbs/hr
	(E)					tons/yr
	(E)					lbs/MMBtu
(Pl 75 App F Sect. 5.2.1) Heat Input	(HI)					MMBtu/hr

EXAMPLE CALCULATIONS (Reference Method 1 - Circular Stack)

- L_{fw} = distance to far wall of stack (in.)
- L_{nw} = distance to near wall of stack (in.) [reference]
- D = diameter of stack (in.)
- A_s = area of stack (ft²)
- B = distance downstream (in.)
- B_D = stack diameters downstream (dia.)
- A = distance upstream (in.)
- A_D = stack diameters upstream (dia.)

Diameter of Stack (in.)

$$D(in.) = L_{fw} - L_{nw}$$

D (in.) = 0 in. - 0 in. = in.

Stack Diameters Downstream

$$B_D(dia.) = \frac{B}{D}$$

$B_D(dia.) = \frac{0 \text{ in.}}{\text{in.}} = \text{ diameters}$

Stack Diameters Upstream

$$A_D(dia.) = \frac{A}{D}$$

$A_D(dia.) = \frac{0 \text{ in.}}{\text{in.}} = \text{ diameters}$



Area of Stack (ft²)

$$A_s(ft^2) = \pi \times \left(\frac{D}{2 \times 12} \right)^2$$

$$A_s(ft^2) = 3.14 \times \left(\frac{\text{in.}}{2 \times 12 \text{ in./ft}} \right)^2 = \text{ft}^2$$

Number of Traverse Points

Based on 40 CFR Part 60, Appendix A, Method 1, Section 2.2



Traverse Point Locations

Based on 40 CFR Part 60, Appendix A, Method 1, Section 2.3

Location of Traverse Points in Circular Stacks (Fraction of Stack Dimension from Inside Wall to Traverse Point)												
Traverse Point Number	2	4	6	8	10	12	14	16	18	20	22	24
1	.146	.067	.044	.032	.023	.021	.018	.016	.014	.013	.011	.011
2	.854	.250	.146	.105	.082	.067	.057	.049	.044	.039	.035	.032
3		.750	.296	.194	.146	.118	.099	.085	.075	.067	.060	.055
4			.933	.704	.323	.226	.177	.146	.125	.109	.097	.087
5				.854	.677	.342	.250	.201	.169	.146	.129	.116
6					.956	.806	.658	.356	.269	.220	.188	.165
7						.895	.774	.644	.366	.283	.236	.204
8							.968	.854	.750	.634	.375	.296
9								.918	.823	.731	.625	.392
10									.982	.882	.799	.717
11										.933	.854	.780
12											.901	.831
13												.943
14												
15												
16												
17												
18												
19												
20												
21												
22												
23												
24												

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 2)

P_b = barometric pressure (in. Hg)

P_{static} = static pressure (in. H₂O)

P_s = absolute stack pressure (in. Hg)

%N₂ = nitrogen concentration (%)

%CO₂ = carbon dioxide concentration (%)

%O₂ = oxygen concentration (%)

%CO = carbon monoxide concentration (%)

MW = molecular weight (lb/lb-mole)

B_{ws} = stack moisture content (%)

M_d = stack dry molecular weight (lb/lb-mole)

M_s = stack wet molecular weight (lb/lb-mole)

T_{std} = standard temperature, 68°F, 528°R

P_{std} = standard pressure, 29.92 in. Hg

v_{sl} = local velocity (ft/sec)

v_s = average stack gas velocity (ft/sec)

Q_{sd} = average stack dry standard flow rate (dscf/hr)

Q_{aw} = average stack wet flow rate (ascf/min)

C_p = pitot tube coefficient

Δp = velocity head (in. H₂O)

A_s = area of stack (ft²)

N_a = null angle (deg.)

t_s = stack temperature (°F)

T_u = temperature offset, 460°R

K_p = pitot tube constant,

$$85.49 \text{ (ft/sec)} \left(\frac{\text{lb/lb-mole}(\text{in. Hg})}{(^{\circ}\text{R})(\text{in. Hg})} \right)^{1/2}$$

Absolute Stack Pressure (in. Hg)

$$P_s \text{ (in. Hg)} = P_b + \frac{P_{static}}{13.6}$$

$$P_s \text{ (in. Hg)} = 0 \text{ in. Hg} + \frac{0.00 \text{ in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O/in. Hg}} = \text{in. Hg}$$

Nitrogen Concentration (%)

$$\% N_2 = 100 - \% CO_2 - \% O_2 - \% CO$$

$$\% N_2 \text{ (%) } = 100 - 0 \% - 0 \% - 0 \% = \%$$

Stack Dry Molecular Weight (lb/lb-mole)

$$M_d \text{ (lb / lb - mol)} = \sum \left(\frac{MW_{comp}}{100} \times \% \text{ component} \right)$$

$$M_d \text{ (lb/lb-mol)} = \left[\frac{44 \text{ lb/lb-mol}}{100} \times 0 \% \right] + \left[\frac{32 \text{ lb/lb-mol}}{100} \times 0 \% \right] + \text{etc.} = \frac{\text{lb}}{\text{lb-mol}}$$

Stack Wet Molecular Weight (lb/lb-mole)

$$M_s \text{ (lb / lb - mol)} = \left[M_d \times \left(1 - \frac{B_{ws}}{100} \right) \right] + \left[MW_{H_2O} \times \frac{B_{ws}}{100} \right]$$

$$M_s \text{ (lb/lb-mol)} = \left[\frac{\text{lb}}{\text{lb-mol}} \times \left(1 - \frac{0 \%}{100} \right) \right] + \left[\frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{0 \%}{100} \right] = \frac{\text{lb}}{\text{lb-mol}}$$

Local Velocity (ft/sec)

$$v_{s(l)} \text{ (ft / sec)} = K_p \times C_p \times \sqrt{\Delta p} \times \sqrt{\frac{t_s + T_u}{P_s \times M_s}}$$

$$v_{sl} \text{ (ft/sec)} = \frac{85.49 \text{ ft}}{\text{sec}} \left(\frac{\text{lb/lb-mol}(\text{in. Hg})}{(^{\circ}\text{R})(\text{in. H}_2\text{O})} \right)^{1/2} \times 0.84 \times \sqrt{0.00 \text{ in. H}_2\text{O}} \times \sqrt{\frac{0 + 460 \text{ }^{\circ}\text{R}}{\text{in. Hg} \times \text{lb/lb-mol}}} = \frac{\text{ft}}{\text{sec}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 2)

P_b = barometric pressure (in. Hg)

P_{static} = static pressure (in. H₂O)

P_s = absolute stack pressure (in. Hg)

%N₂ = nitrogen concentration (%)

%CO₂ = carbon dioxide concentration (%)

%O₂ = oxygen concentration (%)

%CO = carbon monoxide concentration (%)

MW = molecular weight (lb/lb-mole)

B_{ws} = stack moisture content (%)

M_d = stack dry molecular weight (lb/lb-mole)

M_s = stack wet molecular weight (lb/lb-mole)

K_p = pitot tube constant,

$$85.49 \text{ (ft/sec)} \left(\frac{\text{(lb/lb-mole)(in. Hg)}}{(\text{°R})(\text{in. Hg})} \right)^{1/2}$$

T_{STD} = standard temperature, 68°F

P_{STD} = standard pressure, 29.92 in. Hg

v_{sl} = local velocity (ft/sec)

v_s = average stack gas velocity (ft/sec)

Q_{SD} = average stack dry standard flow rate (dscf/hr)

Q_{AW} = average stack wet flow rate (ascf/min)

C_p = pitot tube coefficient

Δp = velocity head (in. H₂O)

A_s = area of stack (ft²)

N_A = null angle (deg.)

t_s = stack temperature (°F)

T_u = temperature offset, 460°R

Average Stack Gas Velocity (ft/sec)

$$v_s \text{ (ft/sec)} = K_p \times C_p \times \left(\sqrt{\Delta p} \right)_{avg} \times \sqrt{\frac{(t_s)_{avg} + T_u}{P_s \times M_s}}$$

$$v_{sl} \text{ (ft/sec)} = \frac{85.49 \text{ ft}}{\text{sec}} \left(\frac{\text{(lb/lb-mol)(in. Hg)}}{(\text{°R})(\text{in. H}_2\text{O})} \right)^{1/2} \times 0.84 \times \text{in. H}_2\text{O}^{1/2} \times \sqrt{\frac{+ 460 \text{ °R}}{\text{in. Hg} \times \text{lb/lb-mol}}} = \frac{\text{ft}}{\text{sec}}$$

Average Stack Dry Standard Flow Rate (dscfh)

$$Q_{sd} \text{ (dscfh)} = \frac{60 \times 60 \times \left(1 - \frac{B_{ws}}{100} \right) \times v_s \times A_s \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

$$Q_{sd} \text{ (dscf/hr)} = \frac{3600 \text{ sec}}{\text{hr}} \times \left(1 - \frac{0.0 \%}{100} \right) \times \frac{\text{ft}}{\text{sec}} \times \text{ft}^2 \times \frac{68}{+ 460 \text{ °R}} \times \frac{\text{in. Hg}}{29.92 \text{ in. Hg}} = \frac{\text{dscf}}{\text{hr}}$$

Average Stack Wet Flow Rate (acfm)

$$Q_{aw} \text{ (acfm)} = 60 \times v_s \times A_s$$

$$Q_{aw} \text{ (acf/min)} = \frac{60 \text{ sec}}{\text{min}} \times \frac{\text{ft}}{\text{sec}} \times \text{ft}^2 = \frac{\text{ascf}}{\text{min}}$$

Average Stack Wet Standard Flow Rate (dscfh)

$$Q_{sw} \text{ (ascfh)} = \frac{60 \times Q_{aw} \times T_{std} \times P_s}{(t_s + T_u) \times P_{std}}$$

$$Q_{sw} \text{ (ascf/hr)} = \frac{60 \text{ min}}{\text{hr}} \times \frac{\text{acf}}{\text{min}} \times \frac{68}{+ 460 \text{ °R}} \times \frac{\text{in. Hg}}{29.92 \text{ in. Hg}} = \frac{\text{ascf}}{\text{hr}}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 3a)

%N₂ = nitrogen concentration (%)

%CO₂ = carbon dioxide concentration (%)

%O₂ = oxygen concentration (%)

ppmCO = carbon monoxide concentration (ppm)

%CO = carbon monoxide concentration (%)

M_d = stack dry molecular weight (lb/lb-mole)

(F_o)_{avg} = average calculated fuel factor

(%EA)_{avg} = average excess air (%)

Carbon Monoxide Concentration (%)

$$\% CO = \frac{ppmCO}{10,000}$$

$$\%CO (\%) = \frac{0.00 \text{ ppm}}{10,000 \text{ ppm}/\%} = \quad \%$$

Nitrogen Concentration (%)

$$\% N_2 = 100 - \% CO_2 - \% O_2 - \% CO$$

$$\%N_2 (\%) = 100 - \quad \% - \quad \% - \quad \% = \quad \%$$

Stack Dry Molecular Weight (lb/lb-mole)

$$M_d (\text{lb} / \text{lb} - \text{mol}) = \sum \left(\frac{MW_{comp}}{100} \times \% \text{ component} \right)$$

$$M_d (\text{lb/lb-mol}) = \left[\frac{44 \text{ lb/lb-mol}}{100} \times \quad \% \right] + \left[\frac{32 \text{ lb/lb-mol}}{100} \times \quad \% \right] + \text{etc.} = \frac{\text{lb}}{\text{lb-mol}}$$

Average Calculated Fuel Factor

$$F_{o(avg)} = \frac{[20.9 - (\% O_2)_{avg} - (0.5 \times (\% CO)_{avg})]}{[(\% CO_2)_{avg} + (\% CO)_{avg}]}$$

$$F_{o(avg)} = \frac{20.9\% - \quad \% - [0.5 \times \quad \%]}{\quad \% + \quad \%} =$$

Average Excess Air (%)

$$\% EA_{avg} (\%) = \frac{100 \times [(\% O_2)_{avg} - (0.5 \times (\% CO)_{avg})]}{[0.264 \times (N_2)_{avg}] - [(\% O_2)_{avg} - (0.5 \times (\% CO)_{avg})]}$$

$$(\%EA)_{AVG} = \frac{100 \times \{ \quad \% - [0.5 \times \quad \%] \}}{[0.264 \times \quad \%] - \{ \quad \% - [0.5 \times \quad \%] \}} = \quad \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 4)

V_{mf} = final dry gas meter reading (dcf)
 V_{mi} = initial dry gas meter reading (dcf)
 V_m = total meter volume (dcf)
 $t_{m(avg)}$ = average meter temp. (°F)
 $t_{s(avg)}$ = average stack temp. (°F)
 P_b = barometric pressure (in. Hg)
 P_{static} = static pressure (in. H₂O)
 ΔH_{avg} = average orifice pressure (in. H₂O)
 V_i = initial impinger volume (ml)
 V_f = final impinger volume (ml)
 W_i = initial impinger weight (g)
 W_f = final impinger weight (g)
 V_t = total impinger volume (ml) = $\Sigma(V_f - V_i)$

W_t = total impinger weight (g) = $\Sigma(W_f - W_i)$
 K_5 = water mass to std water vapor, 0.04715 ft³/g
 K_1 = standard volume correction, 17.65°R/in. Hg
 Y = meter calibration factor
 T_u = absolute temperature offset, 460°R
 B_{ws} = final moisture content (%) = min of $B_{ws(calc)}$ and $B_{ws(svp)}$

Water Volume Weighed (dscf)

$$V_{wsg(std)} (dscf) = W_t \times K_5$$

$$V_{wsg(std)} = \quad \text{g} \times \quad 0.04715 \text{ ft}^3/\text{g} = \quad \text{dscf}$$

Standard Meter Volume (dscf)

$$V_{m(std)} (dscf) = \frac{K_1 \times Y \times V_m \times \left(P_b + \frac{\Delta H_{avg}}{13.6} \right)}{(t_m)_{avg} + T_u}$$

$$V_{m(std)} = \frac{17.65 \text{ }^\circ\text{R}}{\text{in. Hg}} \times \quad \times \quad \text{dcf} \times \left[\text{in. Hg} + \frac{\text{in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O} / \text{in. Hg}} \right] = \quad \text{dscf}$$

°F + 460 °R

Calculated Moisture Content (%)

$$B_{ws(calc)} (\%) = 100 \times \frac{V_{wsg(std)}}{V_{wsg(std)} + V_{m(std)}}$$

$$B_{ws(calc)} = 100 \times \frac{\text{dscf}}{\text{dscf} + \quad \text{dscf}} = \quad \%$$

Saturated Moisture Content (%)

$$B_{ws(svp)} (\%) = 100 \times \frac{10^{\frac{6.691 - \frac{3144}{t_{s(avg)} + 390.86}}{P_b + \frac{P_{static}}{13.6}}} \leq 100$$

$$B_{ws(svp)} = 100 \times \frac{10^{\left[\frac{6.691 - \frac{3144}{^\circ\text{F} + 390.86}}{\text{in. Hg} + \frac{\text{in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O} / \text{in. Hg}} \right]} \leq 100 = \quad \%$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Isokinetic Sampling)

C_n = nozzle diameter constant, 0.03575
 Q_m = estimated orifice flow rate, 0.750 acfm
 else V_m/Θ from previous run
 V_m = total meter volume (acfm)
 Θ = total sampling time (min)
 t_m = average gas meter temperature ($^{\circ}$ F)
 T_u = absolute temperature offset, 460 $^{\circ}$ R
 C_p = pitot tube coefficient
 B_{wm} = meter moisture content (%)
 B_{ws} = stack moisture content (%)
 t_s = average stack temperature ($^{\circ}$ F)
 M_d = stack dry molecular weight (lb/lb-mole)
 P_s = absolute stack pressure (in. Hg)
 C_k = K Factor Constant, 849.8

Δp_{avg} = average pitot tube differential pressure (in. H₂O)
 $\Delta H @$ = DH @ 0.75 SCFM (in. H₂O)
 D_{na} = actual nozzle diameter (in.)
 Δp = velocity head (in. H₂O)

Desired Orifice (in. H₂O)

$$\Delta H_d (\text{in. H}_2\text{O}) = K \times \Delta p$$

$$\Delta H_d (\text{in. H}_2\text{O}) = \quad \times \quad 0 \text{ in. H}_2\text{O} = \quad \text{in. H}_2\text{O}$$

Absolute Meter Pressure (in. Hg)

$$P_m (\text{in. Hg}) = P_b + \frac{\Delta H @}{13.6}$$

$$P_m (\text{in. Hg}) = 0.00 \text{ in. Hg} + \frac{\text{in. H}_2\text{O}}{13.6 \text{ in. H}_2\text{O/in. Hg}} = \quad \text{in. Hg}$$

Recommended Nozzle Diameter (in.)

$$D_{ni} (\text{in.}) = \sqrt{\frac{C_n \times Q_m \times P_m}{(t_m + T_u) \times C_p} \times \left(\frac{1 - \frac{B_{wm}}{100}}{1 - \frac{B_{ws}}{100}} \right) \times \sqrt{(t_s + T_u) \times \left[\frac{M_d \times \left(1 - \frac{B_{ws}}{100} \right) + (18 \times B_{ws})}{P_s \times \Delta p_{avg}} \right]}}$$

$$D_{ni} (\text{in.}) = \frac{0.03575 (\text{lb-mole} \cdot ^{\circ}\text{R} \cdot \text{in. H}_2\text{O})^{1/2} \cdot \text{min} \cdot \text{in.}^2}{\text{acfm} \cdot \text{in. Hg}^{3/4} \cdot \text{lb}^{1/2}} \times \frac{0.75 \text{ acf} \times \text{in. Hg}}{0.84} \times \left(\frac{1 - \frac{0.0 \%}{100}}{1 - \frac{0.0 \%}{100}} \right) \times \sqrt{\left(0 \text{ }^{\circ}\text{F} + 460^{\circ}\text{R} \right) \times \frac{\frac{\text{lb}}{\text{lb-mole}} \times \left(1 - \frac{0.0 \%}{100} \right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{0.0 \%}{100} \right)}{\text{in. Hg} \times 0.00 \text{ in. H}_2\text{O}}} = \quad \text{in.}$$

DP to DH Isokinetic Factor

$$K = C_k \times C_p^2 \times \Delta H @ \times D_{na}^4 \times \left[\frac{M_d \times \left(1 - \frac{B_{wm}}{100} \right) + \left(18 \times \frac{B_{wm}}{100} \right)}{M_d \times \left(1 - \frac{B_{ws}}{100} \right) + \left(18 \times \frac{B_{ws}}{100} \right)} \right] \times \left(\frac{1 - \frac{B_{ws}}{100}}{1 - \frac{B_{wm}}{100}} \right)^2 \times \left(\frac{t_m + T_u}{t_s + T_u} \right) \times \frac{P_s}{P_m}$$

$$K = \frac{849.8}{\text{in. H}_2\text{O} \cdot \text{in.}^4} \times \quad^2 \times \quad \text{in. H}_2\text{O} \times \quad^4 \times \left(\frac{1 - \frac{0.0 \%}{100}}{1 - \frac{0.0 \%}{100}} \right)^2 \times \left(\frac{0 \text{ }^{\circ}\text{F} + 460^{\circ}\text{R}}{0 \text{ }^{\circ}\text{F} + 460^{\circ}\text{R}} \right) \times \quad$$

$$\left(\frac{\frac{\text{lb}}{\text{lb-mole}} \times \left(1 - \frac{0.0 \%}{100} \right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{0.0 \%}{100} \right)}{\frac{\text{lb}}{\text{lb-mole}} \times \left(1 - \frac{0.0 \%}{100} \right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{0.0 \%}{100} \right)} \right) \times \frac{\text{in. Hg}}{\text{in. Hg}} =$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 5)

K_4 = isokinetic conversion constant, 0.0945 min·in. Hg/sec·°R

$m_{\#x}$ = weight measurements (g)

v_a = acetone volume (ml)

v_{ino} = impinger content volume (ml)

v_{org} = organics wash volume (ml)

w_x = blank weight of solids (g)

v_x = blank volume (ml)

m_{fx} = final weight, avg of last two measurements (g)

m_{tx} = tare weight (g)

Total Particulates (mg)

$$M_n (mg) = \sum (m_x - W_x)$$

$$M_n (mg) = \sum [\quad \text{mg} - \quad \text{mg}] + \text{etc...} = \quad \text{mg}$$

Local Stack Velocity (ft/sec)

$$v_{s(l)} (ft/sec) = K_p \times C_p \times \sqrt{\Delta p} \times \sqrt{\frac{t_s + T_u}{P_s \times \left[M_d \times \left(1 - \frac{B_{ws}}{100} \right) + \left(18 \times \frac{B_{ws}}{100} \right) \right]}}$$

$$v_{s(l)} (ft/sec) = \frac{85.49 \text{ ft}}{\text{sec}} \left[\frac{(\text{lb/lb-mol})(\text{in. Hg})}{(^{\circ}\text{R})(\text{in. H}_2\text{O})} \right]^{1/2} \times 0.84 \times \sqrt{0.00 \text{ in. H}_2\text{O}}$$

$$\sqrt{\frac{0 \text{ } ^{\circ}\text{F} + 460 \text{ } ^{\circ}\text{R}}{\text{in. Hg} \times \left[\frac{\text{lb}}{\text{lb-mole}} \times \left(1 - \frac{0.0 \text{ } \%}{100} \right) + \left(\frac{18 \text{ lb}}{\text{lb-mol}} \times \frac{0.0 \text{ } \%}{100} \right) \right]}} = \frac{\quad \text{ft}}{\text{sec}}$$

Cumulative Percent Isokinetic (%)

$$I(\%) = \frac{K_4 \times ((t_s)_{avg} + T_u) \times V_m}{\left(\Theta \times (v_{s(l)})_{avg} \times P_s \times \pi \times \left(\frac{D_{na}}{2} \times \frac{1}{12} \right)^2 \right) \times \left(1 - \frac{B_{ws}}{100} \right)}$$

$$I(\%) = \frac{0.0945 \text{ min} \cdot \text{in. Hg}}{\text{sec} \cdot ^{\circ}\text{R}} \times \left[\frac{\#DIV/0! \text{ } ^{\circ}\text{F} + 460 \text{ } ^{\circ}\text{R}}{\quad} \right] \times \text{scf}$$

$$\text{##### min} \times \frac{\#DIV/0! \text{ ft}}{\text{sec}} \times \text{in. Hg} \times 3.14 \times \left[\frac{\text{in.}}{2} \times \frac{\text{ft.}}{12 \text{ in.}} \right]^2 \times \left[1 - \frac{0 \text{ } \%}{100} \right] = \quad \%$$

Net Wash Volume (ml)

$$v_n (ml) = v_a + v_{ino} + v_{org}$$

$$v_n (ml) = \quad \text{ml} + \quad \text{ml} + \quad \text{ml} = \quad \text{ml}$$

Blank Concentration (mg/ml)

$$C_x (mg/ml) = \frac{1000 \times w_x}{v_x}$$

$$C_x (mg/ml) = \frac{1000 \times \quad \text{g}}{\quad \text{ml}} = \frac{\quad \text{mg}}{\quad \text{ml}}$$

Blank Adjustment (lesser of)

$$W_x (mg) = m_x \cdots \text{or} \cdots v_x \times C_x$$

$$W_x (mg) = \quad \text{mg or} \quad \text{ml} \times \frac{\quad \text{mg}}{\quad \text{ml}} = \quad \text{mg}$$

Weight Gain (mg)

$$m_x (mg) = (m_{fx} - m_{tx}) \times 1000$$

$$m_x (mg) = [\quad \text{mg} - \quad \text{mg}] \times 1000 = \quad \text{mg}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

EXAMPLE CALCULATIONS (Reference Method 5)

M_n = total particulates (mg)

$V_{m(std)}$ = standard meter volume (dscf)

Q_{sd} = dry standard stack flow rate (dscfm)

F_d = fuel f-factor (dscf/MMBtu)

% O_2 = oxygen percentage (%)

Q_{sw} = wet standard stack flow rate (ascfm)

Stack Particulate Concentration (g/dscf)

$$c_s (g / dscf) = 0.001 \times \frac{M_n}{V_{m(std)}}$$

$$c_s (g/dscf) = \frac{g}{1000 \text{ mg}} \times \frac{mg}{dscf} = \frac{g}{dscf}$$

Stack Particulate Concentration (gr/dscf)

$$c'_s (gr / dscf) = 0.001 \times \frac{M_n}{V_{m(std)}} \times \frac{7000}{453.592}$$

$$c'_s (gr/dscf) = \frac{g}{1000 \text{ mg}} \times \frac{mg}{dscf} \times \frac{7000 \text{ gr}}{lb} \times \frac{lb}{453.592 \text{ g}} = \frac{gr}{dscf}$$

Particulate Emissions Rate (kg/hr)

$$E (kg / hr) = c_s \times Q_{sd} \times \frac{60}{1000}$$

$$E (kg/hr) = \frac{kg}{1000 \text{ g}} \times \frac{60 \text{ min}}{hr} \times \frac{g}{dscf} \times \frac{dscf}{min} = \frac{kg}{hr}$$

Particulate Emissions Rate (lb/hr)

$$E' (lb / hr) = \frac{M_n \times Q_{sd}}{V_{m(std)}} \times \frac{60}{453.592 \times 1000}$$

$$E' (lb/hr) = \frac{g}{1000 \text{ mg}} \times \frac{60 \text{ min}}{hr} \times \frac{lb}{453.592 \text{ g}} \times \frac{mg}{dscf} \times \frac{dscf}{min} = \frac{lb}{hr}$$

Particulate Emissions Rate (ton/yr)

$$E'' (ton / yr) = E' \times \frac{8760}{2000}$$

$$E'' (ton/yr) = \frac{ton}{2000 \text{ lb}} \times \frac{8760 \text{ hr}}{yr} \times \frac{lb}{hr} = \frac{ton}{yr}$$

Particulate Emissions Rate (lb/MMBtu)

$$E''' (lb / MMBtu) = \frac{M_n \times F_d}{V_{m(std)} \times 1000 \times 453.592} \times \left(\frac{20.9}{20.9 - \%O_2} \right)$$

$$E''' (lb/MMBtu) = \frac{g}{1000 \text{ mg}} \times \frac{lb}{453.592 \text{ g}} \times \frac{mg}{dscf} \times \frac{dscf}{MMBtu} \times \left(\frac{20.9}{20.9 - \%} \right) = \frac{lb}{MMBtu}$$

Heat Input (MMBtu/hr)

$$HI (MMBtu / hr) = Q_{sw} \times 1000 \times \left(\frac{100 - B_{ws}}{100 \times F_d} \right) \times \left(\frac{20.9 - \%O_2}{20.9} \right)$$

$$HI (MMBtu/hr) = \frac{wksf}{hr} \times \frac{10^3 \text{ scf}}{ksf} \times \left(\frac{100 - \%}{100 \times dscf/MMBtu} \right) \times \left(\frac{20.9 - \%}{20.9} \right) = \frac{MMBtu}{hr}$$

Note: Lack of significant figures may cause rounding errors between actual calculations and example calculations.

APPENDIX E
AIR HYGIENE STATEMENT OF QUALIFICATIONS



Air Hygiene International, Inc.

The Clear Choice

STATEMENT OF QUALIFICATIONS POWERPLANT EMISSIONS TESTING – 2006



AIR HYGIENE INT'L

Corporate Headquarters
5634 S. 122nd E. Ave. Ste. F
Tulsa, OK 74146
918-307-8865 or 888-461-8778

Houston, TX Office
1920 Treble Drive, Suite E-5
Humble, TX 77338

Las Vegas Office
5925 E. Lake Mead Blvd
Las Vegas, NV 89156

Philadelphia, PA Office
8900 State Road
Philadelphia, PA 19136



STATEMENT OF QUALIFICATIONS



AIR HYGIENE

AIR TESTING SERVICES FOR POWER PLANTS

www.airhygiene.com

January, 2005

INTRODUCTION

AIR HYGIENE INTERNATIONAL, INC. (AIR HYGIENE) is a professional air emission testing services firm with fixed offices in Tulsa, Oklahoma; Houston, Texas; Denver, Colorado; and Orlando, Florida. Additional mobilization points are located in Philadelphia, Atlanta, Chicago, Los Angeles, and Seattle to serve all 50 United States. **AIR HYGIENE** specializes in air emission testing services for combustion sources in both simple and combined cycle operation burning multiple fuels with multiple control devices and supporting equipment.

AIR HYGIENE has testing laboratories which serve all fifty (50) of the United States and North America. Each mobile laboratory can be equipped with the following equipment and capabilities:

1. State-of-the-Art air emission analyzers, computers, and datalogging software. All designed into an efficient system to provide the fastest, most reliable information possible!
2. Dual racks for multiple source testing simultaneously or multiple points on a single source (in/out SCR, etc.)!
3. NIST traceable gases for the most accurate calibration. Ranges as low as 5 ppm!
4. PM₁₀, NH₃, mercury, sulfuric acid mist (H₂SO₄), SO₃, and formaldehyde sampling equipment!
5. VOC testing with on-board gas chromatograph to remove methane and ethane!
6. On-board printers to provide hard copies of testing information on-site!
7. Networking capabilities to provide real-time emission data directly into the control room!

AIR HYGIENE is known for providing professional services which include the following:

- Providing superior, cost saving services to our clients!
- High quality emission testing personnel with service oriented, friendly attitude!
- Meeting our client's needs whether it is 24 hour a day testing or short notice mobilization!
- Using great equipment that is maintained and dependable!
- Understanding the unique startup and operational needs associated with combustion turbines!

MISSION STATEMENT

Our mission is to provide innovative, practical, top-quality services allowing our clients to increase operating efficiency, save money, and comply with federal/state requirements. We believe our first responsibility is to the client. In providing our unique services, the owners of **AIR HYGIENE** demand ethical conduct from each employee of the company. The character and integrity of **AIR HYGIENE** employees allows our clients to feel confidence in the air testing services of **AIR HYGIENE**. Through a long-term commitment to this mission, **AIR HYGIENE** is known as a company committed to improving our clients' operations.

AIR HYGIENE	...	Does work worth paying for every time!
	...	Is well known for our emission testing services and uncompromising efforts to serve our clients!
	...	Does work that matters!
	...	Is proud of our emission testing capabilities!
	...	Provides exciting growth opportunities for energetic individuals!




EMISSION TESTING TEAM

Air Hygiene International, Inc. (**AIR HYGIENE**) intends to exceed your expectations on every project. From project management to field-testing teams, we're committed to hard work on your behalf. The job descriptions and flowchart below outline **AIR HYGIENE**'s client management strategy for your testing services.

From the initial request through receipt of the purchase order, the Inquisition To Order (ITO) team strives to inform every client of the benefits gained by using **AIR HYGIENE** for their emission testing project. The ITO team includes representatives from the sales, marketing, and contracts divisions. In addition, several support staff assist to ensure the ITO team provides the support for client needs as requested by a client or project manager.

Project Managers are the primary contact for clients and ultimately responsible for every emission testing project. **AIR HYGIENE**'s Project Managers experience range from masters level, professional engineers to industry experts with over 5,000 testing projects completed. Each project is assigned a Project Manager based primarily upon geographic location, then industry experience, contact history, and availability. The Project Manager prepares the testing strategy and organization for the project. This includes preparation of testing protocol; coordination with state agencies, client representatives, and any interested third parties. The site testing and report preparation are executed under the direction of the Project Manager from start to finish.



Testing Managers have completed Air Hygiene's rigorous demonstration of capability training program and are capable of operating all testing equipment and performing all test methods required for your testing project. Testing Managers assist Project Managers by leading the field testing when required, preparing draft reports, calibrating equipment, and overseeing testing team on-site.

Test Engineers have significant background and understanding of emission testing or related services. Test Engineers prepare pre-test drawings for port location, ensure on-site logistics for electrical and mechanical/structural needs, and conduct on site testing as directed by the Project Manager and/or Testing Manager. Test Engineers often have special understanding of process and/or regulations applicable to specific testing jobs, which provide great value to both the client and Project Manager in testing strategies.

Testing Specialists have performed over 500 emission tests and have a basic understanding of both particulate and gaseous sampling strategies. Testing Specialists have significant testing experience with **AIR HYGIENE** equipment along with a variety of industries and source equipment. Testing Specialists often operate isokinetic sampling trains or gas analyzers on-site under the direction of the Project Manager and assist with preparation of field reports and quality assurance procedures.

Staff Technicians are entry-level personnel who have performed 100 to 500 emission tests. Staff Technicians perform pre-test equipment preparation, on-site test preparation, and testing assistance under the direction of Project Manager and/or Testing Manager. At least one Staff Technician is assigned to every project to assist on-site. Staff Technicians connect sampling probes to ports, assist with leak checks, raise and lower equipment to and from sampling platform, and other support activities under the direction of the Project Manager and/or Testing Manager.

Testing Assistants are entry-level personnel who have performed less than 100 emission tests. Testing Assistants help with equipment set-up, teardown, and simple testing procedures (i.e. move probe, fill ice bath, clean impingers, etc.) as directed.



AIR HYGIENE Emission Services Summary

Air Hygiene International, Inc. (**AIR HYGIENE**) is a privately-held professional services firm headquartered in Tulsa, Oklahoma with additional offices in Denver, Colorado; Houston, Texas; and Orlando, Florida. **AIR HYGIENE** specializes in emission testing services for a variety of industries including natural gas companies, utilities, refineries, printers, glass plants, bulk fuel loading stations, chemical plants, pulp & paper mills, various manufacturers and related industries.

AIR HYGIENE provides turn-key emission testing services which include:

1. Pre-test site visit and consulting for port locations and setup;
2. Preparation of test plan for state agency;
3. Coordination with state agency regarding emission testing;
4. On-site emission testing services; and
5. Preparation of draft and final reports.



AIR HYGIENE has mobile laboratories that serve all 50 United States and around the world. **AIR HYGIENE** employees have performed over 15,000 emission tests on a variety of sources.

AIR HYGIENE performs air emission certification compliance testing on combustion sources (natural gas, coal, fuel oil, jet fuel, etc), NSPS sources, and Title V compliance sites. Our experience ranges from emission testing for new PSD facilities, MACT and RACT required performance certification testing to Relative Accuracy Test Audits (RATA Tests) for Continuous Emission Monitoring Systems (CEMS) and Parametric Emission Monitoring Systems (PEMS).

Air Hygiene has conducted numerous emission testing projects, which involved multiple groups relying upon instantaneous reporting of important test data. These projects relied upon **Air Hygiene's SPIDER** network. The **SPIDER** network provides Simultaneously Produced Information During Emission Readings (**SPIDER**) between the emission monitoring system and multiple locations (i.e. control room, test center, office, etc.). Hence, you can view real-time emission testing data on-demand from any location you choose!

AIR HYGIENE performs FTIR testing by EPA Method 320 for Hazardous Air Pollutants (HAPS) including formaldehyde, benzene, xylene, toluene, hexane, ammonia, hydrogen chloride, etc. This methodology provides real-time analysis of these critical pollutants.

AIR HYGIENE specializes in the following types of pollutants and EPA Reference Methods (RM):

- Nitrogen Oxides (NOx) – RM 7e &/or 20
- Sulfur Dioxide (SO₂) – RM 6c
- Total Hydrocarbons (THC) – RM 25a
- Volatile Organic Compounds (VOC) RM 25a & RM 18
- Particulates (PM) – RM 5(filterable) & 202(condensable)
- PM < 10 microns (PM₁₀) – RM 201a
- PM < 2.5 microns (PM_{2.5}) – RM 201b
- Opacity – RM 9
- Exhaust Flow – RM 2 &/or 19
- Moisture – RM 4
- Carbon Monoxide (CO) – RM 10
- Carbon Dioxide (CO₂) – RM 3a
- Oxygen (O₂) – RM 3a &/or 20
- Dioxin & Furans – RM 23
- Metals – RM 29
- Chrome – RM 306
- Lead – RM 12
- Formaldehyde – RM 320 (FTIR), SW-846 0011, CARB 429, or CTM-037
- H₂S – RM 11
- BTEX – RM 18
- HAPS – FTIR – RM 320 (FTIR)
- Ammonia – CTM-027 or BAAQMD ST-1B
- Mercury – Ontario Hydro Method or RM 29

TESTING EXPERIENCE

AIR HYGIENE testing personnel account for more than sixty-five (65) years of testing experience and over 15,000 emission tests. Our testing services have involved dealings with all 50 state agencies and EPA regional offices. **AIR HYGIENE** testing personnel are rigorously trained on EPA reference test methods from 40 CFR Part 51, 60, 63, and 75. All testing personnel are instructed and tested on test responsibilities and must complete a “Demonstration of Capability” test per the **AIR HYGIENE** Quality Assurance Manual and the **AIR HYGIENE** Emission Testing Standard Operating Procedures Handbook.

AIR HYGIENE has completed testing on over 134 power plants including 315 combustion turbines, 21 coal fired boilers, 17 gas fired boilers representing 64,876 megawatts (MW). *Let us add your project to our list of satisfied customers!*

TESTING SUCCESS STORIES

AIR HYGIENE personnel have performed thousands of testing projects which have yielded significant benefits for our clients. The following project descriptions briefly discuss some of these emission testing projects.


- Conducted numerous projects optimizing SCR performance by conducting inlet & outlet SCR analysis for NH₃, NO_x, flow, and Oxygen. Used information to assist with flow optimization and AIG tuning.
- Conducted federal and state required compliance testing for NO_x, CO, PM-10 (front & back-half), SO₂, VOC, Ammonia, Formaldehyde, Opacity, RATA testing (NO_x and CO) for new and updated power plants with both simple and combined cycle turbines firing natural gas and fuel oil.
- Conducted dry low NO_x burner tuning and performance testing for various models of GE, Siemens Westinghouse, Mitsubishi, Pratt & Whitney, and ABB combustion turbines to verify manufacturer’s emission guarantees for clients in preparation for compliance testing.
- Conducted emission testing for NO_x, CO, and VOC to assist tuning by performance engineers for meeting low-level NO_x emissions and balancing combustion turbine performance.
- Performed power plant emission testing for natural gas fired combustion turbines. Tests included federal required testing per 40 CFR Part 75, state air permit requirements, RATA testing, and emission testing to verify manufacturer’s guarantee’s during electric/heat output performance testing. Other services for combustion turbine testing included preparation of the QA/QC manual, monitoring plan, seven-day drift test report, system linearity test, and cycle time test.



TESTING LOCATIONS

AIR HYGIENE bases mobilization charges on the distance from your site to the closest of nine (9) regional starting points covering all 50 United States. These include Seattle, Los Angeles, Denver, Tulsa, Houston, Chicago, Orlando, Atlanta, and Philadelphia.

Each start point is located such that the **AIR HYGIENE** test teams can mobilize to your site at affordable costs to ensure we are price competitive to any U.S. location.





COMBUSTION TURBINE TESTING SERVICES SUMMARY

Thank you for your consideration of the power and energy industry testing services of Air Hygiene International, Inc. (**AIR HYGIENE**). The following list details some of the testing services and extras **AIR HYGIENE** includes with each testing job.

Types of Air Testing Services for Combustion Turbines:

- Turbine tuning/mapping for NO_x & NH₃ emissions
- Pollutant testing to verify EPC contractual emission guarantees
- Research and Development (R&D) emission data research and turbine optimization
- 40 CFR Part 60 Subpart GG – Turbine Compliance Testing
- 40 CFR Part 75 – Acid Rain Classified Equipment Testing
- 40 CFR Part 75 Appendix E – Peaking Plant CEMS alternative NO_x emissions versus Heat Input mapping
- RATA Testing on CEMS systems for NO_x, CO, SO₂, CO₂ or O₂, Flow (3-D & Wall effects)
- QA/QC Plans, Monitoring Plans, Linearity Checks, Testing Protocols, etc. are provided with our high quality, service oriented emission testing services
- Initial permit compliance testing for PM, PM-10, PM-2.5, SO₂, NO_x, CO, exhaust flow, moisture, O₂, CO₂, Ammonia, Formaldehyde, other HAPs



AIR HYGIENE will provide the following testing services:

- On-site, real-time test data
- Fuel F-Factor calculation data sheet
- Experienced turbine testing personnel
- Flexible testing schedules to meet your needs
- Electronic reports provided on CD upon request
- Extensive experience with all 50 state agencies in the U.S.
- EPA Protocol 1 Certified Gases (one percent accuracy) for precise calibration
- Low range (0-10 ppm) equipment calibration and measurement available
- Test protocol preparation, coordination with state agency, and site personnel
- Numerous mobile testing labs, which may be used for your projects across the U.S.
- State-of-the-art data logging technology to allow real-time examination of meaningful emission data
- Monitor your emissions data measured in our test lab from your control room via our datalogging network system



AIR HYGIENE is committed to providing testing teams that will take the time to meet your needs. We ensure the job is completed on time with the least amount of interruption to your job and site operation as possible. Thank you for considering our services.



AIR HYGIENE's Synergistic Approach to Power Plant Air Emissions Testing

Power plants continue to be built, modified, and improved across the United States. These new or modified facilities are at the forefront of clean energy. These units are very efficient yet environmentally friendly, and must be to meet the stringent requirements set forth by the Environmental Protection Agency (EPA) and relevant state agencies. Air Hygiene International, Inc. (**AIR HYGIENE**) has developed a unique strategy to help owners deal with these complicated requirements.

Unique Testing Strategy

AIR HYGIENE has developed a synergistic approach to assisting the various groups involved in the completion of a commissioning/startup unit or modification project. **AIR HYGIENE** strives to combine the multiple testing aspects involved with bringing a combustion unit to commercial service. By conducting the various emission tests required for a new combustion unit using one test company, the following benefits are a given:

1. Save money by...
 - a. Reduced mobilizations
 - b. Combined tests yield reduced fuel usage and site time
 - c. Bulk projects receive quantity discounts
2. Improve efficiency through familiarity with site needs
3. Site personnel and testing team are comfortable working together

These projects typically involve some or all of the following groups. There is not a defined set of responsibilities that will match every project. The table below simply suggests a typical list of testing responsibilities.

Responsible Party

Owner
 Operator
 Turbine/Boiler manufacturer
 EPC & Construction Company
 CEMS Supplier
 Lending Party (i.e. bank)
 Environmental Consultant

Testing Responsibilities

Initial and on-going federal and state compliance testing (i.e. NSPS Sub GG, Part 75, Operating Air Permit, etc.)
 Initial and on-going federal and state compliance testing (i.e. NSPS Sub GG, Part 75, Operating Air Permit, etc.)
 Contractual emission guarantees of unit (i.e. NOx, SO2, CO, VOC, PM-10, NH3, H2SO4)
 Contractual emission guarantees including control devices (i.e. NOx, SO2, CO, VOC, PM-10, NH3, H2SO4)
 Initial RATA testing (i.e. NOx, CO, SO2, CO2, O2, flow)
 No responsibility, but concerned with outcome of all tests
 Concerned with air permit and overall compliance; may select the test contractor and provide oversight for testing



Example Project:

A recent project provides a prime example of the synergistic benefits of using **AIR HYGIENE** to perform your commissioning/startup or remediation testing needs for performance and compliance. Eight GE Frame 7FA turbines were taken from performance testing through compliance testing in 20 days. The following tests were performed on each turbine:

- NOx tuning and mapping
- Contractual performance testing for NOx, CO, VOC, SO2, NH3, & PM10
- 40 CFR Part 60 Subpart GG: testing for NOx and CO at max load
- 40 CFR Part 75: NOx & CO RATA certification on CEMS
- State required compliance testing for NOx, CO, VOC, NH3(on-site analysis), formaldehyde (on-site analysis by FTIR), opacity and SO2 burning natural gas

Test data was provided on-site for all tests, except PM-10. Electronic files were e-mailed for review to the turbine manufacturer, owner & operator, and environmental consultant within 24 hours following completion of site work. Complete reports including PM-10 were submitted to interested parties within 10 days following each blocks completion.

Power Plant Testing Experience

AIR HYGIENE personnel have over sixty-five (65) years of testing experience on combustion turbines, coal fired boilers, gas fired boilers, landfill gas, wood fired, & diesel fired engines across the United States. **AIR HYGIENE** has 10 combustion labs serving all 50 states from four permanent offices (Tulsa, OK; Houston, TX; Denver, CO; & Orlando, FL) and five mobilization points (Los Angeles, CA; Seattle, WA; Chicago, IL; Atlanta, GA; & Philadelphia, PA). **AIR HYGIENE** has tested plants ranging from 50 to 2,000 megawatts in both simple and combined cycle operation with controls including:

- Selective Catalytic Reduction - Ammonia injection
- Steam/Water injection
- Sprint injection
- Dry Low NOx burners (DLN)

AIR HYGIENE has completed testing at 134 plants on 315 combustion turbines, 21 coal fired boilers, 17 gas fired boilers, and others representing 64,876 megawatts (MW). **AIR HYGIENE** tested 5 power plants in 2000 and we have grown since testing 8 in 2001, 19 in 2002, 41 in 2003, and 52 in 2004. *Let us add your upcoming project to our list of satisfied customers!*





INSTRUMENT CONFIGURATION AND OPERATIONS FOR GAS ANALYSIS

The sampling and analysis procedures used by **AIR HYGIENE** during tests conform in principle with the methods outlined in the Code of Federal Regulations, Title 40, Part 60, Appendix A, Methods 3a, 6c, 7e, 10, 18, 19, 20, and 25a.

The flowchart on the next page depicts the sample system used by **AIR HYGIENE** for analysis of oxygen (O₂), carbon dioxide (CO₂), sulfur dioxide (SO₂), carbon monoxide (CO), nitrogen oxides (NO_x), and volatile organic compounds (VOC) tests. A heated stainless steel probe is inserted into the sample ports of the stack to extract gas measurements from the emission stream. The gas sample is continuously pulled through the probe and transported via 3/8 inch heat-traced Teflon® tubing to a stainless steel minimum-contact condenser designed to dry the sample through Teflon® tubing via a stainless steel/Teflon® diaphragm pump and into the sample manifold within the mobile laboratory. From the manifold, the sample is partitioned to the O₂, CO₂, SO₂, CO, and NO_x analyzers through glass and stainless steel rotameters that control the flow rate of the sample. The VOC sample is measured as a wet gas.

The flowchart shows that the sample system is also equipped with a separate path through which a calibration gas can be delivered to the probe and back through the entire sampling system. This allows for convenient performance of system bias checks as required by the testing methods.

All instruments are housed in an air-conditioned trailer which serves as a mobile laboratory. Gaseous calibration standards are provided in aluminum cylinders with the concentrations certified by the vendor. EPA Protocol No. 1 is used to determine the cylinder concentrations where applicable (i.e. NO_x calibration gases).

All data from the continuous monitoring instruments are recorded on a Logic Beach Hyperlogger which retrieves calibrated electronic data from each instrument every second and reports an average of the collected data every 30 seconds and 10 seconds. The averaging time can be selected to meet the clients needs. **This data is available instantaneously for printout, statistical analysis, viewable by actual values, or examined by a trending graph!**

The number of test runs, test loads, and length of runs is based upon federal and state requirements for the facility. Typical run times associated with emission testing are as follows:


<u>Type of Test</u>	<u># of runs</u>	<u>Length of runs</u>
O ₂ Traverse (GG)	1 run @ low load (8 – 48 points)	2 minutes per point
NO _x Stratification Test	1 run @ base load (12 points)	2 – 4 minutes per point
Subpart GG	3 runs @ 4 loads (30%, 50%, 75%, & 100%)	15 – 60 minutes per run
RATA	9 – 12 runs @ normal load	21 minutes per run
State Permit Test (gases)	3 runs @ base load	1 hour per run
State Permit Test (particulates)	3 runs @ base load	2 – 4 hours per run

The stack gas analysis for O₂ and CO₂ concentrations are performed in accordance with procedures set forth in EPA Method 3a (EPA Method 20 for O₂ on combustion turbines). The O₂ analyzer uses a paramagnetic cell detector. The CO₂ analyzer uses an infrared detector.


CO emission concentrations are quantified in accordance with procedures set forth in EPA Method 10. A continuous nondispersive infrared (NDIR) analyzer is used for this purpose.

NO_x emission concentrations are measured in accordance with procedures set forth in EPA Method 7e and/or 20. A chemiluminescence analyzer is used to determine the nitrogen oxides concentration in the gas stream.

Total hydrocarbons (THC), non-methane, non-ethane hydrocarbons also known as volatile organic compounds (VOC) are analyzed in accordance with procedures set forth in EPA Methods 18 & 25a. A flame ionization detector calibrated with methane is used to determine the THC concentration in the gas stream and VOCs analyzed by GC to determine methane, ethane, and remaining VOCs per EPA Method 18 determination with gas chromatograph using FID detector.



Emission Analyzer System
Flowchart for the
Deluxe Trailer Unit
(Dual Testing System)




NOTES

1. TWO PORTS WITH CENTERLINES AT 90° ANGLES
2. 3/8 INCH THICK STEEL, WELDED TO STACK EXTERIOR, PROVIDES PLACE TO HOOK CHAIN FOR RAIL ASSEMBLY
3. MINIMUM THREE INCH INNER DIAMETER STEEL PIPE, WELDED TO STACK EXTERIOR, HOLE CUT INTO STACK WALL, NO POTRUSIONS OR OBSTRUCTIONS INSIDE STACK WALL
4. IF TOTAL STACK LENGTH IS NOT AVAILABLE, EPA MINIMUM REQUIREMENTS ARE 1/2 X STACK I.D. FROM PORTS TO TOP AND 2 X STACK I.D. FROM PORTS TO BOTTOM



**PORT INSTALLATION
DIAGRAM**
5634 S. 122nd East Ave, Suite F
Tulsa, Oklahoma 74146
www.airhygiene.com
(888) 461-8778



**PORT CLAMPS
INSTALLED**
5634 S. 122nd East Ave, Suite F
Tulsa, Oklahoma 74146
www.airhygiene.com
(888) 461-8778

TURBINE TESTING QUALITY ASSURANCE ACTIVITIES

A number of quality assurance activities are undertaken before, during, and after turbine testing projects. This section describes each of those activities.

Each instrument's response is checked and adjusted in the field prior to the collection of data via multi-point calibration. The instrument's linearity is checked by first adjusting its zero and span responses to zero nitrogen and an upscale calibration gas in the range of the expected concentrations. The instrument response is then challenged with other calibration gases of known concentration and accepted as being linear if the response of the other calibration gases agreed within \pm two percent of range of the predicted values.

NO₂ to NO conversion is checked via direct connect with a EPA Protocol certified concentration of NO₂ in a balance of nitrogen. Conversion is verified to be above 90 percent.

Instruments are both factory tested and periodically field challenged with interference gases to verify the instruments have less than a two percent interference from CO₂, SO₂, CO, NO, and O₂.


After each test run, the analyzers are checked for zero and span drift. This allows each test run to be bracketed by calibrations and documents the precision of the data collected. The criterion for acceptable data is that the instrument drift is no more than three percent of the full-scale response. Quality assurance worksheets summarize all multipoint calibration linearity checks and the zero to span checks performed during the tests are included in the test report.

The sampling systems is leak-checked by demonstrating that a vacuum greater than 10 in. Hg can be held for at least one minute with a decline of less than one in. Hg. A leak test is conducted after the sample system is set up and before the system is dismantled. This test is conducted to ensure that ambient air does not dilute the sample. Any leakage detected prior to the tests is repaired and another leak check conducted before testing will commence.

The absence of leaks in the sampling system is also verified by a sampling system bias check. The sampling system's integrity is tested by comparing the responses of the analyzers to the responses of the calibration gases introduced via two paths. The first path is directly into the analyzers and the second path includes the complete sample system with injection at the sample probe. Any difference in the instrument responses by these two methods is attributed to sampling system bias or leakage. The criterion for acceptance is agreement within five percent of the span of the analyzer.

The control gases used to calibrate the instruments are analyzed and certified by the compressed gas vendors to \pm one percent accuracy for all gases. EPA Protocol No. 1 is used, where applicable, to assign the concentration values traceable to the National Institute of Standards and Technology (NIST), Standard Reference Materials (SRM). The gas calibration sheets as prepared by the vendor are included in the test report.





TURBINE QUALITY ASSURANCE PROGRAM SUMMARY

AIR HYGIENE ensures the quality and validity of its emission measurement and reporting procedures through a rigorous quality assurance (QA) program. The program is developed and administered by an internal QA team and encompasses five major areas:

1. QA reviews of reports, laboratory work, and field testing;
2. Equipment calibration and maintenance;
3. Chain-of-custody;
4. Training; and
5. Knowledge of current test methods.

QA Reviews

AIR HYGIENE's review procedure includes review of each source test report, along with laboratory and fieldwork, by the QA Team. The most important review is the one that takes place before a test program begins. The QA Team works closely with technical division personnel to prepare and review test protocols. Test protocol review includes selection of appropriate test procedures, evaluation of interferences or other restrictions that might preclude use of standard test procedures, and evaluation and/or development of alternate procedures.

Equipment Calibration and Maintenance

The equipment used to conduct the emission measurements is maintained according to the manufacturer's instructions to ensure proper operation. In addition to the maintenance program, calibrations are carried out on each measurement device according to the schedule outlined by the Environmental Protection Agency. Quality control checks are also conducted in the field for each test program. Finally, **AIR HYGIENE** participates in a PT gas program by analyzing blind gases semi-annually to ensure continued quality.

Chain-of-Custody

AIR HYGIENE maintains full chain-of-custody documentation on all samples and data sheets. In addition to normal documentation of changes between field sample custodians, laboratory personnel, and field test personnel, **AIR HYGIENE** documents every individual who handles any test component in the field (e.g., probe wash, impinger loading and recovery, filter loading and recovery, etc.). Samples are stored in a locked area to which only **AIR HYGIENE** personnel have access. Field data sheets are secured at **AIR HYGIENE**'s offices upon return from the field.

Training

Personnel's training is essential to ensure quality testing. **AIR HYGIENE** has formal and informal training programs, which include:

1. Participation in EPA-sponsored training courses;
2. A requirement for all technicians to read and understand Air Hygiene Incorporated's QA manual;
3. In-house training relating to 40 CFR Part 60 Appendix A methods and QA meetings on a regular basis;
4. OSHA 40 hour Hazwopper Training;
5. Visible Emission (Opacity) Training; and
6. Maintenance of training records.

Knowledge of Current Test Methods

With the constant updating of standard test methods and the wide variety of emerging test procedures, it is essential that any qualified source tester keep abreast of new developments. **AIR HYGIENE** subscribes to services, which provide updates on EPA reference methods, rules, and regulations. Additionally, source test personnel regularly attend and present papers at testing and emission-related seminars and conferences. **AIR HYGIENE** personnel maintain membership in various relevant organizations associated with gas fired turbines.



F-Factor Datasheet and Fuel Gas Analysis

Company: XYZ Power
Location: XYZ Power Plant
Date: April 9, 2001

Values to enter from fuel gas analysis by GPA 2166.

Font Scheme:
 Blue Font = enter new data
 Black Font = calculated data
 Green Font = Labels for columns & rows
 Red Font = Important results with notes

Gas Component	Mole (%)	Molecular Weight (lb/lb-mole)	lb Component per lb-Mole of Gas	Weight % of Component	Fuel Heat Value [HHV] (Btu/scf) ¹	Fuel Heat Value [LHV] (Btu/scf) ¹
Methane	CH4	16.04	15.477	92.97	974.27	877.20
Ethane	C2H6	30.07	0.636	3.82	37.41	34.22
Propane	C3H8	44.1	0.082	0.49	4.68	4.31
iso-Butane	iC4H10	58.12	0.011	0.07	0.62	0.57
n-Butane	nC4H10	58.12	0.013	0.08	0.75	0.69
Iso-Pentane	iC5H12	72.15	0.006	0.03	0.32	0.30
n-Pentane	nC5H12	72.15	0.004	0.02	0.20	0.19
Hexanes	C6H14	86.18	0.022	0.13	1.19	1.10
Heptanes	C7H16	100.21	0.000	0.00	0.00	0.00
Octanes	C8H18	114.23	0.000	0.00	0.00	0.00
Carbon Dioxide	CO2	44.01	0.224	1.35	0.00	0.00
Nitrogen	N2	28.01	0.173	1.04	0.00	0.00
Hydrogen Sulfide	H2S	34.08	0.000	0.00	0.00	0.00
Oxygen	O2	32	0.000	0.00	0.00	0.00
Helium	He	4	0.000	0.00	0.00	0.00
Hydrogen	H2	2	0.000	0.00	0.00	0.00
Totals (dry)		100.000	16.648	100.00	1019.44	918.57
Totals (wet)					1001.66	902.55

¹ Standardized to 60°F and 1 atm to match fuel flow data

If total is not 100.000 then the mol% data was either entered incorrectly or the gas analysis is incomplete. Sometimes small differences are due to rounding error.

High Heat Value of dry gas (HHV-dry)
 This is the primary fuel heat value used in emission testing calculations.

Low Heat Value of dry gas. LHV-dry

High Heat Value of wet Gas. HHV-wet

Low Heat Value of wet gas. LHV-wet

Molecular Weight of gas =	16.648	lb/lb-mole
Btu per lb. of gas =	23239.7689	gross (HHV)
Btu per lb. of gas =	20940.2961	net (LHV)
wt % VOC in fuel gas =	0.83	%
Specific Gravity =	0.5749	

Value used to convert THC readings to VOC.

Component	Weight %
carbon	73.71
oxygen	0.98
hydrogen	24.27
nitrogen	1.04
helium	0.00
sulfur	0.00
Total	100.00

F-Factor (scf dry exhaust per MMBtu [HHV] = 8641.17
 (Based on EPA RM-19) at 68°F and 1 atm

Fuel Specific F-Factor. Note that EPA Method 19 lists natural gas's F-factor as 8710.

F-Factor Calculation:

$$F-Factor = 1,000,000 * ((3.64 * \%H) + (1.53 * \%C) + (0.57 * \%S) + (0.14 * \%N) - (0.46 * \%O)) / GCV$$

%H, %C, %S, %N, & %O are percent weight values calculated from fuel analysis and have units of (scf/lb)/%

GCV = Gross Btu per lb. of gas (HHV)

EXAMPLE TESTING DATASHEET FOR GASES
XYZ Power Plant
GE GTG Frame 7FA Combustion Turbine
Fuel: Natural Gas

Fuel Data

Fuel F-Factor	8,671.5	SCF/MMBtu
Generator Output	172.0	MW
Fuel Flow	515,040.8	SCFH
Fuel Heating Value (HHV)	1,076.5	Btu/SCF
Combustor Inlet Pressure	6,166.5	mm Hg
Heat Input (LHV)	500.6	MMBtu/hr
Stack Moisture Content	8.4	%
Stack Exhaust Flow	13,600,266.4	SCFH

Weather Data

Barometric Pressure	29.11	in. Hg
Relative Humidity	82	%
Dry Bulb Temperature	72	F
Specific Humidity	0.0142443	lb H ₂ O/lb air
Wet Bulb Temperature	68	F

yellow - supporting information
gray - raw testing data
green - final results

Run #1 - 100% High Load

Date/Time (mm/dd/yy hh:mm:ss)	Elapsed Time (seconds)	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmvw)	SO ₂ (ppmvd)	CO ₂ (%)
06/27/01 11:47:32	16770	13.57	5.05	-0.38	0.59	0.59	5.09
06/27/01 11:48:02	16800	13.57	5.85	-0.26	0.63	0.63	4.83
06/27/01 11:48:32	16830	13.55	6.37	-0.44	0.71	0.71	4.71
06/27/01 11:49:02	16860	13.54	6.83	0.60	0.83	0.83	4.33
06/27/01 11:49:32	16890	13.55	7.26	0.25	0.99	0.99	4.49
06/27/01 11:50:02	16920	13.55	6.44	-0.24	1.14	1.14	4.64
06/27/01 11:50:32	16950	13.54	6.28	-0.75	1.29	1.29	4.79
06/27/01 11:51:02	16980	13.55	5.68	-0.68	1.46	1.46	4.96
06/27/01 11:51:32	17010	13.58	6.01	-1.14	1.60	1.60	5.10
06/27/01 11:52:02	17040	13.49	5.05	1.36	1.69	1.69	5.19
06/27/01 11:52:32	17070	13.60	5.14	-0.47	1.70	1.70	5.20
06/27/01 11:53:02	17100	13.61	4.58	0.69	1.69	1.69	5.19
06/27/01 11:53:32	17130	13.62	4.93	0.90	1.65	1.65	5.15
06/27/01 11:54:02	17160	13.62	4.69	0.54	1.64	1.64	5.14
06/27/01 11:54:32	17190	13.61	4.83	0.64	1.59	1.59	5.09
06/27/01 11:55:02	17220	13.61	4.76	-0.07	1.60	1.60	5.10
06/27/01 11:55:32	17250	13.64	4.86	-0.02	1.59	1.59	5.09
06/27/01 11:56:02	17280	13.63	4.38	0.92	1.51	1.51	5.01
06/27/01 11:56:32	17310	13.61	4.94	-0.01	1.47	1.47	4.97
06/27/01 11:57:02	17340	13.61	4.89	0.27	1.47	1.47	4.97
06/27/01 11:57:32	17370	13.61	4.82	1.28	1.46	1.46	4.96
06/27/01 11:58:02	17400	13.61	4.69	1.55	1.46	1.46	4.96
06/27/01 11:58:32	17430	13.60	4.23	1.16	1.46	1.46	4.96
06/27/01 11:59:02	17460	13.59	4.69	-0.26	1.46	1.46	4.96
06/27/01 11:59:32	17490	13.57	4.89	-1.46	1.49	1.49	4.99
06/27/01 12:00:02	17520	13.58	4.86	-1.49	1.53	1.53	5.03
06/27/01 12:00:32	17550	13.59	4.79	-0.79	1.53	1.53	5.03
06/27/01 12:01:02	17580	13.58	4.76	-1.57	1.54	1.54	5.04
06/27/01 12:01:32	17610	13.57	4.65	1.17	1.53	1.53	5.03
06/27/01 12:02:02	17640	14.24	4.69	0.01	1.52	1.52	5.02
06/27/01 12:02:32	17670	13.54	4.83	1.68	1.52	1.52	5.02
06/27/01 12:03:02	17700	13.55	5.70	1.31	1.53	1.53	5.03
06/27/01 12:03:32	17730	13.55	5.66	-0.73	1.53	1.53	5.03
06/27/01 12:03:32	17760	13.55	5.04	-0.48	1.53	1.53	5.03
RAW AVERAGE		13.6	5.2	0.1	1.4	1.4	5.0

QA/QC Data Control

		O ₂ (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmvw)	SO ₂ (ppmvd)	CO ₂ (%)
Bias & Drift Checks	Initial Zero	0.2	0.3	-0.2	0.0	0.1	0.1
	Final Zero	0.2	0.5	-0.2	0.2	0.2	0.1
	Avg. Zero	0.2	0.4	-0.2	0.1	0.2	0.1
Upscale Cal Gas	Initial UpScale	12.1	5.8	4.0	3.4	28.3	9.0
	Final UpScale	12.1	5.7	4.0	3.3	28.2	8.8
	Avg. UpScale	12.1	5.8	4.0	3.4	28.3	8.9
Upscale Cal Gas		12.0	5.7	4.0	3.5	28.0	9.0

Emissions Data

	O ₂ (%)	NOx (ppmvd)	CO (ppmvd)	VOC (ppmvd)*	SO ₂ (ppmvd)	CO ₂ (%)
Corrected Raw Averages	13.5	5.1	0.3	1.5	1.3	5.0
ppm @ 15% O ₂	N/A	4.2	0.2	1.2	1.0	N/A
ppm @ 15% O ₂ & ISO	N/A	4.7	0.2	1.4	1.1	N/A
Emission Rate (lb/MMBtu)	N/A	0.015	0.000	0.004	0.005	N/A
Emission Rate (lb/hr)	N/A	8.46	0.27	2.40	2.84	N/A
Emission Rate (ton/year) @ 8760 hr/yr	N/A	37.07	1.20	10.49	12.43	N/A
Emission Rate (g/MW*hr)	N/A	0.06	0.00	0.02	0.02	N/A

*VOC data in Emissions Data Table has been converted to dry values by the equation below.

*VOC uncorrected raw average * (100/100-stack moisture content)

CLIENT REFERENCES

The following are current clients who represent the various companies for whom **AIR HYGIENE** has performed testing services. Please feel free to call and discuss our services with them.

Brian Kearney
Reliant Energy
(814) 533-8261



Linda Boyer
Pennsylvania Power & Light
(610) 774-4400



David Sloat
Sargent & Lundy
(312) 269-2784



Kathy Waxman
Keyspan Energy
(516) 545-2579



Rex Lee
Kiewit
(434) 589-7224



Sheila Wheeler
Burns & McDonnell
(816) 822-3250



Jose P. Lozada
Burns and Roe
(201) 986-4261



Kevin Kellie
Calpine
(918) 486-1830



Mark Chrisos
Intergen
(781) 993-3036



Gush Singh
Bechtel
(301) 228-7281



Ron Sigur
Fresh Meadow Mechanical
(516) 546-1656



Tom Price
Calpine - Oregon
(541) 667-3222



Don Fritz
Mirant
(702) 632-8630



Jordan M. Haywood
Siemens Westinghouse
(407) 736-3045



Ken Welch
Universal Energy
(281) 335-9811



Richard Winch
PowerTek (A Subsidiary of Power Technological Services)
(417) 538-9013

Charles Spell
Arizona Public Service Co.
(602) 250-1383



Glenn Atkinson
Zachry Construction
(770) 251-7915



Roosevelt Huggins
Black & Veatch
(913) 458-7864



Steve Brooks
Aquila
(816) 387-6266



Tim Travers
Florida Power & Light
(610) 859-9591



Tracy Patterson
Cogentrix
(804) 541-4246



Rod Klauer
Peerless Manufacturing
(972) 559-6308



Terrie Blackburn
Williams Power
(918) 573-9766



PK Chelian
Foster Wheeler
(908) 713-2159



Mary Kate Grossman
AES
(817) 579-8201



Sam Faghii
SNC-Lavalin
(425) 896-3916



Tim Mordhorst
Black Hills
(605) 721-2181



Mark Finnlay
Alstrom
mark.finnlay@power.alstom.com



David Stackhouse
KM Power (Kinder Morgan)
(303) 914-7517



Darin Watson
TransAlta
(360) 807-3002



Mike Geers
Cinergy
(513) 287-3839



Monty Wiggins
Modern Continental
(864) 243-0519



Satoru (Scott) Shishido
Hitachi
(914) 524-6614



Karst Postma
TIC
(970) 879-2561



Chris Jacobsen
Tenaska Power Partners
(402) 691-9500



Robert Van Engelenhoven
PacifiCorp
(801) 220-4402



John Davis
LG Constructors
(702) 644-5896



J. Neely Ashe
Duke Energy
(713) 989-8325



Jammie Bowen
Utility Engineering
(806) 359-2497



Joe Elliot
Nooter Erickson
(636) 651-1198



Richard Hooper
Stone & Webster
(303) 741-7409



Marilyn Teague
Semptra Energy
(949) 387-5712



William Stark
RW Beck
(303) 299-5200



Robert Farmer
URS Corporation
(602) 371-1100



Lewis Schuessler
BE&K Engineering
(205) 972-6522



Charles Gibbs
PIC World
(678) 627-4467



Mike Brown
AEP
(724) 449-9700



APPENDIX H

MPCA APPROVALS AND REQUESTED FORMS

Thomas Graham

From: Gorg, Steven [Steven.Gorg@state.mn.us]
Sent: Tuesday, May 29, 2007 3:02 PM
To: chuck.wagoner@fibrowattusa.com
Cc: Terry Walmsley; victor.myers@slthermal.com; robert.dolesky@snclavalin.com; Magee-Hill, Heather; Kilgriff, Sarah; Stock, Curtis; Place, Andrew; tom@airhygiene.com
Subject: Fibrominn, LLC (SV 001): Test Plan Approval Letter (May 29, 2007)
Attachments: Fibrominn (SV 001).pdf; Performance Test Report Completeness Criteria (PTRCC).pdf

Hello Chuck. Attached is the approval letter and referenced form (Performance Test Report Completeness Criteria (PTRCC).pdf) for your recently submitted test plans.

Thanks - Steve

Steven J. Gorg, M.S., P.E.
Environmental Engineer
Industrial Division
Minnesota Pollution Control Agency (MPCA)
520 Lafayette Road, St. Paul, MN 55155-4194
Phone: 651-296-8766
Fax: 651-296-8717
Email: steven.gorg@pca.state.mn.us
MPCA web site: <http://www.pca.state.mn.us>



Minnesota
Pollution
Control
Agency

Performance Test Plan Approval

Minnesota Pollution Control Agency
520 Lafayette Rd. N. Saint Paul, MN 55155-4194 (651) 296-6300
www.pca.state.mn.us

AQ#4065

Facility Name: Fibrominn, LLC
Facility Contact: Chuck Wagoner
Address: 900 Industry Drive
Phone: 320-843-9013
Test Locations: SV 001 (EU 001, MR 001-007; CE 001, 003 and 004)
Scheduled For: June 04 through June 11, 2007, at your facility located in Benson, Minnesota.

Your test plan received on May 07, 2007, and discussed on May 29, 2007, is approved by the Minnesota Pollution Control Agency (MPCA) as follows:

- Shortened test notification approved
- Test plan approved without modification
- Test plan approved with the following provisions:

The performance tests are being performed to measure emissions for determining the compliance status with permitted emission limits/requirements (see the relevant permit requirements for limits/requirements/parameters). Emission units and control equipment associated with the results of the performance test must be operated at maximum capacity/worse case conditions to avoid the establishment of new operational limits. The control equipment operational parameters may change based on the averages recorded during testing.

Include in the final test report(s) the full reference method data record (strip chart and/or datalogger output) used to calculate emissions. The data record should include calibration values for any instrumental analyzer used for emissions compliance testing.

Include in the final test report(s) all process and pollution control equipment operating data collected at 15 minute intervals and averaged for each test period. This information should be easily understood by individuals not familiar with the process.

Include in the final test report and CD-ROM copy; a signed certifications form, the test plan, this test plan approval letter (TPAL) and the email to which the TPAL was attached. The CD-ROM test report copy must be labeled with the AQ File Number, Company Name, Emission Unit Tested and Test Dates as stated on the submittal form. Only one paper copy and one CD-ROM/Microfiche copy of the test report are to be submitted.

Include in the final test report a simplified drawing of the test locations including pollution control equipment, stack orientation and test port locations.

Include the process rates and control equipment rates on the Operating Data Summary Form.

Obtain the required submittal and operating data forms from the website noted below¹.

Required Forms:

- Operating Data Summary- Combustion
- Operating Data Summary- Waste

Sources¹

- Operating Data Summary- Process Sources¹
 Certifications Form¹
 Performance Test Report Completeness Criteria (PTRCC) (attached)

Combustors¹

- Operating Data Summary- Asphalt Plants¹
 Microfiche/CD-ROM Submittal Form¹

¹ – Available at: www.pca.state.mn.us/air/performance/test.html

Approved by:

Date: May 29, 2007



Steven J. Gorg, M.S., P.E.
Environmental Engineer
Industrial Division
Compliance and Enforcement Section

Please contact me at (651) 296-8766 if you have any questions regarding this approval.

Please be aware that enforcement action will be taken for performance test failures indicating emissions above applicable limits (excess actual emissions to the environment). Failures commonly result in assessment of a monetary penalty. Upon the first test failure, the Company should take immediate measures to minimize emissions. The measures taken should be documented, as they will become part of the record of corrective actions.

Hard Copy Performance Test Reports and Microfiche or CD Copy submittals will be addressed to: Compliance Tracking Coordinator, Compliance and Enforcement Unit, Industrial Division, Minnesota Pollution Control Agency, 520 Lafayette Road North, St. Paul, Minnesota 55155-4194

cc: Terry Walmsley, Fibrowatt (email)
Victor Myers, Fibrominn (email)
Robert Dolesky, SNC Lavalin (email)
Thomas Graham, P.E., Air Hygiene International (email)
Heather Magee-Hill, MPCA St. Paul (email)
Sarah Kilgriff, MPCA St. Paul (email)
Curt Stock, MPCA St. Paul (email)
Andy Place, MPCA St. Paul (email)
AQ Correspondence File No. 4065



Facility Information (please print)

Company name: Fibrominn, LLC Furnace(s) No: 1
 Test date(s): July 2-4, 2007

A. Fuel Input and Operating Capacities: Itemize fuels and materials added to the combustion process during the test period. Attach ultimate/proximate analysis of the fuel, if applicable. **List appropriate units.**

Run No.	Fuel type & origin (e.g. Bituminous/Eastern)	Fuel input (list units)	Heat content (list units)	Steam (10 ³ lbs/hr)	Gross MW/hr	Heat input (10 ⁶ Btu/hr)
1	Biomass (turkey litter)	83.9 ton/hr	4,334 Btu/lb	487	61	784.4
2	Biomass (turkey litter)	83.3 ton/hr	4,334 Btu/lb	487	62	774.1
3	Biomass (turkey litter)	88.5 ton/hr	4,334 Btu/lb	490	63	777.9
Avg.	Biomass (turkey litter)	85.22 ton/hr	4,334 Btu/lb	488	62	778.8

B. Operating Data for Furnace and Air Pollution Control Equipment

1. Were the furnace(s) and control equipment operated consistent with normal procedures? Yes No If no, explain

2. Date(s) and procedure(s) of last maintenance/cleaning within 6 months:
 Remains unchanged from information provided in test plan

3. Include a copy of chart/data log records during test for the combustion efficiency indices: carbon monoxide (CO), oxygen (O₂), carbon dioxide, (CO₂), combustibles, steam flow, air flow, etc. (Label as appropriate.)

4. Soot blowing and ash pulling information: No soot blowing or ash pulling conducted, go to Item 5.

What is the normal soot blowing frequency for unit(s)? Continuous, no further information required for this column.

a) minutes/shift: 240

b) shifts/day: 2

What were the soot blowing times during the test?

Start: periodic

End: _____

Start: _____

End: _____

Last time before testing when soot blown? (date and time) _____

What is the normal ash pulling frequency for unit(s)? Continuous, no further information required for this column.

a) minutes/shift: _____

b) shifts/day: _____

What were the soot blowing times during the test?

Start: _____

End: _____

Start: _____

End: _____

Last time before testing when soot blown? (date and time) _____

5. Summarize control equipment operating data documented during testing. Values reported should reflect maximum, minimum, averages, or as approved in the test plan. (See test plan and approval letter)

Examples of APC equipment and parameters generally monitored. Monitor as in the test plan and/or approval letter.

- Scrubber (list type of scrubber): ΔP (in. w.c.) and feed rate (gpm and psig)
- Baghouse, Cyclone, and Multi-clone: ΔP (in. w.c.)
- Catalytic Incinerator :($^{\circ}F_{inlet}$, $^{\circ}F_{outlet}$) and Thermal Incinerator: ($^{\circ}F_{operating}$)
- ESP: Number and identity of operating field(s)

APC equipment and parameter monitored	Run 1	Run 2	Run 3	Average
SDA Slurry Flow (GPM)	27.1	22.3	30.9	26.8
SDA Quench Flow (GPM)	14.4	14.5	8.6	12.5
SH Steam Temp ($^{\circ}F$)	968	971	969	969.2
SH Steam Pres. (psi)	1,500	1,504	1,499	1,501
List pollutant & averaging basis—should reflect permit	Run 1	Run 2	Run 3	Average
Continuous Opacity Monitor(list hourly average): (%)	2.69	2.94	0.83	2.15
NOx Monitor (list averaging basis): lb/MMBtu	0.141	0.118	0.160	0.140
SO2 Monitor (list averaging basis): % reduction	80.88	81.23	80.47	80.86

Abbreviations:

- APC = air pollution control*
- Btu = British thermal units*
- gpm = gallons per minute*
- in. w.c. = inches of water column*
- lbs. = pounds*
- MW = megawatts*
- Psig = pressure per square inch gauge*
- ΔP = pressure drop*

NOTE: This form provides only a summary of the operating conditions during the performance test. Additional and more detailed records are required to meet the requirements of Minn. R. 7017.2035. This form is to be submitted as part of the performance test report.

Hard Copy Performance Test Reports and Microfiche or CD Copy submittals will be addressed to:

Air Quality Compliance Tracking Coordinator
 Minnesota Pollution Control Agency
 520 Lafayette Road North
 St. Paul, Minnesota 55155-4194



Air Performance Test Form

Performance Test Report Completeness Criteria

The owner or operator of an emissions facility is responsible for submitting a complete test report as defined by Minn. R. 7017.2035. A test report may be rejected if it is deemed incomplete. As a result, this form is designed to ensure that your submittal is complete.

- 1) Facility name: Fibrominn Biomass Power Plant
- 2) Air quality facility ID number (first 8 digits of permit number): 15100038
- 3) Air quality file number: _____
- 4) Facility location address: 900 Industry Drive
 City: Benson State: MN Zip code: 56215
- 5) Date of performance test: July 2-4, 2007
- 6) Facility contact person (Individual who is designated to receive agency correspondence related to this test):
 Mr./Ms: _____
 Title: _____
 Mailing address: _____
 City: _____ State: _____ Zip code: _____
 e-mail address: _____

7) Test report checklist:

Cover:

<input checked="" type="checkbox"/>	Name and location (address) of the emission facility	<input checked="" type="checkbox"/>	Date(s) of the performance test
<input checked="" type="checkbox"/>	Identification of emission unit(s) tested (i.e. GP002, EU031, SV028, or CE001 – Identification of the tested unit which has the emission limit as designated by your permit [source designators])	<input checked="" type="checkbox"/>	Name and address of the testing company or agency
<input checked="" type="checkbox"/>	AQ Facility ID Number (first 8 digits of permit number) and AQ File Number	<input checked="" type="checkbox"/>	Facility contact person (individual designated to receive agency correspondence), and contact information including title, address, phone number, fax number, and email address

Certification:

<input checked="" type="checkbox"/>	Signed and dated certification statements as defined by Minn R. 7017.2040 (An exact duplicate must be included in the CD-ROM copy of the test report)
-------------------------------------	---

Introduction:

<input checked="" type="checkbox"/>	Reason for testing (i.e. Permit condition, notice of violation, etc., including permit number or name of other applicable compliance document, include correct Rule citation as outlined in permit)	<input checked="" type="checkbox"/>	Pollutants tested (for each emission unit tested)
<input checked="" type="checkbox"/>	Test location and type of process including source designators as outlined in permit	<input checked="" type="checkbox"/>	Observers names including industry and agency observers
<input checked="" type="checkbox"/>	Test date(s)	<input checked="" type="checkbox"/>	Changes from test plan, problems experienced during test and any other relevant background information

Summary of Results: (see attached Table 1: Summary of Performance Test Results)

<input checked="" type="checkbox"/>	Emission results expressed in the same units as the emission limits	<input checked="" type="checkbox"/>	Description of collected samples
<input checked="" type="checkbox"/>	Process data as related to determination of compliance (must include process rates, process parameters and pollution control equipment parameters that will be used to determine worst case operating conditions and pollution control equipment limitations during the test [see the relevant operator data forms at http://www.pca.state.mn.us/air/performancetest.html])	<input checked="" type="checkbox"/>	Visible emissions summary if applicable
<input checked="" type="checkbox"/>	Emission limits (as stated in your permit or applicable regulations) and applicable regulations citations as stated in your permit	<input checked="" type="checkbox"/>	Discussion of errors, both real and apparent (If no errors occurred, verify by including statement)

Operating Parameters: (see the relevant operator data forms at <http://www.pca.state.mn.us/air/performancetest.html>)

*Note: Readings of discrete data from monitoring instruments must be recorded at least every 15 minutes, or other reasonable time interval as approved, during the test and strip charts or retrieved electronic data from continuous monitors must be included in the test report.

<input checked="" type="checkbox"/>	Description of process and air pollution control devices including emission unit(s) tested (i.e. GP002, EU031, SV028, or CE001 – Identification of the tested unit which has the emission limit as designated by your permit [source designators])	<input checked="" type="checkbox"/>	Process data and results, with example calculations (Process data must be collected and averaged for each test run and averaged for each series of tests for each unit tested. Process data must be displayed in the same units that were used to determine worst case operating conditions during the test. Process data must be easily understood by personnel not familiar with the process.)
<input checked="" type="checkbox"/>	Process and control equipment flow diagrams	<input checked="" type="checkbox"/>	Any specially required operation demonstrations

Maintenance:

<input checked="" type="checkbox"/>	Description including dates of all maintenance and operational inspections, including major cleaning operations and replacement, repair, or modification of functional components of process or control equipment done in the month prior to the test (Include a statement if no maintenance was performed)
-------------------------------------	---

Sampling and Analysis Procedures:

<input checked="" type="checkbox"/>	Sampling port location and dimensioned cross section showing all flow disturbances including fans, elbows, dampers, constrictions and pollution control equipment. Measurements should be included on diagram(s).	<input checked="" type="checkbox"/>	Brief description of sampling procedures and analytical methods, with discussion of deviations from standard methods (include a statement if no deviations were made), including a statement of source methods used, but not including complete copies of reference methods
<input checked="" type="checkbox"/>	Description of sampling point (including duct orientation, number of test ports, number of sampling points, distances to upstream and downstream flow disturbances)	<input checked="" type="checkbox"/>	If a method other than a US EPA reference method was used: a statement of the detection limit and the level of accuracy of the method under the conditions of the test and at the concentration of air pollutant that is reported.
<input checked="" type="checkbox"/>	Description of sampling train	<input type="checkbox"/>	

Appendix:

<input checked="" type="checkbox"/>	Complete results, including any fuel analysis, with example calculations, showing equations used and actual results in equation form on same or adjacent pages, using applicable equations shown in the reference method	<input checked="" type="checkbox"/>	Test log (include test times, test interruptions and causes, and any other significant events related to the testing)
-------------------------------------	--	-------------------------------------	---

<input checked="" type="checkbox"/>	Copies of raw field data	<input checked="" type="checkbox"/>	Calibration procedures and results including pitot tube, nozzle, meter box, thermometer, barometer calibrations and any other equipment used to collect emissions samples. Instrument calibrations must be performed in accordance to the reference method used and calibration values must be displayed on the same data recorder from which emissions results are calculated.
<input checked="" type="checkbox"/>	Laboratory report with chain of custody record	<input checked="" type="checkbox"/>	Project participants and titles
<input checked="" type="checkbox"/>	Raw production data, signed by plant official who can interpret, and be held accountable for the data	<input checked="" type="checkbox"/>	A copy of the most recent version of the test plan and a copy of the commissioner's written approval of the test plan

Additional Information:

<input checked="" type="checkbox"/>	Any other special requirement of the test method, test plan, applicable requirement or compliance document	<input checked="" type="checkbox"/>	Any other information necessary to evaluate compliance with Minn R. 7017.2020 and 7017.2025 as requested by the commissioner.
-------------------------------------	--	-------------------------------------	---

REFERENCED TABLE

Table 1: Summary of Performance Test Results

1(a) Emission Unit Tested	1(b) Limitation Basis	1(c) Pollutant and Emission Limit	1(d) Test Result
EXAMPLE Boiler No. 3 (EU 042/ SV 440)	Minn. Stat. 116.07, subd. 4a	Particulate (B): 12 lbs/hour	Particulate (B): 4.1 lbs/hour
		VOC: 13 lbs/hour as carbon	VOC: 2.3 lbs/hour as carbon
	Title I Condition: 40 CFR § 52.21(j) (BACT limit); Minn. R. 7007.3000	Carbon Monoxide: 0.090 lbs/MMBtu	Carbon Monoxide: 0.00078 lbs/MMBtu
		Volatile Organic Compounds: 0.0090 lbs/MMBtu	Volatile Organic Compounds: 0.00050 lbs/MMBtu
	Title I Condition: 40 CFR § 52.21(k) (modeling); Minn. R. 7007.3000	Carbon Monoxide: 33.6 lbs/hour	Carbon Monoxide: 0.26 lbs/hour

Table References:

- (A) Filterable particulate matter as determined by U.S. Environmental Protection Agency (EPA) Method 5.
- (B) Filterable plus organic condensable particulate matter as determined by EPA Method 5 and Method 202/ Minn. R. 7011.0725.
- (C) Particles with an aerodynamic diameter less than or equal to a nominal ten micrometers (PM₁₀) as determined by EPA Methods 5 and 202.

Instructions for Completing this Form:

- 1) Facility Name -- Enter your facility name.
- 2) AQ Facility ID No. -- Fill in your Air Quality Facility ID Number. This is the first eight digits of the permit number for all new permits issued under the new operating permit program. In the future, this number will replace the AQ File Number in item 3) below.
- 3) AQ File No. -- Fill in your AQ File Number. This is the first group of characters in your current Air Emission Facility Permit. For example, for permit number 1899AB-93-OT-1, the AQ Facility ID number would be 1899AB. Can be found in the upper right hand corner of the Test Plan Approval.
- 4) Facility Location -- Fill in the facility's street address and the city and county where the facility is located.
- 5) Date of Performance Test -- Enter the date of your performance test.
- 6) Facility Contact Person -- Fill in the contact information for the person that the MPCA may contact regarding this performance test.
- 7) Test Report Check List: This checklist is to ensure that your test submittal includes all of the required information.

Reference Table:

- 1) Summary of Performance Test Results:
 - 1a) Emission Unit Tested: As designated by permit (i.e. EU, SV, etc.)
 - 1b) Limitation Basis: All applicable rule citations from permit that apply to tested unit(s).
 - 1c) Pollutant and Emission Limit: Pollutant to be tested and emission limit as outlined in permit
 - 1d) Test Result: State test result.